



- NOTES:**
- PIPELINE TO BE INSTALLED WITH MINIMUM OF 48" COVER IN CROPLANDS, 60" IN STREAMS & 36" COVER IN ALL OTHER LOCATIONS. IF BEDROCK IS ENCOUNTERED, THE MINIMUM COVER WILL BE 24".
 - FOREIGN PIPE CROSSING - INSTALL PIPELINE BELOW 12" COLUMBIA GAS PIPELINE AND 26" AND 30" DOMINION GAS PIPELINES WITH MINIMUM CLEARANCE OF 24".
 - STREAM F: PIPELINE CROSSING - DRY METHOD, SEE SHEET 13, 14 AND EM&CS&P.
 - REFER TO DWG 6172-2101 SHEET 1 FOR SURVEY NOTES.
 - CHECK DAMS, TEMPORARY ACCESS ROADS, STREAM CROSSING, WETLAND CROSSING AND GENERAL EROSION AND SEDIMENT CONTROL DETAILS ARE SHOWN ON SHEETS 13, 14 AND IN THE EM&CS&P.



No.	App'd	By	Date
PA	JH	RM	09/09/11
PB		RM	JULY 20/11
PC		RM	AUG 17/11
PD		RM	AUG 31/11
PE		RM	09/02/11
PF		RM	09/05/11
PG		RM	09/15/11

Submittal / Revision	Date
ISSUED FOR REVIEW	09/09/11
ISSUED FOR REVIEW	JULY 20/11
ISSUED FOR REVIEW	AUG 17/11
ISSUED FOR REVIEW	AUG 31/11
ISSUED FOR REVIEW	09/02/11
ISSUED FOR REVIEW	09/05/11
UPDATED WETLAND/STREAM IDENTIFICATION	09/15/11

NYSEG
 GAS BUSINESS UNIT
 KIRKWOOD, N.Y.

UNAUTHORIZED ALTERATION OR ADDITION
 APPLICABLE STATE AND LOCAL LAWS

CI/A
 International Engineering & Development Corporation

DESIGNED: [] DRAWN: RM CHECKED: []

SENECA WEST PIPELINE INTERCONNECT
 CIVIL ALIGNMENT PLAN

Issue Date: 11/2011 Project No.: 22867 Scale: 1:100