

TEST REPORT FOR THE PATTERN AND CONSTRUCTION OF ELECTRICITY METERS

MANUFACTURER : *Schneider Electric*

TYPE : *PM55***

CLASS : *0.2s (kWh) & 2(kvarh)*

DESCRIPTION : *Polyphase, Active Import/Export (kWh), Reactive Import/Export (kvarh), Transformer Operated, Electricity Meter*

Tested in accordance with IEC 62052-11: 2003, Electricity metering equipment (AC) – General requirements, tests and test conditions.

Part 11: Metering equipment.

And IEC 62053-22: 2003, Electricity metering equipment (AC) – Particular requirements
Part 22: Static meters for active energy (classes 0.2s and 0.5s).

And IEC 62053-23: 2003, Electricity metering equipment (AC) – Particular requirements
Part 23: Static meters for reactive energy (classes 2 & 3).

The meters tested satisfied the required specification.

ISSUED BY:



K. Hunter
Test Engineer

CHECKED BY:



P. Fairless
Test Engineer

VERIFIED BY:



R. Jackson
Metering Manager

REPORT ISSUE DATE: 25th July 2013

"This document is issued by the Company subject to its General Conditions of Service available on request or accessible at www.sgs.com/terms_and_conditions.htm and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law." "Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 28 days only."

Tests marked * are not covered under our UKAS scope.



CONTENTS

INTRODUCTION

INFORMATION OF THE ELECTRICITY METER TESTED

SUPPORTING DOCUMENTATION

SUMMARY OF TEST RESULTS

1	INSULATION
1.1	Impulse Voltage Test
1.2	AC Voltage Test
2	ACCURACY REQUIREMENTS
2.1	Meter Constant
2.2	Starting Conditions
2.3	Running with no load
2.4	Influence of ambient temperature
2.5	Influence Quantities -
2.5.1	Current Variation
2.5.2	Voltage Variation
2.5.3	Frequency Variation
2.5.4	Reverse Phase Sequence
2.5.5	Voltage Unbalance
2.5.6	Continuous Magnetic Induction
2.5.7	Magnetic Induction of 0.5mT
2.5.8	Auxiliary Power Supply Voltage Variation
2.6	Accuracy test in the Presence of Harmonics
2.6.1	Harmonic Components in the Current and Voltage Circuits
2.6.2	Influence of Odd and Sub Harmonics in the AC Current Circuit
3	ELECTRICAL REQUIREMENTS
3.1	Power Consumption
3.2	Influence of Supply Voltage - Interruptions and Dips.
3.3	Influence of Short-Time Over-currents
3.4	Influence of Self Heating
3.5	Influence of Heating
4	ELECTROMAGNETIC COMPATIBILITY (EMC)
4.1	Immunity to Electrostatic Discharges
4.2	Immunity to Electromagnetic HF Fields
4.3	Fast Transient Burst Test
4.4	Immunity to Conducted Disturbances
4.5	Surge Immunity
4.6	Immunity to Damped Oscillatory Waves



5	CLIMATIC INFLUENCES
5.1	Dry Heat Test
5.2	Cold Test
5.3	Damp Heat Cyclic Test
6	MECHANICAL REQUIREMENTS
6.1	Spring Hammer
6.2	Shock
6.3	Vibration
6.4	Resistance to Heat & Fire
ANNEX A	Radiated Immunity Test – Graphical plots of results
ANNEX B	Conducted Immunity Test – Graphical plots of results
ANNEX C	Photographs of Meter Under Test



INTRODUCTION

The type tests described were carried out in the SGS (Durham) measurement laboratory on behalf of:

CLIENT DETAILS: Schneider Electric
44P Electronic City East Phase
Hosur Road
Bangalore
560100
India

ORDER No's: 133576, 133577, 132957

APPLICATION RECEIVED DATE: 19th April 2013

DATE OF RECEIPT OF SAMPLES: 12th April 2013

DATE OF TESTS: 23rd April 2013 to 27th June 2013

In the cases where no or only limited tests have been conducted on the submitted samples, tests carried out during previous OFGEM approval (or by other accredited bodies) on meters of similar construction and designs have been taken to confirm that the meter satisfies the requirements of the relevant standard. See supporting documentation for reference.

Conditions under which the type tests took place:

Unless otherwise stated, the meters were examined at an ambient temperature of $23^{\circ}\text{C} \pm 2^{\circ}\text{C}$, and after the voltage circuits had been connected to reference voltage for at least 1 hour.

Unless otherwise stated, Polyphase tests were tested with a standard phase sequence of L1-L2-L3 (corresponding to the Red, Yellow & Blue phases).

The tests were conducted using equipment, traceable to National and International Standards.



INFORMATION ON THE ELECTRICITY METERS TESTED

Manufacturer	:	<i>Schneider Electric</i>
Type	:	<i>PM5500</i>
Class	:	<i>0.2s (kWh) & 2(kvarh)</i>
Type of circuit	:	<i>3 phase 4 wire</i>
No. of Elements	:	<i>3</i>
Basic Current (In)	:	<i>5A</i>
Maximum Current (Im)	:	<i>10A</i>
Reference Supply Voltage	:	<i>3x230/400V</i>
Auxiliary Voltage	:	<i>100-480V</i>
Rated Frequency	:	<i>50Hz</i>
Pulse output constant	:	<i>10000 imp/kWh & kvarh</i>
Manufacturers Serial No's	:	<i>2271226, 2271222, 2271235, JB1310419000037</i>



GENERAL REQUIREMENTS

Sealing Arrangements

IEC 62052-11 X-Ref. 5.2.1

The meter shall have a case which can be sealed in such a way that the internal parts of the meter are accessible only after breaking the seal(s)

The cover shall not be removable without the use of a tool.

Non permanent deformation may not influence the meter.

Complied

Display of Measured Values

IEC 62052-11 X-Ref. 5.10

The principal unit is (kWh)

The active tariff shall be indicated.

The identification of each tariff applied shall be possible.

The register shall be able to record and display, starting from zero, for a minimum of 1500 h, the energy corresponding to maximum current at reference voltage and unity power factor.

Complied

Non-volatile memory shall have a minimum retention time of four months.

In the case of multiple values presented by a single display, it shall be possible to display the content of all relevant memories. Automatic sequencing displays shall display each value for at least 5 s.

Every numerical element of an electronic display shall be able to show all numbers from "zero" to "nine":

Complied

Inspection of Markings

IEC 62052-11 X-Ref. 5.12

The requirements are met for the marking of the meter samples with respect to both name-plates and connection diagrams.

Complied



SUPPORTING DOCUMENTATION

Accredited Laboratory tests reports:

Radio Interference Suppression
Labtest Certification Inc

X-Ref. 7.5.8
Report No.: 11162-1E

Issued: 2nd January 2013



SUMMARY OF TEST RESULTS

IEC 62052-11: 2003 General Requirements:

EN 62052-11 Clause	Test	Performed	Result
5.2.2.1	Spring hammer	Yes	Complied
5.2.2.2	Shock	Yes	Complied
5.2.2.3	Vibration	Yes	Complied
5.8	Resistance to heat and fire	Yes	Complied
5.9	Penetration of dust and water	No	-
6.3.1	Dry heat	Yes	Complied
6.3.2	Cold	Yes	Complied
6.3.3	Damp heat cyclic	Yes	Complied
6.3.4	Solar radiation	No	-
7.1.2	Voltage dips and short interruptions	Yes	Complied
7.2	Influence of heating	Yes	Complied
7.3.2	Impulse voltage	Yes	Complied
7.5.2	Electrostatic discharge immunity	Yes	Complied
7.5.3	Radiated immunity	Yes	Complied
7.5.4	Fast transient bursts immunity	Yes	Complied
7.5.5	Conducted immunity	Yes	Complied
7.5.6	Surge immunity	Yes	Complied
7.5.7	Damped oscillatory waves immunity	Yes	Complied
7.5.8	Radio interference suppression	No*	-

IEC 62053-22: 2003 Particular Requirements:

EN 62053-22 Clause	Test	Performed	Result
7.1	Power consumption	Yes	Complied
7.2	Influence of short-time over-currents	Yes	Complied
7.3	Influence of self-heating	Yes	Complied
7.3.3	AC voltage	Yes	Complied
8.1	Current variation	Yes	Complied
8.2	Variation of error due to voltage variation	Yes	Complied
8.2	Variation of error due to frequency variation	Yes	Complied
8.2	Reverse Phase Sequence	Yes	Complied
8.2	Voltage Unbalance	Yes	Complied
8.2	Operation of accessories	No	-
8.2	Auxiliary voltage variation	Yes	Complied
8.2	Variation of error due to temperature variation	Yes	Complied
8.2	Variation of error due to harmonics	Yes	Complied
8.2	Sub-harmonics in the AC circuit	Yes	Complied
8.2	Continuous magnetic induction of external origin	Yes	Complied
8.2	Magnetic induction of external origin (0.5mT)	Yes	Complied
8.3	Starting and no-load condition	Yes	Complied
8.4	Meter constant	Yes	Complied



SUMMARY OF TEST RESULTS (cont.)

IEC 62053-23: 2003 Particular Requirements:

EN 62053-23 Clause	Test	Performed	Result
7.1	Power consumption	No	-
7.2	Influence of short-time overcurrents	No	-
7.3	Influence of self-heating	No	-
7.4	AC voltage	No	-
8.1	Current variation	Yes	Complied
8.2	Variation of error due to voltage variation	Yes	Complied
8.2	Variation of error due to frequency variation	Yes	Complied
8.2	Operation of accessories	No	-
8.2	Variation of error due to temperature variation	No	-
8.2	DC Component in the current circuit	No	-
8.2	Continuous magnetic induction of external origin	No	-
8.2	Magnetic induction of external origin (0.5mT)	No	-
8.3	Starting and no-load condition	Yes	Complied
8.4	Meter constant	Yes	Complied

No*: Tests performed at Labtest Certification Inc

Report No: 11162-1E



1 INSULATION

IEC 62052-11 X-Ref. 7

1.1 Impulse Voltage Test

X-Ref. 7.3.2

Test Results ID / Sample No.
Impulse / 2271226

Test Procedure: EN62052-11 Impulse Voltage
I9EMA TP12

Environmental Conditions

Temperature	23°C
Relative Humidity	44%
Barometric Pressure	998mB

Impulse specification: Test level 6kV @ 0.5J open circuit
 Time between impulse's 3s

The meter samples were placed on a flat conducting earth surface with the case wrapped in a conductive foil.

The test voltage was applied 10 times in each polarity between the points listed below:-

- 1) With one terminal of the voltage circuit connect to earth, the impulse voltage was applied between the common voltage/current meter terminal and earth.
- 2) With all meter terminals connected together, impulse voltage was applied between the meter terminals and earth.

During the tests auxiliary circuits with reference rated voltage $\leq 40V$ were connected to earth.

On completion of the above tests, the meter was found to function correctly and within the accuracy specification when subsequently operated under reference operating conditions, with no signs of damage or degradation in the meter's insulation properties.



1.2 AC Voltage Test

IEC 62053-22 X-Ref. 7.4

Test Results ID / Sample No.
AC / 2271226

Test Procedure: EN62052-22 AC Voltage
19EMA TP13

Environmental Conditions

Temperature	23°C
Relative Humidity	44%
Barometric Pressure	998mB

Test level 2kV & 4kV Test duration 1 minute.

The a.c. voltage tests were conducted as follows:

- 1) Between all meter voltage and current circuits connected together, and earth.
- 2) Between all circuits not intended to be connected together in service, and earth.

The earth consisting of a conductive foil wrapped around the meter and connected to a flat conducting earth surface, upon which the meter was placed.

During the tests auxiliary circuits with reference rated voltage $\leq 40V$ were connected to earth.

On completion of the above test, the meter was found to function correctly and within the accuracy specification when subsequently operated under reference operating conditions, with no signs of damage or degradation in the meter's insulation properties.

2 ACCURACY REQUIREMENTS

IEC 62053-22 X-Ref. 8

2.1 Meter Constant

X-Ref. 8.4

The relation between the test output and the meter energy registers were checked to ensure the constant marking on the meter nameplate.

Measurement mode - Active Import Energy kWh

Test Results ID / Sample No. Meter Constant / 2271222	Test Procedure: Meter Constant (1h @ Im) 19EMA TP37
--	--

Test conditions: $U_n: 3 \times 230/400V$ $I_{max}: 10A$ $\cos. \phi = 1.0, 50Hz$

Test Circuit: *3 phase 4 wire*

Measurement mode: *Active Import Energy kWh*

Number of Pulses Recorded	Pulse Constant (p/ kWh)	LED Test Output (kWh)	Energy Registered By Meter (kWh)	Percentage difference between Energy Registered and LED Test Output (%)
69067	10000	6.9067	6.9090	0.03

Limit of % Error Variation: $\pm 0.2\%$ for Class 0.2

Measurement mode - Active Export Energy kWh

Test Results ID / Sample No. Meter Constant / 2271222	Test Procedure: Meter Constant (1h @ Im) 19EMA TP37
--	--

Test conditions: $U_n: 3 \times 230/400V$ $I_{max}: 10A$ $\cos. \phi = 1.0, 50Hz$

Test Circuit: *3 phase 4 wire*

Measurement mode: *Active Export Energy kWh*

Number of Pulses Recorded	Pulse Constant (p/ kWh)	LED Test Output (kWh)	Energy Registered By Meter (kWh)	Percentage difference between Energy Registered and LED Test Output (%)
69042	10000	6.904	6.904	0.00

Limit of % Error Variation: $\pm 0.2\%$ for Class 0.2

During the registration tests, rate registers not active were found not to have been corrupted.

**Meter Constant (cont.)**

IEC 62053-23 X-Ref. 8.4

Measurement mode - Reactive Import Energy kvarh

Test Results ID / Sample No. Meter Constant / 2271226	Test Procedure: Meter Constant (1h @ Im) 19EMA TP37
--	--

Test conditions: $Un: 3 \times 230/400V$ $I_{max}: 10A$ $Cos. \phi = 1.0, 50Hz$ Test Circuit: *3 phase 4 wire*Measurement mode: *Reactive Import Energy kvarh*

Number of Pulses Recorded	Pulse Constant (p/ kWh)	LED Test Output (kWh)	Energy Registered By Meter (kWh)	Percentage difference between Energy Registered and LED Test Output (%)
69051	10000	6.905	6.905	0.00

Limit of % Error Variation: $\pm 2\%$ for Class 2Measurement mode - Reactive Export Energy kvarh

Test Results ID / Sample No. Meter Constant / 2271226	Test Procedure: Meter Constant (1h @ Im) 19EMA TP37
--	--

Test conditions: $Un: 3 \times 120/208V$ $I_{max}: 10A$ $Cos. \phi = 1.0, 50Hz$ Test Circuit: *3 phase 4 wire*Measurement mode: *Reactive Export Energy kvarh*

Number of Pulses Recorded	Pulse Constant (p/ kWh)	LED Test Output (kWh)	Energy Registered By Meter (kWh)	Percentage difference between Energy Registered and LED Test Output (%)
69023	10000	6.9023	6.906	0.05

Limit of % Error Variation: $\pm 2\%$ for Class 2

During the registration tests, rate registers not active were found not to have been corrupted.



2.2 Starting and No-Load condition

IEC 62053-22 X-Ref. 8.3

Initial Start-up of the meter

X-Ref. 8.3.1

Test Results ID / Sample No. Start Up / 2271222	Test Procedure: Start-up
--	--------------------------

The meter sample was fully functional within 5s after rated voltage U_n was applied to the meter terminals.

2.3 Running with No-Load

X-Ref. 8.3.2

Test Results ID / Sample No. No Load / 2271222,	Test Procedure: Non Registration Test 115(%U) 19EMA TP36
--	---

Tests were conducted as follows;

Test conditions: *115% U_n , current circuits open*

The minimum test duration in minutes being given by

$$\Delta t \geq \frac{900 \times 10^6}{k \cdot m \cdot U_n \cdot I_{max}} \quad [\text{min}] \text{ for meters of class 0.2s}$$

$$\Delta t \geq \frac{600 \times 10^6}{k \cdot m \cdot U_n \cdot I_{max}} \quad [\text{min}] \text{ for meters of class 0.5s}$$

where

k is the meter output constant (pulses per kWh)

m is the number of measuring elements

The meter sample was tested for a period of at least Δt minutes, on completion of which, no changes in the energy registers were recorded, and the test output did not produce more than one pulse.



Running with No-Load (cont)

X-Ref. 8.3.2

Test Results ID / Sample No.
No Load / 2271222

Test Procedure: Non Registration Test 115(%U)
19EMA TP36

Test conditions: *115% Un, current circuits open*

The minimum test duration in minutes being given by

$$\Delta t \geq \frac{480 \times 10^6}{k \cdot m \cdot U_n \cdot I_{max}} \quad [\text{min}] \text{ for meters of class 2}$$

$$\Delta t \geq \frac{300 \times 10^6}{k \cdot m \cdot U_n \cdot I_{max}} \quad [\text{min}] \text{ for meters of class 3}$$

where

k is the meter output constant (pulses per kvarh)

m is the number of measuring elements

The meter sample was tested for a period of at least Δt minutes, on completion of which, no changes in the energy registers were recorded, and the test output did not produce more than one pulse.



Starting and No-Load condition

IEC 62053-23

X-Ref. 8.3

Initial Start-up of the meter

X-Ref. 8.3.1

Test Results ID / Sample No.
Start Up / 2271226

Test Procedure: Start-up

The meter sample was fully functional within 5s after rated voltage U_n was applied to the meter terminals.

Starting

X-Ref. 8.3.3

Test Results ID / Sample No.
Starting Current / 2271222

Test Procedure: Starting Current 0.1(% I_b)
19EMA TP36

The meter commenced and continued to measure the active power in both the import and export directions.

Test conditions for Transformer Operated meters

Class 0.2s Active meters : U_{min} , 0.1% I_n , $\cos. \phi = 1.0$, 50Hz

Test Results ID / Sample No.
Starting Current / 2271226

Test Procedure: Starting Current 0.3(% I_b)
19EMA TP36

The meter commenced and continued to measure the applied reactive power in both the import and export directions.

Test conditions for Transformer Operated meters

Class 2 Reactive meters : U_{min} , 0.3% I_n , $\sin \phi = 1.0$, 50Hz

2.4 Influence of Ambient Temperature

IEC 62053-22 X-Ref. 8
X-Ref. 8.2

Test Results ID / Sample No.
Temperature Var. / 2271226

Test Procedure: EN62053-22 Temperature Variation
19EMA TP31

Test conditions: U_n : 3x230/400V U_x : 230V F_n : 50Hz
 I_n : 5A I_m : 10A

Test Circuit: 3 phase 4 wire

Measurement mode - Active Import Energy kWh

Temperature /°C	Current	PF Cos. ϕ	% Error	Mean Temperature coefficient %/K
33	0.05In	1.0	0.00	-0.0025
13	0.05In	1.0	0.05	
33	0.1In	0.5ind	0.04	0.005
13	0.1In	0.5ind	-0.06	
33	In	1.0	-0.01	-0.0025
13	In	1.0	0.04	
33	In	0.5ind	0.04	0.0045
13	In	0.5ind	-0.05	
33	Im	1.0	-0.01	-0.002
13	Im	1.0	0.05	
33	Im	0.5ind	0.04	0.003
13	Im	0.5ind	-0.02	

Limit of Mean Temperature coefficient for: Class 0.2s $\pm 0.01\%/K$ @ Cos. ϕ = 1.0
 $\pm 0.02\%/K$ @ Cos. ϕ = 0.5ind



Influence of Ambient Temperature (cont.)

Operation of meter at the limit of the specified operating temperature range (Indoor meters)

IEC 62053-22 X-Ref. 6.1

Test conditions: $U_n: 3 \times 230/400V$ $U_x: 230V$ $F_n: 50Hz$
 $I_n: 5A$ $I_m: 10A$

Temperature /°C	Current	PF Cos. ϕ	% Error
-10°C	0.1I _n	1.0	0.10
45°C	0.1I _n	1.0	-0.02
-10°C	0.2I _n	0.5ind	-0.15
45°C	0.2I _n	0.5ind	0.11
-10°C	I _n	1.0	0.09
45°C	I _n	1.0	-0.03
-10°C	I _n	0.5ind	-0.13
45°C	I _n	0.5ind	0.10
-10°C	I _m	1.0	0.10
45°C	I _m	1.0	-0.04
-10°C	I _m	0.5ind	-0.11
45°C	I _m	0.5ind	0.09

Limits of % Error: Class accuracy.

Operation of meter at the Limit of temperature range (Indoor meters)

X-Ref. 6.1

Test conditions: $U_n: 3 \times 230/400V$ $U_x: 230V$ $F_n: 50Hz$
 $I_n: 5A$ $I_m: 10A$

Temperature /°C	Current	% Error
70°C	I _n	-0.11
-25°C	I _n	0.08

On completion of the above test, the meter was found to function correctly and within the accuracy specification when subsequently operated under reference operating conditions.

2.5 Influence Quantities

IEC 62053-22 X-Ref. 8

2.5.1 Variation in Current

X-Ref. 8.1

Test Results ID / Sample No.
Current Variation / 2271222

Test Procedure: EN62053-22 Acc3P4W kWh +P
19EMA TP25

Test conditions: U_n : 3x230/400V I_n : 5A I_m : 10A F_n : 50Hz
 U_x : 230V

Test Circuit: 3 phase 4 wire

Measurement mode - Active Import Energy kWh

		Limit of % Error	
CURRENT	PF Cos. ϕ	% Error	Accuracy
			Class 0.2s Class 0.5s
0.01 I_n	1.0	0.03	± 0.4 ± 1.0
0.02 I_n	-	0.01	± 0.4 ± 1.0
0.05 I_n	-	0.02	± 0.2 ± 0.5
0.1 I_n	-	0.02	± 0.2 ± 0.5
0.2 I_n	-	0.02	± 0.2 ± 0.5
0.5 I_n	-	0.00	± 0.2 ± 0.5
I_n	-	0.00	± 0.2 ± 0.5
0.4 I_m	-	0.02	± 0.2 ± 0.5
0.6 I_m	-	0.01	± 0.2 ± 0.5
0.8 I_m	-	0.01	± 0.2 ± 0.5
I_m	-	0.01	± 0.2 ± 0.5
0.02 I_n	0.5ind	0.06	± 0.5 ± 1.0
0.05 I_n	-	0.04	± 0.5 ± 1.0
0.1 I_n	-	0.05	± 0.3 ± 0.6
0.2 I_n	-	0.03	± 0.3 ± 0.6
0.5 I_n	-	0.00	± 0.3 ± 0.6
I_n	-	0.03	± 0.3 ± 0.6
I_m	-	0.04	± 0.3 ± 0.6
0.1 I_n	0.25ind	0.11	± 0.5 ± 1.0
0.2 I_n	-	0.06	± 0.5 ± 1.0
0.5 I_n	-	0.00	± 0.5 ± 1.0
I_n	-	0.06	± 0.5 ± 1.0
0.1 I_n	0.8cap	0.00	± 0.3 ± 0.6
0.2 I_n	-	0.01	± 0.3 ± 0.6
0.5 I_n	-	0.00	± 0.3 ± 0.6
I_n	-	-0.01	± 0.3 ± 0.6
0.1 I_n	0.5cap	-0.02	± 0.5 ± 1.0
0.2 I_n	-	-0.01	± 0.5 ± 1.0
0.5 I_n	-	-0.01	± 0.5 ± 1.0
I_n	-	-0.02	± 0.5 ± 1.0



Polyphase meter carrying a single-phase load, with balanced voltage applied to the voltage's circuits.

X-Ref. 8.1

Test conditions: $U_n: 3 \times 230/400V$ $U_x: 230V$ $F_n: 50Hz$
 $I_n: 5A$ $I_m: 10A$

Test Circuit: *3 phase 4 wire*

Measurement mode - Active Import Energy kWh

Elements/Lines		I1 Element L1	I2 Element L2	I3 Element L3	Limit of % Error	
CURRENT	PF Cos. ϕ	% Error	% Error	% Error	Accuracy	
					Class 0.2s	Class 0.5s
0.05 In	1.0	0.00	0.01	0.02	± 0.3	± 0.6
0.1 In	-	0.02	0.02	0.02	± 0.3	± 0.6
0.2 In	-	0.00	0.00	0.02	± 0.3	± 0.6
0.5 In	-	0.00	0.00	0.00	± 0.3	± 0.6
In	-	0.01	0.02	0.01	± 0.3	± 0.6
Im	-	0.02	0.01	0.01	± 0.3	± 0.6
0.1 In	0.5ind	0.05	0.05	0.06	± 0.4	± 1.0
0.2 In	-	0.01	0.02	0.05	± 0.4	± 1.0
0.5 In	-	0.01	0.02	-0.03	± 0.4	± 1.0
In	-	0.01	0.04	0.01	± 0.4	± 1.0
Im	-	0.02	0.04	0.02	± 0.4	± 1.0
0.2 In	0.5cap	-0.01	-0.03	-0.01	-	-
In	-	0.00	-0.03	-0.02	-	-
Im	-	0.00	-0.02	-0.03	-	-



Variation in Current(cont.)

X-Ref. 8.1

Test Results ID / Sample No.
Current Variation / 22271226

Test Procedure: Acc 3P4W kWh -P
19EMA TP25

Test conditions: U_n : 3x230/400V U_x : 230V F_n : 50Hz
 I_n : 5A I_m : 10A

Test Circuit: 3 phase 4 wire

Measurement mode - Active Export Energy kWh

			Limit of % Error	
CURRENT	PF Cos. ϕ	% Error	Accuracy	
			Class 0.2s	Class 0.5s
0.01 In	1.0	0.04	± 0.4	± 1.0
0.02 In	-	0.04	± 0.4	± 1.0
0.05 In	-	0.04	± 0.2	± 0.5
0.1 In	-	0.02	± 0.2	± 0.5
0.2 In	-	0.02	± 0.2	± 0.5
0.5 In	-	0.03	± 0.2	± 0.5
In	-	0.03	± 0.2	± 0.5
Im	-	0.04	± 0.2	± 0.5
0.02 In	0.5ind	0.43	± 0.5	± 1.0
0.05 In	-	0.11	± 0.5	± 1.0
0.1 In	-	0.05	± 0.3	± 0.6
0.2 In	-	0.04	± 0.3	± 0.6
0.5 In	-	0.03	± 0.3	± 0.6
In	-	0.03	± 0.3	± 0.6
Im	-	0.04	± 0.3	± 0.6
0.1 In	0.8cap	0.01	± 0.3	± 0.6
0.2 In	-	0.02	± 0.3	± 0.6
0.5 In	-	0.04	± 0.3	± 0.6
In	-	0.03	± 0.3	± 0.6
0.1 In	0.5cap	0.00	± 0.5	± 1.0
0.2 In	-	0.01	± 0.5	± 1.0
0.5 In	-	0.04	± 0.5	± 1.0
In	-	0.04	± 0.5	± 1.0



Polyphase meter carrying a single-phase load, with balanced voltage applied to the voltage's circuits.

X-Ref. 8.1

Test conditions: U_n : 3x230/400V U_x : 230V F_n : 50Hz
 I_n : 5A I_m : 10A

Test Circuit: 3 phase 4 wire

Measurement mode - Active Export Energy kWh

Elements/Lines		I1 Element L1	I2 Element L2	I3 Element L3	Limit of % Error	
CURRENT	PF Cos. ϕ	% Error	% Error	% Error	Accuracy	
0.1 In	1.0	0.00	0.03	0.03	Class 0.2s ± 0.3	Class 0.5s ± 0.6
In	-	0.03	0.03	0.04	± 0.3	± 0.6
Im	-	0.03	0.03	0.03	± 0.3	± 0.6
0.2 In	0.5ind	0.02	0.04	0.06	± 0.4	± 1.0
In	-	0.02	0.03	0.04	± 0.4	± 1.0
Im	-	-0.01	0.05	0.04	± 0.4	± 1.0
0.2 In	0.5cap	0.03	0.02	0.02	-	-
In	-	0.03	0.04	0.03	-	-
Im	-	0.03	0.02	0.03	-	-



Variation in Current (cont.)

IEC 62053-22X-Ref. 8
X-Ref. 8.1

Test Results ID / Sample No.
Current Variation / 2271226

Test Procedure: EN62053-23 Acc 3P4W kvarh +Q
19EMA TP25

Test conditions: U_n : 3x230/400V U_x : 230V F_n : 50Hz
 I_n : 5A I_m : 10A

Test Circuit: 3 phase 4 wire

Measurement mode - Reactive Import Energy kvarh

CURRENT	PF Sin ϕ	% Error	Limit of % Error	
			Accuracy	
			Class 2	Class 3
0.05 I_n	1.0	0.02	± 2.5	± 4.0
0.1 I_n	-	0.02	± 2.0	± 3.0
0.2 I_n	-	0.02	± 2.0	± 3.0
0.5 I_n	-	0.01	± 2.0	± 3.0
I_n	-	0.01	± 2.0	± 3.0
0.4 I_m	-	0.01	± 2.0	± 3.0
0.6 I_m	-	0.11	± 2.0	± 3.0
0.8 I_m	-	0.01	± 2.0	± 3.0
I_m	-	-0.09	± 2.0	± 3.0
0.1 I_n	0.5ind	-0.03	± 2.5	± 4.0
0.2 I_n	-	-0.02	± 2.0	± 3.0
0.5 I_n	-	-0.01	± 2.0	± 3.0
I_n	-	-0.01	± 2.0	± 3.0
I_m	-	-0.02	± 2.0	± 3.0
0.2 I_n	0.25ind	-0.08	± 2.5	± 4.0
0.5 I_n	-	0.04	± 2.5	± 4.0
I_n	-	-0.15	± 2.5	± 4.0
0.2 I_n	0.5cap	0.03	± 2.0	± 3.0
0.5 I_n	-	0.01	± 2.0	± 3.0
I_n	-	0.04	± 2.0	± 3.0
I_m	-	0.05	± 2.0	± 3.0
0.2 I_n	0.25cap	0.06	± 2.5	± 4.0
0.5 I_n	-	0.05	± 2.5	± 4.0
I_n	-	0.00	± 2.5	± 4.0



Polyphase meter carrying a single-phase load, with balanced voltage applied to the voltage's circuits.
X-Ref. 8.1

Test conditions: $U_n: 3 \times 230/400V$ $U_x: 230V$ $F_n: 50Hz$
 $I_n: 5A$ $I_m: 10A$

Test Circuit: *3 phase 4 wire*

Measurement mode - Reactive Import Energy kvarh

Elements/Lines		I1 Element L1	I2 Element L2	I3 Element L3	Limit of % Error	
CURRENT	PF Sin ϕ	% Error	% Error	% Error	Accuracy	
0.1 In	1.0	0.01	0.02	0.02	Class 2 ±3.0	Class 3 ±4.0
In	-	0.01	0.02	0.01	±3.0	±4.0
Im	-	0.01	0.02	0.01	±3.0	±4.0
0.2 In	0.5ind	-0.02	-0.02	0.00	±3.0	±4.0
In	-	0.00	-0.01	-0.01	±3.0	±4.0
Im	-	-0.02	0.00	-0.01	±3.0	±4.0
0.2 In	0.5cap	0.03	0.03	0.06	±3.0	±4.0
In	-	0.02	0.04	0.02	±3.0	±4.0
Im	-	0.01	0.04	0.03	±3.0	±4.0



Variation in Current(cont.)

X-Ref. 8.1

Test Results ID / Sample No.
Current Variation / 2271226

Test Procedure: EN62053-23 Acc 3P4W kvarh -Q
19EMA TP25

Test conditions: U_n : 3x230/400V U_x : 230V F_n : 50Hz
 I_n : 5A I_m : 10A

Test Circuit: 3 phase 4 wire

Measurement mode - Reactive Export Energy kvarh

CURRENT	PF Sin ϕ	% Error	Limit of % Error	
			Accuracy	
			Class 2	Class 3
0.05 I_n	1.0	0.01	± 2.5	± 4.0
0.1 I_n	-	0.02	± 2.0	± 3.0
0.2 I_n	-	0.01	± 2.0	± 3.0
0.5 I_n	-	0.00	± 2.0	± 3.0
I_n	-	0.01	± 2.0	± 3.0
I_m	-	0.01	± 2.0	± 3.0
0.1 I_n	0.5ind	-0.02	± 2.5	± 4.0
I_n	-	0.00	± 2.0	± 3.0
I_m	-	-0.02	± 2.0	± 3.0
0.1 I_n	0.5cap	0.06	± 2.0	± 4.0
I_n	-	0.04	± 2.0	± 3.0
I_m	-	0.05	± 2.0	± 3.0



Polyphase meter carrying a single-phase load, with balanced voltage applied to the voltage's circuits.
X-Ref. 8.1

Test conditions: *Un: 3x230/400V* *Ux: 230V* *Fn: 50Hz*
 In: 5A *Im: 10A*

Test Circuit: *3 phase 4 wire*

Measurement mode - Reactive Export Energy kvarh

Elements/Lines		I1 Element L1	I2 Element L2	I3 Element L3	Limit of % Error	
CURRENT	PF Sin ϕ	% Error	% Error	% Error	Accuracy	
In	1.0	0.01	0.01	0.00	Class 2 ±3.0	Class 3 ±4.0
In	0.5ind	-0.01	-0.01	-0.01	±3.0	±4.0
In	0.5cap	0.00	0.06	0.03	±3.0	±4.0



2.5.2 Voltage Variation

IEC 62053-22 X-Ref. 8.2

Specified Operating Range

Test Results ID / Sample No.
Voltage Variation / 2271222

Test Procedure: EN62053-22 Voltage Variation P
19EMA TP26

Test conditions: U_n : 3x230/400V U_x : 230V F_n : 50Hz
 I_n : 5A I_m : 10A

Test Circuit: 3 phase 4 wire

Measurement mode - Active Energy kWh

		110% U_n	100% U_n	90% U_n	Limit of % Error Variation	
Current	PF Cos. ϕ	% Error	% Error	% Error	Accuracy	
0.05 I_n	1.0	-0.01	-0.02	-0.01	Class 0.2s ± 0.1	Class 0.5s ± 0.2
I_n	-	-0.03	-0.02	-0.02	± 0.1	± 0.2
I_m	-	-0.02	-0.02	-0.02	± 0.1	± 0.2
0.1 I_n	0.5ind	0.06	0.07	0.06	± 0.2	± 0.4
I_n	-	0.05	0.07	0.04	± 0.2	± 0.4
I_m	-	0.04	0.05	0.06	± 0.2	± 0.4

Limit Range of Operation

		115% U_n	80% U_n	Limit of % Error Variation	
Current	PF Cos. ϕ	% Error	% Error	Accuracy	
I_n	1.0	-0.02	-0.02	Class 0.2s ± 0.3	Class 0.5s ± 0.6
I_n	0.5ind	0.03	0.03	± 0.6	± 1.2



Voltage Variation (cont.)

IEC 62053-23 X-Ref. 8.2

Specified Operating Range

Test Results ID / Sample No. Voltage Variation / 2271226	Test Procedure: EN62053-23 Voltage Variation Q 19EMA TP26
---	--

Test conditions: U_n : 3x230/400V U_x : 230V F_n : 50Hz
 I_n : 5A I_m : 10A

Test Circuit: 3 phase 4 wire

Measurement mode - Reactive Energy kvarh

		110% U_n	100% U_n	90% U_n	Limit of % Error Variation	
Current	PF Sin ϕ	% Error	% Error	% Error	Accuracy	
0.05 I_n	1.0	0.02	0.02	0.02	Class 2 ± 1.0	Class 3 ± 2.0
I_n	-	0.01	0.01	0.01	± 1.0	± 2.0
I_m	-	0.01	0.02	0.02	± 1.0	± 2.0
0.1 I_n	0.5ind	-0.02	-0.02	-0.02	± 1.5	± 3.0
I_n	-	-0.01	0.00	0.00	± 1.5	± 3.0
I_m	-	0.00	-0.01	0.00	± 1.5	± 3.0

Limit Range of Operation

		115% U_n	80% U_n	Limit of % Error Variation	
Current	PF Sin ϕ	% Error	% Error	Accuracy	
I_n	1.0	0.01	0.01	Class 2 ± 3.0	Class 3 ± 6.0
I_n	0.5ind	0.00	0.00	± 4.5	± 9.0



2.5.3 Frequency Variation

IEC62053-22 X-Ref. 8.2

Test Results ID / Sample No.
Frequency Variation / 2271222

Test Procedure: EN62053-22 Frequency 51Hz to 49Hz P
19EMA TP27

Test conditions: U_n : 3x230/400V U_x : 230V F_n : 50Hz
 I_n : 5A I_m : 10A

Test Circuit: 3 phase 4 wire

Measurement mode - Active Import Energy kWh

		102% F_n	100% F_n	98% F_n	Limit of % Error Variation	
Current	PF Cos. ϕ	% Error	% Error	% Error	Accuracy	
0.05 In In Im	1.0	-0.02	-0.01	-0.02	Class 0.2s ± 0.1	Class 0.5s ± 0.2
	1.0	-0.02	-0.02	-0.03	± 0.1	± 0.2
	1.0	-0.01	-0.02	-0.02	± 0.1	± 0.2
0.10 In In Im	0.5ind	0.00	0.06	0.12	± 0.1	± 0.2
	0.5ind	-0.02	0.04	0.08	± 0.1	± 0.2
	0.5ind	0.00	0.05	0.09	± 0.1	± 0.2



Frequency Variation(cont)

IEC62053-22 X-Ref. 8.2

Test Results ID / Sample No.
Frequency Variation / 2271226

Test Procedure: EN62053-23 Frequency 51Hz to 49Hz Q
19EMA TP27

Test conditions: U_n : 3x230/400V U_x : 230V F_n : 50Hz
 I_n : 5A I_m : 10A

Test Circuit: 3 phase 4 wire

Measurement mode - Reactive Import Energy kvarh

		102% F_n	100% F_n	98% F_n	Limit of % Error Variation	
Current	PF Sins ϕ	% Error	% Error	% Error	Accuracy	
0.05 I_n	1.0	0.01	0.01	0.01	Class 2 ±2.5	Class 3 ±2.5
I_n	1.0	0.06	0.01	0.01	±2.5	±2.5
I_m	1.0	0.02	0.01	0.01	±2.5	±2.5
0.10 I_n	0.5ind	-0.02	-0.02	-0.14	±2.5	±2.5
I_n	0.5ind	0.00	-0.01	-0.12	±2.5	±2.5
I_m	0.5ind	-0.02	-0.01	-0.10	±2.5	±2.5

2.5.4 Reversed Phase Sequence

IEC 62053-22 X-Ref. 8.2

Test Results ID / Sample No.
Reverse Phase / 2271222

Test Procedure: EN62053-22 Reverse Phase Sequence
19EMA TP28

Test conditions: U_n : 3x230/400V U_x : 230V F_n : 50Hz
 I_n : 5A I_m : 10A

Test Circuit: 3 phase 4 wire

Measurement mode - Active Import Energy kWh

		Limit of % Error Variation	
Phase Sequence	% Error	Accuracy	
Current		Class 0.2s	Class 0.5s
Sequence L1-L2-L3 0.1 In	-0.02	-	-
Sequence L1-L3-L2 0.1 In	-0.02	±0.05	±0.1

2.5.5 Voltage Unbalance

IEC 62053-22 X-Ref. 8.2

Test Results ID / Sample No.
Voltage Unbalance / 2271222

Test Procedure: EN62053-22 Phase Interruption
19EMA TP29

Test conditions: U_n : 3x230/400V U_x : 230V F_n : 50Hz
 I_n : 5A I_m : 10A

Test Circuit: 3 phase 4 wire

Measurement mode - Active Import Energy kWh

		Limit of % Error Variation	
Network Phase/Lines connected	% Error	Accuracy	
		Class 0.2s	Class 0.5s
L1 & L2 & L3	-0.02	-	-
L2 & L3	-0.03	±0.5	±1.0
L1 & L3	-0.31	±0.5	±1.0
L1 & L2	-0.43	±0.5	±1.0
L3	-0.03	±0.5	±1.0
L2	-0.03	±0.5	±1.0
L1	0.15	±0.5	±1.0



2.5.6 Continuous Magnetic Induction of External Origin

IEC 62053-22 X-Ref. 8.2

Test Results ID / Sample No.
DC Mag. Field / 2271226

Test Procedure: EN62053-22 DC Magnetic Field P
19EMA TP33

Test conditions: U_n : 3x230/400V U_x : 230V F_n : 50Hz
 I_n : 5A I_m : 10A

Test Circuit: 3 phase 4 wire

Measurement mode - Active Import Energy kWh

		Limit of % Error Variation	
Electromagnetic Position	% Error	Accuracy	
		Class 0.2s	Class 0.5s
No field applied	0.00	-	-
Left side of meter	0.00	±2.0	±2.0
Front of meter	0.00	±2.0	±2.0
Right side of meter	0.00	±2.0	±2.0
Top of meter	0.00	±2.0	±2.0



2.5.7 Magnetic Induction of External Origin 0.5mT IEC 62053-22 X-Ref. 8.2

Ac magnetic induction of external origin, produced by a coil of one metre diameter, field strength at its centre 0.5mT (400 Ampere turns)

Test Results ID / Sample No.	Test Procedure: T/T +P X-X FAIRY RING T/T +P Y-Y FAIRY RING T/T +P Z-Z FAIRY RING 19EMA TP34
AC Mag. Fields / 2271222	

Test conditions: $Un: 3 \times 230/400V$ $Fn: 50Hz$
 $In: 5A$ $PF: \cos. \phi = 1.0$

Test Circuit: *3 phase 4 wire*

Measurement mode - Active Import Energy kWh

Phase angle of the field with respect to U3 (Vph)	Direction of field orientation		
	X - X	Y - Y	Z - Z
	% Error	% Error	% Error
No Field Applied	0.02	-0.02	-0.01
0°	0.01	-0.02	-0.02
30°	0.00	-0.02	-0.03
60°	0.01	-0.01	-0.02
90°	0.01	-0.01	-0.01
120°	0.02	-0.01	-0.01
150°	0.02	-0.01	0.00
180°	0.01	-0.02	0.00
210°	0.02	-0.02	-0.01
240°	0.01	-0.02	-0.01
270°	0.01	-0.02	-0.01
300°	0.00	-0.02	-0.01
330°	0.00	-0.02	-0.01
360°	0.00	-0.02	-0.01

Limit of % Error Variation for Class 0.2s $\pm 0.5\%$
Class 0.5s $\pm 1.0\%$

2.5.8 Auxiliary Power Supply Voltage Variation

IEC 62053-22 X-Ref. 8.2

Test Results ID / Sample No.
Aux Voltage Var / 2271226

Test Procedure: EN62053-22 Aux Voltage Variation (PLE)

Test conditions: $U_n: 3x230/400V$ $U_x: 100V$ $F_n: 50Hz$
 $0.01I_n: 0.05A$ $PF: \cos. \phi = 1.0$

Measurement mode - Active Energy kWh

Auxiliary Power Supply Voltage Level	% Error	Limit of % Error Variation Accuracy	
		Class 0.2s	Class 0.5s
100%	-0.01	-	-
115%	0.02	± 0.05	± 0.1
85%	0.00	± 0.05	± 0.1

Test conditions: $U_n: 3x230/400V$ $U_x: 230V$ $F_n: 50Hz$
 $0.01I_n: 0.05A$ $PF: \cos. \phi = 1.0$

Measurement mode - Active Energy kWh

Auxiliary Power Supply Voltage Level	% Error	Limit of % Error Variation Accuracy	
		Class 0.2s	Class 0.5s
100%	0.02	-	-
115%	-0.02	± 0.05	± 0.1
85%	0.00	± 0.05	± 0.1

Test conditions: $U_n: 3x230/400V$ $U_x: 480V$ $F_n: 50Hz$
 $0.01I_n: 0.05A$ $PF: \cos. \phi = 1.0$

Measurement mode - Active Energy kWh

Auxiliary Power Supply Voltage Level	% Error	Limit of % Error Variation Accuracy	
		Class 0.2s	Class 0.5s
100%	0.03	-	-
115%	0.02	± 0.05	± 0.1
85%	0.00	± 0.05	± 0.1



2.6 Accuracy test in the Presence of Harmonics IEC 62053-23 X-Ref. 8.2

2.6.1 Harmonic Components in the Current and Voltage Circuits X-Ref. 8.2

Test Results ID / Sample No. Harmonics / 2271222	Test Procedure: EN62053-22 Harmonics Tests 19EMA TP32
---	--

Test conditions: $U_n: 3 \times 230/400V$ $U_x: 230V$ $F_n: 50Hz$
 $I_n: 5A$ $I_m: 10A$ $PF: \cos \phi = 1.0$

Fundamental frequency current: $I_0 = 0.5 I_{max}$
Fundamental frequency voltage: $U_0 = U_n$
content of 5th harmonic current: $I_5 = 40\%$ of I_0
content of 5th harmonic voltage: $U_5 = 10\%$ of U_n

Resulting harmonic power due to the 5th harmonic presence: $P_{resultant} = 1.04 P_0$

Test Circuit: *3 phase 4 wire*

Measurement mode - Active Energy kWh

		Limit of % Error Variation	
Waveform	% Error	Accuracy	
Fundamental Only (P_0) 0.5 I_{max}	-0.03	Class 0.2s -	Class 0.5s -
Fundamental + 5 th Harmonic ($P_{resultant} = 1.04 P_0$)	-0.04	±0.4	±0.5

2.6.3 Influence of Odd and Sub Harmonics in the AC Current Circuit

X-Ref. 8.2

Test Results ID / Sample No.
Harmonics / 2271222

Test Procedure: EN62053-22 Harmonics Tests
19EMA TP32

Test conditions: $U_n: 3 \times 230/400V$ $U_x: 230V$ $F_n: 50Hz:$
 $I_n: 5A$ $PF: \cos. \phi = 1.0$

Reference current waveform: $I_{ref} = 0.5 I_n$

Reference voltage: $U = U_n$

Test current Phase-fired waveform: $I_{test} = \sqrt{2} \cdot I_{ref}$

Firing points = 5ms and 15ms \pm 1ms

Test current Burst fired waveform: $I_{test} = 2 \cdot I_{ref}$

Distortion factor on the voltage waveform: $< 0.5 \% THD$

Test Circuit: *3 phase 4 wire*

Measurement mode - Active Energy kWh

		Limit of % Error Variation	
Waveform	% Error	Accuracy	
		Class 0.2s	Class 0.5s
Fundamental Only 0.5 In	-0.02	-	-
Waveform Phase-fired Test current	0.04	± 0.6	± 1.5
Waveform Burst fired Test current	0.03	± 0.6	± 1.5



3 ELECTRICAL REQUIREMENTS

IEC 62053-22 X-Ref. 7

3.1 Power Consumption

X-Ref. 7.1

Test Results ID / Sample No.
Power Consumption / 2271226

Test Procedure: EN62053-22 Power Consumption
19EMA TP22

	Volts/V	Amps/A	VA	Watts/W
Auxiliary Power Supply <u>Wiring Configuration:</u> <u>Single Phase Two Wire</u> Voltage Circuit: L1	<i>480V</i>	<i>0.231A</i>	<i>11.28</i>	<i>3.84</i>

Power consumption limits for auxiliary power supply circuits shall not exceed the following based on IEC 62053-61: 1998-02

<u>Voltage Circuits</u>	<u>Single Phase</u>	<u>Two Element</u>	<u>Three Element</u>
Basic Meter	2W 10VA	2W 10VA	2W 10VA
multi-energy meter	3W 15VA	2.5W 12.5VA	2W 10VA
Multi-function meter	5W 25VA	3.5W 17.5VA	3W 15VA

3.2 Influence of Supply Voltage

IEC 62052-11 X-Ref. 7

Voltage dips and interruptions

X-Ref. 7.1.2

Test Results ID / Sample No.
Voltage Dips / 2271222

Test Procedure: EN62052-11 Voltage Dips
19EMA TP10

Environmental Conditions

Power Supply	230V, 50Hz
Temperature	21°C
Relative Humidity	38%
Barometric Pressure	1004mB

Test Circuit: *1 phase 2 wire, in the case of Polyphase meters tests were conducted on each voltage circuit in turn.*

The tests were applied under the following conditions;

- voltage and auxiliary circuits energised with reference voltage
- current circuits open.

Test a)	Voltage interruption of:	V = 100%
	Interruption time:	1s
	Number of interruptions:	3
	Restoring time between interruption:	50ms
Test b)	Voltage interruption of:	V = 100%
	Interruption time:	20ms
	Number of interruptions:	1
Test c)	Voltage depression of:	V=50%
	Depression time:	60s
	Number of depressions:	1

The application of the above test did not produce a change in the meter registers of more than x kWh/kvarh, and the test output did not produce a signal equivalent of more than x kWh/kvarh, where x is given by

$$x = 10^{-6} \cdot m \cdot U_n \cdot I_{max}$$

3.3 Test of Influence of Short-Time Over-Currents IEC 62053-22 X-Ref. 7.2

Test Results ID / Sample No.
STOC / 2271226

Test Procedure: EN62053-22 Short-Time Over-Current
19EMA TP23

Environmental Conditions

Temperature	21°C
Relative Humidity	45%
Barometric Pressure	1010mB

Test Conditions: I_m : 10A F_n : 50Hz

Test Circuit: 3 phase 4 wire

The test was applied under the following conditions;

Meter for connection through current transformer:

An impulse currents were applied = 20 x I_{max}
At rated frequency for 0.5 second duration
Applied to each current phase

On completion of the test, the meters voltage circuits were energised at reference voltage for 1 hour.

Power Factor	Current	% Error
Cos. ϕ = 1.0	In	0.04

Limit of % Error: Class 0.2s \pm 0.05% for connection through a current transformer
Class 0.5s \pm 0.05% for connection through a current transformer

The meter showed no signs of damage and functioned correctly.



3.4 Test of Influence of Self Heating

IEC 227122262053-22

X-Ref. 7

X-Ref. 7.3

Test conditions:- The meter voltage circuits were energised at reference voltage for at least 2 hours, without any current in the current circuits, after which the meter's maximum rated current was applied and the meter error determined every 5 minutes. The test was conducted at power factors of both $\cos \phi = 1.0$ and $\cos \phi = 0.5$ ind.

Test Results ID / Sample No.
Self Heating / 2271222

Test Procedure: EN62053-22 Self Heating
19EMA TP24

Test conditions: $U_n: 3 \times 230/400V$ $U_x: 230V$
 $I_m: 10A$ $F_n: 50Hz$

Test Circuit: 3 phase 4 wire

Measurement Mode Active Energy kWh

Elapsed Test time (minutes)	Un Im Cos. $\phi = 1.0$	Un Im Cos. $\phi = 0.5$
	% Error	% Error
1	-0.01	0.02
5	-0.02	0.06
10	-0.03	0.09
15	-0.04	0.10
20	-0.04	0.11
25	-0.04	0.11
30	-0.05	0.11
35	-0.03	0.11
40	-0.04	0.10
45	-0.05	0.12
50	-0.05	0.11
55	-0.03	0.12
60	-0.04	0.10

Limit of % Error Variation: Class 0.2s $\pm 0.1\%$ @ $\cos \phi = 1.0$ & $\cos \phi = 0.5$ ind
Class 0.5s $\pm 0.2\%$ @ $\cos \phi = 1.0$ & $\cos \phi = 0.5$ ind



3.5 Test of Influence of Heating

IEC 62052-11 X-Ref. 7.2

Test Results ID / Sample No.
Heating / JB1310419000037

Test Procedure: EN62052-11 Heating
19EMA TP11

The tests were conducted with the meter cover and terminal cover in place

Test conditions: $115\%Un: 3x448.5V$ $Im: 10A$ $Fn: 50Hz$

Ambient Temperature: $40^{\circ}C$
Test Duration: 2 hours
Surface Temperature Rise: Current Circuit: 6.1K
Voltage Circuit: 4.9K

Permissible temperature rise: 25K

Surface temperature of the meter was measured on the meter back, approximately 10mm above the meter current circuit and voltage circuit terminal block.

On completion of the above test, the meter was found to function correctly and within the accuracy specification when subsequently operated under reference operating conditions, with no signs of damage or degradation in the meter's insulation properties.

4 ELECTROMAGNETIC COMPATIBILITY (E.M.C.) IEC 62052-11 X-Ref. 7.5

4.1 Immunity to Electrostatic Discharges (ESD) X-Ref. 7.5.2

Test Results ID / Sample No.
ESD / 2271222

Test Procedure: EN62052-11 Electrostatic Discharge
I9EMA TP14

The meter was tested in accordance with IEC 61000-4-2 as follows:

Environmental Conditions

Power Supply	230V, 50Hz
Temperature	20°C
Relative Humidity	39%
Barometric Pressure	989mB

E.S.D Generator specification:

Test level severities: 8kV contact, conductive surfaces / coupling planes

15kV air gap discharge - non conducting surfaces

Positive / Negative polarity

Number of discharges: 10 at each polarity

Rise time of discharge current: <1ns

Pulse duration (50%) 30ns

Time between discharges: 1s

Meter in operating condition with the voltage and auxiliary circuits energised. Current circuits open.

The application of the electrostatic discharge did not produce a change in the meter registers of more than x kWh, and the test output did not produce a signal equivalent of more than

x kWh, where x is given by

$$x = 10^{-6} \cdot m \cdot U_n \cdot I_{max}$$

where

x is the critical change value in kWh

m is the number of measuring elements

U_n is the reference voltage

I_{max} is the maximum current

4.2 Immunity to Electromagnetic HF Fields

X-Ref. 7.5.3

Test Results ID / Sample No.
RI / 2271222

Test Procedure: EN62052-11 Radiated Immunity
19EMA TP15

The meter was tested in accordance with IEC 61000-4-3 in the SGS Anechoic chamber as follows:

Environmental Conditions

Power Supply	230V, 5A, 50Hz
Temperature	19°C
Relative Humidity	41%
Barometric Pressure	998mB

Port: Enclosure
Test Level: 10 V/m (80-2000MHz) & 1V/m (2000-2700MHz) (test 1) & 30 V/m (test 2)
Frequency Range: 80-2000 MHz & 2000-2700MHz*
Dwell Time: 6 Seconds for Test 1, 2 Seconds for Test 2
Frequency Step Size: 1%
Modulation: 80%, 1 kHz Amplitude Modulation.

*2000-2700MHz: At the request of the client, the radiated immunity test was performed across an additional frequency range of 2000-2700MHz

Operating Mode:

Mode 1) Voltage and auxiliary circuits energised with reference voltage, without any current in the current circuits

Mode 2) Voltage and auxiliary circuits energised with reference voltage and with basic current I_b applied

Test Results (Radiated Immunity 80-2700MHz)

EUT Face	Polarity	Test 1 Maximum % Error Observed	Test 2	Critical Change % Error Limit	
				Accuracy	
				Class 0.5	Class 0.2
Front	Horizontal	0.18	Note 1	±2.0	±1.0
Front	Vertical	0.18	Note 1	±2.0	±1.0
Rear	Horizontal	0.18	Note 1	±2.0	±1.0
Rear	Vertical	0.18	Note 1	±2.0	±1.0
LHS	Horizontal	0.18	Note 1	±2.0	±1.0
LHS	Vertical	0.18	Note 1	±2.0	±1.0
RHS	Horizontal	0.18	Note 1	±2.0	±1.0
RHS	Vertical	0.18	Note 1	±2.0	±1.0

Immunity to Electromagnetic HF Fields (cont)

X-Ref. 7.5.3

Note 1: The application of the RF electromagnetic field did not produce a change in the meter registers of more than x kWh, and the test output did not produce a signal equivalent of more than x kWh, where x is given by

$$x = 10^{-6} \cdot m \cdot U_n \cdot I_{max}$$

where

x is the critical change value in kWh

m is the number of measuring elements

U_n is the reference voltage

I_{max} is the maximum current

4.3 Fast Transient Burst Test

X-Ref. 7.5.4

Test Results ID / Sample No.
FTB / 2271235

Test Procedure: EN62052-11 Fast Transient Bursts
19EMA TP16

The meter was tested in accordance with IEC 61000-4-4 as follows:

Environmental Conditions

Power Supply	230V, 5A, 50Hz
Temperature	19°C
Relative Humidity	40%
Barometric Pressure	996 mB

Transient/Burst specification:

- Pulse level severity 2kV & 4kV
- Rise time 5ns
- Width 50ns
- Repetition Rate 5 kHz & 2.5 kHz
- Burst Duration 15ms
- Burst Period 300ms
- Burst Generation Asynchronous (Common mode)

Operating mode: The meter voltage circuits were energised at reference voltage U_n , with $I_b/I_n \cos \phi = 1.0$ in the current circuits.

Test voltage severity level $\pm 4kV$, Repetition Rate 5kHz voltage and current circuits
Test voltage severity level $\pm 2kV$, Repetition Rate 5kHz auxiliary circuits $> 40V$

The test voltage was applied on the current and voltage circuits in common mode, for a test duration of 60 seconds at each polarity.



Fast Transient Burst Test (cont)

X-Ref. 7.5.4

Test conditions: $Un: 3 \times 230/400V$ $Fn: 50Hz$
 $In: 5A$ $PF: \cos. \phi = 1.0$

Test Circuit: *3 phase 4 wire*

Measurement mode - Active Import Energy kWh

		Critical Change % Error Limit	
Test Voltage (kV)	% Error	Accuracy	
No FTB applied	-0.026	Class 0.5	Class 0.2
+4 Voltage Circuit	-0.065	±2.0	±1.0
-4 Voltage Circuit	-0.057	±2.0	±1.0
-4 Current Circuit	-0.034	±2.0	±1.0
-4 Current Circuit	-0.08	±2.0	±1.0
+2 Auxiliary Circuit	-0.018	±2.0	±1.0
-2 Auxiliary Circuits	-0.049	±2.0	±1.0

On completion of the above test, the meter was found to function correctly and within the accuracy specification when subsequently operated under reference operating conditions, with no signs of damage or corruption to meter register data.

4.4 Immunity to Conducted Disturbances

X-Ref. 7.5.5

Test Results ID / Sample No.
CI / 2271222

Test Procedure: EN62052-11 Conducted Immunity
19EMA TP17

The meter was tested in accordance with IEC 61000-4-6 as follows:

Environmental Conditions

Power Supply	230V, 5A, 50Hz
Temperature	23°C
Relative Humidity	43%
Barometric Pressure	1016mB

Ports:	Current, Voltage and Auxiliary Circuits
Test Level:	10 V
Frequency Range:	0.15 to 80 MHz
Dwell Time:	Function of Meter Pulses (≥ 2 Secs)
Frequency Step Size:	1%
Modulation:	80%, 1kHz Amplitude Modulation.

The compliance test was performed as follows:

Operating Mode

Voltage and auxiliary circuits energised with reference voltage and with basic current I_b applied

Test Results

MUT Port	Frequency Range (MHz)	% Error	Critical Change % Error Limit	
			Accuracy	
Voltage & Current Circuits	0.15 to 80	0.12	Class 0.5	Class 0.2
			± 2.0	± 1.0
Auxiliary Circuits	0.15 to 80	0.24	± 2.0	± 1.0



4.5 Surge Immunity

X-Ref 7.5.6

Test Results ID / Sample No.
Surge / 2271222

Test Procedure: EN62052-11 Surge
19EMA TP18

The meter was tested in accordance with IEC 61000-4-5 as follows:

Ports:	Voltage and Auxiliary Circuits
Test Voltage:	4kV mains, 1kV auxiliary
Test Mode:	Differential
Phase Angle:	60° and 240° relative to zero crossing
Number of Tests:	5 positive and 5 negative
Repetition Rate:	1/min

Environmental Conditions

Power Supply	230V, 50Hz
Temperature	21°C
Relative Humidity	34 %
Barometric Pressure	988mB

The application of the surge immunity test voltage did not produce a change in the meter registers of more than x kWh and the test output did not produce a signal equivalent of more than x kWh, where x is given by

$$x = 10^{-6} \cdot m \cdot U_n \cdot I_{max}$$

4.6 Immunity to Damped Oscillatory Waves

X-Ref. 7.5.7

Test Results ID / Sample No.
DOW / 2271235

Test Procedure: EN62052-11 Damped Oscillatory Waves
19EMA TP19

The meter was tested in accordance with IEC 61000-4-12 as follows:

Environmental Conditions

Power Supply	230V, 5A, 50Hz
Temperature	20°C
Relative Humidity	42%
Barometric Pressure	1011mB

Ports:	Voltage and Auxiliary Circuits
Test Level:	Common Mode: 2.5kV Differential Mode: 1kV
Test Frequencies:	100 kHz, repetition rate: 40Hz 1 MHz, repetition rate: 400Hz
Test Duration:	60s (15 cycles with 2s on, 2s off, for each frequency)
Operating Mode:	The meter voltage and auxiliary circuits were energised at reference voltage U_n , with I_b/I_n $\cos. \phi = 1.0$ in the current circuits.

The test voltage was applied on the voltage circuits in common & differential coupling, for a test duration of 60 seconds at each polarity.

Immunity to Damped Oscillatory Waves (cont.)

X-Ref. 7.5.7

Test a)100kHz Test Frequency Results:

3 Phase Voltage Supply			Limit of % Error Variation	
Test Voltage(kV)	Coupling	% Error	Accuracy	
No DOW's applied	-	-0.055	Class 0.2	Class 0.5
±1	L1-N	0.143	±1.0	±2.0
±1	L2-N	0.152	±1.0	±2.0
±1	L3-N	0.143	±1.0	±2.0
±1	L1-L2	-0.063	±1.0	±2.0
±1	L1-L3	-0.063	±1.0	±2.0
±1	L2-L3	-0.063	±1.0	±2.0
±2.5	L1,L2,L3,N	0.094	±1.0	±2.0

Auxiliary Power Supply			Limit of % Error Variation	
Test Voltage(kV)	Coupling	% Error	Accuracy	
±1	L1-L2	-0.047	Class 0.2	Class 0.5
±2.5	L1 & L2	-0.063	±1.0	±2.0

Immunity to Damped Oscillatory Waves (cont.)

X-Ref. 7.5.7

Test b) 1MHz Test Frequency Results:

3 Phase Voltage Supply			Limit of % Error Variation	
Test Voltage(kV)	Coupling	% Error	Accuracy	
No DOW's applied	-	-0.055	Class 0.2	Class 0.5
±1	L1-N	0.135	±1.0	±2.0
±1	L2-N	0.143	±1.0	±2.0
±1	L3-N	0.135	±1.0	±2.0
±1	L1-L2	-0.072	±1.0	±2.0
±1	L1-L3	-0.055	±1.0	±2.0
±1	L2-L3	-0.063	±1.0	±2.0
±2.5	L1,L2,L3,N	-0.775	±1.0	±2.0

Auxiliary Power Supply			Limit of % Error Variation	
Test Voltage(kV)	Coupling	% Error	Accuracy	
±1	L1-L2	-0.055	Class 0.2	Class 0.5
±2.5	L1 & L2	-0.072	±1.0	±2.0



5 CLIMATIC INFLUENCES

IEC 62052-11 X-Ref. 6

5.1 Dry Heat Test

X-Ref. 6.3.1

Test Results ID / Sample No. Dry Heat / 2271235	Test Procedure: EN62052-11 Dry Heat 19EMA TP07
--	---

The meter was tested in accordance with IEC 60068-2-2 as follows:

Meter in the non-operating condition

Temperature $+70^{\circ}\text{C} \pm 2^{\circ}\text{C}$

Duration of the test 72h

On completion of the above test the meter was found to function correctly and within the accuracy specification when subsequently operated under reference operating conditions with no signs of damage or degradation in the meter's insulation properties.

5.2 Cold Test

X-Ref. 6.3.2

Test Results ID / Sample No. Cold / 2271226	Test Procedure: EN62052-11 Cold 19EMA TP08
--	---

The meter was tested in accordance with IEC 60068-2-1 as follows:

Meter in the non-operating condition

Temperature $-25^{\circ}\text{C} \pm 3^{\circ}\text{C}$

Duration of the test 72h

On completion of the above test the meter was found to function correctly and within the accuracy specification when subsequently operated under reference operating conditions, with no signs of damage or corruption to meter register data.

5.3 Damp Heat, Cyclic Test

X-Ref. 6.3.3

Test Results ID / Sample No. Damp Heat / 2271226	Test Procedure: EN62052-11 Damp Heat 19EMA TP09
---	--

The meter was tested in accordance with IEC 60068-2-30 as follows:

Meter with reference voltage applied

Upper Temperature of $+40^{\circ}\text{C}$

Duration of the test: 6 cycles

On completion of the above test the meter was found to function correctly and within the accuracy specification when subsequently operated under reference operating conditions with no signs of damage or degradation in the meter's insulation properties.



6 MECHANICAL REQUIREMENTS

IEC 62052-11 X-Ref. 5.2.2

6.1 Spring Hammer Test

X-Ref. 5.2.2.1

Test Results ID / Sample No.
Spring Hammer / 2271222

Test Procedure: EN62052-11 Spring Hammer
19EMA TP01

Environmental Conditions

Temperature	20°C
Relative Humidity	38%
Barometric Pressure	998mB

The meter was tested in accordance with IEC 60068-2-75 as follows:

Kinetic Energy of Spring Hammer $0.2 \text{ Nm} \pm 0.05 \text{ Nm}$

The meter case and terminal cover were acted upon all external surfaces, including the display window. After the test no damage was evident and the meter continued to function correctly.



MECHANICAL REQUIREMENTS (cont)

IEC 62052-11 X-Ref. 5.2.2

6.2 Shock Test

X-Ref. 5.2.2.2

Test Results ID / Sample No.
Shock / 2271235

Test Procedure: EN62052-11 Shock
19EMA TP02

Environmental Conditions

Temperature	19°C
Relative Humidity	44%
Barometric Pressure	991mB

The meter was tested in accordance with IEC 60068-2-27 as follows:

Meter in the non-operating condition

Half Sine Pulse

Peak Acceleration of 30 gn (300 m/s^2)

Pulse Duration of 18 ms

On completion of the above tests the meter was found to function correctly and within the accuracy specification when subsequently operated under reference operating conditions.

6.3 Vibration Test

X-Ref. 5.2.2.3

Test Results ID / Sample No.
Vibration / 22712235

Test Procedure: EN62052-11 Vibration
19EMA TP03

Environmental Conditions

Temperature	20°C
Relative Humidity	46%
Barometric Pressure	999mB

The meter was tested in accordance with IEC 60068-2-6 as follows:

Meter in the non-operating condition

Test Procedure A

Frequency Range of 10 Hz to 150 Hz (Transition frequency of 60 Hz)

For $F < 60 \text{ Hz}$, constant amplitude of movement 0.075 mm

For $F > 60 \text{ Hz}$, constant acceleration of 9.8 m/s^2 (1g)

10 sweep cycles per axis

On completion of the above test the meter was found to function correctly and within the accuracy specification when subsequently operated under reference operating conditions.



6.4 Resistance to Heat & Fire

X-Ref. 5.8

Test Results ID / Sample No. Heat & Fire / 2271235	Test Procedure: EN62052-11 Heat & Fire 19EMA TP04
---	--

The meter was tested in accordance with IEC 60695-2-11 as follows:



Terminal block tested at 960°C for 30 seconds.

Result: Flames extinguish with 30 seconds when glow wire removed.



Terminal cover and meter case tested at 650°C for 30 seconds.

Result: No flames or drips occur.



ANNEX A Radiated Immunity Test 80-2000MHz– Graphical plots of results





Radiated Immunity Test 80-2000MHz – Graphical plots of results (cont)





Radiated Immunity Test 80-2000MHz – Graphical plots of results (cont)





Radiated Immunity Test 80-2000MHz – Graphical plots of results (cont)





Radiated Immunity Test 2 – 2.7GHz – Graphical plots of results





Radiated Immunity Test 2 – 2.7GHz – Graphical plots of results (cont)





Radiated Immunity Test 2 – 2.7GHz – Graphical plots of results (cont)



Radiated Immunity Test 2 – 2.7GHz – Graphical plots of results (cont)




ANNEX B Conducted Immunity Test – Graphical plots of results




ANNEX E Photographs of Meter Under Test

Front View



Rear View



Photographs of Meter Under Test (cont)

LHS View



RHS View



