



**NOTES**

- PIPELINE TO BE INSTALLED WITH MINIMUM OF 48" COVER IN CROPLANDS, 60" IN STREAMS & 36" COVER IN ALL OTHER LOCATIONS. IF BEDROCK IS ENCOUNTERED, THE MINIMUM COVER WILL BE 24".
- NO OPEN TRENCHES SHALL BE LEFT OVERNIGHT EXCEPT AT TIE-IN HOLES. TIE-IN HOLES MUST BE BARRICADED WITH CONSTRUCTION FENCE, STATION 218+00 TO STATION 228+00.
- SELECTIVE CLEARING ZONE - CONTRACTOR SHALL CLEAR TREES WITHIN PROPOSED ROW LIMITS AS REQUIRED & SHALL PROTECT & MAINTAIN TREES OUTSIDE PROPOSED ROW LIMITS BETWEEN RESIDENTIAL BACKYARDS & CONSTRUCTION WORK ZONE, STATION 222+00 TO STATION 228+00.
- CLEARING ALONG ELECTRIC POWERLINE, CLEAR BRUSH TO ROW LIMITS AS SHOWN WITHIN EXISTING POWERLINE ROW. ALL TREES LOCATED OUTSIDE ELECTRIC POWERLINE ROW SHALL BE PROTECTED FROM DAMAGE BY CONSTRUCTION ACTIVITIES. ONLY OVERHANGING LIMBS FROM TREES OUTSIDE THE ELECTRIC POWERLINE ROW THAT COULD BE DAMAGED BY CONSTRUCTION ACTIVITIES MAY BE SLICED TRIMMED.
- REFER TO DWG 6172-2101 SHEET 1 FOR SURVEY NOTES.
- CROSS GARDNER ROAD USING OPEN CUT METHOD.
- ALL WOOD SHALL BE STACKED IN UPLAND AREAS OR REMOVED FROM RIGHT-OF-WAY.
- EXTRA WORK SPACE (EWS) AS SHOWN ON DRAWING.
- CHECK DAMS, TEMPORARY ACCESS ROADS, STREAM CROSSING, WETLAND CROSSING AND GENERAL EROSION AND SEDIMENT CONTROL DETAILS ARE SHOWN ON SHEETS 13, 14 AND IN THE EM&CS&P.

No.	App'd	By	Date
PA	JM	RM	09/09/11
PB	JM	RM	07/20/11
PC	JM	RM	08/17/11
PD	JM	RM	08/31/11
PE	JM	RM	09/02/11
PF	JM	RM	09/05/11
PG	JM	RM	09/15/11

Submittal / Revision	Date
ISSUED FOR REVIEW	09/09/11
ISSUED FOR REVIEW	07/20/11
ISSUED FOR REVIEW	08/17/11
ISSUED FOR REVIEW	08/31/11
ISSUED FOR REVIEW	09/02/11
ISSUED FOR REVIEW	09/05/11
UPDATED WETLAND/STREAM IDENTIFICATION	09/15/11

**NYSEG**  
 GAS BUSINESS UNIT  
 KIRKWOOD, N.Y.

UNAUTHORIZED ALTERATION OR ADDITION  
 APPLICABLE STATE AND/OR LOCAL LAWS

**CIA**  
 International Engineering & Development Corporation  
**IEDC**

**SENECA WEST PIPELINE INTERCONNECT**  
 CIVIL ALIGNMENT PLAN  
 Project No.: 22867  
 Scale: 1:100  
 Issue Date: 11/2011