

Case 14-E-0270

Petition Requesting Initiation of a
Proceeding to Examine a Proposal for
Continued Operation of the R.E. Ginna
Nuclear Power Plant, LLC.

Hearing Exhibit 52

Rochester Gas and Electric Corporation

**Petition for Initiation of a Proceeding to Examine a Proposal for Continued Operation of
the R.E. Ginna Nuclear Power Plant
Case 14-E-0270**

INFORMATION REQUEST

Requesting Party and No: Alliance for a Green Economy (AGREE-35)

Request No.: GNP-15-204

Date of Request: September 4, 2015

Response Due: September 16, 2015

Date of Reply: September 16, 2015

Respondent: Timothy Lynch

Re: Alliance for a Green Economy's Fourth Set of Information Requests

Question:

For the year 2015, please provide the number of hours and the number of megawatts to date by which load in the RG&E service territory has exceeded 1430 megawatts. Please use the format used previously to respond to Entergy-3 and AGREE-15.

Response:

RG&E objects to this interrogatory because it requests information that is irrelevant and outside the scope of the current phase of this proceeding (i.e., the interrogatory seeks information that does not "involv[e] the request of RG&E for Commission acceptance of a Reliability Support Services Agreement between RG&E and R.E. Ginna Nuclear Power Plant LLC, and for approval of the allocation and recovery of the costs of that agreement.")

Subject to and without waiving these objections, RG&E provides the following response:

Please see the table on the following page.

Rochester Gas and Electric Corporation

**Petition for Initiation of a Proceeding to Examine a Proposal for Continued Operation of
the R.E. Ginna Nuclear Power Plant
Case 14-E-0270**

INFORMATION REQUEST

2015 - Highest load above 1,430MW in MW

2015	Hour								
Month Day	13	14	15	16	17	18	19	20	21
July									
7			1,430	1,439	1,449				
28			1,461	1,470	1,479	1,458			
29		1,474	1,506	1,515	1,525	1,504	1,485	1,438	
August									
17		1,451	1,491	1,519	1,524	1,507	1,481		
19		1,433	1,467	1,483	1,496	1,498	1,459		
20	1439.58	1,450							
September									
2					1,441				
3			1,452	1,466	1,456				
8	1,450	1,513	1,543	1,544	1,530	1,505	1,463		1,443