



Date: June 16, 2026

Hon. Michelle L. Phillips  
Secretary to the Commission  
New York State Public Service Commission  
Three Empire State Plaza  
Albany, NY 12223-1350

Re: Meter Service Provider for PMHA Peoples Mutual Housing Association

Case #: 11-02802 [11-M-0710]

Dear Secretary Phillips:

As per the PSC requirements outlined in "16 NYCRR Part 92 Operating Manual dated March 14, 2003", SATEC Engineers have performed accuracy testing for the following residential dwellings:

Site address: 334 East 8<sup>th</sup> Street, New York, NY 10009

The meters under tests have been found compliant. Should you need any further information or have any questions about this petition, please feel free to contact us.

Respectively,

A handwritten signature in blue ink, appearing to read "Rodney Jean Charles", written over a horizontal line.

Rodny Jean Charles  
**Project Manager**  
SATEC, Inc., 10 Milltown Ct, Union, NJ 07083  
[rcharles@satecinc.com](mailto:rcharles@satecinc.com)|908-686-9510



## Annual Report of Variable Interval Plan Test Status

Period Ending December 31, 2026  
Residential Electric Sub-Meters

Building Name and Address:				334 East 8th Street, New York, NY 10009									
MFR AND TYPE	Number In Service 1-Jan-2026	Number In Service 31-Dec-26	Net Change + or -	2026 Tests REQUIRED		2026 Tests COMPLETED	2026 METER PERFORMANCE				2027 Tests Required		
				%	#	#	FINAL AVERAGE PERCENT REG.				%	Number	
							Outside 98-102%		More Than 102%				
#	%	#	%	#	%	#	%	#	%	#	%		
BFM 136	30	30	0	4.0%	2	2	0	0.000%	0	0.000%	4.0%	2	

*The above report is a correct summary of all wathour meter  
Variable Interval Tests made by this utility, and all tests were conducted  
according to the rules of the NY Public Service Commission.*

Signed By :           Richel Iran            
SATEC Engineer