

February 13, 2015

VIA ELECTRONIC FILING

Honorable Kathleen H. Burgess
Secretary
New York State Public Service Commission
Three Empire State Plaza
Albany, New York 12223-1350

**Re: Case 04-M-0159 – Proceeding on Motion of the Commission to Examine the
Safety of Electric Transmission and Distribution Systems – 2014 ANNUAL REPORT**

Dear Secretary Burgess:

Niagara Mohawk Power Corporation d/b/a National Grid submits for filing its *2014 Annual Stray Voltage Testing and Facility Inspection Report* in the above proceeding.

Should you have any questions or concerns, please do not hesitate to contact me. Thank you for your time and attention.

Respectfully submitted,

Patric R. O'Brien

Patric R. O'Brien

Attachments

**State of New York
Public Service Commission**

Case 04-M-0159

**Niagara Mohawk Power Corporation
d/b/a National Grid**

Stray Voltage Testing and Facility Inspection

2014 Annual Report

Report on the results of stray voltage testing and facility inspections
for the 12-month period ended December 31, 2014

February 15, 2015

Table of Contents

I.	Background	3
II.	Company Overview	3
III.	Stray Voltage Testing Program	4
IV.	Facility Inspection Program	6
V.	Company Facilities	7
VI.	Annual Performance Targets	8
VII.	Certifications	11
VIII.	Analysis of Causes of Findings and Stray Voltage	11
IX.	Analysis of Inspection Results	12
X.	Quality Assurance	14

I. Background

The New York State Public Service Commission's ("Commission") Electric Safety Standards adopted on January 5, 2005 in Case 04-M-0159, with subsequent revisions issued on July 21, 2005, December 15, 2008, March 22, 2013, and January 13, 2015 (collectively referred to herein as the "Safety Standards" or "Order"), require annual stray voltage testing of certain electric facilities accessible to the public and inspections of utility electric facilities on a minimum of a five-year cycle.

In the March 22, 2013 Order, the Commission revised the annual testing requirement for stray voltage. Under the revision, overhead distribution facilities, underground residential distribution ("URD") facilities, overhead and underground transmission structures, and substation fences that are publicly accessible will be tested for stray voltage at least once every five years. Streetlights and underground distribution facilities will continue to be tested annually.

This report describes Niagara Mohawk Power Corporation's d/b/a National Grid ("Niagara Mohawk" or "Company") stray voltage detection program and facility inspection program conducted for the 12-month period ended December 31, 2014.

II. Company Overview

Niagara Mohawk provides electric service to approximately 1,600,000 customers in a service area of approximately 25,000 square miles in New York State. The Company operates an electric transmission and distribution system. For the stray voltage detection and facility inspection programs, Niagara Mohawk divides its system into subprograms to schedule and track testing and inspections. The subprograms include the Company's (a) distribution overhead system, (b) distribution and transmission underground system, (c) streetlight system, (d) transmission overhead system, and (e) substations.

a. Distribution Overhead System

Niagara Mohawk's distribution overhead system consists of structures supporting circuits energized at voltages of up to 15kV and spans close to 32,000 miles. Stray voltage testing of the distribution system is currently performed by Niagara Mohawk and contractors. Facility inspections of the distribution system are currently performed by the Company's internal workforce and contractors.

b. Distribution and Transmission Underground System

Niagara Mohawk's distribution and transmission underground system is made up of facilities such as manholes, hand-holes, vaults, and switchgear. Fiberglass hand holes are exempt from stray voltage testing under the Safety Standards.¹ Stray voltage testing of the Company's underground system is currently performed by contractors. Facility inspections of the underground system are currently performed by contractors.

¹ See July 21, 2005 Order, at 23; March 22, 2013 Order, at Appendix A, 3(c).

c. Streetlight System

Niagara Mohawk's streetlight system contains underground fed metallic streetlight standards and municipally-owned streetlights and traffic control devices. Overhead fed streetlights on wooden poles are not counted within the streetlight program for stray voltage testing. For the underground fed metallic streetlight standards, contractors perform the stray voltage testing at night when the lights are operational. Stray voltage testing on traffic control devices takes place in conjunction with the contractors' testing of the overhead and underground systems during the daytime hours. The streetlight facility inspections on Company-owned facilities take place during the day and are performed by an external workforce.

d. Transmission Overhead System

Niagara Mohawk's transmission overhead system, which includes the sub-transmission system, consists of structures that support circuits energized at voltages of 12 kV, 23kV, 34.5kV, 46kV, 69kV, 115kV, 230kV, and 345kV. The transmission system spans the entire state and is approximately 8,465 miles in length. Stray voltage testing on the transmission system is performed by Niagara Mohawk and contractors.

e. Substations

There are 908 substations in Niagara Mohawk's service territory. Stray voltage results for substation fences were collected internally by the operating group. The initial dataset identified 908 substation locations to be tested of which a number of these are customer-owned locations.

III. Stray Voltage Testing Program

During the calendar year that ended December 31, 2014, the Company conducted stray voltage testing of 100% of all Company and non-Company owned metallic streetlights and traffic signals and 100% of all publicly accessible Company-owned underground distribution facilities that are capable of conducting electricity. In addition, the Company conducted stray voltage testing of its publicly accessible overhead distribution facilities, URD facilities, overhead and underground transmission structures, and substation fences that are capable of conducting electricity.

In addition, and in compliance with the Safety Standards, Niagara Mohawk:

- a. Immediately safeguarded and/or mitigated all voltage findings ≥ 1.0 volt. In instances where the stray voltage finding was determined to be caused by customer-owned equipment, the area was immediately made safe and the customer or responsible person associated with the premises was notified of the unsafe condition and the need for the customer to arrange for a permanent repair. Voltage findings determined to be caused by a Company-owned facility were immediately safeguarded and/or mitigated. All permanent repairs were made within 45 days.

- b. Tested all publicly accessible structures and sidewalks within a 30 foot radius of the electric facility or streetlight where there was a stray voltage finding ≥ 1.0 volt.
- c. Responded, investigated, and mitigated positive findings of shock incidents reported by the public.

Niagara Mohawk visited 377,218 facilities for stray voltage testing in calendar year 2014. Testing was not required on 96,636 facilities because: the facilities are wood utility poles that have no attached appurtenances capable of conducting electricity; the facilities' electrically conductive appurtenances are not accessible to the public (pre-wired wood); the facilities are enclosed in fiberglass (non-conductive materials); the facilities are de-energized; and/or the facilities are inaccessible to the public.

Inaccessible facilities include:

- a. Locked Gate/Fence – Poles behind locked gates and fences that are not accessible to the public, *i.e.*, facilities located in fenced areas owned by other utilities such as water companies.
- b. Dangerous Grades – Poles located on cliffs and other dangerous grades are generally inaccessible to Company personnel and the general public and are approached only under urgent circumstances. The performance of stray voltage testing on these facilities would constitute an unacceptable risk to the employee.
- c. Company Property – Poles located on Company property such as substations, are accessible only to Company personnel and authorized contractors.
- d. Vaults – Structures located inside buildings. These structures are accessible only to Company and building maintenance personnel.
- e. Limited Access Highway Facilities – Structures located on highways and exit and entrance highway ramps. The performance of stray voltage testing on these structures would constitute an unacceptable risk to the employee.

As required by the Safety Standards, Niagara Mohawk performed 3,243 miles of mobile testing system scans between January 1, 2014 and December 31, 2014. A summary of the results of the mobile testing scans is contained in Appendix 8, which is a copy of the Company's mobile scan report filed with the Commission on December 9, 2014.

IV. Facility Inspection Program

The Safety Standards require Niagara Mohawk to visually inspect approximately 20% of its facilities annually, resulting in a five-year inspection goal for all facilities to be inspected.

Niagara Mohawk visually inspects its overhead distribution and transmission systems on a five-year cycle from the ground, as prescribed by the Safety Standards.

In addition, Niagara Mohawk performs the following inspections, some of which are recurring on specific cycles, some of which are scheduled on an as-needed basis:

- Aerial Infrared – Helicopter-based thermographic imaging of connections and equipment.
- Tower Footing – Embedded support structure that supports a transmission tower.
- Wood Pole – Inspection of the wood pole at and below the ground line.
- Aerial Patrols – Helicopter based visual examination of transmission facilities and equipment.
- Comprehensive Helicopter Patrol – A comprehensive methodical examination of all components comprising the transmission system by helicopter.

Niagara Mohawk’s ground-based visual inspection program is segmented into five categories: distribution facility inspection; underground facility inspections; streetlight inspections; transmission facility inspections; and substation inspections.² Each program is summarized by its associated procedure document. The inspections include visual inspections of the assets to determine if deficiencies exist. Deficiencies are captured by codes entered into handheld computers. Data is then downloaded for review and follow up work.

In accordance with the Safety Standards, Niagara Mohawk uses the following severity levels to establish priority for repairs and scheduling:

- a. Level I – Repair as soon as possible but not longer than one week. A Level I classification represents an actual or imminent safety hazard to the public or a serious and immediate threat to the delivery of power. Critical safety hazards present at the time of the inspection shall be guarded until the hazard is mitigated.
- b. Level II – Repair within one year. A Level II classification represents conditions that are likely to fail prior to the next inspection cycle and represent a threat to safety and/or reliability should a failure occur prior to repair.

² Substation inspections are more complex than those performed on other facilities and differ in variety of ways including, but not limited to: inspection schedules, system that captures inspection data, and work prioritization (supervisory review determines work to be completed versus Levels I-IV). Substation inspection procedure and protocols are provided in Attachment 15 (SMS 400.06.1 entitled “Substation V&O Inspection Standard” and SMP 400.06.2 entitled “Substation V&O Inspection Procedure”).

- c. Level III – Repair within three years. A Level III classification represents conditions that do not present immediate safety or operational concerns and would likely have a minimal impact on the safe and reliable delivery of power should a failure occur prior to repair.
- d. Level IV – A Level IV classification represents conditions found, but repairs are not needed at this time. Level IV is used to track atypical conditions that do not require repair within a five-year timeframe. This level is used for future monitoring purposes and planning proactive maintenance activities.

In accordance with the Safety Standards, when a temporary repair is located during an inspection or is performed by the Company, best efforts are made to make a permanent repair of the facility within 90 days. Temporary repairs that remain on the system for more than 90 days are due to extraordinary circumstances (*i.e.*, storms and outage constraints), and usually require extensive repair activity. Niagara Mohawk has compiled a list of exceptions of temporary repairs that still remain in place after the 90 day requirement. The list and justifications can be found in Appendix 5 of this report.

Niagara Mohawk provides classroom and field training to personnel inspecting facilities in accordance with the Company’s Electric Operating Procedures (“EOPs”). The classroom training covers topics including: EOPs, distribution maintenance inspection and elevated voltage testing training, Computapole handheld training, Computapole database training, distribution vegetation training, geographic information system training, feeder patrols training, and basic electricity training.

The Company provides new distribution inspectors with training upon hiring, with ongoing yearly refresher courses. As part of the refresher training, Niagara Mohawk updates all training materials due for updates from the following year. Specifically, the updates are done yearly using relevant EOPs and Company standards that have been updated.

V. Company Facilities

Niagara Mohawk has approximately 1,538,511 individual facilities that must be visited for stray voltage testing and approximately 1,565,968 individual facilities that require a facility inspection. These facilities are broken down into the following five main categories and are summarized in the tables beginning on page 9:

- a. Distribution Overhead – The Company’s testing criterion for distribution overhead facilities involves testing all Company-owned or jointly-owned wood poles with utility electrical facilities located on both public thoroughfares and customer property, including backyards or alleys. Stray voltage testing is performed on all wooden poles with metallic attachments such as ground wires, ground rods, anchor guy wires, riser pipes, or any electrical equipment within reach of the general public. Distribution overhead facilities are included in both the stray voltage and facility inspection programs.

b. Distribution and Transmission Underground Facilities –The Company’s testing criterion for underground facilities involves testing all subsurface structures, including above ground, pad-mounted structures. Included in the underground facilities are padmount switchgear cases, padmount transformer cases, electric utility manhole covers, submersible transformer covers, electric utility handhole covers, network vaults, and grates. These facilities are included in both the stray voltage and facility inspection programs. Inspections of the underground system involve underground and padmount assets.

c. Streetlights and Traffic Signals – Streetlights include Company-owned metal pole streetlights and municipal-owned metal pole streetlights to which the Company provides service. The testing criterion for streetlights and traffic signals involves testing all metal pole streetlights, traffic signals, and pedestrian crosswalk signals located on publicly accessible thoroughfares. Stray voltage testing of streetlights is performed at night while the fixtures are energized. Privately-owned light fixtures are not included in the stray voltage testing program per the Safety Standards.³ All Company-owned streetlights are included in the facility inspection program.

d. Substation Fences - Niagara Mohawk operates and maintains 908 substation facilities that are necessary for the operation of the electric grid. These substations are fenced in for security, as well as to ensure the safety of the general public. Substation fences are included in the stray voltage testing program.

e. Transmission Overhead Structures – The testing criteria for transmission overhead structures involves testing all structures, guys, and down leads attached to the facilities. Transmission structures support circuit voltages of 12 kV and greater. Transmission poles with distribution underbuild are included in the transmission category. All transmission structures are included in both the stray voltage and facility inspection programs.

VI. Annual Performance Targets

The year ended December 31, 2014 was the fifth and final year of the Company’s stray voltage and inspection Cycle 2 program. The Company met the annual performance target for stray voltage testing of 100% of metallic streetlights and traffic signals and Company-owned underground distribution facilities. In addition, the Company conducted stray voltage testing of 100% of its overhead distribution facilities, URD facilities, overhead and underground transmission structures, and substations during the five year period ended December 31, 2014.

The Company also met the fifth year performance target for inspections of 100% of its electric facilities for the five-year period ended December 31, 2014.

³ March 22, 2013 Order, at Appendix A, §§ 1(d) and 3(a).

The results are summarized in the tables below.

Stray Voltage Testing Results

Elevated Voltage Testing Annual Summary			
Program	Total Units	Units Completed in 2014	% Completed
Distribution**	1,317,338	243,138	18.456
Underground	29,127	29,127	100.000
Streetlights*	86,307	86,307	100.000
Transmission**	104,831	17,738	16.920
Substation	908	908	100.000

*Note: Streetlights include traffic controls but exclude fiberglass standards.

**Note: Pursuant to the March 22, 2013 Order, the Company is required to test 100% of streetlights and underground distribution facilities annually. Overhead distribution facilities, URD facilities, overhead and underground transmission structures, and substation fences are required to be tested at least once every five years.

Facility Inspection Program Results

Category	Total System Units	Units Completed in 2014	Actual Inspected in 2014
Overhead Distribution	1,238,759	229,300	18.510%
Overhead Transmission	102,419	18,889	18.442%
Underground	93,171	19,124	20.525%
Pad-mounted Transformers	65,781	12,308	18.710%
Streetlights	65,838	13,623	20.691%
TOTAL	1,565,968	293,244	18.726%

Inspection Performance Summary

Overhead Distribution Facilities

Inspection Year	Number of Overhead Distribution Structures Inspected	% of Overall System Inspected (Cumulative)
2010	232,604	19%
2011	246,005	20%
2012	266,755	22%
2013	265,168	21%
2014	229,300	18%

Overhead Transmission Facilities

Inspection Year	Number of Overhead Transmission Facilities Inspected	% of Overall System Inspected (Cumulative)
2010	20,369	21%
2011	27,148	26%
2012	24,913	24%
2013	21,457	20%
2014	18,889	18%

Underground Facilities

Inspection Year	Number of Underground Facilities Inspected	% of Overall System Inspected (Cumulative)
2010	17,624	20%
2011	19,987	21%
2012	19,128	20%
2013	24,845	26%
2014	19,124	20%

Padmount Transformers

Inspection Year	Number of Padmount Transformers Inspected	% of Overall System Inspected (Cumulative)
2010	10,619	17%
2011	12,846	20%
2012	12,861	20%
2013	17,190	26%
2014	12,308	18%

Streetlights

Inspection Year	Number of Streetlights Inspected	% of Overall System Inspected (Cumulative)
2010	5,200	8%
2011	35,733	54%
2012	14,996	23%
2013	12,688	19%
2014	13,623	20%

VII. Certifications

Pursuant to Section 7 of Appendix A of the Safety Standards, the president or officer of each utility with direct responsibility for overseeing stray voltage testing and facility inspections shall provide an annual certification to the Commission that the utility has, to the best of his or her knowledge, exercised due diligence in carrying out a plan, including quality assurance, that is designed to meet the stray voltage testing and inspection requirements, and that the utility has:

- Tested its publicly accessible electric facilities and street lights in accordance with the Safety Standards, and
- Inspected the requisite number of electric facilities.

The certifications are attached as Appendix 17 to this report.

VIII. Analysis of Causes of Findings and Stray Voltage

The Safety Standards require the electric utilities to perform an inventory on all stray voltage findings and report on the number of these findings each year. Section 1(f) of the December 15, 2008 Order defines a finding as “[a]ny confirmed voltage reading on an electric facility or streetlight greater than or equal to 1 volt measured using a volt meter and 500 ohm shunt resistor.” Section 1(c) defines stray voltage as “[v]oltage conditions on electric facilities that should not ordinarily exist. These conditions may be due to one or more factors, including, but not limited to, damaged cables, deteriorated, frayed, or missing insulation, improper maintenance, or improper installation.” Utilities are required to report on all findings whether or not the voltage is normal to the electric system.

Niagara Mohawk identified 67 instances of stray voltage during the Company’s manual stray voltage testing program in 2014. These voltages resulted from a variety of conditions including: deterioration of conductors; age of equipment; exposure to the elements; and various customer related issues. A majority (48) of stray voltage conditions identified were on transmission structures. Down grounds was the leading cause of stray voltage findings.

The following table contains a breakdown of the causes of stray voltage findings identified through the Company’s 2014 manual testing effort. Niagara Mohawk has repaired and/or mitigated all findings that were determined to be hazardous. Mobile testing findings are addressed in the Mobile Stray Voltage Testing Report attached as Appendix 8.

Structure Type	Cause of Stray Voltage	Stray Voltages Found
Distribution	Cable & Ground	1
Distribution	Cable Feed	1
Distribution	Down Ground	1
Distribution	Equip Other	5
Distribution	Ground Connection	1
Distribution	Guy	5

Distribution	Induce Voltage	1
Street Lights – Traffic Signals	Cable & Ground	1
Street Lights – Traffic Signals	Cable Feed	2
Street Lights – Traffic Signals	Equip Other	1
Transmission	Down Ground	40
Transmission	Poor Insulation	1
Transmission	Ground Connection	1
Transmission	Induce Voltage	1
Transmission	None Required	2
Transmission	Guy	3
TOTAL		67

In accordance with the Safety Standards, when Niagara Mohawk discovered a finding on an electric facility or streetlight during stray voltage testing, the Company tested all publicly accessible structures and sidewalks within a minimum 30 foot radius of the electric facility or streetlight. Niagara Mohawk did not identify any additional findings associated with the initial test structure as a result of the 30-foot radius testing.

IX. Analysis of Inspection Results

Note: Total Number of Deficiencies may add up to more than the total Locations with Deficiencies due to deficiencies on multiple facilities at a single location.

Overhead Distribution Structures

Table of Locations with Deficiencies

Locations Inspected	Locations w/ Deficiencies	% Locations w/ Deficiencies
229,300	125,746	54.839%

Breakdown of Locations with Deficiencies

Priority Rating	Number of Deficiencies	% Deficiencies Found
1	416	0.164%
2	22,932	9.051%
3	33,351	13.164%
4	196,653	77.621%
Total:	253,352	100.000%

Overhead Transmission Facilities

Table of Locations with Deficiencies

Locations Inspected	Locations w/ Deficiencies	% Locations w/ Deficiencies
18,889	12,007	63.566%

Breakdown of Locations with Deficiencies

Priority Rating	Number of Deficiencies	% Deficiencies Found
1	10	0.046%
2	526	2.404%
3	2,423	11.072%
4	18,925	86.479%
Total:	21,884	100.000%

Underground Facilities

Table of Locations with Deficiencies

Locations Inspected	Locations w/ Deficiencies	% Locations w/ Deficiencies
19,124	10,451	54.649%

Breakdown of Locations with Deficiencies

Priority Rating	Number of Deficiencies	% Deficiencies Found
1	125	1.253%
2	999	10.017%
3	276	2.767%
4	8,573	85.962%
Total:	9,973	100.000%

Pad-mount Transformers

Table of Locations with Deficiencies

Locations Inspected	Locations w/ Deficiencies	% Locations w/ Deficiencies
12,308	2,976	24.179%

Breakdown of Locations with Deficiencies

Priority Rating	Number of Deficiencies	% Deficiencies Found
1	36	0.544%
2	446	6.741%
3	0	0.000%
4	6,134	92.715%
Total:	6,616	100.000%

Streetlights

Table of Locations with Deficiencies

Locations Inspected	Locations w/ Deficiencies	% Locations w/ Deficiencies
13,623	5,728	42.047%

Breakdown of Locations with Deficiencies

Priority Rating	Number of Deficiencies	% Deficiencies Found
1	0	0.000%
2	159	1.953%
3	18	0.221%
4	7,964	97.826%
Total:	8,141	100.000%

In 2014, Niagara Mohawk identified an overall total of 299,966 deficiencies:

- Priority Rating 1 Total = 587, or 0.196% of the overall total.
- Priority Rating 2 Total = 25,062, or 8.355% of the overall total.
- Priority Rating 3 Total = 36,068, or 12.024% of the overall total.
- Priority Rating 4 Total = 238,249 (inventory), or 79.425% of the overall total.

X. Quality Assurance

Electric Quality Assurance/Quality Control Program

National Grid's Elevated Voltage ("EV") and Visual Inspection & Maintenance ("I&M") Quality Assurance/Quality Control program ("QA/QC") provides for increased program continuity, monthly audits for monitoring of program performance, and assurance that a Quality Assurance/Quality Control program independent of the EV and I&M work groups is maintained.

Separate of the independent Electric QA/QC program, Quality Control (“QC”) audits are conducted by National Grid I&M supervisory staff. The purpose of the QC audits is to self-validate recorded findings involving all distribution, transmission, and sub-transmission assets that have been inspected for identifying potential maintenance codes and elevated voltage issues. Conversely, the independent Electric QA/QC program encompasses a quantitative random sampling of the entire population of inspection results derived from the field assessed EV testing and I&M inspections.

The Electric QA/QC program made the following revision in 2014:

- I&M validation accuracy calculation was revised, with the new calculation calculating the number of Risks levels per Maintenance code as opposed to Structure counts.
 - Example: The asset inspection reveals that the field inspector recorded five (5) maintenance codes, the QA/QC auditor agrees to four of the five codes, and assigns a risk level to the one incorrect maintenance code. The field inspector will receive partial credit for four out of five as opposed to failing the whole inspection. This approach targets on the maintenance codes that are incorrect or missed and credits the findings that the field inspector recorded during inspection.

I&M Risk Levels Identified: The analysis of the QA/QC I&M Program data is intended to identify the nature and magnitude of Risk Level 1 and 2 as applicable to the I&M Program results.

Electric QA/QC I&M Risk Level Definitions
QA/QC program involves performing an additional QA/QC audit of randomly-selected assets having been previously assessed by the field inspector, with the intent of verifying previously identified maintenance codes.
<p><u>Risk 1</u></p> <ul style="list-style-type: none"> • Reliability/Safety Concern. • Identified facility/component repaired or replaced within one week of the inspection date.
<p><u>Risk 2</u></p> <ul style="list-style-type: none"> • Facility/component condition that must be repaired/replaced within one year. • QA/QC identification of maintenance codes which may affect reliability.
<p><u>Risk 3</u></p> <ul style="list-style-type: none"> • Facility/component condition that must be repaired/replaced within three years. • QA/QC identification of maintenance codes which may not affect reliability. • The QA/QC inspector determined the original I&M inspector’s maintenance code was incorrect. • The independent field inspector determines a data quality issue.

Electric QA/QC Program – Asset Inspection & Maintenance Audits

The National Grid Electric QA/QC group audited (3,699) distribution, transmission and sub-transmission assets that had been field inspected for maintenance during 2014. The method used to confirm and/or achieve the required quality of asset audits involved follow-up field audits by QA/QC personnel through a monthly random sample, with the intent of verifying identified maintenance codes derived from the population of assets inspected by field force operations during calendar year 2014. This process captured incorrect or missed maintenance codes, and noted timeliness of repairs when evident. In order to achieve a minimum 95% level of confidence, applicable to the entire population of inspection data and resulting random sample analysis, commonly applied statistical principles were utilized to conduct the audit process.

The National Grid Electric QA/QC field audit process is designed to validate the field inspector findings. Results are considered to be passing when there is a match between the field inspection maintenance codes and QA/QC follow-up audit results. Based upon the accrued inspection data provided by the Company’s Inspections Department, and the findings identified through follow-up QA/QC process, the overall accuracy of field inspection findings that impacts reliability (Risk 1 and Risk 2), was validated at **96%**.

2014 Field Inspection I&M Program:

The population and breakdown of assets inspected by field force operations during calendar year 2014 is as follows:

- Distribution: 229,300 (locations)
- Transmission: 8,864
- Sub-transmission: 10,024

Electric QA/QC I&M Audit Results

The following table illustrates the validation accuracy percentages related to system reliability concerns (Risk Levels 1&2 findings) identified through QA/QC process during calendar year 2014

2014 I&M Results – QA/QC Audits Risk Levels 1& 2

<u>Asset Category</u>	<u>QA/QC Audits</u>	<u>QA/QC Risk Levels</u>	<u>Validation Accuracy (%)</u>
	Total Maintenance Codes		
Distribution	5,370	Risk 1 = 2 Risk 2 = 218 Total = 220	96%

Sub-Transmission	191	Risk1 = 0 Risk 2 = 0 Total = 0	100%
Transmission	183	Risk 1 = 0 Risk2 = 10 Total = 10	95%
Totals	5,744	230	96%

Electric QA/QC I&M Audit Analysis

National Grid desires a minimum threshold for inspection validation accuracy at 95%. QA/QC analysis of regional findings by additional maintenance codes is conducted for the purpose of determining percent validated accuracy of maintenance code trending for a particular region.

QA/QC Validated Accuracy (VA) Percentage = Total # of MCodes ÷ Total Sample size

- If the validation accuracy is less than 95% to 90%, the electric QA/QC group will conduct further analysis of accrued data for potential trending. Operations will be responsible for corrective action, where applicable.
- If the validation accuracy is less than 90%, Operations is responsible for further trending analysis and/or corrective action and implantation plan to improve field force inspections.

Electric QA/QC Risk Analysis- Distribution Maintenance Code Audits Results

Regions	Distribution			Validation Accuracy	Electric QA/QC Additional Analysis Required	Operations Corrective Action Required
	MCod e	QA/QC Addition al MCodes Reporte d	Total Sampl e Size Audit ed	Percentag e	>90% and <95%	<90%
Region 48	212	22	319	93%	YES	
	225	50	319	84%		YES
Region 50	212	22	395	94%	YES	
	225	25	395	94%	YES	
Region 51	225	18	251	93%	YES	
Region 54	N/A	N/A	756	N/A	N/A	N/A

Region 56	118	23	349	93%	YES	
Region 57	N/A	N/A	519	N/A	N/A	N/A
Region 60	N/A	N/A	1690	N/A	N/A	N/A
Region 62	N/A	N/A	1091	N/A	N/A	N/A

Note: In regions where QA/QC field audits validated the minimum confidence level to have been met or exceeded, no additional analysis or corrective action is required (N/A).

Electric QA/QC Risk Analysis - Sub-Transmission Maintenance Code Audits Results

Regions	Sub-Transmission Maintenance Codes			Validation Accuracy	Electric QAQC Additional Analysis Required	Operations Corrective Action Required
	MCod e	QAQC Additional MCodes Reported	Total Sample Size Audited	Percentage	>90% and <95%	<90%
Region 48	N/A	N/A	0	N/A	N/A	N/A
Region 50	584	13	19	32%		YES
	591	8	19	58%		YES
Region 51	584	21	25	16%		YES
Region 54	N/A	0	25	100%		
Region 56	N/A	N/A	6	N/A	N/A	N/A
Region 57	N/A	N/A	63	N/A	N/A	N/A
Region 60	N/A	N/A	24	N/A	N/A	N/A
Region 62	N/A	N/A	8	N/A	N/A	N/A

Electric QA/QC Risk Analysis- Transmission Maintenance Code Audits Results

Regions	Transmission Maintenance Codes			Validation Accuracy	Electric QA/QC Additional Analysis Required	Operations Corrective Action Required
	MCode	QAQC Addition al MCodes Reporte d	Total Sample Size Audite d	Percentage	>90% and <95%	<90%
Region 48	N/A	N/A	13	N/A	N/A	N/A
Region 50	528	5	41	88%		YES
	543	3	41	93%	YES	
	581	6	41	85%		YES

	584	3	41	93%	YES	
Region 51	N/A	N/A	N/A	N/A	N/A	N/A
Region 54	N/A	N/A	N/A	N/A	N/A	N/A
Region 56	528	7	14	50%		YES
Region 57	N/A	N/A	N/A	N/A	N/A	N/A
Region 60	N/A	N/A	N/A	N/A	N/A	N/A
Region 61	N/A	N/A	96	N/A	N/A	N/A

I&M Results – Repairs

Per the Safety Standards, the QA/QC program is responsible for verifying permanent repairs that have been made in response to field force operations inspections performed, along with the timeliness of the repair. The 2013 field force inspection process yielded the following asset deficiencies and repair activities for I&M defined Level 1, Level 2, Level 3, and Level 4 priorities:

Summary of Deficiencies and Repair Activity Resulting from the Inspection Process

Year	Priority Level / Repair Expected	Deficiencies Found (Total)	Repaired Within Required Time Frame	Repaired Past Required Due Date	Not Repaired and Not Due	Not Repaired – Overdue
2014						
	I Within 1 week	587	578	5	0	4
	II Within 1 year	25062	2540	13	22406	103
	III Within 3 years	36068	705	0	35363	0
	IV N/A	238249	53197	0	185052	0
	Temp Repairs Within 90 days	170	162	2	0	6

QA/QC I&M Results – Level 1 Repairs

The QA/QC group performed thirty-five (35) Level 1 follow-up field audits and validated that the repairs were completed within the required time frame.

Electric QA/QC Program – Elevated Voltage (EV)

The National Grid 2014 EV field inspection program targeted an overall minimum confidence level of 95% applicable to field force operations inspection of its distribution, underground, transmission and sub-transmission assets. Additionally, a minimum confidence level of 98% should be realized for tested streetlights. The inspection process requires elevated voltage testing be conducted for each utility asset that is capable of conducting electricity and is publicly accessible. In order for each QA/QC EV audit to have successfully “passed”, the following test parameters must be validated:

- The voltage recording shall be below established regulatory thresholds (\leq 1 volt or mitigated).

- All assets having a “testable object” were in fact tested by the field Inspector.

EV Risks Identified: The analysis of the QA/QC EV Program data is intended to identify the nature and magnitude of Risk 1 & 2 as applicable to the EV Program results.

Electric QA/QC EV Risk Level Definitions	
QA/QC program methodology involved performing an additional QA/QC audit of randomly-selected assets having been previously tested by field inspector. In order for the QA/QC test to have ‘passed’, it must confirm that all assets having a ‘testable object’ were in fact tested.	
<u>Risk 1</u>	
<ul style="list-style-type: none"> • An elevated voltage reading was indentified by the EV field tester and the independent QA/QC audit found the voltage not mitigated below regulatory/company thresholds after the forty-five (45) days. • The QA/QC inspector measured a voltage that exceeds the regulatory/company thresholds greater than or equal to <u>1 volt</u>. 	
<u>Risk 2</u>	
<ul style="list-style-type: none"> • The EV field tester determined there was not a testable object, and the independent QA/QC inspector identifies a testable component existed at the audited asset. • The EV field tester determined there was in fact a testable component and the independent QA/QC audit revealed no testable component at the audited asset. 	
<u>Risk 3</u>	
<ul style="list-style-type: none"> • The EV field tester and or the independent QA/QC field inspector deem the structure inaccessible or non-testable. • The independent QA field inspector determines a data quality issue. • Reasonable effort to effectively eliminate the stray voltage condition on overhead sub-transmission or transmission structures was attempted, but in some cases cannot achieve a reading of 1 volt or less after mitigation due to neutral currents and induced voltages. 	

The National Grid Electric QA/QC group performed 3,486 EV audits pertaining to distribution, transmission and sub-transmission elevated voltage assets during 2014 across the eight (8) operating regions.

Total QA/QC EV Audit Population

Upstate NY Regions	QA/QC Audit Totals
Region 48	680
Region 50	230
Region 51	172
Region 54	633
Region 56	187
Region 57	339
Region 60	557
Region 62	688

Total	3,486
--------------	--------------

Total QA/QC EV Inspections Totals by Category Type

<u>Category Type</u>	<u>Region 48</u>	<u>Region 50</u>	<u>Region 51</u>	<u>Region 54</u>	<u>Region 56</u>	<u>Region 57</u>	<u>Region 60</u>	<u>Region 62</u>	<u>Totals</u>
Distribution	231	200	149	454	169	327	405	590	2525
Underground	0	0	0	10	0	0	23	6	39
Sub Trans	0	9	23	0	12	12	0	14	70
Transmission	11	21	0	16	6	0	0	21	75
Streetlights	438	0	0	153	0	0	129	57	777
Totals	680	230	172	633	187	339	557	688	3,486

EV Results – QA/QC Asset Inspections

Risk 1 Level

The National Grid 2014 QA/QC EV audits achieved an overall confidence level of **99%** for Risk 1 level for distribution, underground, transmission and sub-transmission assets.

$$\begin{aligned}
 \text{Validated Accuracy \%} &= \text{Total \# of Risks} \div \text{Total Sample size (100)} - 100 \\
 &= (1/2709) \\
 &= (.0004 \times 100) - 100 \\
 &= 99.9
 \end{aligned}$$

Additionally, an overall confidence level of **99%** for Risk 1 Level was achieved for the electric QA/QC EV streetlight/traffic control audits.

$$\begin{aligned}
 \text{Validated Accuracy \%} &= \text{Total \# of Risks} \div \text{Total Sample size (100)} - 100 \\
 &= (6/777) \\
 &= (.0077 \times 100) - 100 \\
 &= 99.2
 \end{aligned}$$

QA/QC Summary of Risk 1 Level Identified

<u>Category Type</u>	<u>Region 48</u>	<u>Region 50</u>	<u>Region 51</u>	<u>Region 54</u>	<u>Region 56</u>	<u>Region 57</u>	<u>Region 60</u>	<u>Region 62</u>	<u>Total</u>
Distribution	0	0	0	1	0	0	0	0	1
Underground	0	0	0	0	0	0	0	0	0

Transmission	0	0	0	0	0	0	0	0	0
Sub Trans	0	0	0	0	0	0	0	0	0
Streetlights	0	0	0	0	0	0	6	0	6
Totals	0	0	0	1	0	0	6	0	7

Risk 2& 3 Levels

A total of 361 QA/QC EV audits (approximately 10% of 3,486 audits performed) resulted in Risk 2 and Risk 3 levels being identified. An analysis of the QA/QC data verified 89% accuracy of identification of testable components.

QA/QC Summary of Risk Level 2 & 3 Conditions Identified

<u>Category Type</u>	Region 48	Region 50	Region 51	Region 54	Region 56	Region 57	Region 60	Region 62	<u>Total</u>
Distribution	70	52	18	16	19	27	43	26	271
Underground	0	0	0	0	0	0	1	0	1
Transmission	1	0	0	4	0	0	0	0	5
Sub Trans	0	5	14	0	0	0	0	12	31
Streetlights	10	0	0	0	0	0	4	39	53
Totals	81	57	32	20	19	27	48	77	361

Analysis of Asset EV Audits

Category Type: Distribution, Underground, Sub-Transmission & Transmission

- If the validation accuracy range is 90% to 95% (Distribution, Underground, Sub-Transmission & Transmission), the electric QA/QC group will conduct further analysis of accrued data for potential trending. Operations will be responsible for corrective action where applicable.
- If the validation accuracy is less than 90% (Distribution, Underground, Sub-Transmission & Transmission), Operations is responsible for further trending analysis and/or corrective action and implantation plan to improve field force inspections.

Risk Levels 1 & 2 EV Distribution, Sub-T & Transmission findings per Region

Regions	Distribution Sub-Transmission & Transmission			Validation Accuracy Percentage	Electric QAQC Additional Analysis Required >90% and ≤95%	Operations Corrective Action Required <90%
	Risk 1	Risk 2	Total Audits			
Region 48	0	69	242	71%		YES
Region 50	0	57	230	75%		YES
Region 51	0	32	172	81%		YES
Region 54	1	15	480	97%	N/A	N/A
Region 56	0	19	121	84%		YES
Region 57	0	25	339	93%	YES	
Region 60	0	44	428	90%	YES	
Region 62	0	38	631	94%	YES	

Note: In regions where QA/QC field audits validated the minimum confidence level to have been met or exceeded, no additional analysis or corrective action is required (N/A).

QA/QC Analysis of Asset EV Audits

Category Type: Streetlights & Traffic Controls

- If the validation accuracy range is 95% to 98% (Street Lights & Traffic Controls), the electric QA/QC group will conduct further analysis of accrued data for potential trending. Operations will be responsible for corrective action, where applicable.
- If the validation accuracy is less than 95% (Street Lights & Traffic Controls), Operations is responsible for further trending analysis and/or corrective action and implantation plan to improve field force inspections

QA/QC Risk Levels 1 & 2 EV Streetlight & Traffic control findings per Region

Regions	Street Lights & Traffic Controls			Validation Accuracy	Electric QAQC Additional Analysis Required	Operations Corrective Action Required
	Risk 1	Risk 2	Total Audits	Percentage	>95% and ≤98%	<95%
Region 48	0	10	438	98%	N/A	N/A
Region 50	0	0	0	N/A	N/A	N/A
Region 51	0	0	0	N/A	N/A	N/A
Region 54	0	0	153	100%	N/A	N/A
Region 56	0	0	0	N/A	N/A	N/A
Region 57	0	0	0	N/A	N/A	N/A
Region 60	6	4	129	92%		YES
Region 62	0	0	57	100%	N/A	N/A

Summary

QA/QC Asset Audit (I&M) Program

The Company’s electric QA/QC analysis of the additional maintenance codes missed (defects) conducted in 2014 concluded the following:

Distribution

Maintenance Code 225 (Guy not bonded/Isolated per Company Standards) was missed repetitively (41% of the entire defects sample size). QA/QC discovered ninety-three (93) errors applicable to Maintenance Code 225.

Sub-transmission

Maintenance Code 584 (Install/Replace Warning Sign) was missed repetitively (19% of the entire defects sample size). QA/QC discovered thirty-four (34) errors applicable to Maintenance Code 584.

Maintenance Code 591 (Misc – Distribution Underbuilt) was missed repetitively (81% of the entire defects sample size). QA/QC discovered eight (8) errors applicable to Maintenance Code 591.

Transmission

Maintenance Code 528 (Aerial Number Missing) was missed repetitively (71% of the entire defects sample size). QA/QC discovered seven (7) errors applicable to Maintenance Code 528.

Action item:

The Electric QA/QC and Electric Operations conducted further analysis of the data file and additional investigation into identification of deficiency causal factors. Corrective actions have been assigned to the appropriate regional inspection groups. Additional investigation into causal factors associated with missed/incorrect Maintenance Codes 225,528,584 & 591 is required.

QA/QC Asset Inspection (EV) Program

A total of one (1) Distribution EV Risk Level 1 deficiency was identified through the QA/QC audit process. Based upon the validated accuracy of QA/QC audit findings (99% accuracy), further analysis of the accrued QA/QC EV inspection data is not warranted.

Action Item: N/A

A total of six (6) Streetlight EV Risk Level 1's were identified through the QA/QC audit process. Based upon the validated accuracy of QA/QC audit findings (99% accuracy), further analysis of the accrued QA/QC EV inspection data is not warranted.

Action Item: N/A

EV Data Quality Deficiencies:

A total of thirty-nine (39) QA/QC audits resulted in a data quality problem being realized. The issue involved the EV field inspector having determined that a testable object had been identified as non-testable. In each of these instances, the follow-up QA/QC field audit verified the asset as a testable object. An analysis of the data concluded that all of these Data Quality failures were related to the EV field inspector's interpretation of how the data is recorded.

Action Item: National Grid Electric QA/QC group has submitted a corrective action to Inspection and maintenance compliance team for resolution.

APPENDIX SUMMARY

Appendix 1: Stray Voltage Testing Summary

Appendix 2: Summary of Energized Objects

Appendix 3: Summary of Shock Reports from the Public

Appendix 4: Summary of Deficiencies and Repair Activity Resulting from the Inspection Process

Appendix 5: Temporary Repair Exceptions

Appendix 6: Inspections Summary

Appendix 7: Summary of Overdue Repairs

Appendix 8: Mobile Testing

Appendix 9: NG-USA EOP G016 Elevated Equipment Voltage Testing

Appendix 10: NG-USA EOP D004 Distribution Line Patrol and Maintenance

Appendix 11: NG-USA EOP UG006 Underground Inspection and Maintenance

Appendix 12: NG-USA PR 06.01.601.001 Transmission Line Maintenance Procedure

Appendix 13: NG-USA EOP G017 Street Light Standard Inspection Program

Appendix 14: NG-USA EOP G004 Shock Complaints

Appendix 15: NG-USA SMS 400.06.1 Substation V&O Inspection Standard and SMP 400.06.2 Substation Inspection Procedure

Appendix 16: NG-USA EOP G029 Tracking Temporary Repairs To Electric System

Appendix 17: Certifications

Appendix 1

Stray Voltage Testing Summary

Appendix 1

Stray Voltage Testing Summary

nationalgrid	Total System Units Requiring Testing	Units Completed	Percent Completed	Units with Voltage Found (>= 1.0v)	Percent of Units Tested with Voltage (>= 1.0v)	Units Classified as Inaccessible
Testing Summary						
Distribution Facilities	1,317,338	243,138	18.46%	15	0.006%	3,406
Monthly Update		399	0.03%		0.000%	21
Underground Facilities	29,127	29,127	100.00%		0.000%	1,063
Monthly Update		403	1.38%		0.000%	35
Street Lights / Traffic Signals	86,307	86,307	100.00%	4	0.005%	800
Monthly Update		7,259	8.41%		0.000%	168
Substation Fences	908	908	100.00%			
Monthly Update		79	8.70%			
Transmission	104,831	17,738	16.92%	48	0.27%	75
Monthly Update		6	0.01%		0.00%	
TOTAL	1,538,511	377,218	24.52%	67	0.02%	5,344
Monthly Update		8,067	0.52%		0.00%	224

Appendix 2

Summary of Energized Objects

Appendix 2

Summary of Energized Objects (Manual Testing)

nationalgrid	Initial Readings				Readings After Mitigation		
	1 - 4.4 V	4.5 - 24.9 V	> 25 V	Total	< 1 V	1 - 4.4 V	> 4.5 V
Distribution Facilities	7	5	3	15	15	0	0
Pole (910)	0	1	3	4	4	0	0
Ground (914)	1	1	0	2	2	0	0
Guy (915)	5	2	1	8	8	0	0
Riser (916)	1	1	0	2	2	0	0
Other	0	1	0	1	1	0	0
Underground Facilities	0	0	0	0	0	0	0
Handhole / Pull box (950)	0	0	0	0	0	0	0
Manhole (951)	0	0	0	0	0	0	0
Padmount Switchgear (952)	0	0	0	0	0	0	0
Padmount Transformer (953)	0	0	0	0	0	0	0
Vault – Cover/Door (954)	0	0	0	0	0	0	0
Pedestal	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0
Street Lights / Traffic Signals	3	0	1	4	4	0	0
Metal Street Light Pole (971/981)	2	0	1	3	3	0	0
Traffic Signal Pole (991)	0	0	0	0	0	0	0
Control Box (992)	0	0	0	0	0	0	0
Pedestrian Crossing Pole (993)	0	0	0	0	0	0	0
Other	2	0	0	2	2	0	0
Substation Fences	0	0	0	0	0	0	0
Fence (995)	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0
Transmission	46	2	0	48	16	31	1
Lattice Tower (931)	2	0	0	2	1	1	0
Pole (930)	0	0	0	0	0	0	0
Ground (933)	39	2	0	41	14	26	1
Guy (934)	1	0	0	1	0	1	0
Other	6	0	0	6	1	5	0
Totals	56	7	4	67	35	31	1

NOTE - National Grid is only mitigating those locations where voltage is confirmed to be 1.0 volts or greater

NOTE - Individual facility counts (pole, ground, guy, etc) may add up to more than the total on a summary line due to voltage on multiple facilities at a single location or pole

NOTE - "Other" category generally includes incorrect facility types reported (example - a pole code turned in for voltage found on an underground device).


NOTE - 'Readings after Mitigation' total reflects only permanent repairs made. Temporary repairs will be made permanent within 45 days.


Appendix 3


Summary of Shock Reports from the Public


Appendix 3

Summary of Shock Reports from the Public

 2014 1st Quarter January 1, 2014 - March 31, 2014	Quarterly Update	Yearly Total
I. Total shock calls received:	33	33
Unsubstantiated	4	4
Normally Energized Equipment	3	3
Stray Voltage:		
Person	25	25
Animal	1	1
II. Injuries Sustained/Medical Attention Received Due To SV		
Person	4	4
Animal		
III. Voltage Source:	26	26
Utility Responsibility		
Issue with primary, joint, or transformer		
Secondary joint (Crab)		
SL service Line		
Abandoned SL service line		
Defective service line		
Abandoned service line		
OH Secondary		
OH Service	4	4
OH Service neutral	2	2
Pole		
Riser		
Other		
Customer Responsibility		
Contractor damage		
Customer equipment/wiring	19	19
Other Utility/Gov't Agency Responsibility		
SL Base Connection		
SL Internal wiring or light fixture		
Overhead equipment	1	1
IV. Voltage Range:	26	26
1.0V to 4.4V	4	4
4.5V to 24.9V	1	1
25V and above	2	2
Unknown	19	19

 2014 2nd Quarter April 1, 2014 - June 30, 2014	Quarterly Update	Yearly Total
I. Total shock calls received:	49	82
Unsubstantiated Normally Energized Equipment Stray Voltage: Person Animal	5 7 35 2	9 10 60 3
II. Injuries Sustained/Medical Attention Received Due To SV		
Person Animal	2 5	6 5
III. Voltage Source:	37	63
Utility Responsibility Issue with primary, joint, or transformer Secondary joint (Crab) SL service Line Abandoned SL service line Defective service line Abandoned service line OH Secondary OH Service OH Service neutral Pole Riser Other Customer Responsibility Contractor damage Customer equipment/wiring Other Utility/Gov't Agency Responsibility SL Base Connection SL Internal wiring or light fixture Overhead equipment	4 2 2 1 28 0	4 6 4 1 47 1
IV. Voltage Range:	37	63
1.0V to 4.4V 4.5V to 24.9V 25V and above Unknown	1 3 5 28	5 4 7 47

 2014 3rd Quarter July 1, 2014 - September 30, 2014	Quarterly Update	Yearly Total
I. Total shock calls received:	38	120
Unsubstantiated Normally Energized Equipment Stray Voltage: Person Animal	1 5 31 1	10 15 91 4
II. Injuries Sustained/Medical Attention Received Due To SV		
Person Animal	2	8 5
III. Voltage Source:	32	95
Utility Responsibility Issue with primary, joint, or transformer Secondary joint (Crab) SL service Line Abandoned SL service line Defective service line Abandoned service line OH Secondary OH Service OH Service neutral Pole Riser Other Customer Responsibility Contractor damage Customer equipment/wiring Other Utility/Gov't Agency Responsibility SL Base Connection SL Internal wiring or light fixture Overhead equipment	3 8 3 18	7 14 4 4 65 1
IV. Voltage Range:	32	95
1.0V to 4.4V 4.5V to 24.9V 25V and above Unknown	1 3 6 22	6 7 13 69

 2014 4th Quarter October 1, 2014 - December 31, 2014	Quarterly Update	Yearly Total
I. Total shock calls received:	29	149
Unsubstantiated	1	11
Normally Energized Equipment	5	20
Stray Voltage:		
Person	22	113
Animal	1	5
II. Injuries Sustained/Medical Attention Received Due To SV		
Person	3	11
Animal		5
III. Voltage Source:	23	118
Utility Responsibility		
Issue with primary, joint, or transformer	5	12
Secondary joint (Crab)		
SL service Line		
Abandoned SL service line		
Defective service line		
Abandoned service line		
OH Secondary		
OH Service	1	15
OH Service neutral		4
Pole		
Riser		
Other		4
Customer Responsibility		
Contractor damage		
Customer equipment/wiring	17	82
Other Utility/Gov't Agency Responsibility		
SL Base Connection		
SL Internal wiring or light fixture		
Overhead equipment		1
IV. Voltage Range:	23	118
1.0V to 4.4V	1	7
4.5V to 24.9V	2	9
25V and above	3	16
Unknown	17	86

INCLUDES 1 SHOCK REPORT FROM JUNE/3RD QUARTER CLOSED IN OCTOBER

Appendix 4

Summary of Deficiencies and Repair Activity Resulting from the Inspection Process

Appendix 4

Summary of Deficiencies and Repair Activity Resulting from the Inspection Process

Detail of Deficiencies by Facilities	2010				2011				2012				2013				2014			
	I	II	III	Temp Repairs	I	II	III	Temp Repairs	I	II	III	Temp Repairs	I	II	III	Temp Repairs	I	II	III	Temp Repairs
	Within 1 week	Within 1 year	Within 3 years	Within 90 days	Within 1 week	Within 1 year	Within 3 years	Within 90 days	Within 1 week	Within 1 year	Within 3 years	Within 90 days	Within 1 week	Within 1 year	Within 3 years	Within 90 days	Within 1 week	Within 1 year	Within 3 years	Within 90 days
Overhead Facilities																				
Repaired in Time Frame	334	17877	36199	62	366	23575	16199	83	358	29406	12168	170	326	17877	3216	133	408	2439	676	139
Repaired - Overdue	3	1323	323	11	5	1335	120	7	2	2675	56	12	2	604	0	15	4	13	0	2
Not Repaired - Not Due	0	0	0	0	0	0	0	0	0	0	10700	0	0	0	15871	0	0	20428	32675	0
Not Repaired - Overdue	0	0	1	0	0	0	83	0	0	60	52	0	0	200	0	1	4	52	0	3
Total Overhead Facilities	337	19200	36523	73	371	24910	16402	90	360	32141	22976	182	328	18681	19087	149	416	22932	33351	144
Underground Facilities																				
Repaired in Time Frame	39	1685	201	0	76	1264	286	6	75	1319	122	8	216	641	12	7	124	27	14	13
Repaired - Overdue	0	114	0	0	0	535	2	0	0	426	0	1	6	91	0	3	1	0	0	0
Not Repaired - Not Due	0	0	0	0	0	0	0	0	0	0	38	0	0	0	279	0	0	922	262	0
Not Repaired - Overdue	0	0	1	0	0	0	50	0	0	4	2	0	3	494	0	0	0	50	0	0
Total Underground Facilities	39	1799	202	0	76	1799	338	6	75	1749	162	9	225	1226	291	10	125	999	276	13
Pad Mount Facilities																				
Repaired in Time Frame	31	249	21	1	17	297	1	1	26	259	0	1	42	271	0	4	36	35	0	8
Repaired - Overdue	0	3	0	0	0	16	0	0	0	2	0	0	1	13	0	1	0	0	0	0
Not Repaired - Not Due	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	411	0	0
Not Repaired - Overdue	0	0	0	0	0	0	0	0	0	1	0	0	0	52	0	0	0	0	0	0
Total Pad Mount Facilities	31	252	21	1	17	313	1	1	26	262	1	1	43	336	0	5	36	446	0	8
Streetlight Facilities																				
Repaired in Time Frame	2309	6	0	0	1	686	11	0	0	393	0	0	0	547	0	0	0	0	0	0
Repaired - Overdue	0	0	0	0	0	16	0	0	8	58	0	0	0	53	0	0	0	0	0	0
Not Repaired - Not Due	0	0	0	0	0	0	0	0	0	0	1	0	0	0	1	0	0	159	18	0
Not Repaired - Overdue	0	0	0	0	0	19	2	0	0	22	0	0	0	35	0	0	0	0	0	0
Total Streetlight Facilities	2309	6	0	0	1	721	13	0	8	473	1	0	0	635	1	0	0	159	18	0
Transmission Facilities																				
Repaired in Time Frame	10	144	942	2	24	224	1974	3	21	497	480	1	13	257	38	0	10	39	15	2
Repaired - Overdue	1	31	229	4	2	74	167	6	0	96	0	2	2	53	0	0	0	0	0	0
Not Repaired - Not Due	0	0	0	0	0	0	0	0	0	0	2500	0	0	0	1328	0	0	486	2408	0
Not Repaired - Overdue	0	3	157	0	0	40	385	3	0	43	104	0	0	96	0	0	0	1	0	3
Total Transmission Facilities	11	178	1328	6	26	338	2526	12	21	636	3084	3	15	406	1366	0	10	526	2423	5

Summary of Deficiencies and Repair Activity Resulting from the Inspection Process - Level IV Conditons										
Overhead Facilities	2010		2011		2012		2013		2014	
	Number of Conditions Found	Number of Conditions Repaired	Number of Conditions Found	Number of Conditions Repaired	Number of Conditions Found	Number of Conditions Repaired	Number of Conditions Found	Number of Conditions Repaired	Number of Conditions Found	Number of Conditions Repaired
Overhead Facilities										
Pole Condition										
Pole Condition	28408	20207	26344	16894	38686	26654	45209	27250	56643	34521
Grounding System	71189	3	12666	0	31762	3	34692	0	44692	8
Anchors/Guy Wire	44883	18413	48642	13223	56924	16883	52345	13552	56116	9290
Cross Arm/Bracing	16354	2	2103	1	2335	0	1656	0	1284	0
Riser	0	0	0	0	0	0	1	0	1	0
Conductors										
Primary Wire/Broken Ties	1198	0	1044	0	916	0	879	0	0	0
Secondary Wire	445	0	1	0	1	0	1	0	1	0
Neutral	0	0	0	0	0	0	0	0	0	0
Insulators	18864	3	9084	1	8502	0	6548	1	5679	0
Pole Equipment										
Transformers	28923	359	24968	29	26794	110	26461	15	22258	3
Cutouts	23815	1	28359	1	35711	2	42126	1	3383	3
Lightning Arrestors	1685	0	2818	0	2741	1	2440	0	3155	0
Other Equipment	11964	0	370	0	411	1	382	1	359	0
Miscellaneous										
Trimming Related	2006	1335	1669	1285	2045	1816	2227	399	3013	14
Other	27	1	46	0	57	0	14	0	69	0
Overhead Facilities Total	249761	40324	158114	31434	206885	45470	214981	41219	196653	43839
Transmission Facilities										
Towers/Poles										
Steel Towers	169	8	199	0	316	0	144	2	777	49
Poles	856	4	3499	11	2743	2	2923	2	1948	0
Anchors/Guy Wire	595	224	224	213	737	447	921	603	742	397
Crossarm/Brace	1	0	0	0	0	0	0	0	0	0
Grounding System	47	7	43	0	40	0	17	0	1071	0
Conductors										
Cable	14	0	9	0	37	0	15	0	24	0
Static/Neutral	0	0	0	0	2	0				
Insulators	205	1	138	0	245	0	159	0	160	0
Miscellaneous										
Right of Way Condition	382	7	377	0	382	6	558	34	314	25
Other	5723	2105	7924	2962	11350	3685	13454	5752	13889	3343
Transmission Facilities Total	7992	2356	12413	3186	15852	4140	18191	6393	18925	3814

Underground Facilities										
Underground Structures										
Damaged Cover	73	2	10	0	7	0	5	1	19	0
Damaged Structure	352	128	226	63	321	102	272	83	727	61
Congested Structure	0	0	0	0	0	0	0	0	0	0
Damaged Equipment	189	6	124	4	143	3	235	1	211	0
Conductors										
Primary Cable	4	4	2	2	1	1	0	0	0	0
Secondary Cable	5	5	11	11	4	4	2	2	0	0
Neutral Cable	0	0	0	0	0	0	0	0	0	0
Racking Needed	25	25	23	23	6	6	4	4	0	0
Miscellaneous										
Other	6045	2422	5645	1937	4162	1050	6932	1515	7616	1921
Underground Facilities Total	6693	2592	6041	2040	4644	1166	7450	1606	8573	1982
Pad Mount Transformers										
Underground Structures										
Damaged Structure	2236	1825	3036	2197	2148	1649	2189	788	1718	671
Damaged Equipment	0	0	0	0	0	0	0	0	0	0
Damaged Cable	0	0	0	0	0	0	0	0	0	0
Oil Leak	0	0	0	0	0	0	0	0	0	0
Off Pad	0	0	0	0	0	0	0	0	0	0
Lock/Latch/Penta	0	0	0	0	0	0	0	0	0	0
Miscellaneous										
Other	5229	4211	5824	4822	3767	2869	4534	2544	4416	2891
Pad Mount Transformer Total	7465	6036	8860	7019	5915	4518	6723	3332	6134	3562
Streetlights										
Streetlight										
Base/Standard/Light	0	0	6996	3	6105	5	4465	0	5176	0
Handhole/Service Box	0	0	0	0	0	0	0	0	0	0
Service/Internal Wiring	0	0	4696	2	393	1	866	0	983	0
Access Cover	0	0	11142	1	1271	0	2116	0	1522	0
Miscellaneous										
Other	0	0	260	0	222	0	52	0	283	0
Streetlight Total	0	0	23094	6	7991	6	7499	0	7964	0
Total Level IV Conditions										
Overall Total	271,911	51,308	208,522	43,685	241,287	55,300	254,844	52,550	238,249	53,197

Summary of Deficiencies and Repair Activity Resulting from the Inspection Process

Year	Priority Level / Repair Expected	Deficiencies Found (Total)	Repaired In Time Frame	Repaired - Overdue	Not Repaired - Not Due	Not Repaired - Overdue
2010						
	I	Within 1 week	2727	2723	4	0
	II	Within 1 year	21435	19961	1471	0
	III	Within 3 years	38074	37363	552	0
	IV	N/A	271910	51308	0	220602
	Temp Repairs	Within 90 days	80	65	15	0
2011						
	I	Within 1 week	491	484	7	0
	II	Within 1 year	28081	26046	1976	0
	III	Within 3 years	19280	18471	289	0
	IV	N/A	208522	43685	0	164837
	Temp Repairs	Within 90 days	109	93	13	0
2012						
	I	Within 1 week	490	480	10	0
	II	Within 1 year	35261	31874	3257	0
	III	Within 3 years	26224	12770	56	13240
	IV	N/A	241287	55300	0	185987
	Temp Repairs	Within 90 days	195	180	15	0
2013						
	I	Within 1 week	611	597	11	0
	II	Within 1 year	21284	19593	814	0
	III	Within 3 years	20745	3266	0	17479
	IV	N/A	254847	52550	0	202297
	Temp Repairs	Within 90 days	164	144	19	0
2014						
	I	Within 1 week	587	578	5	0
	II	Within 1 year	25062	2540	13	22406
	III	Within 3 years	36068	705	0	35363
	IV	N/A	238249	53197	0	185052
	Temp Repairs	Within 90 days	170	162	2	0

Appendix 5

Temporary Repair Exceptions

Appendix 5

Temporary Repair Exceptions

National Grid has 5 temporary repair exceptions to report.

Distribution

Feeder#	Line#	Pole#	Location	Region	Op District	Date Inspected	Comments	Maint Code	Priority	Comments	Work Order#	Quantity
3355	147	6-1	N 13 th ST	51	10	09/22/2014 11:54	XARM ADDED TO TOP OF POLE FOR TEMP FIX FOR CLEARANCE	116	9	XARM ADDED FOR CLEAR		1
30056	107	3	Main alley/Off Remsen St	60	31	05/05/2014	LEVEL 1 MADE SAFE BY OPC VERIFIED BY DI MIKE BOWERS. CHANGED TO LEVEL 9. WR#16966220 NOT OH ISSUE PER D. DECHIARO SENT TO UNDERGROUND. IN PLANNING PER D. GERKE ON 08/11	115	9		16966220	1

Transmission

Circuit ID#	Structure#	Region	District	Location	Structure Type	Date Inspected	Maint Code	Priority	Quantity	Comments	Circuit Name	Work Order#
A0110	102	48	01	DODGE RD	AI	03/11/2014 14:02	541	9	1	CONDUCTOR BOLTED TO SIDE OF TOWER. NOT SUSPENDED FROM INSULATOR. LINE RETIRED IN PLACE.	92W Lockport to Open (A0110)	
S3300	3	51	08	RT 20	SI	04/29/2014 11:44	526	9		MANY FILLED	866 W Portland to Hartfield (S3300)	
T6180	155	57	25	between Ct Rt. 15 & Irish Settlement Rd.	H-	10/28/2014 14:45	510	9		beavers !!!	4 Corning to Battle Hill #4 (T6180)	

Appendix 6

Inspections Summary

2014 PSC QTR 4 REPORT

NATIONAL GRID									
2010- 2014 Inspection Summary		Total System Units	2010 Units Completed	2011 Units Completed	2012 Units Completed	2013 Units Completed	2014 Units Completed	2010 - 2014 Units Completed	2010 - 2014 Percent Completed
Distribution - Unique Inspections	1,238,759	232,604	246,005	266,755	265,168	229,300	1,239,832	100.09%	
Distribution - Total Inspections	0	233,011	246,657	267,055	265,806	230,263	1,242,792	n/a	
Underground Facilities - Unique	93,171	17,624	19,987	19,128	24,845	19,124	100,708	108.09%	
Underground Facilities - Total	0	19,143	20,306	19,461	25,535	19,714	104,159	n/a	
URD - Unique Inspections	65,781	10,619	12,846	12,861	17,190	12,308	65,824	100.07%	
URD -Total Inspections	0	10,628	12,858	12,871	17,224	12,367	65,948	n/a	
Street Light / Traffic Sig - Unique	65,838	5,200	35,733	14,996	12,688	13,623	82,240	124.91%	
Street Light / Traffic Sig - Total	0	5,200	36,159	15,231	13,132	13,705	83,427	n/a	
Transmission - Unique Inspections	102,419	20,369	27,148	24,913	21,457	18,889	112,776	110.11%	
Transmission - Total Inspections	0	20,924	27,454	25,190	21,579	19,094	114,241	n/a	
Grand Total - Unique Inspections	1,565,968	286,416	341,719	338,653	341,348	293,244	1,601,380	102.26%	

Appendix 7

Summary of Overdue Repairs

Appendix 7

Summary of Overdue Repairs for Level II Repairs

Year	Facilities	-- Repaired -- Number of Days Overdue				-- Not Repaired -- Number of Days Overdue				Comments
		1-30	31-90	91-180	>180	1-30	31-90	91-180	>180	
2010	Distribution									
	Transmission								3	Not Repaired: 3 Items
	Subtransmission									
	Underground									
	Pad-mounts									
	Streetlights									
2011	Distribution									
	Transmission									
	Subtransmission								42	Not Repaired: 42 Items
	Underground									
	Pad-mounts									
	Streetlights									
2012	Distribution				1				60	Not Repaired: 60 Items
	Transmission				4				2	Not Repaired: 2 Items
	Subtransmission								41	Not Repaired: 41 Items
	Underground								3	Not Repaired: 3 Items
	Pad-mounts									
	Streetlights									
2013	Distribution	36	29	10	2	22	85	12	108	Not Repaired: 227 Items
	Transmission	1						17	1	Not Repaired: 18 Items
	Subtransmission			10		11	42	25	13	Not Repaired: 91 Items
	Underground	3		11		11	19	123	345	Not Repaired: 498 Items
	Pad-mounts									
	Streetlights									
2014	Distribution									
	Transmission									
	Subtransmission									
	Underground									
	Pad-mounts									
	Streetlights									

Summary of Overdue Repairs for Level III Repairs

Year	Facilities	-- Repaired -- Number of Days Overdue				-- Not Repaired -- Number of Days Overdue				Comments
		1-30	31-90	91-180	>180	1-30	31-90	91-180	>180	
2010	Distribution								1	Not Repaired: 1 Item
	Transmission				1				45	Not Repaired: 45 Items
	Sub Transmission								133	Not Repaired: 133 Items
	Underground								1	Not Repaired: 1 Item
	Pad-mounts									
	Streetlights									
2011	Distribution		1	70		1	46	66	5	Not Repaired: 118 Items
	Transmission		3					13	19	Not Repaired: 32 Items
	Sub Transmission	18	4				148	85	143	Not Repaired: 376 Items
	Underground		1	1		7	18	18	6	Not Repaired: 49 Items
	Pad-mounts									
	Streetlights									
2012	Distribution									
	Transmission									
	Sub Transmission									
	Underground									
	Pad-mounts									
	Streetlights									
2013	Distribution									
	Transmission									
	Sub Transmission									
	Underground									
	Pad-mounts									
	Streetlights									
2014	Distribution									
	Transmission									
	Sub Transmission									
	Underground									
	Pad-mounts									
	Streetlights									

Appendix 8

Mobile Testing

December 9, 2014

VIA ELECTRONIC FILING

Honorable Kathleen H. Burgess
Secretary
New York State Public Service Commission
Three Empire State Plaza
Albany, New York 12223-1350

Re: Case 10-E-0271 – In the Matter of Examining the Mobile Testing Requirements of the Electric Safety Standards

Dear Secretary Burgess:

Niagara Mohawk Power Corporation d/b/a National Grid (“Niagara Mohawk”) submits for filing its 2014 Mobile Stray Voltage Testing Report pursuant to the Commission’s *Orders Requiring Additional Mobile Stray Voltage Testing*, issued July 21, 2010 and June 23, 2011 in the above proceeding. The report details the results of Niagara Mohawk’s mobile testing in the cities of Buffalo, Niagara Falls, and Albany during 2014.

Should you have any questions or concerns, please do not hesitate to contact me. Thank you for your time and attention.

Respectfully submitted,

/s/Patric R. O'Brien

Patric R. O'Brien



**2014 Mobile Stray Voltage Testing Report
December 9, 2014**

A Background

Niagara Mohawk Power Corporation d/b/a National Grid (“Niagara Mohawk” or “Company”) submits its 2014 Mobile Stray Voltage Testing Report (“Report”) pursuant to the Public Service Commission’s *Order Adopting Changes to Electric Safety Standards* issued December 15, 2008 in Case 04-M-0159 and *Orders Requiring Additional Mobile Stray Voltage Testing*, issued July 21, 2010 and June 23, 2011 in Case 10-E-0271 (collectively, the “Orders”). In compliance with the Commission’s Orders, Niagara Mohawk’s 2014 mobile testing consisted of one mobile scan in Albany and Niagara Falls and two mobile scans in Buffalo. The results of the mobile scans are detailed in the tables below.

Niagara Mohawk utilized Power Survey LLC (“Power Survey”) to conduct the mobile scans. Niagara Mohawk also utilized Power Survey to perform the mobile scans in 2009 through 2013.

B. Mobile Testing Verification Process

Niagara Mohawk verifies a stray voltage finding made by the mobile scan by using its own internal testing verification procedure as outlined in Section V of the Company’s Electric Operating Procedure NG-USA EOP G016. Verification entails using an HD probe to test all metallic objects in the area using a ground reference point as close as practical to the facility being tested up to 25 feet. In the event a suitable ground source cannot be located within the 25 foot range, the Company employs Power Survey’s verification procedure, which allows for using a ground reference point of within 100 feet of the structure.

C. Mobile Testing Results by City

1. Albany

Testing began in Albany on August 25, 2014 and was completed on August 29, 2014 with the following results:

- a. Total stray voltage findings = 127
- b. Stray voltage findings at 4.4v and below = 103 (81%)
- c. Stray voltage findings at 4.5v and above = 24 (19%)
- d. Miles scanned = 236
- e. Niagara Mohawk structures scanned = 4,683

	<i>Events/Hits</i>					
	2009	2010	2011	2012	2013	2014
<i>Albany</i>	101	217	148	168	106	127
98% of events in 2014 were found on streetlights						

2. Niagara Falls

Testing began in Niagara Falls on June 26, 2014 and was completed on June 27, 2014 with the following results:

- a. Total stray voltage findings = 13
- b. Stray voltage findings at 4.4v and below = 12 (92%)
- c. Stray voltage findings at 4.5v and above = 1 (8%)
- d. Miles scanned = 24
- e. Niagara Mohawk structures scanned = 1,347

<i>Events/Hits</i>						
	2009	2010	2011	2012	2013	2014
<i>Niagara Falls</i>	54	11	47	15	12	13
85% of events in 2014 were found on streetlights						

3. Buffalo

Niagara Mohawk conducted two separate mobile scans of Buffalo in 2014. The first mobile scan began on May 5, 2014 and was completed on June 26, 2014 with the following results:

- a. Total stray voltage findings = 450
- b. Stray voltage findings at 4.4v and below = 376 (84%)
- c. Stray voltage findings at 4.5v and above = 74 (16%)
- d. Miles scanned = 1,632
- e. Niagara Mohawk structures scanned = 27,680

The second mobile scan began on September 29, 2014 and was completed on October 30, 2014 with the following results:

- a. Total stray voltage findings = 293
- b. Stray voltage findings at 4.4v and below = 228 (78%)
- c. Stray voltage findings at 4.5v and above = 65 (22%)
- d. Miles scanned = 1,351¹
- e. Niagara Mohawk structures scanned = 27,588²

<i>Events/Hits</i>											
	2009	2010- Scan 1	2010- Scan 2	2011- Scan 1	2011- Scan 2	2012- Scan 1	2012- Scan 2	2013- Scan 1	2013- Scan 2	2014- Scan 1	2014- Scan 2
<i>Buffalo</i>	2,678	931	837	714	566	316	260	345	570	450	293
Approx 90% of events were found on streetlights (2014 Scans 1 & 2)											

¹ Variances in mileages are directly attributable to the same crews performing both scans and optimizing their routes during the second scan resulting in less overlap.

² Variances in scanned structures are attributable to unscannable assets due to inaccessible roadways due to construction, road blocks, and private roads.

A majority of the 2014 findings were below 4.5v in Albany (81%), Niagara Falls (92%), and Buffalo (84% in Scan 1 and 78% in Scan 2).

D. Mobile Testing Repair/Mitigation Efforts

As of November 18, 2014, Niagara Mohawk has completed 76% of the total permanent repairs in Buffalo (Scan 1 & Scan 2), Niagara Falls, and Albany.

A summary table illustrating repair status by region can be found in Appendices A-E. These tables are updated as of November 18, 2014.

E. Mobile Testing Program Costs

As of November 18, 2014, the mobile scan surveys totaled \$1,969,606.

City	Actual Miles	Events Found	Event Rate	Repairs	Mobile Inspection Cost
Buffalo Scan 1	1,632	450	0.28	450	\$1,889,369
Buffalo Scan 2	1,351	293	0.22	95	
Niagara Falls	24	13	0.54	13	\$36,081
Albany	236	127	0.54	127	\$44,156
Total	3,243	883		685	\$1,969,606

F. Mobile and Manual Testing Program Comparison

It cost the Company on average 9 times more to conduct mobile testing (per mile cost) when compared to manual testing (per unit cost) in Albany, Niagara Falls, and Buffalo in 2014.

	Albany		Niagara Falls		Buffalo Scan 1 & 2	
	Manual ³	Mobile	Manual	Mobile	Manual	Mobile
2014 Estimated Costs						
Non-Streetlighting Eqp.	\$9,995	\$44,156	\$2,449	\$36,081	\$57,892	\$1,889,369
Metallic Streetlighting Eqp.	\$2,933		\$1,292		\$18,580	
Delta	Δ \$31,228		Δ \$32,340		Δ \$1,812,897	


³ The estimated manual testing costs are based on the per unit cost of conducting a manual elevated voltage test in Albany, Niagara Falls, and Buffalo and the number of facilities scanned during mobile testing in 2014. The numbers reflect what it would have cost the Company had it performed manual testing in these cities in 2014.

Appendix A Mobile Testing & Repair Summary

NY Stray Voltage Mobile Testing Summary Report 2014					
11/18/2014					
	Buffalo Scan 1	Buffalo Scan 2	N. Falls	Albany	Grand Total
Testing Summary					
Total Number of Events	450	293	13	127	883
<i>At or Above 4.5 Volts</i>	74	65	1	24	164
<i>Between 1.0 and 4.4 Volts</i>	376	228	12	103	719
Total NGRID Owned Events (streetlights)	450	293	13	127	883
<i>At or Above 4.5 Volts</i>	74	65	1	24	164
<i>Between 1.0 and 4.4 Volts</i>	376	228	12	103	719
Total Private Owned Events	6	4	1	11	22
<i>At or Above 4.5 Volts</i>	1	4	1	2	8
<i>Between 1.0 and 4.4 Volts</i>	5	0	0	9	14
Survey Percent Complete by City					
<i>Buffalo (Scan 1)</i>	1632				100.00%
<i>Buffalo (Scan 2)</i>		1351			100.00%
<i>Niagara Falls</i>			24		100.00%
<i>Albany</i>				236	100.00%
Total Miles To Be Scanned (estimates)	1,632	1,351	24	236	3,243
NY Stray Voltage Mobile Testing Repair Summary Report 2014					
11/18/2014					
	Buffalo Scan 1	Buffalo Scan 2	N. Falls	Albany	Grand Total
Repair Summary					
NGRID Repairs					
Required	450	293	13	127	883
Completed	450	95	13	127	685
Pending (All repairs)	0	198	0	0	198
Pending (De-energized streetlights)	0	46	0	0	46
Exceeding 45 Days		1			1
Percent Complete	100.00%	32.42%	100.00%	100.00%	77.58%
TOH Repairs	14	0	0	0	14
TOH Complete	14	0	0	0	14
TOH Pending	0	0	0	0	0
TOH Exceeding 90 Days	0	0	0	0	0
TOH Percent Complete	100.00%	100.00%	100.00%	100.00%	100.00%
Private Repairs					
Required	6	4	1	11	22
Completed	6	4	1	11	22
Pending	0	0	0	0	0
Exceeding 45 Days	0	0	0	0	0
Percent Complete	100.00%	100.00%	100.00%	100.00%	100.00%
Total Repairs Pending	0	198	0	0	198
Total Repairs Complete	450	95	13	127	685
Total Repairs Percent Complete	100.00%	32.42%	100.00%	100.00%	77.58%

Appendix B

Summary of Energized Objects - Mobile Testing - City of Niagara Falls


 Data as of November 18, 2014	Initial Readings				Readings After Mitigation		
	1 - 4.4 V	4.5 - 24.9 V	> 25 V	Total	< 1 V	1 - 4.4 V	> 4.5 V
Distribution Facilities	0	0	0	0	0	0	0
Pole (910)	0	0	0	0	0	0	0
Ground (914)	0	0	0	0	0	0	0
Guy (915)	0	0	0	0	0	0	0
Riser (916)	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0
Underground Facilities	0	0	0	0	0	0	0
Handhole / Pull box (950)	0	0	0	0	0	0	0
Manhole (951)	0	0	0	0	0	0	0
Padmount Switchgear (952)	0	0	0	0	0	0	0
Padmount Transformer (953)	0	0	0	0	0	0	0
Vault – Cover/Door (954)	0	0	0	0	0	0	0
Pedestal	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0
Street Lights / Traffic Signals	10	1	0	11	11	0	0
Metal Street Light Pole (971/981)	10	1	0	11	11	0	0
Traffic Signal Pole (991)	0	0	0	0	0	0	0
Control Box (992)	0	0	0	0	0	0	0
Pedestrian Crossing Pole (993)	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0
Substation Fences	0	0	0	0	0	0	0
Fence (995)	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0
Transmission	0	0	0	0	0	0	0
Lattice Tower (931)	0	0	0	0	0	0	0
Pole (930)	0	0	0	0	0	0	0
Ground (933)	0	0	0	0	0	0	0
Guy (934)	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0
Miscellaneous Facilities	2	0	0	2	2	0	0
Sidewalk	0	0	0	0	0	0	0
Gate/Fence/Awning*	0	0	0	0	0	0	0
Control Box	0	0	0	0	0	0	0
Scaffolding	0	0	0	0	0	0	0
Bus Shelter	0	0	0	0	0	0	0
Fire Hydrant	0	0	0	0	0	0	0
Phone Booth	0	0	0	0	0	0	0
Water Pipe	0	0	0	0	0	0	0
Riser	0	0	0	0	0	0	0
Other**	2	0	0	2	2	0	0
Totals	12	1	0	13	13	0	0

*Includes railing

**Including but not limited to manhole cover, sewer cover, no parking sign, parking meter, private sign, stop sign, storm grate.

Appendix C

Summary of Energized Objects - Mobile Testing - City of Albany


 Data as of November 18, 2014	Initial Readings				Readings After Mitigation		
	1 - 4.4 V	4.5 - 24.9 V	> 25 V	Total	< 1 V	1 - 4.4 V	> 4.5 V
Distribution Facilities	0	0	0	0	0	0	0
Pole (910)	0	0	0	0	0	0	0
Ground (914)	0	0	0	0	0	0	0
Guy (915)	0	0	0	0	0	0	0
Riser (916)	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0
Underground Facilities	0	0	0	0	0	0	0
Handhole / Pull box (950)	0	0	0	0	0	0	0
Manhole (951)	0	0	0	0	0	0	0
Padmount Switchgear (952)	0	0	0	0	0	0	0
Padmount Transformer (953)	0	0	0	0	0	0	0
Vault – Cover/Door (954)	0	0	0	0	0	0	0
Pedestal	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0
Street Lights / Traffic Signals	103	21	2	126	126	0	0
Metal Street Light Pole (971/981)	103	20	2	125	125	0	0
Traffic Signal Pole (991)	0	1	0	1	1	0	0
Control Box (992)	0	0	0	0	0	0	0
Pedestrian Crossing Pole (993)	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0
Substation Fences	0	0	0	0	0	0	0
Fence (995)	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0
Transmission	0	0	0	0	0	0	0
Lattice Tower (931)	0	0	0	0	0	0	0
Pole (930)	0	0	0	0	0	0	0
Ground (933)	0	0	0	0	0	0	0
Guy (934)	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0
Miscellaneous Facilities	0	1	0	1	1	0	0
Sidewalk	0	0	0	0	0	0	0
Gate/Fence/Awning*	0	0	0	0	0	0	0
Control Box	0	0	0	0	0	0	0
Scaffolding	0	0	0	0	0	0	0
Bus Shelter	0	0	0	0	0	0	0
Fire Hydrant	0	0	0	0	0	0	0
Phone Booth	0	0	0	0	0	0	0
Water Pipe	0	0	0	0	0	0	0
Riser	0	0	0	0	0	0	0
Other**	0	1	0	1	1	0	0
Totals	103	22	2	127	127	0	0

*Includes railing

**Including but not limited to manhole cover, sewer cover, no parking sign, parking meter, private sign, stop sign, storm grate.

Appendix D

Summary of Energized Objects - Mobile Testing - City of Buffalo Scan 1


 Data as of November 18, 2014	Initial Readings				Readings After Mitigation		
	1 - 4.4 V	4.5 - 24.9 V	> 25 V	Total	< 1 V	1 - 4.4 V	> 4.5 V
Distribution Facilities	0	0	0	0	0	0	0
Pole (910)	0	0	0	0	0	0	0
Ground (914)	0	0	0	0	0	0	0
Guy (915)	0	0	0	0	0	0	0
Riser (916)	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0
Underground Facilities	0	0	0	0	0	0	0
Handhole / Pull box (950)	0	0	0	0	0	0	0
Manhole (951)	0	0	0	0	0	0	0
Padmount Switchgear (952)	0	0	0	0	0	0	0
Padmount Transformer (953)	0	0	0	0	0	0	0
Vault – Cover/Door (954)	0	0	0	0	0	0	0
Pedestal	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0
Street Lights / Traffic Signals	361	65	7	433	433	0	0
Metal Street Light Pole (971/981)	340	60	7	407	407	0	0
Traffic Signal Pole (991)	18	5	0	23	23	0	0
Control Box (992)	3	0	0	3	3	0	0
Pedestrian Crossing Pole (993)	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0
Substation Fences	0	0	0	0	0	0	0
Fence (995)	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0
Transmission	0	0	0	0	0	0	0
Lattice Tower (931)	0	0	0	0	0	0	0
Pole (930)	0	0	0	0	0	0	0
Ground (933)	0	0	0	0	0	0	0
Guy (934)	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0
Miscellaneous Facilities	15	2	0	17	17	0	0
Sidewalk	2	0	0	2	2	0	0
Gate/Fence/Awning*	0	0	0	0	0	0	0
Control Box	0	0	0	0	0	0	0
Scaffolding	0	0	0	0	0	0	0
Bus Shelter	0	0	0	0	0	0	0
Fire Hydrant	0	0	0	0	0	0	0
Phone Booth	0	0	0	0	0	0	0
Water Pipe	0	0	0	0	0	0	0
Riser	0	0	0	0	0	0	0
Other**	13	2	0	15	15	0	0
Totals	376	67	7	450	450	0	0

*Includes railing

**Including but not limited to manhole cover, sewer cover, no parking sign, parking meter, private sign, stop sign, storm grate.

Appendix E

Summary of Energized Objects - Mobile Testing - City of Buffalo Scan 2

 Data as of November 18, 2014	Initial Readings				Readings After Mitigation		
	1 - 4.4 V	4.5 - 24.9 V	> 25 V	Total	< 1 V	1 - 4.4 V	> 4.5 V
Distribution Facilities	0	0	0	0	0	0	0
Pole (910)	0	0	0	0	0	0	0
Ground (914)	0	0	0	0	0	0	0
Guy (915)	0	0	0	0	0	0	0
Riser (916)	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0
Underground Facilities	0	0	0	0	0	0	0
Handhole / Pull box (950)	0	0	0	0	0	0	0
Manhole (951)	0	0	0	0	0	0	0
Padmount Switchgear (952)	0	0	0	0	0	0	0
Padmount Transformer (953)	0	0	0	0	0	0	0
Vault – Cover/Door (954)	0	0	0	0	0	0	0
Pedestal	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0
Street Lights / Traffic Signals	211	52	7	270	83	0	0
Metal Street Light Pole (971/981)	207	46	6	259	75	0	0
Traffic Signal Pole (991)	3	5	1	9	6	0	0
Control Box (992)	1	1	0	2	2	0	0
Pedestrian Crossing Pole (993)	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0
Substation Fences	0	0	0	0	0	0	0
Fence (995)	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0
Transmission	0	0	0	0	0	0	0
Lattice Tower (931)	0	0	0	0	0	0	0
Pole (930)	0	0	0	0	0	0	0
Ground (933)	0	0	0	0	0	0	0
Guy (934)	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0
Miscellaneous Facilities	16	5	2	23	11	0	0
Sidewalk	0	0	0	0	0	0	0
Gate/Fence/Awning*	0	0	0	0	0	0	0
Control Box	0	0	0	0	0	0	0
Scaffolding	0	0	0	0	0	0	0
Bus Shelter	0	1	0	1	1	0	0
Fire Hydrant	0	0	0	0	0	0	0
Phone Booth	0	0	0	0	0	0	0
Water Pipe	0	0	0	0	0	0	0
Riser	0	0	0	0	0	0	0
Other**	16	4	2	22	10	0	0
Totals	227	57	9	293	94	0	0

*Includes railing

**Including but not limited to manhole cover, sewer cover, no parking sign, parking meter, private sign, stop sign, storm grate.

Appendix 9

NG-USA EOP G016 Elevated Equipment Voltage Testing

nationalgrid	ELECTRIC OPERATING PROCEDURE	Doc. # NG-EOP G016
	GENERAL	Page 1 of 20
	Equipment Elevated Voltage Testing	Version 2.0 – 09/30/13

INTRODUCTION

The purpose of this procedure is to outline the requirements for the annual equipment elevated voltage testing on National Grid Facilities in New York as required by the New York Public Service Commission's "Electric Safety Standards" issued on January 5, 2005, the New York Public Service Commission's "Order Adopting Changes to Electric Safety Standards issued and effective on December 15, 2008, the New York Public Service Commission's "Order Requiring Additional Mobile Stray Voltage Testing" issued and effective on July 21, 2010 and the New York's Public Service Commission "Order Granting Petition In Part and Modifying Electric Safety Standards" issued and effective on March 22, 2013.

This procedure also outlines requirements for equipment elevated voltage testing in Rhode Island and requirements by the Rhode Island Public Utilities Commission in Docket 4237 "Order to Establish a Contact Voltage Detection, Repair and Reporting Program" issued on November 9, 2012, and the subsequent order issued on February 1, 2013.

Additionally the Massachusetts Department of Telecommunications and Energy provided a series of recommendations on December 9, 2005, that have been included in this procedure.

While there are variances in requirements between New York, Massachusetts, and Rhode Island driven by particular regulatory requirements in each State, the minimum requirements are based on sound utility practice.

PURPOSE

This procedure applies to all personnel involved with or responsible for the testing, repair and reporting of facilities designated by this EOP for equipment elevated voltage. It should be noted that the term "Contact Voltage" has been adopted and is used in the EOP (refer to definitions section).

ACCOUNTABILITY

1. Standards, Policies and Codes
 - A. Update program as necessary.
 - B. Provide personnel guidance and assistance as requested.
2. Inspections & Maintenance
 - A. Ensure the equipment elevated voltage program as outlined in this EOP is implemented properly and timely.
 - B. Ensure that the program as outlined in the EOP is completed each year.
 - C. Provide qualified personnel to complete equipment elevated voltage testing.
 - D. Ensure all equipment elevated voltage inspectors have been trained.

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED.		
FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G016 Equipment Elevated Voltage Testing MGA	Originating Department: Standards, Policies & Codes	Sponsor: Susan Fleck

nationalgrid	ELECTRIC OPERATING PROCEDURE	Doc. # NG-EOP G016
	GENERAL	Page 2 of 20
	Equipment Elevated Voltage Testing	Version 2.0 – 09/30/13

3. Equipment Elevated Voltage Inspector
 - A. Demonstrate the ability and proficiency to perform equipment elevated voltage testing per this EOP.
 - B. Demonstrate the ability to become proficient in the use of the appropriate database.
 - C. Possess the ability to do walking patrols, collect information, edit data, and guard unsafe facilities.
 - D. Attend equipment elevated voltage training program.
4. Learning & Development
 - A. Provide training upon request.
5. Distribution Network Strategy
 - A. Provide input into program revisions.
 - B. Ensure the equipment elevated voltage program as outlined in this EOP is implemented properly and timely.
 - C. Ensure the program as outlined in the EOP is completed each year.
 - D. Provide qualified personnel to complete equipment elevated voltage testing.
 - E. Ensure all equipment elevated voltage inspectors have been trained.
 - F. Provide program management.

REFERENCES

NYPSC Order 04-M-0159
 NYPSC Order Adopting Changes to Electric Safety Standards
 NYPSC Order Requiring Additional Mobile Stray Voltage Testing
 RIPUC Docket 4237 Order 20871 (November 9, 2012) and Order 20950 (February 1, 2013)
 Proposed Rhode Island Electric Contact Voltage Program, Revised October 2, 2012 (Docket 4237)
 NYSpsc Order Granting Petition in Part and Modifying Electric Safety Standards
 Applicable National Grid Safety Rules & Procedures
 Testing Equipment Operation Instructions

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G016 Equipment Elevated Voltage Testing MGA	Originating Department: Standards, Policies & Codes	Sponsor: Susan Fleck

nationalgrid	ELECTRIC OPERATING PROCEDURE	Doc. # NG-EOP G016
	GENERAL	Page 3 of 20
	Equipment Elevated Voltage Testing	Version 2.0 – 09/30/13

DEFINITIONS

Contact Voltage (Draft definition as defined by the Working Group of the Institute of Electrical and Electronic Engineers (IEEE)): Voltage resulting from abnormal power system conditions that may be present between two conductive surfaces that can come into contact by members of the general public and/or animals. Contact voltage is caused by power system fault current as it flows through the impedance of available fault current pathways. Contact voltage is not related to normal system operation and can exist at levels that may be hazardous.

Contact Voltage Area (CVA): Designated underground distribution areas within the cities of Providence, Pawtucket, Newport and Woonsocket established in the “proposed Rhode Island Electric Contact Voltage Program”, Revised October 2, 2012 (Docket 4237).

Equipment Elevated Voltage: An A.C. rms voltage difference between utility equipment and the earth, or to nearby grounded facilities that exceeds the lowest perceptible voltage levels for humans.

Equipment Elevated Voltage Inspector: The individual performing the equipment elevated voltage inspection.

Finding: Any confirmed voltage reading on an electric facility or streetlight greater than or equal to 1V measured using a volt meter and a 500 ohm shunt resistor.

Handheld Computer: An electronic data recording device that is used in the field to create a record of conditions found.

Mitigation: Corrective actions performed by the utility to address the stray voltage finding.

Proximity Detection Unit: A low voltage hand held detector used to test exposed metallic surfaces and conductors for the presence of low voltage from 6V to 600V.

Shall: The word shall is to be understood as mandatory.

Should: The word should is to be understood as advisory.

Stray Voltage: As defined by NYPSC the term “Stray Voltage” means voltage conditions on electric facilities that should not ordinarily exist.

Stray Voltage Testing: The process of checking an electric facility for stray voltage using a device capable of reliably detecting and audibly and/or visually signaling voltages in the range of 6 to 600 volts.

Total Harmonic Distortion (THD): This term has come into common usage to define either voltage or current “distortion factor.”

Distortion Factor (harmonic factor): The ratio of the root-mean-squared of the harmonic content to the root-mean-squared value of the fundamental quantity, expressed as a percent of the fundamental.

$$DF = \sqrt{\frac{\text{sum_of_squares_of_amplitudes_of_all_harmonics}}{\text{square_of_amplitude_of_fundamental}}} * 100\%$$

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED.		
FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G016 Equipment Elevated Voltage Testing MGA	Originating Department: Standards, Policies & Codes	Sponsor: Susan Fleck

nationalgrid	ELECTRIC OPERATING PROCEDURE	Doc. # NG-EOP G016
	GENERAL	Page 4 of 20
	Equipment Elevated Voltage Testing	Version 2.0 – 09/30/13

DOCUMENT CONTENTS

Table of Contents

1.0 FACILITIES WHERE EQUIPMENT ELEVATE VOLTAGE TESTING/DOCUMENTATION IS REQUIRED – NEW YORK..... 5

2.0 FACILITIES WHERE EQUIPMENT ELEVATED VOLTAGE TESTING/DOCUMENTATION IS REQUIRED – RHODE ISLAND 7

3.0 FACILITIES WHERE EQUIPMENT ELEVATED VOLTAGE TESTING/DOCUMENTATION IS REQUIRED – MASSACHUSETTS 8

4.0 TEST EQUIPMENT 9

5.0 TEST PROCEDURE 10

6.0 CORRECTIVE ACTION REQUIREMENTS FOR ELEVATED VOLTAGE FINDINGS 12

7.0 DATABASE REQUIREMENTS 14

8.0 NEW YORK ANNUAL REPORTING AND CERTIFICATION REQUIREMENTS 15

9.0 MASSACHUSETTS REPORTING REQUIREMENTS..... 17

10.0 RHODE ISLAND REPORTING REQUIREMENTS..... 17

11.0 TYPE OF EQUIPMENT - APPENDIX A..... 19

12.0 REVISION HISTORY 20

nationalgrid	ELECTRIC OPERATING PROCEDURE	Doc. # NG-EOP G016
	GENERAL	Page 5 of 20
	Equipment Elevated Voltage Testing	Version 2.0 – 09/30/13

1.0 FACILITIES WHERE EQUIPMENT ELEVATE VOLTAGE TESTING/DOCUMENTATION IS REQUIRED – NEW YORK



1.1 Street Lights and Municipally Owned Facilities

- 1.1.1 Company owned metallic street lighting standards are required to be tested for equipment elevated voltage annually. This test is to be performed while the light is operating.
- 1.1.2 Municipally owned street light systems that National Grid directly provides energy to shall be tested for equipment elevated voltage annually. National Grid will complete this testing unless assurances of the completion of required testing and transfer of such test data are made by the appropriate municipality. This test is to be performed while the light is operating.
- 1.1.3 Municipal owned metallic traffic signal standards and accessible devices are to be tested annually for equipment elevated voltage by National Grid.
- 1.1.4 All street lights identified on public thoroughfares regardless of ownership are to be tested annually.
- 1.1.5 All street lights under a maintenance contract are to be tested annually. Exceptions not requiring equipment elevated voltage testing: private lighting, park associations, parking lots, fiberglass (or other non-conductive) street light standards, and locations where street light standards are not publicly accessible, such as facilities located in the center of highways that cannot be accessed without stopping traffic or creating potentially hazardous situations for the worker and/or public.

1.2 National Grid Substation Fences

- 1.2.1 Metallic fencing surrounding substations with National Grid Facilities shall be tested for equipment elevated voltage annually. This fencing can be customer owned for customer stations, if a National Grid facility is part of the station.

1.3 Overhead Distribution Facilities

- 1.3.1 Towers and/or metallic poles with distribution facilities shall be tested for equipment elevated voltage at an annual rate of twenty percent (20%) in conjunction with field inspections on a five-year cycle. 
- 1.3.2 The following equipment on wood distribution poles requires equipment elevated voltage testing at an annual rate of twenty percent (20%) in conjunction with field inspections on a five-year cycle: 
 - 1. Metallic riser guard or conduit (company or non-company).
 - 2. Uncovered or uninsulated down ground (company or non-company).
 - 3. Down guy (company or non-company).
 - 4. Any other publicly accessible conductive piece of equipment (company or non-company) on the pole within reach from the ground.

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G016 Equipment Elevated Voltage Testing MGA	Originating Department: Standards, Policies & Codes	Sponsor: Susan Fleck

nationalgrid	ELECTRIC OPERATING PROCEDURE	Doc. # NG-EOP G016
	GENERAL	Page 6 of 20
	Equipment Elevated Voltage Testing	Version 2.0 – 09/30/13

1.3.3 Exceptions: Customer meters and customer meter poles are excluded.

1.4 Overhead Transmission Facilities

1.4.1 Towers and/or metallic poles with transmission facilities shall be tested for equipment elevated voltage at an annual rate of twenty-percent (20%) in conjunction with field inspections on a five-year cycle.

1.4.2 The following equipment on wood transmission poles or structures require equipment elevated voltage testing at an annual rate of twenty-percent (20%) in conjunction with field inspections on a five-year cycle:

- a. Metallic riser guard or conduit (company or non-company).
- b. Uncovered or uninsulated down ground (company or non-company).
- c. Down guy (company or non-company).
- d. Any other publicly accessible conductive piece of equipment (company or non-company) on the pole or structure within reach from the ground.

1.5 Underground Facilities

1.5.1 Annual equipment elevated voltage testing is required on all of the following equipment where accessible to the public.

- a. All metallic manhole covers, vault covers and grates, junction box covers, and handhole covers.

1.5.2 Pad-mounted transformers and switchgear are tested at an annual rate of twenty percent (20%) in conjunction with field inspections on a five-year cycle.

1.5.3 Starting in 2010 and continuing thereafter, unless changed by subsequent order of the NY Public Service Commission, two mobile stray voltage surveys shall be conducted annually in Buffalo and one mobile stray voltage survey is required to be conducted annually in Albany and Niagara Falls.

1.5.4 Exceptions: Non-metallic concrete or fiberglass pads or handholes or pull/splice boxes are not required to be tested.

1.6 Daily Job Site Test Requirements

1.6.1 Each job site where National Grid personnel or its contractors complete a work assignment shall be tested for equipment elevated voltage at the start and at the end of the work day or at the start or at the completion of the assignment. This testing requirement is considered good utility practice and does not require specific documentation.

1.6.2 Exceptions:

- a. Substation fencing will not require equipment elevated voltage testing unless scheduled as part of the inspection program or if work was done on the fencing.
- b. In a storm situation, where mutual aid is required, testing by other than National Grid personnel will not be required.

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED.		
FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G016 Equipment Elevated Voltage Testing MGA	Originating Department: Standards, Policies & Codes	Sponsor: Susan Fleck

nationalgrid	ELECTRIC OPERATING PROCEDURE	Doc. # NG-EOP G016
	GENERAL	Page 7 of 20
	Equipment Elevated Voltage Testing	Version 2.0 – 09/30/13

1.7 Exemptions

1.7.1 A completely fenced in area where access is denied to the general public and where access is only achieved by climbing a fence. Good judgment is required by the tester in these scenarios.

2.0 FACILITIES WHERE EQUIPMENT ELEVATED VOLTAGE TESTING/DOCUMENTATION IS REQUIRED – RHODE ISLAND

2.1 Company Owned Street Lights

2.1.1 Company owned metallic street lighting standards are required to be tested for equipment elevated voltage on a three-year cycle.

2.1.2 Exceptions: Testing shall not be completed at locations where street light standards are not publicly accessible, such as facilities located in the center of highways that cannot be accessed without stopping traffic or creating potentially hazardous situations for the worker and/or the public.

2.2 Overhead Distribution Facilities

2.2.1 Towers and/or metallic poles with transmission facilities shall be tested for equipment elevated voltage at an annual rate of twenty-percent (20%) in conjunction with field inspections on a five-year cycle..

2.2.2 The following equipment on wood transmission poles or structures require equipment elevated voltage testing at an annual rate of twenty-percent (20%) in conjunction with field inspections on a five-year cycle:

- a. Metallic riser guard or conduit (company or non-company).
- b. Uncovered or uninsulated down ground (company or non-company).
- c. Down guy (company or non-company).
- d. Any other publicly accessible conductive piece of equipment (company or non-company) on the pole or structure within reach from the ground.

2.3 Underground Facilities

2.3.1 Testing for equipment elevated voltage shall be done while completing scheduled inspections of underground equipment covered by NG-EOP UG006, Underground Inspection and Maintenance. The following items are to be tested on a five year cycle, pad-mounted transformers, pad-mounted switchgears, and metallic handhole covers.

2.3.2 Testing for equipment elevated voltage shall be completed on underground facilities while completing working inspections covered by NG-EOP UG006. The metallic items to be tested are manholes covers, vault covers and grates, handhole covers, splice box covers, junction box covers, pad-mounted transformers, pad-mounted switchgears, and submersible equipment covers.

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED.		
FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G016 Equipment Elevated Voltage Testing MGA	Originating Department: Standards, Policies & Codes	Sponsor: Susan Fleck

nationalgrid	ELECTRIC OPERATING PROCEDURE	Doc. # NG-EOP G016
	GENERAL	Page 8 of 20
	Equipment Elevated Voltage Testing	Version 2.0 – 09/30/13

2.3.3 Starting in Fiscal Year 2013 and continuing thereafter, unless changed by subsequent order of the Rhode Island Public Utilities Commission, mobile contact voltage surveys will be performed in designated Contact Voltage Areas (CVA) The mobile surveys will be performed on a five-year cycle. A survey of 100 percent of the CVA will be performed the first year of the program followed by 20 percent of the CVA in successive years.

2.4 Daily Job Site Test Requirements

2.4.1 Each job site where National Grid personnel or its contractors complete a work assignment shall be tested for equipment elevated voltage at the start and at the end of the work day or at start and at the completion of the assignment. This testing requirement is considered good utility practice and does not require specific documentation.

- a. In a storm situation, where mutual aid is required, testing by other than National Grid personnel will not be required.

2.5 Exemptions

2.5.1 A completely fenced in area where access is denied to the general public and where access is only achieved by climbing a fence. Good judgment is required by the tester in these scenarios.

3.0 FACILITIES WHERE EQUIPMENT ELEVATED VOLTAGE TESTING/DOCUMENTATION IS REQUIRED – MASSACHUSETTS

3.1 Company Owned Street Lights

3.1.1 Company owned metallic street lighting standards are required to be tested for equipment elevated voltage on a five year cycle.

3.1.2 Exceptions: Testing shall not be completed at locations where street light standards are not publicly accessible, such as facilities located in the center of highways that cannot be accessed without stopping traffic or creating potentially hazardous situations for the worker and/or public.

3.2 Overhead Distribution Facilities

3.2.1 Towers and/or metallic poles with transmission facilities shall be tested for equipment elevated voltage at an annual rate of twenty-percent (20%) in conjunction with field inspections on a five-year cycle.

3.2.2 The following equipment on wood transmission poles or structures require equipment elevated voltage testing at an annual rate of twenty-percent (20%) in conjunction with field inspections on a five-year cycle:

- a. Metallic riser guard or conduit (company or non-company).
- b. Uncovered or uninsulated down ground (company or non-company).
- c. Down guy (company or non-company).

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED.		
FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G016 Equipment Elevated Voltage Testing MGA	Originating Department: Standards, Policies & Codes	Sponsor: Susan Fleck

nationalgrid	ELECTRIC OPERATING PROCEDURE	Doc. # NG-EOP G016
	GENERAL	Page 9 of 20
	Equipment Elevated Voltage Testing	Version 2.0 – 09/30/13

- d. Any other publicly accessible conductive piece of equipment (company or non-company) on the pole within reach from the ground.

3.3 Underground Facilities

3.3.1 Equipment elevated voltage testing is required on all of the following equipment where accessible to the public on a five year cycle.

- a. All metallic manhole covers, vault covers and grates, junction box covers, handhole covers, pad-mounted transformers, secondary pedestals, and pad-mounted switchgears.

Exceptions: Non-metallic concrete or fiberglass pads or handholes or pull/splice boxes are not required to be tested.

3.4 Daily Job Site Test Requirements

3.4.1 Each job site where National Grid personnel or its contractors complete a work assignment shall be tested for equipment elevated voltage at the start and at the end of the work day or at the start or at the completion of the assignment. This testing requirement is considered good utility practice and does not require specific documentation.

- a. In a storm situation, where mutual aid is required, testing by other than National Grid personnel will not be required.

3.5 Exemptions

3.5.1 A completely fenced in area where access is denied to the general public and where access is only achieved by climbing a fence. Good judgment is required by the tester in these scenarios.

4.0 TEST EQUIPMENT

4.1 A hand held device (proximity detection unit) that is capable of detecting voltage from 6 volts to 600 volts.

4.2 A portable AC digital high impedance volt meter must have the ability to take readings with and without an input load impedance of 500 ohms.

4.3 The handheld devices utilized shall be certified by an independent test laboratory as being able to reliably detect voltages of 6 – 600 volts. The following units have been certified:

4.3.1 HD Electric model LV-S-5 (5-600 volts).

- Fluke 85
- Fluke 87
- Fluke 170 series or equivalent
- Fluke 175
- Fluke 177
- Fluke 179
- Fluke 187
- Fluke 189

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G016 Equipment Elevated Voltage Testing MGA	Originating Department: Standards, Policies & Codes	Sponsor: Susan Fleck

nationalgrid	ELECTRIC OPERATING PROCEDURE	Doc. # NG-EOP G016
	GENERAL	Page 10 of 20
	Equipment Elevated Voltage Testing	Version 2.0 – 09/30/13

- 4.4 Mobile Voltage Detection Equipment:
- Narda 8950/10 Stray Voltage System
 - SVD2000 Stray Voltage Mobile Detector

5.0 TEST PROCEDURE

5.1 Job Briefing

- 5.1.1 At minimum, the following information shall be communicated to all personnel at the beginning of each shift for equipment elevated voltage testing:
- a. Structures are never to be touched with a bare hand while performing the tests, only the voltage detector or meter probe is to be used to make contact with the facilities.
 - b. Appropriate PPE shall be worn.
 - c. Each individual needs to be aware of his/her surroundings at all times.
 - d. Make sure to observe all traffic before entering a street, either at intersections or any other point.
 - e. Traffic safety vest (DOT Compliant Class II) is to be worn at all times when exposed to traffic. Be aware that when bending down, the visibility benefits of the traffic safety vest are diminished.
 - f. Obey all traffic control devices.
 - g. When working in the street, face oncoming traffic whenever possible.

5.2 Measurements for voltages will be performed in accordance with the following:

- 5.2.1 Initial measurements for the presence of voltage shall be made using a certified proximity detection unit as noted in the testing equipment certified equipment list in Section 4.0, 4.3.
- a. To verify the proper operation of the proximity detector, follow operating instructions for the particular certified unit being utilized, this is to be done daily.
 - b. After verification that the detection unit is working, approach the area/equipment to be tested. The proximity detector will illuminate prior to touching the area/equipment being tested if voltage is present. If the proximity detector does not illuminate in close proximity to the area/equipment touch the area/equipment to be tested with the probe of the unit.
- 5.2.2 If this test detects voltage, repeat the test with the portable AC voltmeter (The 500 ohm resistor is NOT used in this initial test):
- a. Measurements with a portable AC voltmeter shall be taken on clean bare metallic surface (structure, ground wire, etc.)
 - b. When using a portable AC voltmeter, connection shall be made to suitable neutral or ground source with the common (black) lead.

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED.		
FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G016 Equipment Elevated Voltage Testing MGA	Originating Department: Standards, Policies & Codes	Sponsor: Susan Fleck

nationalgrid	ELECTRIC OPERATING PROCEDURE	Doc. # NG-EOP G016
	GENERAL	Page 11 of 20
	Equipment Elevated Voltage Testing	Version 2.0 – 09/30/13

1. In locations where the neutral or ground point is at a distance in excess of the voltmeter lead length, the connection to the neutral/ground shall be made with up to 25' of # 16 stranded copper lead wire (covered), the other end of which shall be securely connected to the negative (black) probe of the meter. When using such "extension leads" appropriate care shall be taken in the placement of such leads so as to not create a physical hazard to workers, pedestrian or vehicular traffic.
 2. In locations where a system ground is not available, or the existing ground registered voltage upon the proximity test, a metal rod shall be firmly embedded into the earth to a depth of no less than 6" to create a ground reference point for the measurement to be taken. An alternate method is available for obtaining a ground reference point utilizing an aluminum plate in lieu of driving a ground rod. The reference point should be as close as practicable to the facility being tested to simulate an equipment elevated voltage situation (3' to 4'.) On occasion longer leads may be necessary to find undisturbed earth (up to 25'.)
- c. The "live" meter probe lead shall then be placed into contact with the structure under inspection to determine the voltage.
1. Voltages readings greater than 30 volts shall be recorded in the database for the site.
 2. For voltage readings less than 30 volts, install a 500 ohm input load impedance resistor on the volt meter. Take another voltage measurement and record this voltage in the database for the site.
- 5.2.3 Measurements for elevated voltages/contact voltage using mobile technology will be performed in accordance with the following:
- a. Mobile testing is performed by contract crews driving pre-determined routes in Contact Voltage Areas searching for elevated voltage levels. The equipment used is mounted to vehicles and detects voltage levels greater than 1 volt while driving at speeds of up to 25 mph near underground facilities. Once elevated voltages are detected the crew stops and performs a thorough check with certified manual testing equipment to determine if there is contact voltage present.
- 5.2.4 Any positive indications by either mobile testing or hand held tools shall be followed up with multi-meter measurements on the target structures. Voltage measurements shall be taken in accordance with Section 5.2.2 above. The investigators shall verify that a suitable ground (i.e. a ground that is not energized) is used as a reference. Ground source location shall be marked with tape, paint or flag for future testing of repair work.
- 5.2.5 A Total Harmonic Distortion (THD) test method will be implemented as a pilot for Rhode Island mobile elevated voltage testing. THD will be determined by the

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G016 Equipment Elevated Voltage Testing MGA	Originating Department: Standards, Policies & Codes	Sponsor: Susan Fleck

nationalgrid	ELECTRIC OPERATING PROCEDURE	Doc. # NG-EOP G016
	GENERAL	Page 12 of 20
	Equipment Elevated Voltage Testing	Version 2.0 – 09/30/13

use of a Fluke Power Quality clamp meter or a Fluke scope meter both of which have the ability to measure THD.

6.0 CORRECTIVE ACTION REQUIREMENTS FOR ELEVATED VOLTAGE FINDINGS

6.1 State Specific Requirements

6.1.1 New York

If equipment elevated voltage condition is found and verified by the Test Procedure in Section 5.0, the site is to be guarded until made safe by Company personnel or if municipally owned, made safe by the owner or company. Guarded for the purpose of this EOP is defined as guarded by a person or a protective barrier that prevents public contact if the equipment elevated voltage found is greater than 1 volt. **If the voltage measures less than 1 volt and is found to be consistent with system operation design (no visual evidence of a problem upon review) no further action is required.** If the voltage measures greater than or equal to 1 volts and less than 4.5 volts it can either be guarded in person or by a protective barrier that prevents public contact, contact your supervisor for required action. Sound judgment shall be utilized in this application. If the voltage measurement is greater than or equal to 4.5 volts it shall be guarded by an equipment elevated voltage inspector or a Company employee that has been trained to stand by on energized facilities, and immediate response is required using the notification in Section 6.3 below.

6.1.2 Massachusetts and Rhode Island

If equipment elevated voltage condition is found and verified by the Test Procedure in Section 5.0, the site is to be guarded until made safe by Company personnel or if municipally owned, made safe by the owner or company. Guarded for the purpose of this EOP is defined as guarded by a person or a protective barrier that prevents public contact if the equipment elevated voltage found is greater than 4.5 volts. **If the voltage measures less than 4.5 volts and is found to be consistent with system operation design (no visual evidence of a problem upon review) no further action is required.** If the voltage measures greater than 4.5 volts and less than 8 volts it can either be guarded in person or by a protective barrier that prevents public contact, contact your supervisor for required action. Sound judgment shall be utilized in this application. If the voltage measurement is greater than 8 volts it shall be guarded by an equipment elevated voltage inspector or a Company employee who has been trained to stand by on energized facilities; an immediate response is required using the notification in section 6.3 below

6.1.3 Rhode Island Total Harmonic Distortion Pilot

Under the Total Harmonic Distortion (THD) pilot in Section 5.2.5, if during mobile testing of the Contact Voltage Area the voltage measures greater than 1 volt and less than 4.5 volts and has a total harmonic distortion of less than 10% the voltage will be considered contact voltage. These areas will then be safeguarded from the public and permanent repairs will be made. If the total harmonic

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G016 Equipment Elevated Voltage Testing MGA	Originating Department: Standards, Policies & Codes	Sponsor: Susan Fleck

nationalgrid	ELECTRIC OPERATING PROCEDURE	Doc. # NG-EOP G016
	GENERAL	Page 13 of 20
	Equipment Elevated Voltage Testing	Version 2.0 – 09/30/13

distortion is greater than 10% and no visual defects are found, no further action will be required.

6.1.4 New York and Rhode Island

In the event of an elevated voltage finding on an electric facility or street light during the stray voltage test procedure, all publicly accessible structures and sidewalks within a minimum 30 foot radius of the electric facility or street light must be tested for stray voltage.

6.2 The following notification process for personnel to respond shall be utilized.

6.2.1 Notification by location:

a. New York: contact Systems Operations Dispatch 1-877-716-4996

b. New England North, Northborough Distribution Control Center:

1. North Shore (MA) 1-877-247-3606
2. Merrimack Valley (MA) 1-877-247-3607
3. Central (MA) 1-877-247- 3608
4. Western (MA) 1-877-247-3609

c. New England South, Northborough Distribution Control Center

1. Capital (RI) 1-877-247-3610
2. Coastal (RI) 1-877-247-3599
3. Southeast (MA) 1-877-411-3812
4. South Shore (MA) 1-877-411-5599

6.2.2 Inform the operator that this is an equipment elevated voltage call, giving inspector name, company (if not National Grid), unique ID, address where problem is identified, facility number, circuit number, ownership, type of equipment, voltage found and whether they are physically guarding or leaving the site after flagging and installing a protective barrier. National Grid personnel or designee will be assigned to respond.

6.3 Temporary repairs may be used to correct the equipment elevated voltage thereby removing the need to guard the site.

6.4 Except as noted in Section 6, 6.6, permanent repairs to the equipment shall be made within 45 days of the occurrence.

6.5 If permanent repairs can not be made within 45 days due to extraordinary circumstances, the company shall periodically perform site visits to monitor the condition of the temporary repair. For New York, all exceptions shall be identified and justified in the annual reporting of the program to the NYPSC.

6.6 The Stray Voltage Tester/Equipment elevated Voltage Inspector may detect a minimal voltage level that is attributable to the design of the facility and not the result of an improper condition, no corrective action is required in this instance.

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED.		
FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G016 Equipment Elevated Voltage Testing MGA	Originating Department: Standards, Policies & Codes	Sponsor: Susan Fleck

nationalgrid	ELECTRIC OPERATING PROCEDURE	Doc. # NG-EOP G016
	GENERAL	Page 14 of 20
	Equipment Elevated Voltage Testing	Version 2.0 – 09/30/13

- 6.7 The individuals conducting the equipment elevated voltage tests on street light standards shall have a supply of “Angel guards” available for installation if the cover is missing or wires are found to be exposed to the public at the time of testing. Angel guards shall only be installed after the testing of the street light standard is complete and 1) there is no indication of equipment elevated voltage above 1 volt, or 2) repairs have been completed to correct the equipment elevated voltage.
- 6.8 The equipment elevated voltage inspector shall report any potentially hazardous conditions found on National Grid facilities seen visually during the survey process.
- 6.9 Customer Owned Equipment
- 6.9.1 Where the Company finds equipment elevated voltage above 1 volt and identifies its source as customer-owned equipment, the Company shall guard the site and notify the customer or a responsible person, as appropriate, that a potentially hazardous situation exists. The Company shall advise the customer or responsible person that the cause of the equipment elevated voltage shall be immediately remedied.
- 6.9.2 Company personnel are encouraged to work with the customer to determine and rectify the problem. If the customer agrees to accept the Company’s assistance, the Company may charge a reasonable cost for this effort.
- a. The Company may temporarily remove a customer’s meter or take such other actions as are appropriate and necessary to protect the public.

7.0 DATABASE REQUIREMENTS

- 7.1 The database in use shall be easily searchable for information and reporting.
- 7.2 Information fields required to be completed for facilities:
- Survey Date
 - Region
 - District
 - Contractor
 - GIS ID/Asset # (Unique ID)
 - Facility Type
 - Owner
 - Feeder/Circuit
 - Line #
 - Tax District
 - Pole/Structure/Equipment ID
 - Street Name
 - Inspectors Name
 - GPS Taken
 - Pre-load Match
 - Equipment elevated Voltage Test Required
 - Voltage Found Y/N
 - Voltage Measurement

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED.		
FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G016 Equipment Elevated Voltage Testing MGA	Originating Department: Standards, Policies & Codes	Sponsor: Susan Fleck

nationalgrid	ELECTRIC OPERATING PROCEDURE	Doc. # NG-EOP G016
	GENERAL	Page 15 of 20
	Equipment Elevated Voltage Testing	Version 2.0 – 09/30/13

Type of Equipment (See Appendix A)
 Immediate Action Taken
 Person Notified
 Permanent Repair Date
 Type of Repair
 Person Responsible for repair (Employee ID)

7.3 Information fields required to be completed for facilities in mobile testing

Survey Date
 Region
 District
 Contractor
 Facility Type
 Owner
 Pole/Structure/Equipment ID
 Street Name
 GPS taken
 Voltage Measurements
 Type of Equipment (see Appendix A)
 Immediate Action Taken
 Person Notified
 Permanent Repair Date
 Type of Repair

8.0 NEW YORK ANNUAL REPORTING AND CERTIFICATION REQUIREMENTS

- 8.1 Each Regional program supervisor shall provide certification to the program manager that the Region they supervise has complied with the equipment elevated voltage testing and inspection program as ordered by the PSC.
- 8.2 The program manager shall provide certification to the Vice President Distribution Network Strategy and the Senior Vice President of Customer Operations & Maintenance that the organization has complied with the equipment elevated voltage testing and inspection program as ordered by the PSC.
- 8.3 Written certification of the completion and results of every equipment elevated voltage test and inspection shall be completed, as well as a certification that all unsafe conditions identified have been remediated by appropriate company personnel.
- 8.4 The President or officer with direct responsibility for overseeing the equipment elevated voltage testing and inspection shall provide an annual certification to the NYSPSC that the Company has tested all of its publicly accessible conductive surface electric facilities and all street lights, as well as completed all required inspections.
- 8.5 The President or officer with direct responsibility for overseeing facility inspections shall provide an annual certification to the Commission that the utility is in compliance with its inspection program and has inspected the requisite number of electric facilities. Additionally, at the end of the five-year inspection cycle, the officer shall certify that all of the utility's electric facilities have been inspected at least once.

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G016 Equipment Elevated Voltage Testing MGA	Originating Department: Standards, Policies & Codes	Sponsor: Susan Fleck

nationalgrid	ELECTRIC OPERATING PROCEDURE	Doc. # NG-EOP G016
	GENERAL	Page 16 of 20
	Equipment Elevated Voltage Testing	Version 2.0 – 09/30/13

- 8.6 The annual reporting and certification is required by February 15 of each year. In addition to certifications, it shall address the following:
- 8.6.1 Details the results of stray voltage test results and inspections conducted over the 12-month period ending December 31 of the prior calendar year. (A separate report will be required for inspections from November 1 – December 31, 2008 to account for transition to calendar year reporting.)
 - 8.6.2 Addresses the performance mechanism contained in Section 10 of the PSC Order Adopting Changes to Electric Safety Standard effective December 15, 2008 (December 15, 2008 Order).
 - 8.6.3 Contain certification describe in 8.3, 8.4 and 8.5 of this section.
 - 8.6.4 Contain a breakdown of the voltage findings in a tabular format as detailed in Attachment 1 of the December 15, 2008 Order; for all findings that result in a reading of 1 V or more after completion of mitigation efforts, a detail report of company efforts shall be provided.
 - 8.6.5 Contain a breakdown of the shock reports received from the public as detailed in Attachment 2 of the December 15, 2008 Order.
 - 8.6.6 Discussion of the analysis undertaken on the causes of the stray voltage within the Company's electric system, the conclusions drawn there from, the preventative and remedial measures identified, and the Company's plan to implement those measures.
 - 8.6.7 Description of the priority levels used to gauge the severity of a deficiency, including repair timeframes, and details the requirements for training personnel to properly identify and categorize the deficiencies.
 - 8.6.8 Contain a breakdown of facilities to be inspected, unique inspection conducted per year, and the cumulative number of unique inspections conducted to meet the five year requirement.
 - 8.6.9 Contain a breakdown of the deficiencies found, permanent repair actions taken by year, whether a repair was completed within the required timeframe, and the number of deficiencies awaiting repair. This information should be provided on a yearly basis by priority level and by equipment groupings as detailed in Attachment 3 of the December 15, 2008 Order.
 - 8.6.10 Contain a review and analysis of the inspection results. Identifying areas of concern along with remedial actions or future plans to alleviate inadequacies in current program assets.
 - 8.6.11 Description of the quality assurance program along with the results from quality assurance activities conducted during the year.
 - 8.6.12 Any additional information that is pertinent to the issues addressed by the safety standards should also be included.

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G016 Equipment Elevated Voltage Testing MGA	Originating Department: Standards, Policies & Codes	Sponsor: Susan Fleck

nationalgrid	ELECTRIC OPERATING PROCEDURE	Doc. # NG-EOP G016
	GENERAL	Page 17 of 20
	Equipment Elevated Voltage Testing	Version 2.0 – 09/30/13

- 8.7 The Company shall file reports on their mobile stray voltage testing with the Secretary of the New York PSC within 45 days after completion of the mobile testing or February 15, 2011, whichever is earliest, and in each subsequent year. The filing shall include the historic results and costs associated with the manual test program in each area listed in Section 1.5 of this procedure.
- 8.8 The Company is required by the December 15, 2008 Order to have independence in the quality assurance program required by the order. The management and personnel performing the quality assurance activities shall be separate from those performing the required stray voltage testing and inspection activities.
- 8.9 The Company shall maintain its written certification and other documentary proof of its testing at its' Albany, Buffalo, and Syracuse office facilities. These documents shall be made available to the public for review upon request.

9.0 MASSACHUSETTS REPORTING REQUIREMENTS

- 9.1 National Grid shall submit an annual report that includes the following:
 - 9.1.1 Annual reports that list inspection and testing data, including number of inspections conducted by equipment type.
 - 9.1.2 Number of equipment elevated voltage events detected by inspection personnel versus call-ins or notification by third parties.
 - 9.1.3 Variance reports on current year inspection targets.
 - 9.1.4 Equipment elevated voltage events detected on equipment that is not included in equipment elevated voltage equipment inspection schedules (which will enable the DTE to determine if the company is inspecting and testing the correct equipment).
 - 9.1.5 Number of exceptional or non-routine events that required reporting to OSHA or other government organizations due to injuries or other substantive impacts

10.0 Rhode Island Reporting Requirements

- 10.1 National Grid shall submit an annual report that includes the following in a searchable form:
 - 10.1.1 Event record number
 - 10.1.2 Location of testing
 - 10.1.3 Date and time of testing
 - 10.1.4 Company or customer asset
 - 10.1.5 Failed equipment type
 - 10.1.6 Voltage recorded
 - 10.1.7 Personal injuries to members of the public, pets or property damage

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G016 Equipment Elevated Voltage Testing MGA	Originating Department: Standards, Policies & Codes	Sponsor: Susan Fleck

nationalgrid	ELECTRIC OPERATING PROCEDURE	Doc. # NG-EOP G016
	GENERAL	Page 18 of 20
	Equipment Elevated Voltage Testing	Version 2.0 – 09/30/13

- 10.1.8 Any other equipment involved and age
- 10.1.9 Prior incidents at this location in the past five years
- 10.1.10 Corrective actions taken at the location and date taken
- 10.1.11 Number of customers if service is interrupted while making repairs
- 10.1.12 Duration of interruption
- 10.1.13 Summary of investigation into cause of the incident
- 10.1.14 Number of calls to the company “shock” line
- 10.1.15 Total repair costs by Contact Voltage Area
- 10.1.16 All information as provided for in Section 7.3

The Company will provide a summary of the above information as part of the report. In addition, the Company will include a recommendation for which specific CVAs will be tested the following year, whether there are any recommended changes to the CVAs and whether there are any advances in technology for detection of elevated voltages.

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G016 Equipment Elevated Voltage Testing MGA	Originating Department: Standards, Policies & Codes	Sponsor: Susan Fleck

nationalgrid	ELECTRIC OPERATING PROCEDURE	Doc. # NG-EOP G016
	GENERAL	Page 19 of 20
	Equipment Elevated Voltage Testing	Version 2.0 – 09/30/13

11.0 TYPE OF EQUIPMENT - APPENDIX A

TYPE	CODE	EQUIPMENT DESCRIPTION
Distribution	910	Pole
	911	Regulator
	912	Sectionalizer
	913	Recloser
	914	Ground
	915	Guy
	916	Riser
	917	Switch Handle Mechanical Operated
	929	Distribution – Other (use comments)
Transmission	930	Pole
	931	Tower
	932	Guy
	933	Ground
	934	Riser
	935	Switch Hand Mechanical Operator
	949	Transmission – Other (use comments)
Underground	950	Handhole
	951	Manhole
	952	Switchgear
	953	Transformer
	954	Vault – Cover/Door
	969	Underground – Other (use comments)
Street Light	970	Handhole
	971	Standard
	979	Street light – Other (use comments)
Customer Street Light/Other	980	Handhole
	981	Standard
	989	Customer SL/Other – Other (use comments)
Traffic Control	990	Handhole
	991	Standard
	992	Control Box
	993	Pedestrian Crossing Pole
	999	Traffic control – Other (use comments)

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED.		
FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G016 Equipment Elevated Voltage Testing MGA	Originating Department: Standards, Policies & Codes	Sponsor: Susan Fleck

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G016 Page 20 of 20
	Equipment Elevated Voltage Testing	Version 2.0 – 09/30/13

12.0 REVISION HISTORY

<u>Version</u>	<u>Date</u>	<u>Description of Revision</u>
1.0	04/01/11	This document supersedes document dated 08/17/09.
2.0	09/30/13	This document supersedes document dated 04/01/11.

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G016 Equipment Elevated Voltage Testing MGA	Originating Department: Standards, Policies & Codes	Sponsor: Susan Fleck

Appendix 10

NG-USA EOP D004 Distribution Line Patrol and Maintenance

nationalgrid	ELECTRIC OPERATING PROCEDURE DISTRIBUTION OVERHEAD	Doc. # NG-EOP D004 Page 1 of 11
	DISTRIBUTION LINE PATROL AND MAINTENANCE	Version 1.0 – 04/01/11

INTRODUCTION

The purpose of this procedure is to outline the requirements for the patrol and maintenance activities associated with National Grid Distribution feeders. The Distribution Maintenance Program was designed to provide for a patrol and subsequent maintenance of each distribution feeder once every five (5) years in NY and once every six (6) years in NE. The patrols are conducted by a Distribution Inspector identifying all required maintenance on a *Windows®* based hand held computer. The maintenance items identified through this patrol are separated into four priority levels 1, 2, 3, and 4. The problem codes identified default to the appropriate priority level. The default priority level can be adjusted by the individual performing the inspection based on actual field conditions. These priority levels are defined as follows:

Level 1 - An identified facility/component or tree condition that must be repaired/replaced within 1 week.

Level 2 - Identified facility/component condition that must be repaired/replaced within 1 year.

Level 3 – Identified facility/component condition that must be repaired/replaced within 3 years.

Level 4 – This priority category is to collect inventory information on actual field conditions to be used by Investment Strategy and Work Planning.

All Level 1 priority conditions identified in the field shall be called in by the Distribution Inspector as follows:

Notification by location:

New York: System Operations Dispatch 1-877-716-4996

NE North: Westboro Control Center 1-508-421-7879

NE South: Lincoln Control Center 1-508-421-7885

Detailed information provided to the regional notification location:

Identify yourself as a Company Distribution Inspector and your work reporting area.

Details of the Level 1 Priority Condition:

Problem found.

District, Feeder No., Line No., Tax District and Pole No.

Street address and any additional information that would assist in finding the location of the problem.

If you are standing by or have secured the location.

Notification to area Inspections Supervisor for follow-up.

nationalgrid	ELECTRIC OPERATING PROCEDURE DISTRIBUTION OVERHEAD	Doc. # NG-EOP D004 Page 2 of 11
	DISTRIBUTION LINE PATROL AND MAINTENANCE	Version 1.0 – 04/01/11

PURPOSE

This procedure applies to all personnel involved with or responsible for the inspection and repair of Overhead (OH) Distribution facilities, Underground Residential Developments (URDs) and Underground Commercial Developments (UCDs).

ACCOUNTABILITY

1. Distribution Engineering Services
 - A. Update EOP as necessary.
2. Customer Operations
 - A. Ensure the work generated by the Distribution Maintenance Program and assigned by Asset Strategy and Investment Planning is completed in the appropriate time frame.
 - B. Request assistance from CMS when necessary to complete work assigned in the appropriate time frame.
3. Contract Management Services
 - A. At the request of Customer Operations obtain, schedule and manage contractors to perform inspections and required maintenance.
 - B. Provide input into program revisions.
4. Distribution Inspector
 - A. Demonstrate the ability to identify maintenance concerns and the aptitude to become proficient in the use of a hand held computer and desktop computer.
 - B. Demonstrate the understanding and requirements of this NG-EOP D004.
 - C. Possess the ability to do walking patrols, collect information on a hand held, download to a desk top computer, edit data, provide requested information/reports/work tickets to supervision, and track/close out work completed in the database system.
5. Distribution Asset Strategy
 - A. Select program codes/circuits to be scheduled for maintenance repair work using data collected through Distribution Maintenance Program.
 - B. Approve changes to the maintenance code table.
 - C. Select circuits to be patrolled for a running five-year cycle.
 - D. Provide input into program revisions.
6. Inspections
 - A. Ensure circuits scheduled for patrol are completed each year.
 - B. Provide qualified personnel as inspectors to provide consistent and accurate identified maintenance concerns/problems.
 - C. Provide program management.
 - D. Report System Maintenance progress monthly by Division.

nationalgrid	ELECTRIC OPERATING PROCEDURE DISTRIBUTION OVERHEAD	Doc. # NG-EOP D004 Page 3 of 11
	DISTRIBUTION LINE PATROL AND MAINTENANCE	Version 1.0 – 04/01/11

7. Process and Systems.
 - A. Provide and support database.

REFERENCES

Applicable National Grid Safety Rules and Procedures
NY PSC Order 04-M-0159
NY PSC Order Adopting Changes to Electric Safety Standard, December 2008
Elevated Equipment Voltage Testing NG-EOP G016
Underground Inspection NG USA EOP UG006
Massachusetts DTE Directive 12/9/05

DEFINITIONS

Patrol: A walking/vehicle assessment of National Grid distribution facilities for the purpose of determining the condition of the facility and its associated components.

Hand Held Computer: A *Windows*® based data recording device that is used in the field to create a record of conditions found.

Desktop Computer: A personal computer that is connected to the National Grid network that is used to download the Hand Held Computer and retrieve the information in the form of reports.

Distribution Inspector: An employee that has been trained to identify deficiencies or non-standard construction conditions on National Grid facilities.

TRAINING

Provide training upon request.

nationalgrid	ELECTRIC OPERATING PROCEDURE	Doc. # NG-EOP D004
	DISTRIBUION OVERHEAD	Page 4 of 11
	DISTRIBUTION LINE PATROL AND MAINTENANCE	Version 1.0 – 04/01/11

DOCUMENT CONTENTS

Table of Contents

1.0 DISTRIBUTION PATROL..... 5

2.0 EQUIPMENT TO BE INSPECTED AND MAINTENANCE CODES 6

3.0 DISTRIBUTION MAINTENANCE DATA BASE 8

4.0 MAINTENANCE SCHEDULE..... 8

5.0 COMPLETION OF MAINTENANCE CODES 8

6.0 REVISION HISTORY 11

nationalgrid	ELECTRIC OPERATING PROCEDURE DISTRIBUTION OVERHEAD	Doc. # NG-EOP D004 Page 5 of 11
	DISTRIBUTION LINE PATROL AND MAINTENANCE	Version 1.0 – 04/01/11

1.0 DISTRIBUTION PATROL

- 1.1 Distribution Patrols are conducted by a Distribution Inspector that has been trained to identify deficiencies or non-standard construction conditions on National Grid facilities. Distribution patrols are scheduled in such a manner that each distribution feeder is examined in the field once every five (5) years in NY and once every six (6) years in NE. In NY, the patrols shall be completed by December 31 due to regulatory reporting. In NE the patrols shall be completed by March 31. The most current Distribution Patrol schedule can be found in the Distribution Maintenance Program data base (RPT 1310 Feeder Patrol Status). New Distribution Feeders added to the system will be incorporated through our Geographic Information System (GIS) system and added to the appropriate inspection cycle. If the Distribution Inspector finds unmapped facilities from the information supplied from GIS, the inspector shall add the information into the *Windows*® based hand held computer for maintenance tracking purposes. NG-USA EOP G011, Preparation and Distribution of Electric Facilities Records, identifies the correct procedure for updating GIS records, if needed.
- 1.2 Distribution Patrol data is recorded by the Distribution Inspector on a *Windows*® based hand held computer and downloaded to the Distribution Maintenance Program. The Distribution Inspector shall also complete maintenance code 118, stencil installed and maintenance code 220, guy wire marker, maintenance code 660, switchgear missing nomenclature, maintenance code 681, transformer missing nomenclature, and maintenance code 745, enclosure missing nomenclature if found deficient upon inspection while at the site. Maintenance Codes are shown on the Distribution Field Survey Worksheet #NG0236 (Page 7). The Distribution Field Survey Worksheet can be used by the field to record maintenance items and is used for informational purposes only. The latest distribution maintenance codes are downloaded to the Hand Held Computer each time there is a change that affects the maintenance code table contained in the Distribution Maintenance Database. Printed copies of the latest maintenance code tables may be obtained by running a report on the look up tables from the Distribution Maintenance Database.
- 1.3 The *Windows*® based hand held computer is to be used as the primary vehicle for recording maintenance problems in the field. There may be times where it is not practicable to use the hand held computer. In these cases, the person performing the inspection should record the information on the Distribution Field Survey Worksheet #NG0236).

<http://docuweb3:8092/ngs/servlet/NgStreamer?name=NG0236+Dist+Field+Survey+Wksht+D004>

Once complete, the Distribution Field Survey Worksheet information must be input into the Distribution Maintenance Database by the inspector, clerk, or supervisor or their designee.

nationalgrid	ELECTRIC OPERATING PROCEDURE DISTRIBUTION OVERHEAD	Doc. # NG-EOP D004 Page 6 of 11
	DISTRIBUTION LINE PATROL AND MAINTENANCE	Version 1.0 – 04/01/11

2.0 EQUIPMENT TO BE INSPECTED AND MAINTENANCE CODES

Wood Pole Mounted Street Light
 Poles
 Crossarms
 Insulators
 Primary
 Transformers
 Capacitor
 Regulator
 Sectionalizer
 Recloser
 Switches
 Ground
 Guy
 Anchor
 Secondary
 Service
 ROW
 GIS
 Spacer Cable
 Cutout
 Risers
 Switchgear
 Padmount Transformers
 Enclosures

DISTRIBUTION FIELD SURVEY WORKSHEET



REGION	DISTRICT	EMPLOYEE ID	DATE
FEEDER	TAX DISTRICT/TOWN	MAP #	
LINE # / ROUTE #	POLE #/SUFFIX #		
LOCATION			
# MAIN LINE CATV ATTACHMENT 1 2 3 4 5	# MAIN LINE TELEPHONE ATTACHMENT 1 2 3 4 5	STREET LIGHT ATTACHED <input type="checkbox"/> Yes <input type="checkbox"/> No	
WOOD POLE MOUNTED STREET LIGHT			
098 1,2,9 (NR) <input type="checkbox"/> Street Light Hazard Cond.	180 1,2,9 (NR) <input type="checkbox"/> Oil Weeping	280 1,2,9 (R) <input type="checkbox"/> Defective Cutout	/
099 2,9 (NR) <input type="checkbox"/> Not Bonded	181 1,2 (R) <input type="checkbox"/> Bushings Broken/Cracked	281 2 (R) <input type="checkbox"/> Potted Porcelain	/
POLE			
106 3 (NR) <input type="checkbox"/> Dbl Wood-NG Trnsf Req'd	182 2,9 (R) <input type="checkbox"/> Missing Ground Wire	282 4 (NR) <input type="checkbox"/> Banded Porcelain	/
107 4 (NR) <input type="checkbox"/> Dbl Wood-Tel Trnsf Req'd	183 4 (NR) <input type="checkbox"/> Control Cab Height/Ground	283 4 (NR) <input type="checkbox"/> Enclosed	/
108 4 (NR) <input type="checkbox"/> Dbl Wood-CATV Trnsf Req'd	184 3,9 (R) <input type="checkbox"/> Improper/Missing Bond	284 4 (NR) <input type="checkbox"/> Non Porcelain	/
110 1,2,9 (R) <input type="checkbox"/> Broken/severely damaged	185 3,9 (R) <input type="checkbox"/> Animal Guard Missing	285 4 (NR) <input type="checkbox"/> Hybrid	/
111 1,2,3,4 (RP) <input type="checkbox"/> Visual Rotting Grd Line	186 3,9 (R) <input type="checkbox"/> LA Blown/Missing/Improper	286 4 (R) <input type="checkbox"/> SpurTap Not Fused	/
113 3 (NR) <input type="checkbox"/> CuNap Treated Bthmark Yr	RECLOSER		289 4 (NR) <input type="checkbox"/> Other
114 2,4 (R) <input type="checkbox"/> Woodpecker Holes	190 1,2,9 (NR) <input type="checkbox"/> Oil Weeping	RISER	
115 1,2,3,9 (NR) <input type="checkbox"/> Riser Guard Req'd	191 1,2 (R) <input type="checkbox"/> Bushings Broken/Cracked	290 1,2,3,9 (NR) <input type="checkbox"/> Improper Cable Supp/Term	/
116 1,2,3,4 (RP) <input type="checkbox"/> Visual Rotting Pole Top	192 2,9 (R) <input type="checkbox"/> Missing Ground Wire	291 2,9 (R) <input type="checkbox"/> Improper/Missing Bond	/
117 1,2 (NR) <input type="checkbox"/> Leaning Pole	193 4 (NR) <input type="checkbox"/> Control Cab Height/Ground	292 3,9 (R) <input type="checkbox"/> Animal Guard Missing	/
118 P (NR) <input type="checkbox"/> Stencil / Correction Req'd	194 3,9 (R) <input type="checkbox"/> Improper/Missing Bond	293 2,3,9 (R) <input type="checkbox"/> LA Blown/Missing/Improper	/
119 4 (NR) <input type="checkbox"/> Bird's Nest	195 3,9 (R) <input type="checkbox"/> Animal Guard Missing	INFRARED	
CROSSARM		400 1,2,3,9 (R) <input type="checkbox"/> Problem - Switch	/
120 1,2,4,9 (R) <input type="checkbox"/> Damage Arm	203 1,2 (R) <input type="checkbox"/> Gang Oper'd Defective	401 1,2,3,9 (R) <input type="checkbox"/> Problem - Cutout	/
121 1,2,4 (NR) <input type="checkbox"/> Loose/Defective Pins	204 1,2,3,9 (R) <input type="checkbox"/> Single Phase Defective	402 1,2,3,9 (R) <input type="checkbox"/> Problem - Splice	/
122 3,9 (NR) <input type="checkbox"/> Wooden Pine 13.2kv	205 3,9 (R) <input type="checkbox"/> Improper/Missing Bond	403 1,2,3,9 (R) <input type="checkbox"/> Problem - Other	/
123 1,2,4 (R) <input type="checkbox"/> Loose Brace, Hrdwr	207 3,4,9 (R) <input type="checkbox"/> LA Blown/Missing/Improper	HANDHOLES	
124 1,2,4,9 (R) <input type="checkbox"/> Damage Dbl Crossarm	208 2,9 (NR) <input type="checkbox"/> Handle Not Bonded	600 1,2,9 (NR) <input type="checkbox"/> Broken/Damaged/Unsecured	/
125 1,2,4,9 (R) <input type="checkbox"/> Damage Alley Arm	GROUND		602 P (NR) <input type="checkbox"/> Missing Nomenclature
127 1,2,9 (R) <input type="checkbox"/> Primary On Arm	210 1,2,9 (R) <input type="checkbox"/> Wire Broken/Loose	603 1 (R) <input type="checkbox"/> Secondary Needs Repair	/
INSULATOR		604 4 (NR) <input type="checkbox"/> Other (use comments)	/
130 1,2 (R) <input type="checkbox"/> Broken/Cracked/Flashed	211 1,2,9 (R) <input type="checkbox"/> Hazard Condition	SWITCHEAR	
131 1,2,9 (R) <input type="checkbox"/> Floating	212 3,4 (NR) <input type="checkbox"/> Guard Req'd	651 1,2,3,9 (R) <input type="checkbox"/> Barrier Brkn/Dmgd/Unsec	/
132 3,4 (NR) <input type="checkbox"/> 17 Aluminum Capped	213 3,4 (NR) <input type="checkbox"/> Non Standard	652 1,2 (NR) <input type="checkbox"/> Base Broken/Damaged	/
133 3,9 (R) <input type="checkbox"/> Non-Standard Voltage	214 3,9 (NR) <input type="checkbox"/> Not Bonded to Neutral	654 2,9 (R) <input type="checkbox"/> Cable Not Bonded	/
134 3,4 (NR) <input type="checkbox"/> AL Cap Assoc w/Switch/Fuse	GUY		656 2,9 (R) <input type="checkbox"/> Door Broken/Damaged
PRIMARY		657 F (NR) <input type="checkbox"/> Excessive Vegetation	/
140 1,2,9 (R) <input type="checkbox"/> Insnuff. Grnd Clearance	220 P (NR) <input type="checkbox"/> Guy Wire Marker	659 2,9 (R) <input type="checkbox"/> Missing Ground	/
141 1,2,3,9 <input type="checkbox"/> Damaged Cond/Brkn Strands	221 2,9 (NR) <input type="checkbox"/> Not in Compliance w/Code	660 P (NR) <input type="checkbox"/> Missing Nomenclature	/
142 1, F (NR) <input type="checkbox"/> Limbs on Primary	222 3,9 (NR) <input type="checkbox"/> Excessive Slack	661 4 (NR) <input type="checkbox"/> Other	/
145 1,2,3,9 (R) <input type="checkbox"/> Dmg'd Stirrups/Connector	223 1,2,3,9 (R) <input type="checkbox"/> Broken Wire	662 4 (NR) <input type="checkbox"/> Rusted/Paint Peeling	/
146 2,3 (R) <input type="checkbox"/> Improper Sag	225 4 (NR) <input type="checkbox"/> Guy not Bonded/Isolated per Standards	PAD TRANSFORMER	
147 4 (R) <input type="checkbox"/> LA Missing Transition	ANCHOR		672 1,2,3,9 (R) <input type="checkbox"/> Bushing Broken/Cracked
148 4 (R) <input type="checkbox"/> LA Missing End of Line	226 1,2,3,9 (NR) <input type="checkbox"/> Req'd - Jt. Owned	673 1,2,P (R) <input type="checkbox"/> Door Broken/Damaged	/
149 3,9 (R) <input type="checkbox"/> LA Blown	227 1,2,3,9 (NR) <input type="checkbox"/> Req'd - Sole NG	675 1,2 (R) <input type="checkbox"/> Elbows/Terminator/Tracking/Burned	/
TRANSFORMER		676 F (NR) <input type="checkbox"/> Excessive Vegetation	/
150 1,2,9 (NR) <input type="checkbox"/> Oil Weeping	231 1,F (NR) <input type="checkbox"/> Limb on Secondary	680 2,9 (R) <input type="checkbox"/> Missing Ground	/
151 1,2 (R) <input type="checkbox"/> Bushings Broken/Cracked	232 1,2 (NR) <input type="checkbox"/> Improper Sag	681 P (NR) <input type="checkbox"/> Missing Nomenclature	/
152 2 (R) <input type="checkbox"/> Missing Ground Wire	234 1,2,3,9 (NR) <input type="checkbox"/> Floating	684 1,2,9 (NR) <input type="checkbox"/> Oil Weeping	/
153 2,4 (R) <input type="checkbox"/> LA Blown/Missing/Improper	SERVICE		685 1,2,3,4,9 (NR) <input type="checkbox"/> Pad Broken/Damaged
155 4 (R) <input type="checkbox"/> Animal guards required	240 1 (NR) <input type="checkbox"/> Ins. Loose from House	686 4 (NR) <input type="checkbox"/> Protection (Ballards)	/
156 3,9 (NR) <input type="checkbox"/> Non Std Install of Gap	241 1,F (NR) <input type="checkbox"/> Limb on Service	687 4 (NR) <input type="checkbox"/> Rusted/Paint Peeling	/
157 2,9 (R) <input type="checkbox"/> Improper/Missing Bond	243 1 (NR) <input type="checkbox"/> Non Std/Unsecured	ENCLOSURES	
CAPACITOR		740 1,2,3,4,9 (R) <input type="checkbox"/> Base Broken/Cracked	/
160 1,2,9 (NR) <input type="checkbox"/> Oil Weeping	250 F (NR) <input type="checkbox"/> Brush/Tree/Washout	741 1,2,3,9,P (R) <input type="checkbox"/> Door Brkn/Dmgd/Unsec	/
161 1,2,9 (R) <input type="checkbox"/> Bulging	GIS		742 1,2,3,9 (R) <input type="checkbox"/> Elbows Tracking/Burned
162 1,2 (R) <input type="checkbox"/> Bushings Broken/Cracked	260 4 (NR) <input type="checkbox"/> Map Doesn't Match Field	743 F (NR) <input type="checkbox"/> Excessive Vegetation	/
163 2,9 (NR) <input type="checkbox"/> Missing Ground Wire	261 4 (NR) <input type="checkbox"/> Pole/Line Numbering Error	744 2 (NR) <input type="checkbox"/> Missing Ground	/
164 2,9 (NR) <input type="checkbox"/> Blown Fuse	262 4 (NR) <input type="checkbox"/> Equip/Hardware/Missing	745 P (NR) <input type="checkbox"/> Missing Nomenclature	/
165 3,9 (NR) <input type="checkbox"/> Improper/Missing Bond	263 4 (NR) <input type="checkbox"/> Equip Removed in Field, Remove From GIS	746 4 (NR) <input type="checkbox"/> Rusted/Paint Peeling	/
166 3,9 (R) <input type="checkbox"/> Animal Guard Missing	269 4I (NR) <input type="checkbox"/> Other GPS/GIS Errors	POLE INSPECTION	
167 3,9 (R) <input type="checkbox"/> LA Blown/Missing/Improper	SPACER CABLE		801 1,2,3,4,9 (NR) <input type="checkbox"/> Identified Priority Pole
168 4 (NR) <input type="checkbox"/> Control Cab Height/Ground	270 1,2,3,9 (R) <input type="checkbox"/> Damaged/Missing Spacer	802 1,2,3,4,9 (NR) <input type="checkbox"/> Identified Reject Pole	/
REGULATOR		803 4 (NR) <input type="checkbox"/> Excessive Checking	/
170 1,2,9 (NR) <input type="checkbox"/> Oil Weeping	271 1,2,3,9 (R) <input type="checkbox"/> Bracket Damage	804 4 (NR) <input type="checkbox"/> Climbing Inspection	/
171 1,2 (R) <input type="checkbox"/> Bushings Broken/Cracked	272 3,9 (R) <input type="checkbox"/> Bracket Not Bonded	KEY	
172 2,9 (R) <input type="checkbox"/> Missing Ground Wire	273 3,9 (R) <input type="checkbox"/> Messenger Not Bonded	P/Q = Priority / Quantity	
174 4 (NR) <input type="checkbox"/> Control Cab Height/Ground	274 3,9 (R) <input type="checkbox"/> Messenger Guard Missing	NR = Maint. Code May Not Direct Affect Reliability	
175 3,9 (R) <input type="checkbox"/> Improper/Missing Bond	276 3,9 (R) <input type="checkbox"/> Uncovered Splice	R = Maint. Code May Affect Reliability	
176 3,9 (R) <input type="checkbox"/> Animal Guard Missing		RP = Maint. Code May Affect Reliability and Has Specific Program to Place to Address	
177 3,9 (R) <input type="checkbox"/> LA Blown/Missing/Improper			

nationalgrid	ELECTRIC OPERATING PROCEDURE DISTRIBUTION OVERHEAD	Doc. # NG-EOP D004 Page 8 of 11
	DISTRIBUTION LINE PATROL AND MAINTENANCE	Version 1.0 – 04/01/11

3.0 DISTRIBUTION MAINTENANCE DATA BASE

- 3.1 The Distribution Maintenance database consists of information collected in the field down loaded from the *Windows*® based hand held computer and data gathered from other sources entered from the desktop computer. The *Windows*® based hand held computer can be down loaded to any National Grid desk top computer that is connected to the network by an employee that has been authorized to perform this function. The Distribution Maintenance database is used by various departments throughout National Grid to generate maintenance reports and cost estimates.
- 3.2 The Distribution Maintenance database contains information to be used by Asset Strategy and Investment Planning to track maintenance codes that may affect reliability (R), affect reliability that have a specific program in place to address (RP), or may not directly affect reliability (NR):

4.0 MAINTENANCE SCHEDULE

- 4.1 Maintenance activities are scheduled by priority Levels. All “Level 1 Priority” conditions identified must be repaired/corrected within 1 week. All “Level 2 Priority” conditions identified must be repaired/corrected within 1 year. All “Level 3 Priority” conditions must be repaired within 3 years. Level 4 Priority is for inventory purposes only.
- 4.2 Once the Distribution Feeder is completed in the Distribution Maintenance Database or 21 days have elapsed since the inspection, the Level 2 and Level 3 Priority maintenance codes are downloaded into STORMS. Expense maintenance work goes straight to scheduling while the capital work goes to Distribution Design. Level 1 Priority maintenance codes are communicated by the Distribution Inspector directly to the field operations group for the area where the feeder is located.

5.0 COMPLETION OF MAINTENANCE CODES

- 5.1 Level 1 priority maintenance codes completion process:
 - 5.1.1 Distribution Inspector contacts System Operations Dispatch (SOD) providing information on the Level 1 maintenance item and fills out a Level 1 Priority Report Form (page 10).
 - 5.1.2 SOD generates a PowerOn order from Regional Control.
 - 5.1.3 Inspections Supervisor captures PowerON ID # and details for Level 1 maintenance item status. Inspections Supervisor tracks Level 1 maintenance status with operations ensuring that the Level 1 item is completed within 1 week. Inspection Supervisor closes out the Level 1 maintenance item in the Distribution Maintenance Database by adding the PowerOn ID # number to maintenance record.

nationalgrid	ELECTRIC OPERATING PROCEDURE DISTRIBUION OVERHEAD	Doc. # NG-EOP D004 Page 9 of 11
	DISTRIBUTION LINE PATROL AND MAINTENANCE	Version 1.0 – 04/01/11

- 5.2 Level 2 and Level 3 priority maintenance codes are completed in the Distribution Maintenance database once the 699 requirement is completed in STORMS for the work request associated with the maintenance code.

ALL MAINTENANCE WORK IS TO BE COMPLETED PER NATIONAL GRID DISTRIBUTION STANDARDS.

ALL MAINTENANCE WORK PERFORMED THAT WAS IDENTIFIED ON THE WORK ORDER OR DISCOVERED DURING THE REPLACEMENT/REPAIR/CORRECTION OF THE ORIGINAL MAINTENANCE PROBLEM MUST BE LISTED ON THE DATABASE AND THEN CLOSED OUT WHEN COMPLETE.

nationalgrid	ELECTRIC OPERATING PROCEDURE DISTRIBUTION OVERHEAD	Doc. # NG-EOP D004 Page 10 of 11
	DISTRIBUTION LINE PATROL AND MAINTENANCE	Version 1.0 – 04/01/11



Level “1” & Elevated Voltage Priority Report Form

Any Level “1” Priority or Elevated Voltage condition found must be called into Dispatch.

Feeder: _____

Line #: _____

Pole #: _____

Closest Meter #: _____

Street Address: _____

City/Town: _____

Level “1” Priority/Elevated Voltage condition found.

Call Dispatch to inform that this is either an Elevated Voltage call or an Inspection issue.

Dispatcher notified: _____

Date/Time: _____

Inspector: _____


nationalgrid	ELECTRIC OPERATING PROCEDURE DISTRIBUION OVERHEAD	Doc. # NG-EOP D004 Page 11 of 11
	DISTRIBUTION LINE PATROL AND MAINTENANCE	Version 1.0 – 04/01/11

6.0 REVISION HISTORY

<u>Version</u>	<u>Date</u>	<u>Description of Revision</u>
1.0	04/01/11	This document supersedes document dated 08/17/09.

Appendix 11

NG-USA EOP UG006 Underground Inspection and Maintenance

 ELECTRIC OPERATING PROCEDURES	Doc No.: NG-USA EOP UG006
	Page: Page 1 of 8
	Date: 08/17/09
SUBJECT: Underground Inspection and Maintenance	SECTION: Underground

GENERAL INFORMATION:

The purpose of this procedure is to outline the requirements for the patrol and maintenance activities associated with National Grid’s underground transmission and distribution facilities.

The variance in inspection procedures in New York, Massachusetts, New Hampshire, and Rhode Island service territories is due to the requirements of New York Public Service Order 04-M-0159 and the Massachusetts Department of Telecommunications and Energy recommendations of December 9 2005, which is incremental to National Grid in New York and Massachusetts.

This program is designed for the patrol and designated maintenance of underground facilities on a five year schedule. The Inspector will record all required maintenance on an approved National Grid database.

The underground distribution facility maintenance items identified through this patrol are separated into four priority levels 1, 2, 3, and 4. The problem codes identified default to the appropriate priority level. The default priority level can be adjusted by the individual performing the inspection based on actual field conditions. These priority Levels are defined as follows:

Level 1- An identified facility/component or tree condition that must be repaired/replaced within 1 week.

Level 2 - Identified facility/component condition that must be repaired/replaced within 1 year.


Level 3 – Identified facility/component condition that must be repaired/replaced within 3 years.

Level 4 – This priority category is to collect inventory information on actual field conditions to be used by Investment Strategy and Work Planning.

All Level 1 priority conditions identified in the field shall be called in by the Underground Inspector as follows:

1. Notification by location:
 - a. New York: contact System Operations Dispatch 1-877-716-4996.
 - b. Bay State West and North & Granite: Westboro Control Center 1-508-389-9032.
 - c. Bay State South, and Ocean State: Lincoln Control Center 1-401-335-6075.

2. Detailed information provided to the regional notification location:
 - a. Identify yourself as a Company Underground Inspector and your work reporting area.
 - b. Details of the Level 1 Priority Condition:
 - i. Problem found.
 - ii. District, Circuit/Feeder No., Line No., Tax District and Manhole/vault No.
 - iii. Street address and any additional information that would assist in finding the location of the problem.
 - iv. If you are standing by or have secured the location.

Supersedes Document Dated: 06/26/08	Authorized By: Director-Distribution Engrg. Services	Approved By:  SVP- Network Strategy
--	---	---

APPLICABILITY:

This procedure applies to all personnel involved with or responsible for the inspection or maintenance of underground transmission and distribution facilities.

DEFINITIONS:

Desktop Computer: A personal computer that is connected to the National Grid network and used to download the Hand Held device and retrieve the information in the form of reports.

Elevated Equipment Voltage Test: An A.C. rms voltage difference between utility equipment and the earth, or to nearby grounded facilities that exceeds the highest perceptible voltage levels for humans.

Hand Held Computer: An electronic data recording device that is used in the field to create a record of conditions found.

Hand-Hole: An enclosure identified for use in underground systems, provided with an open or closed bottom, and sized to allow personnel to reach into, but not enter, for the purpose of installing, operating, or maintaining equipment or wiring or both.

Infrared Inspection: An inspection conducted to detect abnormal heating conditions associated with separable connectors. An infrared inspection is required before work begins in an enclosed space, enclosure, padmounted transformer or padmounted switchgear.

Inspector: A qualified worker who can identify deficiencies or non-standard construction conditions on National Grid facilities.

Manhole: An enclosure identified for use in underground systems, provided with an open or closed bottom, and sized to allow personnel to enter, for the purpose of installing, operating, or maintaining equipment or wiring or both.

Patrol: An assessment of National Grid facilities for the purpose of determining the condition of the facility and any associated components.

Secondary Splice Box: An enclosure identified for use in underground systems. A secondary splice box may be required where the customer's number of secondary cables exceeds the maximum allowed amount on the transformer.

Service Box: See Hand-hole

Submersible Equipment: Electric equipment such as transformers and switches that, are generally located within a Hand-hole, Manhole, or Vault.

URD: Underground Residential Distribution

UCD: Underground Commercial Distribution

Underground Distribution Facilities: Manholes, vaults, hand-holes and service boxes, padmounted equipment and the components and equipment contained in these structures. (See GENERAL INFORMATION above).

User: An individual who the program administrator has authorized to use the inspection reporting program.

Vault: An enclosure, above or below ground, which personnel may enter and which is used for the purpose of installing, operating, or maintaining equipment or wiring or both.

PROGRAM ADMINISTRATOR:

Distribution Engineering Services

SCOPE:

Underground Transmission and Distribution Facility Maintenance

- I. Patrols
- II. Equipment to be Inspected and Maintenance Codes
- III. Maintenance database
- IV. Maintenance Schedule
- V. Completion of Maintenance Codes
- VI. Responsibilities

I. PATROLS

1. New York

Inspection of underground equipment will be scheduled in such a manner that each underground facility will be examined once every five years. These patrols shall be completed by December 31st of the schedule year.

One-fifth of all underground utility components should be inspected each year. URD and UCD facilities shall be inspected on the existing overhead distribution circuit schedule. Additionally all riser poles are inspected in accordance with the Transmission and Distribution Overhead Inspection Programs, NG-USA EOP T007 and NG-USA EOP D004. Customer owned manholes and vaults that enclose National Grid equipment shall require the inspection of these National Grid facilities.

The Inspection group is responsible to create the patrol schedule for their respective Regions for the remainder of underground facilities. The Inspector uses a Windows based hand held computer to record region, district, employee ID, feeder number, structure ID number, GPS location, tax zone, line number, comments and maintenance problem codes. The Inspector while patrolling shall also complete the following maintenance codes if found deficient upon inspection: 602 – Handhole missing nomenclature, 617 – manhole missing nomenclature, 639 - network transformer- missing nomenclature, 660 – switchgear missing nomenclature, 681 – transformer missing nomenclature, and 707 – vaults improper nomenclature. The Inspector will input the code into the Windows based handheld as required, as well as completing the work unit in the handheld upon field completion while at the site. If the Inspector finds unmapped facilities from the information supplied from the Geographic Information System (GIS), refer to NG-USA EOP G011, Preparation and Distribution of Electric Facilities Records, for required procedure for corrections.

2. New Hampshire and Rhode Island

Inspection of designated underground equipment will be scheduled in such a manner that each designated Underground Facility will be examined once every five years. These patrols shall be completed by March 31st of the fiscal year.

One-fifth of all metallic handholes, padmount transformers and switchgear shall be inspected annually. The metallic handhole covers shall be opened for a visual inspection. An external visual inspection shall be completed on the padmount transformers and switchgear. Additionally all separable components in the

metallic handholes are to be inspected by infrared. Refer to NG-USA EOP UG001 for infrared procedure. A “Level 1 Priority” shall be assigned to a temperature gradient greater than 20°, although it is recognized that consideration must be taken as to whether a customer outage will occur at this time and the negative impact the outage could have on the customer. This may require scheduling an outage with the customer within one week to satisfy this requirement. A “Level 2 Priority” shall be assigned to a temperature gradient between 10° and 20°. A “Level 3 Priority” shall be assigned to a temperature gradient less than 10°. Additionally, an elevated equipment voltage test shall be completed at each location, refer to NG-USA EOP-G016.

A working inspection on underground facilities is required for all manholes, vaults, handholes, splice boxes, junction boxes, padmount transformers, switchgear and submersible equipment, each time a crew performs work at one of these facilities. The format for data collected shall follow this EOP. All separable components in these facilities are to be inspected by infrared. Additionally an elevated equipment voltage test shall be completed at each location, refer to NG-USA EOP-G016.

All transmission riser poles are inspected in accordance with the Transmission NG-USA EOP-T007.

The Inspection group is responsible to create the patrol schedule for their respective Regions for the designated underground facilities. The Inspector uses a hand held computer to record region, district, employee ID, feeder number, structure ID number, GPS location, line number, comments and maintenance problem codes. The Inspector, while patrolling or crew while inspecting, shall also complete the following maintenance codes if found deficient upon inspection, 602 – Handhole missing nomenclature, 617 – manhole missing nomenclature, 639 - network transformer- missing nomenclature, 660 – switchgear missing nomenclature, 681 – transformer missing nomenclature, and 707 – vaults improper nomenclature. The Inspector will input the code into the Windows based handheld as required, as well as completing the work unit in the handheld upon field completion while at the site. If the Inspector finds unmapped facilities from the information supplied from GIS, refer to NG-USA EOP G011, Preparation and Distribution of Electric Facilities Records, for required procedure for corrections. Crews performing working inspections are to follow the same protocol for inspections by using either a handheld data entry unit or paper inspection logs requiring data entry by clerical support.

3. Massachusetts

Inspection of designated underground equipment will be scheduled in such a manner that each designated Underground Facility will be examined once every five years. These patrols shall be completed by March 31 of the fiscal year.

One-fifth of all manholes, vaults, metallic handholes, padmount transformers and switchgear shall be inspected annually. The metallic handhole covers shall be opened for a visual inspection. Manholes and vaults shall be opened and entered for inspection. An external visual inspection shall be completed on the padmount transformers and switchgear. Additionally all separable components in the metallic handholes, manholes, and vaults are to be inspected by infrared. Refer to NG-USA EOP UG001 for infrared procedure. A “Level 1 Priority” shall be assigned to a temperature gradient greater than 20°, although it is recognized that consideration must be taken as to whether a customer outage will occur at this time and the negative impact the outage could have on the customer. This may require scheduling an outage with the customer within one week to satisfy this requirement. A “Level 2 Priority” shall be assigned to a temperature gradient between 10° and 20°. A “Level 3 Priority” shall be assigned to a temperature gradient less than 10°. Additionally, an elevated equipment voltage test shall be completed at each location, refer to NG-USA EOP-G016.

A working inspection on underground facilities is required for all manholes, vaults, splice boxes, junction boxes, padmount transformers, switchgear and submersible equipment, each time a crew performs work at one of these facilities. The format for data collected shall follow this EOP. All separable components in these facilities are to be inspected by infrared. Additionally an elevated equipment voltage test shall be completed at each location, refer to NG-USA EOP-G016.

All transmission riser poles are inspected in accordance with the Transmission NG-USA EOP-T007.

The Inspection group responsible to create the patrol schedule for their respective Regions for the designated underground facilities. The Inspector uses a hand held computer to record region, district, employee ID, feeder number, structure ID number, GPS location, line number, comments and maintenance problem codes. The Inspector, while patrolling or crew while inspecting, shall also complete the following maintenance codes if found deficient upon inspection, 602 – Handhole missing nomenclature, 617 – manhole missing nomenclature, 639 - network transformer- missing nomenclature, 660 – switchgear missing nomenclature, 681 – transformer missing nomenclature, and 707 – vaults improper nomenclature. The Inspector will input the code into the Windows based handheld as required, as well as completing the work unit in the handheld upon field completion while at the site. If the Inspector finds unmapped facilities from the information supplied from GIS, refer to NG-USA EOP G011, Preparation and Distribution of Electric Facilities Records, for required procedure for corrections. Crews performing working inspections are to follow the same protocol for inspections by using either a handheld data entry unit or paper inspection logs requiring data entry by clerical support.

II. EQUIPMENT TO BE INSPECTED AND MAINTENANCE CODES

This EOP requires the visual inspection of the following facilities as designated above for New York, New Hampshire, Rhodes Island or Massachusetts, which require opening, and may require pumping on some items to assure a proper inspection:

- Manholes
- Vaults
- Handholes – non-fiberglass
- Splice boxes – non-fiberglass
- Junction boxes – non-fiberglass
- Pad mount transformers
- Pad mount switchgears
- Submersible equipment
- Handholes – fiberglass do not require opening
- Splice boxes – fiberglass do not require opening
- Junction boxes – fiberglass do not require opening

Maintenance Codes are shown on the Underground Field Survey Worksheet (Table 1). The Underground Field Survey Worksheet can be used by the field to record maintenance items and is used for informational purposes only. The latest transmission maintenance codes are downloaded to the Hand Held Computer each time there is a change that affects the maintenance code table contained in the Underground Maintenance Database. Printed copies of the latest maintenance code tables may be obtained by running a report on the look up tables from the Underground Maintenance Database.

INSPECTION PROGRAM AND MAINTENANCE CODES

TABLE 1

UNDERGROUND FIELD SURVEY WORKSHEET																															
DATE:				INSPECTOR NAME:				EMPLOYEE ID																							
DIVISION				DISTRICT				FEEDER:																							
TOWN:			STREET:			POLE, MANHOLE, VAULT #			SUFFIX #																						
Handhole		Manhole		Net Protect		Net XFMR's		Switchgear		Transformer																					
Vault		Trench		Submersible		Pull Box		Other		Equipment #																					
MANHOLES, HANDHOLES, VAULT STRUCTURES						EV Test Required: Yes No Voltage Action Taken: Repaired De-energized																									
Water (in hole) Yes No						EV Found Voltage: Yes No																									
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th colspan="2">Gas Monitor Readings</th> <th colspan="2">Alarm Setting</th> </tr> </thead> <tbody> <tr> <td>Lower Explosive Limit (LEL)</td> <td></td> <td colspan="2">10% or above</td> </tr> <tr> <td>Oxygen (O₂)</td> <td></td> <td colspan="2">% below 19.5, above</td> </tr> <tr> <td>Carbon Monoxide (CO)</td> <td></td> <td colspan="2">33 ppm</td> </tr> <tr> <td>Hydrogen Sulfide (H₂S)</td> <td></td> <td colspan="2">10 ppm</td> </tr> </tbody> </table>						Gas Monitor Readings		Alarm Setting		Lower Explosive Limit (LEL)		10% or above		Oxygen (O ₂)		% below 19.5, above		Carbon Monoxide (CO)		33 ppm		Hydrogen Sulfide (H ₂ S)		10 ppm							
Gas Monitor Readings		Alarm Setting																													
Lower Explosive Limit (LEL)		10% or above																													
Oxygen (O ₂)		% below 19.5, above																													
Carbon Monoxide (CO)		33 ppm																													
Hydrogen Sulfide (H ₂ S)		10 ppm																													
GIS				P/Q	SWITCHGEAR				P/Q																						
260 4 (NR)	GIS map doesn't match field			/	657 F (NR)	Excessive vegetation			/																						
261 4 (NR)	GIS Pole/line numbering in error on GIS			/	659 2 (R)	Missing ground			/																						
262 4 (NR)	GIS equip/hardware missing in GIS			/	660 P (NR)	Missing nomenclature			/																						
263 4 (NR)	GIS equip removed in field, remove from GIS			/	661 4 (NR)	Other			/																						
269 4 (NR)	GIS Other GPS/GIS Errors			/	662 4 (NR)	Rusted/Paint Peeling			/																						
HANDHOLES					TRANSFORMER																										
600 2 (NR)	Broken/damaged/unsecured			/	672 1,2,3 (R)	Bushing Broken/Cracked			/																						
602 P (NR)	Missing nomenclature			/	673 1,2,3 (R)	Door Broken/damaged/unsecure			/																						
603 1 (R)	Secondary needs repair			/	675 1,2,3 (R)	Elbows/tracking/burned			/																						
604 4 (NR)	Other (use comments)			/	676 F (NR)	Excessive vegetation			/																						
MANHOLE					680 1 (R) Missing Ground				/																						
610 2 (NR)	Ground rods missing			/	681 P (NR)	Missing nomenclature			/																						
611 2 (R)	Cable/Joint leaking			/	682 4 (NR)	Mud/debris			/																						
612 2 (NR)	Cables bonded/grid defective			/	684 1,2 (NR)	Oil Weeping			/																						
614 1,2,3,4 (NR)	Cracked/broken			/	685 1,2,3,4 (NR)	Pad broken/damaged			/																						
615 3 (R)	Fire proofing			/	686 4 (NR)	Protection (ballards) damage			/																						
616 4 (NR)	Improper grade			/	687 4 (NR)	Rusted/Paint peeling			/																						
617 P (NR)	Missing nomenclature			/	688 1,2 (NR)	Pad Pushed Off Base			/																						
620 2 (NR)	Rerack			/	TRENCH																										
621 1,2,3,4 (NR)	Ring/cover repair/replace			/	690 1 (R)	Exposed Cable			/																						
622 1,4 (NR)	Roof condition – use comments			/	692 4 (NR)	Path – Sunken			/																						
623 1,4 (NR)	Chimney Condition – comments			/	VAULTS																										
624 4 (NR)	Manhole needs cleaning			/	700 2 (NR)	Cable missing bond			/																						
625 1 (R)	Secondary needs repair			/	702 1,2,3,4 (NR)	Cracked/broken			/																						
626 4 (NR)	No Holes in Manhole Cover			/	703 1,2,4 (NR)	Damaged/broken cover			/																						
NETWORK PROTECTOR					704 1,2,4 (NR)	Damaged/broken door			/																						
630 2 (R)	Barriers broken/damage			/	705 1,2,4 (NR)	Damaged/broken ladder			/																						
632 1 (R)	Oil leak			/	706 1,2,3,4,P (NR)	Improper grade			/																						
633 2 (NR)	Worn/damaged gasket			/	707 4,P (NR)	Improper nomenclature			/																						
NETWORK TRANSFORMER					708 4 (NR)	Light not working			/																						
635 2 (R)	Bushing Broken/cracked			/	712 4 (NR)	Sump pump broken			/																						
637 2 (R)	Low oil			/	713 1 (R)	Secondary needs repair			/																						
638 1 (NR)	Missing ground			/	SUBMERSIBLE EQUIPMENT																										
639 P (NR)	Missing nomenclature			/	720 1,2,3,4 (R)	Excess Corrosion			/																						
642 1, 2 (R)	Oil Weeping			/	721 1,2,3,4 (R)	Physical damage			/																						
643 4 (NR)	Rusted/paint peel			/	722 1,2 (R)	Leaking			/																						
SWITCHGEAR					ANODES																										
651 1,2,3 (R)	Barrier broken/damaged/unsecure			/	730 3 (R)	Missing			/																						
652 1,2,3 (NR)	Base broken/damaged			/	731 3 (NR)	Need replacement			/																						
654 2 (R)	Cable not bonded			/	KEY																										
656 1,2,3 (R)	Door Broken/Damaged			/	PQ = Priority Quantity																										
					NR = Maint.Code May Not Directly Affect Reliab.																										
					R = Maint. Code May Affect Reliability																										
					RP = Maint. Code May Affect Reliab. and Has Specific Program to Place to Address																										
Comments:																															

III. MAINTENANCE DATABASE

The Maintenance database consists of data downloaded from the Windows based hand held and data entered from the desktop computer. The Windows based hand held used in the field, can be downloaded to any National Grid desk top computer that is connected to the network and the inspector is logged on as a valid user of the UG Maintenance program. The National Grid desktop computer is also used to generate various reports and work tickets depending on the user's need. These reports are utilized to schedule and accomplish distribution maintenance work.

IV. MAINTENANCE SCHEDULE

Maintenance activities are scheduled by priority Levels. All "Level 1 Priority" conditions identified must be repaired/corrected within 1 week. All "Level 2 Priority" conditions identified must be repaired/corrected within 1 year. All "Level 3 Priority" conditions must be repaired within 3 years. Level 4 Priority is for inventory purposes only.

Once the Underground Circuit/Feeder is completed in the Underground Maintenance Database, the Level 2 and Level 3 Priority maintenance codes are downloaded into STORMS. Expense maintenance work goes straight to scheduling while the capital work goes to Underground Engineering. Level 1 Priority maintenance codes are communicated by the Underground Inspector directly to the field operations group for the area where the feeder is located.

V. COMPLETION OF MAINTENANCE CODES

The completion of Level 1 priority maintenance codes is performed by the field operations Supervisor or their designee. Level 2 and Level 3 priority maintenance codes are completed in the Underground Maintenance database once the 699 requirement is completed in STORMS for the work request associated with the maintenance code.

ALL MAINTENANCE WORK IS TO BE COMPLETED PER NATIONAL GRID UNDERGROUND CONSTRUCTION STANDARDS.

VI. RESPONSIBILITIES:

Distribution Engineering Services

1. Update program as necessary.

Customer Operations

1. Ensure the Underground Maintenance Program as outlined in this EOP is implemented properly and timely.
2. Select circuits to be patrolled for a running five-year cycle and ensure that the circuits scheduled for patrol are completed each year.
3. Provide qualified personnel as the inspectors, to provide consistent and accurate identified maintenance concerns/problems.
4. Ensure program is completed annually as required.

Underground Inspector

1. Demonstrate the ability to identify maintenance concerns and the aptitude to become proficient in the use of a hand held computer and desktop computer.
2. Demonstrate the understanding and requirements of this EOP.
3. Possess the ability to do walking patrols, collect information on a hand held, download to a desktop computer, edit data, provide requested information/reports/work tickets to supervision, and track/close out work completed in the database.

Contract Management Services

1. At the request of Customer Operations/Distribution Network Strategy obtain, schedule and manage contractors to perform inspections and perform required maintenance.
2. Ensure the Underground Maintenance Program as outlined in this EOP is implemented properly and timely.
3. Provide inspectors where applicable.
4. Ensure inspectors are trained.
5. Provide program management.
6. Ensure program is completed annually as required.

Asset Strategy and Policy

1. Provide input into program revisions.
2. Provide program management.
3. Ensure program is completed annually as required.
4. Ensure the Underground Maintenance Program as outlined in this EOP is implemented properly and timely.

Process and Systems

1. Provide and support database.

T&D Technical Training

1. Provide training upon request.

REFERENCE:

NY PSC Order 04-M-0159

NY PSC Order Order Adopting Changes to Electric Safety Standard, December 2008

Applicable National Grid Safety Rules and Procedures

Distribution Line Patrol and Maintenance NG-USA EOP D004

Elevated Equipment Voltage Testing NG USA EOP-G016

Transmission Line Patrol and Maintenance NG USA EOP – T007

Massachusetts DTE Directive 12/9/05

NG-USA EOP UG006

“Underground Inspection and Maintenance”

08/17/09

Changed levels from ABC to 1234 and added Underground Field Survey Worksheet.

Appendix 12

NG-USA PR 06.01.601.001 Transmission Line Maintenance Procedure

nationalgrid	TRANSMISSION LINE MAINTENANCE PROCEDURE	Doc.# PR 06.01.601.001 Page 1 of 38
	Ground Based Visual Inspection	Version 2.1 – 02/03/2011

Ground Based Visual Inspection

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE ENGINEERING DEPARTMENT DOCUMENTS CABINET IN DOCUMENTUM		
File: PR 06.01.601.001 Ground Based Visual Inspection	Originating Department: Transmission Line O&M Engineering	Sponsor: Mark S. Browne

nationalgrid	TRANSMISSION LINE MAINTENANCE PROCEDURE	Doc.# PR 06.01.601.001 Page 2 of 38
	Ground Based Visual Inspection	Version 2.1 – 02/03/2011

Revision History

Version	Date	Revision	Author	Reviewer	Approver
1.0	02/02/2010	Initial	J.M.McGrath		M.S.Browne
2.0	01/07/2011	Code changes, corrections	J.M.McGrath		M.S.Browne
2.1	2/3/2011	Code changes, warning sign revision, changed wood pole evaluation methodology	J.M.McGrath		M.S.Browne

Note: This document supersedes EOP T007 – Transmission Line Patrol and GL 06.01.118 – Visual Inspection of Transmission Line Assets

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE ENGINEERING DEPARTMENT DOCUMENTS CABINET IN DOCUMENTUM		
File: PR 06.01.601.001 Ground Based Visual Inspection	Originating Department: Transmission Line O&M Engineering	Sponsor: Mark S. Browne

Table of Contents

FORWARD	4
1.0 General.....	4
2.0 Administration.....	4
3.0 Application	4
4.0 References.....	4
5.0 Definitions	4
6.0 Follow Up Prioritization.....	5
7.0 Documentation.....	6
9.0 Responsibilities	6
PROCEDURE	8
10.0 General.....	8
11.0 Inspect Steel Condition	8
12.0 Inspect Steel Grillage Foundation.....	8
13.0 Inspect Concrete Foundation	9
14.0 Inspect Wood Poles and Structures - Overall	9
15.0 Inspect Wood Poles – Individual	9
16.0 Inspect Steel Poles and Structures	10
17.0 Inspect Conductor	10
18.0 Inspect Insulators/Hardware.....	10
19.0 Inspect Foundation – General.....	11
20.0 Inspect Right of Way.....	11
21.0 Inspect Miscellaneous.....	11
22.0 Inspect Switch – Visual Inspection	11
23.0 Document GIS Data Issues	12
24.0 Engineering-Specific Inspection	12
Appendix A – Transmission Field Survey Worksheet	14
Appendix B – Steel Evaluation Categories.....	15
Appendix C – Concrete Evaluation Categories/Rating Matrix	16
Appendix D – Wood Poles and Structures Evaluation	18
Appendix E – Individual Wood Pole Evaluation.....	24
Appendix F – Steel Poles and Structures Evaluation	25
Appendix G – Conductor and Line Hardware Evaluation.....	27
Appendix H – Foundation Evaluation	32
Appendix I – ROW/Misc./Switch/GIS Evaluation	33
Appendix J – Complete List of Computapole Codes.....	37

nationalgrid	TRANSMISSION LINE MAINTENANCE PROCEDURE	Doc.# PR 06.01.601.001 Page 4 of 38
	Ground Based Visual Inspection	Version 2.1 – 02/03/2011

FORWARD

1.0 General

- 1.1 The purpose of this procedure is to outline the requirements for the visual Inspection from ground level of National Grid US transmission circuits.
- 1.2 All applicable safety and environmental rules must be followed when executing these Inspections. Inspectors shall be aware of hazards that may be encountered.
- 1.3 Inspectors shall be notified by TLOME for all changes to this document and are to be trained yearly on this procedure. New Inspectors shall be trained on this document prior to performing this inspection.
- 1.4 This procedure is associated with Specification SP.06.01.601.000, Transmission Line Inspection and Maintenance.

2.0 Administration

- 2.1 Maintenance of this document is the responsibility of Transmission Line Operations and Maintenance Engineering (TLOME).
- 2.2 Specific planned work performed under this procedure will be coordinated by TLOME via a Work Plan document to be released prior to the start of each fiscal year.

3.0 Application

- 3.1 This document applies to all overhead line assets managed by National Grid US Transmission as defined by Transmission Group Procedure 12 (TGP 12) and applies to anyone performing Inspection and Maintenance activities on these assets. It is expected that this procedure be executed by Qualified Personnel as determined by training specific to the task performed.

4.0 References

- 4.1 Transmission Line Inspection and Maintenance Specification, SP.06.01.601.000
- 4.2 Transmission Line Switch Inspection Procedure, PR.06.01.601.008
- 4.3 Transmission Wood Pole Inspection and Treatment Procedure, PR.06.01.601.005
- 4.4 Transmission Steel Structure Foundation/Footer Inspection and Repair SP.06.01.601.004
- 4.5 National Grid Employee Safety Handbook

5.0 Definitions

- 5.1 Ground Based Visual Inspection – An Inspection performed from a stationary ground position. Movement along the line between Inspection points may be by vehicle or foot

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE ENGINEERING DEPARTMENT DOCUMENTS CABINET IN DOCUMENTUM		
File: PR 06.01.601.001 Ground Based Visual Inspection	Originating Department: Transmission Line O&M Engineering	Sponsor: Mark S. Browne

nationalgrid	TRANSMISSION LINE MAINTENANCE PROCEDURE	Doc.# PR 06.01.601.001 Page 5 of 38
	Ground Based Visual Inspection	Version 2.1 – 02/03/2011

- 5.2 Hand Held Computer – A data recording device that is used in the field to create a record of conditions found for the purposes of communicating this data to a Maintenance Management System
- 5.3 Inspection – A careful viewing of assets to find defects and other problems that require Maintenance or monitoring
- 5.4 Inspection and Maintenance Program – National Grid’s planned program for Inspecting and Maintaining its transmission lines.
- 5.5 Inspector – Qualified Personnel who identify defects via a specific type of Inspection
- 5.6 Maintenance – Work to correct defects or other problems. This work is often generated through the Inspection process
- 5.7 Maintenance Management System (MMS) – A computer application that schedules and tracks Inspections and/or Maintenance work
- 5.8 National Grid Representative – National Grid personnel designated as the point of contact for a contracted inspector
- 5.9 Pocket – A void in a pole resulting from damage, weathering or decay. This may lower the strength of the pole.
- 5.10 Qualified Personnel – Personnel trained to safely perform a specific Inspection.
- 5.11 Work Plan – A document published each fiscal year that, among other things, lists all Inspection and Maintenance scheduled for the year.

6.0 Follow Up Prioritization

- 6.1 Assets are to be assessed as follows:
 - All assets are to be graded based on worst critical member/location or discrete area, i.e. the weakest link of the asset.
 - Each steel structure, pole or member is to be graded according to Sections 10 and 11 of this procedure, using scales found in Appendix B, for engineering reference.
 - Each concrete foundation is to be graded according to Section 12 of this procedure, using scales found in Appendix C, for engineering reference.
 - Switches shall be inspected according to Procedure Section 21. Defects shall be assigned a Maintenance Priority Level of 1 to 4 per Appendix I.
 - All other assets shall be inspected according to the applicable section and defects found shall be assigned a Maintenance Priority Level of 1 to 4 in accordance with Appendices D-I.
- 6.2 Once reported, defects shall be repaired or addressed as follows per Transmission Line Inspection and Maintenance Specification, SP.06.01.601.000:
 - Level 1 – Address within 1 week*
 - Level 2 – Address within 6 months**
 - Level 3 – Address within 3 years**
 - Level 4 – Monitor condition or use for studies

* Time period starts on the day the problem is found
 **Time period starts when the defect is entered into Computapole

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE ENGINEERING DEPARTMENT DOCUMENTS CABINET IN DOCUMENTUM		
File: PR 06.01.601.001 Ground Based Visual Inspection	Originating Department: Transmission Line O&M Engineering	Sponsor: Mark S. Browne

nationalgrid	TRANSMISSION LINE MAINTENANCE PROCEDURE	Doc.# PR 06.01.601.001 Page 6 of 38
	Ground Based Visual Inspection	Version 2.1 – 02/03/2011

- 6.3 Any exceptions to the grading guide below shall only be made with approval of TLOME. Any changes to levels already entered into Computapole shall only be made with approval of TLOME.
- 6.4 All Level 1 conditions shall be reported no later than two hours after discovery as follows:
- New York – Contact Transmission Control Center @ (315) 460-2110
 - New England – Contact Transmission Control Center @ (800) 423-6029
 - Indicate problem found
 - Indicate circuit and structure number
 - Indicate street address and any additional information that would assist in identifying the location
 - Indicate if you are standing by or have safely secured the location
 - Indicate whether someone from In House Construction or Engineering is required for evaluation (immediate or not)
- 6.5 In cases where, in the judgment of the inspector, a serious safety issue may exist, the Inspector may be required to stand by a defect until other personnel arrive. This may be by the decision of the inspector or other groups. It is extremely important that the Inspector keep themselves and others a safe distance away from any hazards that are encountered. In such cases, the Safety group or National Grid Representative may also be advised.

7.0 Documentation

- 7.1 Information gathered from the Ground Based Visual Inspection shall be documented in the Computapole Maintenance Management System via the Hand Held Computer. If the computer isn't available, information can be temporarily documented on the Transmission Field Survey Worksheet in Appendix A.

8.0 Other Inspections

- 8.1 This document may be utilized in conjunction with other Inspections and condition assessments such as engineering walk-downs etc. by personnel not typically engaged in Inspections. If any defects are found that are considered Level 1, it is expected that Section 6 above shall be followed. All Level 1 and 2 defects found shall also be reported to the following:
- Manager of TLOME, via phone or email, as soon as possible.
- 8.2 It is strongly encouraged that Level 1 and 2 defects found be evaluated by personnel from In House Construction or Transmission Inspections as soon as possible. This may not be necessary if the Inspection is being performed by someone with sufficient knowledge of transmission line construction that can fully understand the impact of the defect.

9.0 Responsibilities

- 9.1 Transmission Line O&M Engineering

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE ENGINEERING DEPARTMENT DOCUMENTS CABINET IN DOCUMENTUM		
File: PR 06.01.601.001 Ground Based Visual Inspection	Originating Department: Transmission Line O&M Engineering	Sponsor: Mark S. Browne

nationalgrid	TRANSMISSION LINE MAINTENANCE PROCEDURE	Doc.# PR 06.01.601.001 Page 7 of 38
	Ground Based Visual Inspection	Version 2.1 – 02/03/2011

- Create the transmission line portion of the Work Plan outlining the circuits that are to be inspected and otherwise addressed according to this specification in a given fiscal year.
- Provide guidance and support for the execution of the Inspection and Maintenance Program
- Approve exceptions as noted above

9.2 System Delivery

- Ensure the Inspection Program as outlined in the Fiscal Year Work Plan is safely executed according to this specification and its associated procedures in a timely manner.
- Repair problems found during Inspection

9.3 Transmission Inspections

- Provide National Grid Representative when contractors are used
- Be qualified to perform specific Inspections and identify defects.
- Be qualified to perform applicable basic Maintenance such as the installation of guy guards and stenciling.
- Follow all applicable National Grid US Safety Rules.
- Demonstrate the understanding and requirements of this specification and all related procedures and guidelines.

9.4 Transmission Investment Management

- Track performance of Work Plan completion
- Track performance of Maintenance within assigned priority level time frames

9.5 Transmission Network Asset Strategy

- Provide input into program revisions.

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE ENGINEERING DEPARTMENT DOCUMENTS CABINET IN DOCUMENTUM		
File: PR 06.01.601.001 Ground Based Visual Inspection	Originating Department: Transmission Line O&M Engineering	Sponsor: Mark S. Browne

nationalgrid	TRANSMISSION LINE MAINTENANCE PROCEDURE	Doc.# PR 06.01.601.001 Page 8 of 38
	Ground Based Visual Inspection	Version 2.1 – 02/03/2011

PROCEDURE

10.0 General

- 10.1 All assets must be physically visited and visually inspected so that all potential defects can be identified. Exceptions must have approval from the appropriate department manager and be documented in the Maintenance Management System.
- 10.2 The intent of this procedure is to visit assets in order as they physically exist in the field and apply the appropriate Inspection to each asset. To conform to the current Maintenance Management System input process, the steps in this procedure are arranged so as to line up numerically with the Computapole Maintenance priority codes.
- 10.3 All elements of this procedure are intended to be performed from ground level. Tools to facilitate a clear, close up view of assets, such as binoculars or scopes, should be used where necessary.
- 10.4 Some Computapole codes do not apply to this Inspection and are not included in this procedure. A complete list of Computapole codes including valid levels and STORMS qualifiers is in Appendix J.

11.0 Inspect Steel Condition

- 11.1 Grading Reference:
- Appendix B - Steel Evaluation Categories (1-6 Rating)
- 11.2 Inspection Note:
- Grade all steel collectively. The overall tower rating shall be assigned as the visual rating of the worst 5% of members on the tower or discrete area on the steel pole, or the visual rating of the worst critical members, e.g. tower legs and insulator attachment points, whichever is worse.
 - Structures rated as 4 or worse will require additional review, so additional photos and notes should be taken to assist in structure evaluation.
 - At the discretion of the Inspector, any structure may be classified as 6 "Very Severe Deterioration" due to special circumstances. The reason for this must be reported in the Inspection report.
- 11.3 Visually inspect for the following:
- Steel condition
 - Weathering steel for excessive corrosion of joints. Report any excessive corrosion of weathering steel joints to Transmission Line O&M Engineering.

12.0 Inspect Steel Grillage Foundation

- 12.1 Grading Reference:
- Appendix B - Steel Evaluation Categories (1-6 Rating)
- 12.2 Visually inspect for the following:
- Steel condition above grade

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE ENGINEERING DEPARTMENT DOCUMENTS CABINET IN DOCUMENTUM		
File: PR 06.01.601.001 Ground Based Visual Inspection	Originating Department: Transmission Line O&M Engineering	Sponsor: Mark S. Browne

nationalgrid	TRANSMISSION LINE MAINTENANCE PROCEDURE	Doc.# PR 06.01.601.001 Page 9 of 38
	Ground Based Visual Inspection	Version 2.1 – 02/03/2011

13.0 Inspect Concrete Foundation

- 13.1 Grading Reference:
- Appendix C - Concrete Evaluation (1-5 Rating)
- 13.2 Inspection Note:
- At the Inspector's discretion, any structure foundation may be classified as 5: Very Severe Deterioration. The reason for this must be given in the Inspection report.
- 13.3 Visually inspect for the following:
- Poor workmanship, including honeycombing
 - Cracking, including pattern or solitary cracks
 - Disintegration and deterioration of concrete
 - Distortion/movement resulting in change in alignment of structure components
 - Seepage – movement of water/fluids through pores
 - Spalling – development of fragments
 - Delamination
 - Degradation of steel/concrete interface
 - Excessive corrosion of reinforcement
 - Condition of anchor bolts. Ensure all hardware present and tight.

14.0 Inspect Wood Poles and Structures - Overall

- 14.1 Grading Reference:
- Appendix D (Maintenance Priority Level 1-4 Rating)
- 14.2 Sound pole, visually inspect for the following and grade using the indicated code (note – unless an immediate risk of failure exists, poles with visual rotting and/or hollow sound should be classified as a Level 4 and scheduled for a Wood Pole Inspection):
- Code 510 - Broken
 - Code 511 - Visual rotting/hollow sounding pole
 - Code 512 - Leaning
 - Code 513 - Replace single arm
 - Code 514 - Replace double arm
 - Code 515 - Repair brace
 - Code 516 - Replace brace
 - Code 517 - Replace anchor
 - Code 518 - Install anchor
 - Code 519 – Repair/replace guy wire
 - Code 521 - Tighten guy wire
 - Code 522 - Replace guy shield
 - Code 524 - Guy bonding
 - Code 525 - Lightning damage
 - Code 526 - Woodpecker damage
 - Code 527 - Insects
 - Code 528 - Aerial number missing

15.0 Inspect Wood Poles – Individual

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE ENGINEERING DEPARTMENT DOCUMENTS CABINET IN DOCUMENTUM		
File: PR 06.01.601.001 Ground Based Visual Inspection	Originating Department: Transmission Line O&M Engineering	Sponsor: Mark S. Browne

nationalgrid	TRANSMISSION LINE MAINTENANCE PROCEDURE	Doc.# PR 06.01.601.001 Page 10 of 38
	Ground Based Visual Inspection	Version 2.1 – 02/03/2011

- 15.1 Grading Reference:
- Appendix E (Maintenance Priority Level 1-4 Rating)
- 15.2 Note: A C-Truss repair is not considered a temporary repair. However, if a pole with a C-Truss is significantly deteriorated, it shall be graded as if no C-Truss was installed.
- 15.3 Identify via badge left after Wood Pole Groundline Inspection. Use only Level 4 and are meant to be a documentation of pole labeling that results from the Wood Pole Groundline Inspection:
- Code 901 - Identified priority pole
 - Code 902 - Identified reject pole
 - Code 903 - Excessive checking
 - Code 904 - Climbing inspection required
 - Code 905 - No inspection tag

16.0 Inspect Steel Poles and Structures

- 16.1 Grading Reference:
- Appendix F (Maintenance Priority Level 1-4 Rating)
- 16.2 Visually inspect for the following and grade using the indicated code:
- Code 531 - Broken legs
 - Code 532 - Aerial number missing
 - Code 534 - Loose or missing bolts/hardware
 - Code 535 - Anti climb equipment damaged/missing
 - Code 536 - Vegetation on tower
 - Code 537 - Structure damage
 - Code 538 - Tower needs straightening
 - Code 539 - Arms damaged

17.0 Inspect Conductor

- 17.1 Grading Reference:
- Appendix G (Maintenance Priority Level 1-4 Rating)
- 17.2 Note: TLOME may revise levels for conductor damage based on factors such as mechanical and electrical loading.
- 17.3 Visually inspect for the following and grade using the indicated code:
- Code 541 - Conductor condition overall
 - Code 542 - Static wire condition overall
 - Code 543 - Ground wire condition overall
 - Code 544 - Sleeve/splice/connector condition
 - Code 546 - Clearance issues

18.0 Inspect Insulators/Hardware

- 18.1 Grading Reference:
- Appendix G (Maintenance Priority Level 1-4 Rating)
- 18.2 Note – Where multiple strings of insulators are encountered, each string shall be evaluated on its own.

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE ENGINEERING DEPARTMENT DOCUMENTS CABINET IN DOCUMENTUM		
File: PR 06.01.601.001 Ground Based Visual Inspection	Originating Department: Transmission Line O&M Engineering	Sponsor: Mark S. Browne

nationalgrid	TRANSMISSION LINE MAINTENANCE PROCEDURE	Doc.# PR 06.01.601.001 Page 11 of 38
	Ground Based Visual Inspection	Version 2.1 – 02/03/2011

- 18.3 Visually inspect for the following and grade using the indicated code:
- Code 551 - Insulator damage
 - Code 552 - Insulators out of plumb
 - Code 553 - Hardware loose or damaged
 - Code 555 - Lightning arrestor issues

19.0 Inspect Foundation – General

- 19.1 Grading Reference:
- Appendix H (Maintenance Priority Level 1-4 Rating)
- 19.2 Visually inspect for the following and grade using the indicated code:
- Code 563 - Erosion

20.0 Inspect Right of Way

- 20.1 Grading Reference:
- Appendix I (Maintenance Priority Level 1-4 Rating)
 - All Code 574 – Danger Trees rated as an “F”
- 20.2 Visually inspect for the following and grade using the indicated code:
- Code 571 - Erosion
 - Code 572 - Encroachments
 - Code 573 - Debris
 - Code 574 - Danger trees
 - Code 575 - Broken gates
 - Code 576 - Oil/Gas/Hazmat leak

21.0 Inspect Miscellaneous

- 21.1 Grading Reference:
- Appendix I (Maintenance Priority Level 1-4 Rating)
- 21.2 Visually inspect for the following and grade using the indicated code:
- Code 581 - Structure not marked – ground level
 - Code 582 - Switch damaged (see below)
 - Code 583 - Switch ground damaged (see below)
 - Code 584 - Install warning sign
 - Code 585 - Replace warning sign
 - Code 586 - Remove steps
 - Code 587 - Add dirt and tamp
 - Code 589 - Bird Nest
 - Code 590 - Excessive bird perching

22.0 Inspect Switch – Visual Inspection

- 22.1 Grading Reference:
- Appendix I (Maintenance Priority Level 1-4 Rating)
- 22.2 Inspection Note:
- This inspection can be performed from the ground with the switch in service. Refer to the Line Switch Inspection Procedure, PR06.01.601.008 for further

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE ENGINEERING DEPARTMENT DOCUMENTS CABINET IN DOCUMENTUM		
File: PR 06.01.601.001 Ground Based Visual Inspection	Originating Department: Transmission Line O&M Engineering	Sponsor: Mark S. Browne

nationalgrid	TRANSMISSION LINE MAINTENANCE PROCEDURE	Doc.# PR 06.01.601.001 Page 12 of 38
	Ground Based Visual Inspection	Version 2.1 – 02/03/2011

information. Since one code is used for most of this inspection, note problem details.

22.3 Visually inspect for the following and grade using the indicated code:

- Code 582 Noise – Arcing and other abnormal noise, if energized. If disconnect switches are making unusual noises while energized, leave the area immediately and contact the appropriate control center.
- Code 582 Insulators – Surface contamination, tracing, damaged porcelain
- Code 582 Primary Connections – Discoloration of or heat rising from connections (overheating), cracks, visibly loose connections
- Code 582 Live Parts – Blades properly turned into jaws (horizontal), damaged or misaligned arcing horns, damaged, misaligned or missing parts
- Code 582 Load break interrupters – Damage or deterioration
- Code 582 Operating mechanism – Properly locked, operating pipe for breakage, bending, phase to phase linkage for breakage, bending, manual operating mechanism for damage, deterioration or missing parts
- Code 583 Operating mechanism properly grounded

23.0 Document GIS Data Issues

23.1 Grading Reference:

- Appendix I (Maintenance Priority Level 1-4 Rating)

23.2 Document all mismatches between the GIS and the field as follows:

- Code 760 - GIS map mismatch
- Code 761 - GIS – equipment stencil mismatch
- Code 762 - GIS – equipment/hardware missing
- Code 763 - GIS – equipment removed in field
- Code 769 - GIS – other GPS/GIS errors

24.0 Engineering-Specific Inspection

24.1 This section contains additional guidelines for Inspections related to engineering activities and is not to be included in the regular Ground Based Visual Inspection. The guidelines presented below shall be used by engineers completing and interpreting field Inspections as part of preliminary engineering as specified in SP.06.01.101 “Transmission Engineering and Design Services”.

24.2 The sum total of the guidance provided in sections 9 through 23 shall be used in completing engineering analysis of lines.

24.3 Notes on Priority Codes

- Priority 1 – Reserved for immediate and substantial threats to public safety and/or system reliability. These should generally be very rare
- Priority 2 – Items which require repair due to a near term risk of failure, the repairs should not wait for the normal two-year project life cycle
- Priority 3 – Repairs are required, but a more deliberate approach can be taken over a two-year period

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE ENGINEERING DEPARTMENT DOCUMENTS CABINET IN DOCUMENTUM		
File: PR 06.01.601.001 Ground Based Visual Inspection	Originating Department: Transmission Line O&M Engineering	Sponsor: Mark S. Browne

nationalgrid	TRANSMISSION LINE MAINTENANCE PROCEDURE	Doc.# PR 06.01.601.001 Page 13 of 38
	Ground Based Visual Inspection	Version 2.1 – 02/03/2011

- Priority 4 – Repairs should be completed if the work is incidental to another project, but the item can wait for the next Inspection cycle for further assessment

24.4 The following features or defects shall be determined and documented:

- Asset Information
 - Structure Number
 - Circuit
 - Tower/Pole ID# including circuit according to National Grid nomenclature
 - Tower/Pole Location in Latitude/Longitude format
 - Tower/Pole Groundline elevation
 - Structure location (City/Town and State)
- Visual Inspection
 - Year Installed
 - Tower/Pole Height
 - Structure Height
 - Structure Type
 - Structure Description (painted/galvanized/weathered/foundation)
 - Structure condition(s) and overall rating
 - Presence of steel distress or deterioration
 - Concrete foundation condition(s) and overall rating
 - Presence of concrete foundation distress or deterioration
 - Concrete foundation surface mapping diagram
 - Mechanical or fire damage
 - Broken hardware such as insulators or adversely impacted structural components such as foundations
 - Adjacent roads, railroads, parks, and other areas considered frequently accessible by the general public
 - Any unusual conditions or safety hazards
 - Digital photographs
 - Field sketches of foundation condition

25.0 Temporary Repairs

- 25.1 Some defects encountered may have been repaired temporarily. These defects shall be inspected monthly by Transmission Inspections, until a permanent repair is completed.
- 25.2 If an Inspector encounters a temporary repair, the defect shall still be reported with a note indicating a temporary repair.

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE ENGINEERING DEPARTMENT DOCUMENTS CABINET IN DOCUMENTUM		
File: PR 06.01.601.001 Ground Based Visual Inspection	Originating Department: Transmission Line O&M Engineering	Sponsor: Mark S. Browne

Appendix A – Transmission Field Survey Worksheet

TRANSMISSION FIELD SURVEY WORKSHEET						
Patrolled Circuit/No.	Unique ID	Pole/Tower No.		Voltage	District	
Additional Circuit/No.	Unique ID					
Area	Between _____ Rd. And _____ Rd.		Date	Employee ID		
TYPE	<input type="checkbox"/> A) Single <input type="checkbox"/> B) H. Frame <input type="checkbox"/> C) 3 Pole <input type="checkbox"/> D) 4 Pole <input type="checkbox"/> E) 5 Pole <input type="checkbox"/> F) 6 Pole <input type="checkbox"/> G) Flex-Tower <input type="checkbox"/> H) Square-Tower <input type="checkbox"/> I) Hairpin <input type="checkbox"/> J) Other					
MATERIAL	<input type="checkbox"/> A) Wood (fill in information for each pole, i.e., 2 pole, 3 pole, 4 pole, etc.) Height _____ Class _____ Year Set _____ Manufacturer _____ Year Last Treated _____ Treatment <input type="checkbox"/> A) External <input type="checkbox"/> B) Internal <input type="checkbox"/> C) Both <input type="checkbox"/> D) Other <input type="checkbox"/> E) Unknown <input type="checkbox"/> F) None <input type="checkbox"/> B) Steel <input type="checkbox"/> C) Lattice					
CONFIGURATION	<input type="checkbox"/> Deadend <input type="checkbox"/> Tangent <input type="checkbox"/> Switch Structure <input type="checkbox"/> Davit Arm <input type="checkbox"/> Stand Off <input type="checkbox"/> Other					
STEEL/LATTICE CONDITION	(Circle One) 1 2 3 4 5 6		FOUNDATION: STEEL CONCRETE		(Circle One) 1 2 3 4 5 6 1 2 3 4 5	
POLE *		Sub. No.	Priority Qty	CONDUCTOR **		Circuit No.
*Enter Sub No. if a Multiple Structure				**Enter Circuit No. if More Than Circuit on Pole		Priority Qty
510 1, 2 (R) <input type="checkbox"/> Broken		/	/	541 1,2,3 (R) <input type="checkbox"/> Conductor		/
511 1,4 (RP) <input type="checkbox"/> Visual Rotting		/	/	542 1,2,3 (R) <input type="checkbox"/> Static		/
512 1,2,3,4 (R) <input type="checkbox"/> Leaning		/	/	543 1,2,3 (R) <input type="checkbox"/> Ground Wire		/
513 1,2,3 (R) <input type="checkbox"/> Replace Single Arms		/	/	544 1,2,3 (R) <input type="checkbox"/> Sleeve/Conn.		/
514 1,2,3 (R) <input type="checkbox"/> Replace Double Arm		/	/	546 1,4 (NR) <input type="checkbox"/> Under 25 Ft.		/
515 1,2,3 (R) <input type="checkbox"/> Repair Braces		/	/	LINE HARDWARE		
516 1,2,3 (R) <input type="checkbox"/> Replace Braces		/	/	551 1,2,3,4 (R) <input type="checkbox"/> Insulators/Dam		/
517 1,2 (R) <input type="checkbox"/> Replace Anchor		/	/	552 4 (R) <input type="checkbox"/> Insulator Plumb		/
518 1,2,3,4 (R) <input type="checkbox"/> Install Anchor		/	/	553 1,2,3,4 (R) <input type="checkbox"/> Hardware Dam		/
519 1,2,3 (R) <input type="checkbox"/> Repair/Replace Guy Wire		/	/	555 2 (R) <input type="checkbox"/> Lightning Arrestor		/
521 2,3 (R) <input type="checkbox"/> Tighten Guy Wire		/	/	FOUNDATION – GENERAL		
522 P (NR) <input type="checkbox"/> Replace/Install Guy Shield		/	/	563 1,2,3,4 (R) <input type="checkbox"/> Erosion		/
524 4 (R) <input type="checkbox"/> Guy Not Bonded		/	/			
525 1,2,3,4 (RP) <input type="checkbox"/> Lightning Damage		/	/			
526 2,3,4 (RP) <input type="checkbox"/> Woodpecker Damage		/	/	RIGHT OF WAY		
527 2,4 (RP) <input type="checkbox"/> Insects		/	/	571 1,2,4 (NR) <input type="checkbox"/> Erosion		/
528 4 (NR) <input type="checkbox"/> Aerial Number Missing		/	/	572 4 (NR) <input type="checkbox"/> Encroachments		/
TOWER				573 4 (NR) <input type="checkbox"/> Debris		/
531 1,2 (R) <input type="checkbox"/> Tower Legs Broken		/	/	574 F (R) <input type="checkbox"/> Danger Tree		/
532 4 (NR) <input type="checkbox"/> Aerial Numbers Missing		/	/	575 4 (NR) <input type="checkbox"/> Gate Broke		/
534 1,2,3 (R) <input type="checkbox"/> Loose Bolts/Hard		/	/	576 4 (NR) <input type="checkbox"/> Oil/Gas Leak		/
535 4 (NR) <input type="checkbox"/> Repair Anti-Climb		/	/			
536 F (R) <input type="checkbox"/> Vegetation On Tower		/	/	MISCELLANEOUS		
537 1,2,3 (R) <input type="checkbox"/> Structure Damage		/	/	581 4,P (NR) <input type="checkbox"/> Stencil/Line/ Struct No. Ground level		/
538 1,2,3,4 (R) <input type="checkbox"/> Straighten Tower		/	/	582 1,2,3,4 (R) <input type="checkbox"/> Switch Damaged		/
539 1,2,3,4 (R) <input type="checkbox"/> Arms Damaged		/	/	583 2 (R) <input type="checkbox"/> Damaged Ground		/
POLE INSPECTION				584 4,P (NR) <input type="checkbox"/> Install/Replace Warning Sign		/
901 4 (RP) <input type="checkbox"/> Identified Priority Pole		/	/	586 4 (NR) <input type="checkbox"/> Remove Steps		/
902 4 (RP) <input type="checkbox"/> Identified Reject Pole		/	/	587 3,4 (R) <input type="checkbox"/> Add Dirt & Tamp		/
903 4 (RP) <input type="checkbox"/> Excess Checking		/	/	589 1,3,4 (R) <input type="checkbox"/> Bird Nest		/
904 4 (RP) <input type="checkbox"/> Climbing Inspection Req'd		/	/	590 4 (R) <input type="checkbox"/> Bird Perching		/
905 4 (RP) <input type="checkbox"/> No Inspection Tag		/	/	GIS		
NR=Maint. Code may not directly affect reliab. R=Maint. Code may affect reliability. RP = Maintenance Code may affect and has specific program in place to address.				760 4 (NR) <input type="checkbox"/> GIS Map Doesn't Match Field		/
				761 4 (NR) <input type="checkbox"/> GIS Equip. Stenciling In Error		/
				762 4 (NR) <input type="checkbox"/> GIS Equip./Hardware Missing		/
				763 4 (NR) <input type="checkbox"/> GIS Equip. Removed In Field Remove from GIS		/
				769 4 (NR) <input type="checkbox"/> GIS Other GPS/GIS Errors		/
Comments on rear of sheet NG0237 (12/09)						

Appendix B – Steel Evaluation Categories



Visual Rating 6 – Very Severe Deterioration
Perforated Element – severe physical damage




Visual Rating 5 – Significant Pitting
Significant pitting – loss of section clearly visible, edges feathered/thinned



Visual Rating 4 – Light Pitting
Some very light edge roughening. Loss of greater majority of coating and zinc layers. Corroded surface would dominate surface preparation – remedial action using wire brush, scraper and brushed paint not sufficient to give greatly increase life



Visual Rating 3 – Light Corrosion
Very light surface corrosion, majority of coating intact



Visual Rating 2 – Intact
Paint coating over all surface – overcoat may not be intact and some very small areas (<1%) of light corrosion may be present. Galvanizing intact except for some very small areas (<1%) of light corrosion




Visual Rating 1 – Serviceable
Fully painted – overcoat and undercoat intact
Fully galvanized – coating intact


Appendix C – Concrete Evaluation Categories/Rating Matrix



Honeycombing
Construction faults, poor workmanship




Pattern Cracking



Disintegration
Deterioration of concrete into small fragments



Erosion/Abrasion



Seepage
Movement of water or other fluids through pores









Spalling
Development of fragments

Distortion or Movement
Change in alignment of the components of a structure

Delamination
Degradation of steel/concrete interface


		Overall Foundation Rating				
		Very Severe Deterioration 5	Severe Deterioration 4	Medium Deterioration 3	Light Deterioration 2	Serviceable 1
Concrete Foundation Condition Categories	Cracking	Wide cracks (over 0.08" width)	Medium Cracks (between 0.04" and 0.08" width)	Fine Cracks (0.04" width)	Negligible	Negligible
	Disintegration	Very Severe Disintegration (loss of mortar and coarse aggregate at a depth greater than 0.8")	Severe Disintegration (loss of mortar between 0.4" and 0.8" around coarse aggregate)	Medium Disintegration (loss of surface mortar between 0.2" and 0.4" and exposure of coarse aggregate)	Light Disintegration (no exposure of coarse aggregate)	Negligible
	Spalling	Large spall (greater than 0.8" in depth and greater than 6" in any dimension)	Small spall (not greater than 0.8" in depth or greater than 6" in any dimension)	Negligible	Negligible	Negligible

Appendix D – Wood Poles and Structures Evaluation

Typical Pole Defects		
Bark Inclusion	Checking (Solitary)	Checking (Around Periphery of Pole)
		
<p>The growth of the main stem around a dead branch</p>	<p>The separation of fibers parallel to the grain and extending towards the center of the pole</p>	<p>Multiple checks around entire pole circumference</p>
Cross Break	Mechanical Damage	Split
		
<p>The separation of fibers perpendicular or at an angle to the grain</p>	<p>Transportation and erection damage due to machinery such as chainsaws or cranes</p>	<p>The cracking of a pole due to mechanical connections or the intersection of checks</p>
Dead Streak	Decay	Decay Knot
		
<p>The growth of the main stem around the dead wood</p>	<p>The softening of the pole due to fungal growth</p>	<p>Knots which have decayed and can extend towards the center of the pole</p>
Pocket		
<p>A Solitary Check, a series of checks at one location, or area of decay at the surface of the wood pole</p>		



510 Pole – Broken

- Used when pole is broken due to impact, stress etc.

Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
Damage poses significant risk of imminent failure	 <p>Damage is not an immediate threat to the integrity of the network or to public safety</p>	N/A	N/A


511 Pole – Visual Rotting

- Used for physical damage which compromises the strength and/or integrity of the pole (checking, dead streak, bark inclusion, cross break, decay, burning, hollow sounding pole)

Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
 <p>Damage poses significant risk of imminent failure</p>	N/A	N/A	 <p>All Others</p>


512 Pole – Leaning

- Used when pole/structure is out of plumb(excludes raked angle structures which are intentionally out of plumb due to line angle)

Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
Leaning pole which in Inspector's judgment poses immediate and substantial threat to public safety and/or system reliability	Pole top deflection in Inspector's judgment poses a near-term risk to structure integrity	 <p>Slope > 2" per 10' pole height</p>	All other leaning poles

513 Pole – Replace Single Arm

• Used for damaged single arms. Arm refers to any horizontal member extending out from the main structure generally to support the conductor.

Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
Arm damage poses immediate and substantial threat to public safety and/or system reliability	Substantial damage to cross section of arm causing the arm to deflect – failure may occur under non-extreme loading	 <p>Appreciable damage – failure may occur under extreme loading</p>	N/A

514 Pole – Replace Double Arm

• Used for damaged double arms.

Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
Arm damage poses immediate and substantial threat to public safety and/or system reliability	Substantial damage to cross section of arm causing the arm to deflect – failure may occur under non-extreme loading	Appreciable damage – failure may occur under extreme loading	N/A

515 Pole – Repair Braces


• Used for damage to braces. Braces refer to intermediate members that connect parts of the structure.

Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
Brace damage poses immediate and substantial threat to public safety and/or system reliability	Substantial damage to cross section of brace causing the arm to deflect – failure may occur under non-extreme loading	Appreciable damage – failure may occur under extreme loading	N/A

516 Pole – Replace Braces

• Used for damage to braces or missing braces. Braces refer to intermediate members that connect parts of the structure.

Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
Brace damage or lack of brace poses immediate and substantial threat to public safety and/or system reliability	Substantial damage to cross section of brace or lack of brace causing the arm to deflect – failure may occur under non-extreme loading	Appreciable damage – failure may occur under extreme loading	N/A

517 Pole – Replace Anchor			
<ul style="list-style-type: none"> • Used for damage to anchor rod or head or pull out of the anchor 			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
Guy failure poses immediate and substantial threat to public safety and/or system reliability	Anchor rod has corroded substantially or is broken, or anchor has pulled out and is no longer functioning as a structural member, or a guy should be present but is not	Appreciable damage – failure may occur under extreme loading	Superficial damage – but will not fail in 5 years
518 Pole – Install Anchor			
<ul style="list-style-type: none"> • Used when necessary anchor is missing 			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
Damage poses immediate and substantial threat to public safety and/or system reliability	Damage is not an immediate threat to the integrity of the network or to public safety	N/A	N/A
519 Pole – Repair/Replace Guy Wire			
<ul style="list-style-type: none"> • Used when a guy wire or its associated hardware, included fiberglass or wood rods, are in need of repair or replacement 			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
Guy failure poses immediate and substantial threat to public safety and/or system reliability	Guy is broken or seriously compromised (e.g. broken strands)	Guy is currently structurally sound, but has been compromised by corrosion, damage, etc.	N/A
521 Pole – Tighten Guy Wire			
<ul style="list-style-type: none"> • Used when a guy wire has gone slack, as from anchor pull out, structure movement, etc. 			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
N/A	Slack guy is causing excessive structure deflection or overstress of other guys	 <p>Slack guy is not causing excessive structure deflection or overstress of other guys or the structure</p>	N/A

522 Pole – Replace Guy Shield

- Used when guy shield is damaged. Inspector should install a new one.

All Priority Level “P” Perform


524 Pole – Guy Not Bonded

- Used when guy bond is inadequate or missing

Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
N/A	N/A	N/A	Guy not bonded




525 Pole – Lightning Damage

- Used when pole is damaged due to lightning.

Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
Damage in Inspector's judgment poses immediate and substantial threat to public safety and/or system reliability	Non-serviceable Damage	 Serviceable Damage	Superficial Damage

526 Pole – Woodpecker Damage

- Used when pole is damaged by woodpeckers creating nests in pole

Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
N/A	 Several Large (>5") Diameter Holes	 Single Large (>5") Diameter Holes	 Several Small (<5") Diameter Holes

527 Pole – Insects

- Used when pole is damaged by insects

Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
Damage poses significant risk of imminent failure	N/A	N/A	All other noticeable damage

528 Pole – Aerial Number Missing


- Used when aerial numbers are not installed where required

Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
N/A	N/A	N/A	Aerial numbers are required at all road crossing, all structures ending in zero, and the first and last structures of a line.

Appendix E – Individual Wood Pole Evaluation




<u>901 Osmose – Identified Priority Pole</u>			
• Used to document pole identified as a priority reject on Wood Pole Groundline Inspection			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
N/A	N/A	N/A	All
<u>902 Osmose – Identified Reject Pole</u>			
• Used to document pole identified as a reject on Wood Pole Groundline Inspection			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
N/A	N/A	N/A	All
<u>903 Osmose – Inspect Excessive Check (not reject)</u>			
• Used to document pole identified as having excessive checking on Wood Pole Ground Line Inspection			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
N/A	N/A	N/A	All
<u>904 Osmose – Climbing Inspection Required (not reject)</u>			
• Used to document pole identified as needing a climbing inspection on Wood Pole Ground Line Inspection			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
N/A	N/A	N/A	All
<u>905 Osmose – No Inspection Tag</u>			
• Used to document pole that has no evidence of prior Wood Pole Inspections. Not required for poles under 10 years old.			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
N/A	N/A	N/A	All

Appendix F – Steel Poles and Structures Evaluation

531 Tower – Tower Legs Broken			
<ul style="list-style-type: none"> Used when tower legs are broken 			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
Leg damage which in Inspector's judgment poses immediate and substantial threat to public safety and/or system reliability	Leg damage which in Inspector's judgment poses a near-term risk to structure integrity	N/A	N/A
532 Tower – Aerial Number Missing			
<ul style="list-style-type: none"> Used when aerial numbers are not installed where required 			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
N/A	N/A	N/A	Aerial numbers are required at all road crossing, all structures ending in zero, and the first and last structures of a line.
534 Tower – Loose Bolts/Hardware			
<ul style="list-style-type: none"> Used loose or missing connections on hardware 			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
Missing connections on members in judgment of Inspector pose an immediate and substantial threat to public safety and/or system reliability	Missing connections	 Loose Connections	N/A
535 Tower – Repair Anti-Climb			
<ul style="list-style-type: none"> Used to repair anti-climb device 			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
N/A	N/A	N/A	Anti-climbing device needs repair
536 Tower – Vegetation on Tower			
<ul style="list-style-type: none"> Used when vegetation needs to be cleared from tower 			
All Priority Level "F" - Forestry			

537 Tower – Structure Damage

- Used for broken, bent or missing members on tower

Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
 <p>Damage in judgment of Inspector poses and immediate and substantial threat to public safety and/or system reliability</p>	 <p>Broken or nearly broken members</p>	 <p>Damage/Excessive bending on minor members</p>	N/A

538 Tower – Straighten Tower

- Used when tower is out of alignment





Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
<p>Leaning tower in judgment of Inspector poses immediate and substantial threat to public safety and/or system reliability</p>	<p>Substantial deflection, near-term risk to structural stability</p>	<p>Appreciable deflection, ability of tower to sustain extreme loading conditions may be compromised</p>	<p>Aesthetic only</p>

539 Tower – Arms Damaged

- Used when the arms on a tower are damaged

Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
<p>Damaged arms in Inspector's judgment pose an immediate and substantial threat to public safety and/or system reliability</p>	<p>Arm damage poses a risk of failure under routine loading e.g. a near term risk of failure</p>	<p>Arm damage poses a risk of failure under heavy loading</p>	<p>Superficial damage only</p>


Appendix G – Conductor and Line Hardware Evaluation

541 Conductor – Bird Caging (Add comment – Bird Caging)			
<ul style="list-style-type: none"> Used to rate conductor bird caging. 			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
N/A	N/A	N/A	 Bird Caging
541 Conductor – Broken (Add comment – Broken Conductor)			
<ul style="list-style-type: none"> Used to rate conductor damage. Note: TLOME may revise priority levels based on an engineering evaluation of factors such as mechanical and electrical loading. 			
230kV and Above			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
 Any broken conductors	N/A	N/A	N/A
115kV and Below			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
 Significant percentage of broken strands	 Small percentage of broken strands	N/A	N/A



542 Conductor – Static

- Used to rate static wire damage.
- Note: TLOME may revise priority levels based on an engineering evaluation of factors such as mechanical and electrical loading.

230kV and Above

Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
 Any broken conductors	N/A	N/A	N/A

115kV and Below

Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
 Significant percentage of broken strands	 Small percentage of broken strands	Exterior damage which does not pose a near-term threat	N/A

543 Conductor – Ground Wire

- Used for any damage to the ground leads on the structure

Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
Ground wire damage in judgment of Inspector poses an immediate and substantial threat to public safety and/or system reliability; this includes a loose ground wire near the top of the pole which may be a risk to contact the conductor	Ground wire missing or disconnected/broken on 3 or more adjacent structures	Ground wire missing or disconnected/broken on isolated structures only, or ground wire is loose near the base of the pole where there is no risk of contacting the conductor	N/A

544 Conductor – Sleeve/Connector

- Used for damage to splices or connectors on the shield/static wire or conductors

Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
Failure in judgment of Inspector poses an immediate and substantial threat to public safety and/or system reliability	Visible physical damage to connector/splice/conductor	Visible corrosion at splice/connector	N/A

546 Conductor – Under 25 Feet



- Used for substandard clearances and conductors with excessive sag.

Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
Conductor poses significant risk of danger to the public	N/A	N/A	General Guidelines by Voltage: <ul style="list-style-type: none"> • 69kV – 115kV 25 ft • 230kV – 345kV 30 ft Clearances must meet requirements of latest National Electric Safety Code, as well as local requirements (e.g. MA CMR)

551 Line Hardware – Insulator Damage


- Used for chipped or broken insulators.
 - Insulators that are physically separated are always Level 1
- NOTE: A chipped or cracked insulator (porcelain damage does not reach more than ½ way to the center of the insulator) may not be counted as a damaged insulator if damage is not severe. This is up to the inspector’s discretion.

Number of Insulators in String	Number of Damaged Insulators per String			
	Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
Any	Any Physical Separation	N/A	N/A	N/A
5	2 or more	1	N/A	N/A
6	2 or more	1	N/A	N/A
7	3 or more	2	1	N/A
8	3 or more	2	1	N/A
9	3 or more	2	1	N/A
10	4 or more	3	2	1
11	4 or more	3	2	1
12	4 or more	3	2	1
13	4 or more	3	2	1
14	5 or more	3 or 4	2	1
15	5 or more	4	2 or 3	1
16	5 or more	4	2 or 3	1
17	6 or more	4 or 5	2 or 3	1
18	6 or more	4 or 5	2 or 3	1
19	6 or more	4 or 5	3	2 or less
20	6 or more	5	3 or 4	2 or less
21	7 or more	5 or 6	3 or 4	2 or less

Broken Insulators	Separated Insulators
	

552 Line Hardware – Insulator Plumb

- Used for insulators unintentionally out of plumb

Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
			
N/A	N/A	N/A	Usually a sign of high amplitude conductor movement, galloping.

553 Line Hardware – Hardware Damage

- Used for any damage to other line hardware

Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
Hardware damage in Inspector's judgment poses and immediate and substantial risk to public safety and/or system reliability	Structural Hardware damage which poses a near-term risk to structural integrity	Structural Hardware damage, e.g. damaged connections	Cosmetic Damage

555 Line Hardware – Lightning Arrestor


- Used when a lightning arrestor is damaged or has failed

Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
N/A	Arrestor has failed. Lightning arrestors fail by disconnecting and falling away from the conductor	N/A	N/A


Appendix H – Foundation Evaluation



563 Foundation – Erosion			
• Used for any erosion around foundations			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
Erosion in Inspector's judgment poses and immediate and substantial risk to public safety and/or system reliability	Erosion is compromising structural integrity	Structure not yet at risk, but erosion appears to be progressing at a significant rate	Small erosion, may eventually become significant


Appendix I – ROW/Misc./Switch/GIS Evaluation

<u>571 Right of Way – Erosion</u>			
<ul style="list-style-type: none"> Used for any overall erosion in ROW 			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
Erosion exposes counterpoise and presents a significant danger to public and/or vehicular traffic	Erosion exposes counterpoise and presents a danger to public	N/A	Any other ROW erosion, i.e. washed out road or culverts
<u>572 Right of Way - Encroachments</u>			
<ul style="list-style-type: none"> Used for any unapproved use of ROW or things too close to lines 			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
N/A	N/A	N/A	 <p>Any encroachments</p>
<u>573 Right of Way – Debris</u>			
<ul style="list-style-type: none"> Used for any debris in ROW 			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
N/A	N/A	N/A	Any debris in ROW blocking access
<u>574 Right of Way – Danger Tree</u>			
<ul style="list-style-type: none"> Used for any danger trees adjacent to lines <p>REPORT ALL TO TRANSMISSION FORESTRY</p>			
<u>Voltage</u>	<u>Vertical or Lateral Clearance</u>	<p align="center">All Priority Level “F” - Forestry</p>	
23 – 46kV	4' or less		
69kV	6' or less		
115kV	10' or less		
230kV	14' or less		
345kV	18' or less		
<u>575 Right of Way – Gate Broken</u>			
<ul style="list-style-type: none"> Used for broken ROW gates 			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
N/A	N/A	N/A	Broken gate
<u>576 Right of Way – Oil/Gas Leak</u>			
<ul style="list-style-type: none"> Used for any oil, gas leaks or other foreign substances in ROW. Notify System Delivery immediately 			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
N/A	N/A	N/A	Oil/gas found in ROW

581 Misc – Stencil Line/Structure Number at Ground			
• Used when line/structure number is missing. Inspector to stencil structure			
Priority Level 1	Priority Level 2	Priority Level P	Priority Level 4
N/A	N/A	Inspector stencils number	Inspector cannot stencil number
581 Misc – Stencil Line/Structure Number at Ground			
• Used when line/structure number is missing. Inspector to stencil structure.			
All Priority Level “P” - Perform			
582 Misc – Switch Damaged			
• Used when switch is damaged			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
Visible arcing is present or condition could result in immediate failure.	Switch may fail, burning and other evidence of arcing	Switch may not be able to be operated, but likely won't fail and put the line out of service	Insignificant damage
583 Misc – Damaged Switch Ground			
• Used for damaged switch grounds			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
N/A	Ground grid is exposed or lead is damaged	N/A	N/A
584 Misc – Install/Replace Warning Sign			
• Used for damaged or missing warning signs. Warning signs required on both sides of all structures (2 signs total).			
Priority Level 1	Priority Level 2	Priority Level P	Priority Level 4
N/A	Install warning signs at all structures that are adjacent to roads, regularly traveled pedestrian thoroughfares, or places where persons frequently gather (such as schools or public playgrounds)	Sign installed/replaced by Inspector	Install/replace signs at a low risk location where public interaction is not likely.
585 Misc – Replace Signs			
• Used for missing aerial structure signs. Aerial circuit and structure ID is required on all structures at road crossings, the first and last structures of a line, and all structures ending in zero.			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
N/A	N/A	N/A	Install/replace signs
586 Misc – Remove Steps			
• Steps must be removed at least 10' from the ground line			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
N/A	N/A	N/A	Remove steps

587 Misc – Add Dirt and Tamp			
<ul style="list-style-type: none"> Used on poles when fill dirt is insufficient 			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
N/A	N/A	Structure may be weakened by absence of tamped dirt around base	 <p>Dirt and tamping required around base of pole</p>

589 Misc – Bird Nest			
<ul style="list-style-type: none"> Used when bird nests are found on line 			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
 <p>Bird nest in Inspector's judgment poses and immediate and substantial risk to public safety and/or system reliability</p>	N/A	 <p>Limited risk of bird contact but nest should be removed</p>	<p>No risk of contact such as very small nests or those at bottom of structure</p>

589 Misc – Bird Perching			
<ul style="list-style-type: none"> Used when bird perching could lead to problems 			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
N/A	N/A	N/A	 <p>Birds perching on line or evidence of bird perching on line</p>

760 GIS – Map Does Not Match Field			
<ul style="list-style-type: none"> Used when GIS map does not match field 			
Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
N/A	N/A	N/A	Note error

761 GIS – Equipment Stenciling in Error in GIS

- Used when equipment labels do not match GIS

Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
N/A	N/A	N/A	Note error

762 GIS – Equipment/Hardware Missing in GIS

- Used when equipment is missing on GIS

Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
N/A	N/A	N/A	Note error

763 GIS – Equipment Removed in Field, Remove from GIS

- Used when equipment has been removed in field but not on GIS

Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
N/A	N/A	N/A	Note error

769 GIS – Other GPS/GIS Errors

- Used for all other GIS errors

Priority Level 1	Priority Level 2	Priority Level 3	Priority Level 4
N/A	N/A	N/A	Note error

Appendix J – Complete List of Computapole Codes

Code	Description	CAP/EXP	Default Level	Valid Levels
501	OSMOSE - Identified priority pole	C	3	2
502	OSMOSE - Identified reject pole	C	3	3
503	OSMOSE - Insp excessive check (not rej)	C	4	4
504	OSMOSE - Climbing Insp re'q (not rej)	C	4	4
901	OSMOSE - Identified priority pole	E	4	4
902	OSMOSE - Identified reject pole	E	4	4
903	OSMOSE - Insp excessive check (not rej)	E	4	4
904	OSMOSE - Climbing Insp re'q (not rej)	E	4	4
510	POLE - Broken	C	2	12
511	POLE - Visual Rotting	C	3	14
512	POLE - Leaning	E	4	1234
513	POLE - Replace Single Arms	C	3	123
514	POLE - Replace Double Arms	C	3	123
515	POLE - Repair Braces	E	3	123
516	POLE - Replace Braces	E	3	123
517	POLE - Replace Anchor	E	2	12
518	POLE - Install Anchor	C	3	1234
519	POLE - Repair/Replace Guy Wire	E	3	123
521	POLE - Tighten Guy Wire	E	3	23
522	POLE - Replace/Install Guy Shield	E	P	P
524	POLE - Guy Not Bonded	E	4	4
525	POLE - Lightning Damage	C	3	1234
526	POLE - Woodpecker Damage	E	3	234
527	POLE - Insects	E	3	14
528	POLE - Aerial Number Missing	E	4	4
531	TOWER - Tower Legs Broken	E	2	12
532	TOWER - Aerial number Missing	E	4	4
534	TOWER - Loose Bolts/Hard	E	3	123
535	TOWER - Repair Anti-Climb	E	4	4
536	TOWER - Vegetation on Tower	E	F	F
537	TOWER - Structure Damage	E	3	123
538	TOWER - Straighten Tower	E	3	1234
539	TOWER - Arms Damaged	E	3	1234
540	CONDUCTOR - Infrared Problem	E	3	123
541	CONDUCTOR - Conductor	E	3	123
542	CONDUCTOR - Static	E	3	123
543	CONDUCTOR - Ground Wire	E	3	123
544	CONDUCTOR - Sleeve/Conn	E	3	123
546	CONDUCTOR - Under 25 ft	E	4	14
547	Infrared Problem Identified	E	2	124
552	LINE HDW - Insulator Plumb	E	4	4
553	LINE HDW - Hardware Dam	E	3	1234
555	LINE HDW - Lightning Arrestor	C	2	2
556	LINE HDW - Infrared Problem	C	3	123
563	FOUNDATION - Erosion	E	3	1234
571	RIGHT OF WAY - Erosion	E	4	124
572	RIGHT OF WAY - Encroachments	E	4	4
573	RIGHT OF WAY - Debris	E	4	4
574	RIGHT OF WAY - Danger Tree	E	F	F
575	RIGHT OF WAY - Gate Broke	E	4	4

Code	Description	CAP/EXP	Default Level	Valid Levels
576	RIGHT OF WAY - Oil/Gas Leak	E	4	4
581	MISC - Stencil Lin/Struct num at ground	E	P	4,P
582	MISC - Switch Damaged	E	3	1234
583	MISC - Damaged Switch Ground	E	2	2
584	MISC - Install/Replace Warning Sign	E	4	4P
585	MISC - Replace Signs	E	4	4
586	MISC - Remove Steps	E	4	4
587	MISC - Add Dirt and Tamp	E	3	34
588	Switch - Infrared Problem	E	3	123
589	MISC - Bird Nest	E	3	134
590	MISC - Bird Perching	E	4	4
760	GIS - Map Doesn't Match Field	E	4	4
761	GIS - Equip. Stenciling In Error	E	4	4
762	GIS - Equip/Hardware Missing	E	4	4
764	GIS - Equip. Removed In Field Remove from GIS	E	4	4
769	GIS - Other GPS/GIS Errors	E	4	4

Notes

1. All Level 1 codes do not enter STORMS. The expectation is that the situation will be reported immediately, work complete within a week and a confirming work order used to track costs.
2. All Level 2 and 3 codes pass through STORMS and Design
3. All Level P codes imply that work was done by the inspector to correct defect
4. All Level F codes go to Forestry
5. All Level 4 codes are for notation only, they do not enter STORMS
6. All codes marked "E" are expense
7. All codes marked "C" are capex

Appendix 13

NG-USA EOP G017 Street Light Standard Inspection Program

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G017 Page 1 of 8
	STREET LIGHT STANDARD INSPECTION PROGRAM	Version 1.0 - 02/16/10

INTRODUCTION

The purpose of this procedure is to outline the requirements for the inspection cycle for Street Light Standard installations owned by National Grid.

The inspection shall include identifying and reporting the physical condition of street lighting equipment on street lighting standards. Street lights attached to wood poles are inspected as part of the Overhead Distribution Inspection Patrol covered by NG-USA EOP D004.

All street lighting equipment will be inspected for physical damage, potentially hazardous conditions or obvious deterioration.

Inspections will be recorded on a Windows® based hand held computer. The maintenance items identified during this inspection will be separated into four priority levels 1, 2, 3, and 4. The problem codes identified default to the appropriate level. The default level can be adjusted by the individual performing the inspection based on actual field conditions. These priority levels are defined as follows:

Level 1- An identified facility/component or tree condition that must be repaired/replaced within 1 week.

Level 2 - Identified facility/component condition that must be repaired/replaced within 1 year.

Level 3 – Identified facility/component condition that must be repaired/replaced within 3 years.

Level 4 – This priority category is to collect inventory information on actual field conditions to be used by Investment Strategy and Work Planning.

All Level 1 priority conditions identified in the field shall be called in by the Inspector as follows:

1. Notification by location:
 - a. New York: contact System Operations Dispatch 1-877-716-4996.
 - b. NE North: Westboro Control Center 1-508-389-9032.
 - c. NE South: Lincoln Control Center 1-401-335-6075.

2. Detailed information provided to the regional notification location:
 - a. Identify yourself as a Company Inspector and your work reporting area.
 - b. Details of the Level 1 Priority Condition:
 - i. Problem found.
 - ii. District, Feeder No., Line No., Tax District and Pole No.
 - iii. Street address and any additional information that would assist in finding the location of the problem.
 - iv. If you are standing by or have secured the location.

3. Notification to area Inspections Supervisor for follow-up.

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NGEOP G017 STREET LIGHT STANDARD INSPECTION PROGRAM	Originating Department: Distribution Engineering Services	Sponsor: Patrick Hogan

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G017 Page 2 of 8
	STREET LIGHT STANDARD INSPECTION PROGRAM	Version 1.0 - 02/16/10

Equipment will be inspected on a five year cycle such that one-fifth of the inspections should be scheduled on an established annual basis.

PURPOSE

This procedure applies to all personnel involved with or responsible for the inspection and maintenance of street lighting standards and associated facilities owned by National Grid.

ACCOUNTABILITY

1. Distribution Engineering Services
 - A. Update program as necessary
 - B. Provide field support and training as requested.
2. Customer Operations
 - A. Provide qualified personnel as the distribution inspectors, to provide consistent and accurate data or to contact Contract Management Services for contracting where applicable.
3. Distribution Inspector
 - A. Demonstrate the ability to identify maintenance items and the aptitude to become proficient in the use of a hand held computer and desktop computer.
 - B. Demonstrate the understanding and requirements of this National Grid EOP.
 - C. Possess the ability to do patrols, collect information on a hand held, down load to a desktop computer, edit data, provide requested information/reports/work tickets to supervision, and track/close out work completed in the database.
Provide qualified personnel to inspect where applicable.
 - D. Ensure all inspectors have been trained.
4. Contract Management Services
 - A. At the request of Customer Operations/Distribution Network Strategy obtain, schedule and manage contractors to perform inspections and perform required maintenance.
5. Network Asset Strategy
 - A. Provide input into program revisions.
 - B. Ensure the program as outlined in this EOP is completed each year.
 - C. To develop and/or revise a five-year inspection schedule of all facilities covered by this EOP.
 - D. Develop Outdoor Lighting Asset Strategy
6. Process and Systems
 - A. Provide and support database.

COORDINATION

Not Applicable

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NGEOP G017 STREET LIGHT STANDARD INSPECTION PROGRAM	Originating Department: Distribution Engineering Services	Sponsor: Patrick Hogan

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G017 Page 3 of 8
	STREET LIGHT STANDARD INSPECTION PROGRAM	Version 1.0 - 02/16/10

REFERENCES

Applicable National Grid Safety Rules and Procedures
 NY PSC Order 04-M-0159
 NY PSC Order Adopting Changes to Electric Safety Standard, December 2008
 Elevated Equipment Voltage NG-USA EOP G016

DEFINITIONS

Patrol: A walking assessment of distribution facilities for the purpose of determining the condition of the facility and it's associated components.

Hand Held Computer: A portable, self-contained electronic data recording device used to create a record of conditions found in the field.

Inspector: A qualified employee or contractor who can identify deficiencies, or non-standard construction conditions, on the Company's street light facilities.

Valid User: An individual who has been authorized to use the Street Lighting Maintenance Program by the Program Administrator.

Street Light Standard: A metallic or fiberglass shaft and arm assembly which supports street lighting luminaire(s) and associated wiring.

TRAINING

T&D Technical Training - Provide training upon request.

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NGEOP G017 STREET LIGHT STANDARD INSPECTION PROGRAM	Originating Department: Distribution Engineering Services	Sponsor: Patrick Hogan

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G017 Page 4 of 8
	STREET LIGHT STANDARD INSPECTION PROGRAM	Version 1.0 - 02/16/10

DOCUMENT CONTENTS

Table of Contents

1.0 STREET LIGHT PATROLS 5

2.0 EQUIPMENT TO BE INSPECTED AND MAINTENANCE CODES 5

3.0 STREET LIGHT MAINTENANCE DATABASE/REPORTS 7

4.0 MAINTENANCE SCHEDULE 7

5.0 COMPLETION 7

6.0 REVISION HISTORY 8

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NGEOP G017 STREET LIGHT STANDARD INSPECTION PROGRAM	Originating Department: Distribution Engineering Services	Sponsor: Patrick Hogan

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G017 Page 5 of 8
	STREET LIGHT STANDARD INSPECTION PROGRAM	Version 1.0 - 02/16/10

1.0 STREET LIGHT PATROLS

Street Lighting inspections will be performed as patrols and are conducted by a street light qualified worker. The patrols are scheduled in such a manner that street lighting facilities are inspected once every five years. The Outdoor Lighting group is responsible for creating and/or revising this schedule for the respective geographic areas. The Distribution Inspector uses a Windows® based hand held computer to record employee ID, region, district, street lighting installation standard number, GPS location, Priority Level 1, 2, 3 and 4 maintenance items, and comments. The listing of these maintenance items are shown in Table I. Any new facilities added to the system will be incorporated through our Customer Service System – Outdoor Lighting (CSS-OL) database and added to the appropriate inspection cycle. The street light standards inspections scheduled for the year shall be completed by December 31st. The inspector shall place the CSS-OL street light standard number on the facility if not found numbered during the patrol.

2.0 EQUIPMENT TO BE INSPECTED AND MAINTENANCE CODES

- 2.1 Luminaires
- 2.2 Arms
- 2.3 Standards
- 2.4 Foundations
- 2.5 Conductor

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NGEOP G017 STREET LIGHT STANDARD INSPECTION PROGRAM	Originating Department: Distribution Engineering Services	Sponsor: Patrick Hogan

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G017 Page 6 of 8
	STREET LIGHT STANDARD INSPECTION PROGRAM	Version 1.0 - 02/16/10

TABLE I

PRIORITY 1, 2 and 3 MAINTENANCE ITEMS FOR OUTDOOR LIGHTING

Category	CODE	Default Priority	Description
Luminaire	300	2	Light "ON" Day
	301	2	Replace Lens
	302	4	Clean
	303	4	Paint
	304	4	Replace Wattage Label
	305	1	Wires Exposed
	306	2	Damaged - Replace
	307	4	Missing
	308	4	Other - Comments
Arm	320	2	Damaged - Replace
	321	4	Damaged - Repair
	322	4	Rust - Paint
	323	4	Other - Comments
Standard	330	2	Structure Damage - Replace
	331	4	Damaged/Leaning - Repair
	332	4	Paint/Maintenance
	333	1	Access Cover - Replace
	334	4	Bad Wiring - Repair
	335	4	Stencil Required
	336	2	Temporary Overhead *
	337	2	Ground - Repair
	338	4	Knockdown/Missing
339	4	Other - Comments	
Foundation	350	4	Damaged/Leaning - Repair
	351	4	Anchor Bolts Damaged
	352	4	Elevated - Repair
	353	4	Other - Comments

Note: The default priority of Level 4 for missing luminaires and street light standards is utilized for informational use only. If the street light standard is missing or missing a luminaire, the item shall be reviewed with records, if found to be a required and an active asset it shall be changed to a Level 1 priority.

***Refer to EOP NG-EOP G029 (Tracking Temporary Repairs to Electric System) for tracking and reporting of temporary repairs.**

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G017 Page 7 of 8
	STREET LIGHT STANDARD INSPECTION PROGRAM	Version 1.0 - 02/16/10

3.0 STREET LIGHT MAINTENANCE DATABASE/REPORTS

The Street Light Maintenance Data Base consists of records downloaded from the hand held computers and information entered from the desktop computers. The records can be downloaded to the database through any desktop computer that is connected to the network and the inspector is logged on as a valid user of the Street Light Standard Inspection program. The desktop computer is also used to generate various reports and work tickets, depending on the user's need. These reports/work tickets are utilized to schedule and accomplish distribution maintenance work.

4.0 MAINTENANCE SCHEDULE

Maintenance activities are scheduled by priority Levels. All "Level 1 Priority" conditions identified must be repaired/corrected within 1 week. All "Level 2 Priority" conditions identified must be repaired/corrected within 1 year. All "Level 3 Priority" conditions must be repaired within 3 years. Level 4 Priority is for inventory purposes only.

Once the Street Light Patrol is completed in the Street Light Maintenance Database or 21 days have elapsed since the inspection, the Level 2 and Level 3 Priority maintenance codes are downloaded into STORMS. Expense maintenance work goes straight to scheduling while the capital work goes to Distribution Design. Level 1 Priority maintenance codes are communicated by the Distribution Inspector directly to the field operations group for the area where the feeder is located.

5.0 COMPLETION

The completion of Level 1 priority maintenance codes is performed by the field operations Supervisor or their designee. Level 2 and Level 3 priority maintenance codes are tracked in the Street Light Maintenance database and placed into the Customer Service System – Outdoor Lighting (CSS-OL) database. CSS-OL database automatically initiates a STORMS order. CSS-OL database is updated once the associated STORMS orders are complete for the work request associated with the maintenance code from the Street Light Database.

ALL MAINTENANCE WORK IS TO BE COMPLETED PER NATIONAL GRID DISTRIBUTION STANDARDS.

ALL MAINTENANCE WORK PREFORMED THAT WAS IDENTIFIED ON THE WORK ORDER OR DISCOVERED DURING THE REPLACEMENT/REPAIR/CORRECTION OF THE ORGINAL MAINTENANCE PROBLEM MUST BE LISTED ON THE DATABASE AND THEN CLOSED OUT WHEN COMPLETE

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED.		
FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NGEOP G017 STREET LIGHT STANDARD INSPECTION PROGRAM	Originating Department: Distribution Engineering Services	Sponsor: Patrick Hogan

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G017 Page 8 of 8
	STREET LIGHT STANDARD INSPECTION PROGRAM	Version 1.0 - 02/16/10

6.0 REVISION HISTORY

<u>Version</u>	<u>Date</u>	<u>Description of Revision</u>
1.0	02/16/10	This document supercedes document dated 07/25/05.

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NGEOP G017 STREET LIGHT STANDARD INSPECTION PROGRAM	Originating Department: Distribution Engineering Services	Sponsor: Patrick Hogan

Appendix 14

NG-USA EOP G004 Shock Complaints

nationalgrid	ELECTRIC OPERATING PROCEDURE	Doc. # NG-EOP G004
	GENERAL	Page 1 of 7
	Shock Complaints	Version 1.0 – 07/14/11

INTRODUCTION

This procedure describes the requirements for investigating and reporting on a customer's shock complaint. A shock complaint is a customer call that states a person has received a shock. When investigating of a shock complaint, Company field personnel must determine if the shock was caused by faulty customer equipment, a neutral-to-earth voltage associated with the Company's distribution system, or an external DC voltage source. Regardless of the cause, a shock complaint is considered an emergency and shall be dispatched as soon as possible. The appropriate Dispatch or Control Center shall be notified of all shock incidents by the field, and all communications shall be completed as required by National Grid Electric Operating Procedure NG-EOP G009.

PURPOSE

This document details specific steps that should be followed when National Grid receives a shock complaint call.

ACCOUNTABILITY

1. Distribution Engineering Services
 - A. Update procedure as necessary
2. Operations
 - A. Ensure that this procedure is understood and implemented
 - B. Ensure that all personal are trained in this procedure.
3. Employee
 - A. Demonstrate the understanding of this procedure.
 - B. Comply with the requirements of this procedure.

COORDINATION

N/A

REFERENCES

National Grid Employee Safety Handbook
 National Grid Safety and Health Policies & Procedures
 NG-USA EOP G003 Shock and/or Neutral-to-Earth Voltage Complaint
 NG-EOP G009 Personal Injury Accidents/Newsworthy Event Reports
 Metering Services Department Procedure MS505 Shock Complaint
 Metering Services Department Procedure MS508 Warning Tag Electric
 National Grid OH Construction Standards

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G004 Shock Complaints MGA	Originating Department: Distribution Engineering Services	Sponsor: Susan Fleck

nationalgrid	ELECTRIC OPERATING PROCEDURE	Doc. # NG-EOP G004
	GENERAL	Page 2 of 7
	Shock Complaints	Version 1.0 – 07/14/11

DEFINITIONS

Shock Voltage: Voltage between two points that is high enough to be perceptible to people.

Primary Voltage: All distribution circuit cables or conductors energized at 4, 15, 23, or 34.5 kV.

Shall: The word shall is to be understood as mandatory.

Should: The word should is understood as recommended.

TRAINING

Provide line personnel with training, through progression schools and as necessary.

DOCUMENT CONTENTS

Table of Contents

1.0 SAFETY 2

2.0 ORDER PROCESSING 2

3.0 INVESTIGATION 3

4.0 REVISION HISTORY 7

1.0 SAFETY

- 1.1 All work shall be performed in accordance with the National Grid Employee Safety Handbook and all appropriate National Grid Electric Operating Procedures.
- 1.2 All appropriate Personal Protective Equipment including, but not limited to, hard hat, safety glasses/eye protection, rubber protective equipment, appropriate footwear and FR clothing shall be worn when performing work as required by the National Grid Employee Safety Handbook and applicable work procedures.

2.0 ORDER PROCESSING

- 2.1 Regardless of the cause, all shock complaints are considered an emergency order type that requires immediate dispatch. When the Customer Contact Center (CCC) receives a call from a customer stating that a person has received a shock, the CCC:
 - 2.1.1 Immediately transfers to Dispatch any calls from 911 officials with an associated emergency or life threatening situation.

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED.		
FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G004 Shock Complaints MGA	Originating Department: Distribution Engineering Services	Sponsor: Susan Fleck

nationalgrid	ELECTRIC OPERATING PROCEDURE	Doc. # NG-EOP G004
	GENERAL	Page 3 of 7
	Shock Complaints	Version 1.0 – 07/14/11

- 2.1.2 Retrieve the customer's account information and verify the customer's account information on the Account window.
- 2.1.3 Inform the customer that someone needs to be present at the premise in order for the shock complaint to be investigated. Inform the customer that their service may be disconnected if no one is present at the premise and a problem is detected.
- 2.1.4 Complete the Issue Investigation Order for Account or a Service Order Form (paper copy) in its entirety and fax the completed form to the appropriate dispatch office when the Customer Service System is down.
- 2.1.5 Call Dispatch office to verify receipt the Investigation Order or the Faxed Service Order.

3.0 INVESTIGATION

- 3.1 The individual investigating (generally a field service representative) a shock complaint shall:
 - 3.1.1 Initiate Shock and/or Neutral to Earth Voltage Complaint Investigation Form NG0024 (Exhibit 1) <http://infonetus/formscatalogweb/forms/NG0024.pdf>
Use this form on **every** shock complaint order, even when the individual conducting the investigation resolves the problem him/herself without involving outside departments.
 - 3.1.2 Make the first check with a National Grid approved testing device between a known ground source and the origin of the shock.
 - 3.1.3 If the test between the ground and the shock source indicates higher than secondary voltages:
 - a. Safely evacuate customer(s) from the premise.
 - b. Contact Customer Meter Services Supervisor and System Operations Dispatch from a remote location and request Electric Operations assistance.
 - c. Safeguard and keep the hazardous area clear until Electric Operations provides relief.
 - 3.1.4 If the test between ground and the source of the shock indicates secondary or lower voltages:
 - a. Connect an AC multi-range voltmeter (such as Fluke 87) that provides true RMS at the same location and observe the readings. Leave the voltmeter connected at this location.
 - b. Check for proper bonding. If additional bonding is required, assist or advise the customer accordingly.
 - c. Open the customer's main breaker(s)/fuse(s), remove the meter and observe the voltmeter.

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G004 Shock Complaints MGA	Originating Department: Distribution Engineering Services	Sponsor: Susan Fleck

nationalgrid	ELECTRIC OPERATING PROCEDURE	Doc. # NG-EOP G004
	GENERAL	Page 4 of 7
	Shock Complaints	Version 1.0 – 07/14/11

1. If voltage drops to zero, the problem is within the customer's equipment.
 - i. Reinstall meter and close main breaker(s)/fuse(s).
 - ii. Isolate the trouble circuit by opening each breaker/fuse one at a time until the voltage reading on the voltmeter drops to zero.
 - iii. Identify equipment and wiring on troubled circuit.
 - iv. Isolate and disconnect troubled equipment or wiring and issue an Electric Warning Tag Form NG0023 (Exhibit 2).
<http://infonetus/formscatalogweb/forms/NG0023.pdf>
 - v. The individual conducting the investigation shall inform the customer to contact a licensed electrician or appliance repair person to check out internal wiring or appliances.
 - vi. Record this information on the Shock and/or Neutral to Earth Voltage Complaint Investigation Form NG0024 (Exhibit 1).
2. If the voltage does not drop to zero, each customer on the same secondary shall be disconnected in the same manner as above. Any other customers in close proximity and with a common water supply may also have to be checked. In each case, the voltmeter should remain connected at the original complaint's premise.
3. If voltage is still present after steps 1 & 2 have been completed, it will be necessary to determine if the condition is the result of a neutral-to-earth AC source or a DC voltage. Connect the AC-DC multi-range voltmeter that provides true RMS and use the DC scale to observe readings:
 - i. If DC voltage is measured, the problem is with a DC source (i.e., cable TV, telephone). Inform the customer that the problem is with a source that National Grid cannot correct or check.
 - ii. Record this information on the Shock and/or Neutral to Earth Voltage Complaint Investigation Form NG0024 (Exhibit 1).
 - iii. Notify Communications Companies.
4. If voltage is still present after steps 1 & 2 have been completed and the voltage is AC:
 - i. Further investigation is required by the Engineering Lab in NE or the Meter and Test Department in NY as per Electric Operating Procedure G003 – Shock and/or Neutral-to-Earth Voltage Complaint.
 - ii. Record this information on the Shock and/or Neutral to Earth Voltage Complaint Investigation Form NG0024 (Exhibit 1) and forward to the Engineering Lab in NE or the Meter and Test Department in NY.

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED.		
FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G004 Shock Complaints MGA	Originating Department: Distribution Engineering Services	Sponsor: Susan Fleck

nationalgrid	ELECTRIC OPERATING PROCEDURE	Doc. # NG-EOP G004
	GENERAL	Page 6 of 7
	Shock Complaints	Version 1.0 – 07/14/11

EXHIBIT 2
“Warning Notice” Form #NG0023
<http://infonetus/formscatalogweb/forms/NG0023.pdf>

WARNING NOTICE

TO OUR CUSTOMER

M _____

In response to your request we have inspected your electrical installation and found the cause of your service failure to be as follows:

- _____ Short in _____
- _____ Defective _____
- _____ Overloaded Branch Circuit
- _____ General Overload
- _____ Over-fused Branch Circuits
- _____ _____

NOTE: Replacing of blown fuses will not correct the trouble listed above.

We recommend that you call your:

- _____ Electrical Contractor
- _____ Appliance Repairman

to make the necessary repairs.

nationalgrid

SERVICE REP _____
 DATE _____

NG0023(01.06)

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED.		
FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G004 Shock Complaints MGA	Originating Department: Distribution Engineering Services	Sponsor: Susan Fleck

nationalgrid	ELECTRIC OPERATING PROCEDURE	Doc. # NG-EOP G004
	GENERAL	Page 7 of 7
	Shock Complaints	Version 1.0 – 07/14/11

4.0 REVISION HISTORY

<u>Version</u>	<u>Date</u>	<u>Description of Revision</u>
1.0	07/14/11	This document supersedes document dated 02/01/07.

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G004 Shock Complaints MGA	Originating Department: Distribution Engineering Services	Sponsor: Susan Fleck

Appendix 15

**NG-USA SMS 400.06.1 Substation V&O
Inspection Standard and SMP 400.06.2
Substation Inspection Procedure**

nationalgrid	SUBSTATION MAINTENANCE Standard	Doc. # SMS 400.06.1 Page 1 of 4
	Visual and Operational Inspection (V&O)	Version 2.0 – 06/30/09

INTRODUCTION

Substation Inspection or Visual and Operational (V&O) Inspection of each Substation and Switchyard is a key element in the National Grid USA preventive maintenance program. V&O Inspections are performed with the apparatus in service and are designed to detect abnormal conditions before the apparatus is damaged or a customer outage occurs. Data collected during the V&O Inspection is one of the elements used by AIMMS to prioritize individual apparatus for complete and diagnostic inspections.

PURPOSE

N/A

ACCOUNTABILITY

N/A

COORDINATION

N/A

REFERENCES

N/A

DEFINITIONS

N/A

TRAINING

N/A

DOCUMENT CONTENTS

Table of Contents

1.0 SCHEDULE 2

2.0 PROBLEMS AND DISCREPANCIES..... 2

3.0 V&O GUIDELINES..... 2

4.0 REVISION HISTORY 3

nationalgrid	SUBSTATION MAINTENANCE Standard	Doc. # SMS 400.06.1 Page 2 of 4
	Visual and Operational Inspection (V&O)	Version 2.0 – 06/30/09

1.0 SCHEDULE

- 1.1 Each transmission and distribution substation and switchyard will have a V&O Inspection at least bimonthly.

2.0 PROBLEMS AND DISCREPANCIES

- 2.1 Severe Trouble shall be reported to the responsible Control Center and the person in charge of the substation immediately.
- 2.1.1 The employee shall secure the area and warn unauthorized people to stay clear of the danger.
- 2.1.2 A severe trouble condition is a situation that is hazardous to the system operation and/or National Grid employees or the public.
- 2.2 Problems and discrepancies found should be repaired during the V&O Inspection whenever possible.
- 2.3 Problems and discrepancies not corrected during the V&O Inspection shall be recorded on the Inspection Card (Apparatus Inspections) or as a note in the PDA (Station V&O Inspections).
- 2.3.1 The Supervisor reviewing the inspection shall generate follow-up work orders to document the required work.

3.0 V&O GUIDELINES

- 3.1 To provide uniform and effective V&O Inspections throughout National Grid, the Substation Maintenance Standards and Procedures Books should be referenced for detailed information on the inspection of each type of apparatus.
- 3.1.1 Some of the typical items to be checked include: air, hydraulic and gas pressures, operation counters, oil levels and temperatures, and visual condition.
- 3.2 The station should be inspected for cracked or broken line terminators, bus supports and post insulators, heat discolored wire and wire terminations and blown surge arresters. All fuses and disconnects should be checked for proper seating and heat discoloration.
- 3.3 Alarm and communication radios operation should be verified. The telephones should be checked for proper operation.
- 3.4 Station Service secondary supplies should be checked alive and transfer switches checked for correct position.
- 3.5 Structures and foundations should be inspected for deterioration, damage and paint condition.
- 3.6 Substation security measures must be checked for proper operation and signs of unauthorized entry. This includes: fencing, gates, warning signs, entry alarms, locks and chains.
- 3.7 General substation housekeeping should also be taken care of.

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: SMS 400.06.1 Visual and Operational Inspection	Originating Department: Substation O&M Services	Sponsor: Donald T. Angell

nationalgrid	SUBSTATION MAINTENANCE Standard	Doc. # SMS 400.06.1 Page 3 of 4
	Visual and Operational Inspection (V&O)	Version 2.0 – 06/30/09

4.0 REVISION HISTORY

<u>Version</u>	<u>Date</u>	<u>Description of Revision</u>
1.0	12/26/06	Corrected - Formatting Changed - Header title, Document number prefix Changed - First page footer to reference Documentum Removed – Subtitle Added – AIMMS PM numbers
1.1	05/23/07	Document Added - Documentum Version # to headers Added - File name to footer
1.2	08/20/07	Problems And Discrepancies Added - Section
2.0	06/30/09	Converted to new EDO format - content unchanged

nationalgrid	SUBSTATION MAINTENANCE Standard	Doc. # SMS 400.06.1 Page 4 of 4
	Visual and Operational Inspection (V&O)	Version 2.0 – 06/30/09

[PAGE INTENTIONALLY LEFT BLANK]

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: SMS 400.06.1 Visual and Operational Inspection	Originating Department: Substation O&M Services	Sponsor: Donald T. Angell

VISUAL AND OPERATIONAL (V&O) INSPECTION

INTRODUCTION

This procedure describes the methods used to perform Visual and Operational (V&O) Inspections of electrical substations used in the transmission and distribution of electricity.

PURPOSE

V&O Inspections, are performed with the apparatus in service, and are used to:

- Verify the security of fences, gates etc. that prevent entry of the public, and provide a legal record of their inspection.

- Detect any hazards to company employees or the public.

- Verify that animal protection measures are present and in good condition.

- Detect abnormal conditions before the apparatus is damaged or a customer outage occurs.

- Collect data (counter readings, fault operations etc.) used to prioritize individual apparatus inspections.

- Collect data (regulator travels, load readings, relay targets etc.) used for system operation purposes.

ACCOUNTABILITY

Substation and other Supervisors supervising inspection and maintenance activities.

Substation and other Workers performing inspection and maintenance activities.

REFERENCES

National Grid USA Safety Handbook

SMS 400.13.1 Oil Leak Reporting Procedure

SMS 400.08.1 Trouble Reporting Procedure

EP-14 Oil Filled Electrical Equipment Management

Manufacturer's Installation, Operating, and Maintenance manuals for the specific equipment to be inspected.

Manufacturer's operating manuals for the specific test equipment to be used.

PROCEDURE CONTENTS

Table of Contents

1.	TEST EQUIPMENT REQUIRED.....	2
2.	MATERIALS REQUIRED.	2
3.	INITIAL SUBSTATION ENTRY	2
4.	INSPECT YARD	3
5.	NOTIFY THE SYSTEM OPERATOR.....	3
6.	REPORTING AND CORRECTING PROBLEMS AND DISCREPANCIES	3
7.	CONTROL HOUSE	4
8.	YARD INSPECTION.....	7
9.	OIL LEAK REPORTING	9
10.	APPARATUS INSPECTIONS	10
11.	FINAL CHECKLIST	12
12.	APPENDIX A. - ADDITIONAL MATERIALS	12
13.	APPENDIX B – TROUBLE REPORTING	15
14.	RECORD OF REVISIONS.....	16

1. Test Equipment Required.

- 1.1 Digital Multi-meter, IEC 1010-1 Cat. IV
 - 1) Spare battery
- 1.2 Recloser Battery test meter with load test feature.
 - a) For Form 3 Recloser battery tests.

2. Materials Required.

- 2.1 PDA with National Grid V&O software installed.
- 2.2 Clipboard
- 2.3 Binoculars
- 2.4 Flashlight
- 2.5 Magnet for resetting drag hands
- 2.6 Additional items listed in Appendix A

3. Initial Substation Entry

- 3.1 Personal Protective Equipment.
 - 1) Minimum requirement is ANSI Z41/EH rated safety footwear, hard hat and safety glasses.
- 3.2 Vehicles entering substation.
 - 1) Lower and/or insure antennas will maintain minimum approach distances to energized conductors and apparatus.
 - 2) Use extreme caution when maneuvering to avoid hitting apparatus or violating Minimum Approach Distances.

4. Inspect Yard

- 4.1 Perform a quick initial inspection for:
- 1) Alarms.
 - 2) Cut or removed ground grid or ground grid connections.
 - 3) Obvious damage.
 - 4) Security of gates, fence and locks.
 - 5) Unusual noises.

5. Notify the System Operator

- 5.1 Inform them you are in the Station for a V&O Inspection and that you will be testing alarms.
5.2 Ask System Operator if any equipment has been tagged out or relays blocked.

6. Reporting and Correcting Problems and Discrepancies

- 6.1 Severe Trouble shall be reported to the responsible Control Center and the person in charge of the substation immediately.
- 1) The employee shall secure the area and warn unauthorized people to stay clear of the danger.
 - 2) A severe trouble condition is a situation that is hazardous to the system operation and/or National Grid employees or the public.
 - a) See Trouble Reporting Appendix at the end of this document for additional information on trouble reporting.
- 6.2 See the section Oil Leak Reporting for information on reporting oil leaks.
- 6.3 Document all paint and preservation problems.
- 1) Rust, corrosion, or fading to the point where primer, or bare metal shows.
- 6.4 Problems and discrepancies found should be repaired during the V&O Inspection whenever possible.
- 6.5 Problems and discrepancies not corrected during the V&O Inspection shall be recorded on the Inspection Card (Apparatus Inspections) or as a note in the PDA (Station V&O Inspections).
- 1) The Supervisor reviewing the inspection shall generate follow-up work orders to document the required work.
- 6.6 Record findings in the PDA if listed in the PDA "round".
- 1) Record other readings or problems as Notes in the PDA
 - 2) If performing an apparatus inspection record the V&O Inspection portion in the V&O section of the Inspection Card.

7. Control House

- 7.1 Check control house door locks working and in good condition.
- 7.2 Station Log Book
 - 1) Enter the date, time and employee names that are performing the V&O Inspection.
 - 2) Check the Station Log Book for abnormal conditions that can be corrected during the V&O Inspection.
 - a) After the V&O Inspection, record all abnormal problems found in the Log Book, with red pen, and whether they were corrected or not.
- 7.3 SPCC – SPCC locations only.
 - 1) Verify SPCC Plan is available at the substation.
 - 2) Verify SPCC notification list posted.
 - 3) Check oil spill containment kits complete and in good condition.
- 7.4 Control Panels
 - 1) Indicating Lights
 - a) Check that the indicating lights on the control board are working.
 - b) Check the available stock of spare bulbs; restock as necessary.
 - c) Inspect rear of Control boards for any signs of overheating, burned wiring, moisture, etc.
- 7.5 Noises - Listen for any unusual noises from relays, modules, RAPRs, timer circuits etc.
- 7.6 Relay targets and alarms.
 - 1) Record targets and alarms on the V&O Report and in the station log book.
 - a) List the apparatus affected indicating circuit designation, phase and type of relay or alarm,
 - 2) Reset and report relay targets and alarms to the System Operator and your supervisor.
- 7.7 Reclosing Relays
 - 1) Check that reclosing relays are in service.
 - a) Record any reclosing relays that are off and tagged.
 - b) Report any reclosing relays that are off and not tagged to the System Operator.
 - 2) Verify mechanical reclosing relays are in the start or zero position.
- 7.8 Ground Trip Switches (cutouts)
 - 1) Check that all ground trip relays are in service (ON).
 - a) Record any ground trip switches that are off and tagged.
 - b) Report any ground trip switches that are off and not tagged to the System Operator.

7.9 Bus Transfer Schemes

- 1) Check both buses alive (load ammeters, bus voltmeters bus alive lights).
- 2) Check timers reset
- 3) Check that the sequence timers in normal position
- 4) Check transfer scheme auto
 - a) Record any auto transfer switches that are manual or off and tagged.
 - b) Report any auto transfer switches that are manual or off and not tagged to the System Operator.
- 5) Check tie breakers properly setup (setup varies by station scheme).

7.10 High Side Transfer Schemes

- 1) Check both lines alive (load ammeters, line alive lights).
- 2) Check timers reset
- 3) Check that the sequence timers in normal position
- 4) Check transfer scheme auto
 - a) Record any auto transfer switches that are manual or off, and tagged.
 - b) Report any auto transfer switches that are manual or off, and not tagged to the System Operator.
- 5) Check air break/circuit breaker/circuit switcher status (open or closed).

7.11 Annunciator and Alarm Test Switches

- 1) Annunciator panel
 - a) Move toggle switches, that are not tagged, to the TEST position to check lights. This will send an alarm to the Control Center.
 - b) To clear trouble condition, turn the toggle switch to the reset position, then back to ON.
 - c) Check with supervisor before testing any switches that are in the off position.
 - d) Verify the System Operator received the alarms.
- 2) Test Switches
 - a) If the alarm light is on perform steps b) through f).
 - b) Verify the System Operator received the alarm.
 - c) Open knife blades one by one and leave open until the light goes out and the alarm clears.
 - d) Close the knife switches opened one at a time, checking for alarm indications.
 - e) When the alarm light comes on reopen the last switch closed and continue closing the rest. This will find multiple alarms, if present.
 - f) Operating the knife switches does not reset this type of alarm system. The light only stays out when the trouble condition has cleared.

- 3) Repair of alarm conditions.
 - a) Alarm conditions should be corrected during the V&O Inspection.
 - b) If the alarm condition can not be corrected during the V&O:
 - The alarm should be cleared by opening the test twitch or turning the annunciator switch to OFF.
 - The switch should be tagged with the date, reason and inspectors name.
 - Both the System Operator and your supervisor should be notified that the alarm condition exists and the alarm point is off.

7.12 Radio Alarms

- 1) Inspect condition of radio system for damage, and proper operation.
- 2) If individual alarms have not been sent to the System Operator send a test alarm to from the radio cabinet.
 - a) Verify the System Operator received the alarm.
- 3) Make sure cabinet door is closed so the receiver voice communication is disabled.

7.13 Tags and Clearance and Control switching forms and Supplies

- 1) Check the stock of Clearance and Control Tags.
 - a) Restock as necessary.
- 2) Check the stock of Ground Device Identification Tickets (GDIT).
 - a) Restock as necessary.
- 3) Check the stock of Filed Switching Order Pads
 - a) Restock as necessary.
- 4) Check that pens (red and blue/black) and pencils are available.
 - a) Restock as necessary.

7.14 Control House Heating and Lighting

- 1) Test control house lighting.
 - a) Replace any defective bulbs, or ballasts or sockets.
- 2) Test emergency lighting.
 - a) Replace batteries if needed
- 3) Inspect heaters, fans and thermostats for proper operation. Make sure fans are not broken or bound up and they are in good working order.

7.15 Station Service and Transfer Switch

- 1) Check transfer switch on preferred supply
- 2) Check transfer switch for damage or overheating.
- 3) Test and record preferred and alternate secondary voltages at transfer panel.

7.16 Check AC supply panels for:

- 1) Tripped circuit breakers.
- 2) Circuit breakers in the proper position.

7.17 Check DC Circuit Breaker of Fuse Panel

- 1) Check DC supply panels for:
 - a) Tripped circuit breakers or blown fuses.
 - b) Circuit breakers in the proper position.

7.18 Protective Grounds

- 1) Check that grounds in station are in sets of 3 and that they are hung up properly.
- 2) Check that the phase end and ground clamps are in good working order.
- 3) Lubricate as required.
- 4) Inspect for the cracked or cut insulation and broken conductor strands.
- 5) Replace or repair damaged protective grounds. Do not leave damaged grounds at the station.

7.19 Switch Sticks

- 1) Inspect Switch Sticks and Grounding Sticks for current dielectric test date.
 - a) Send out of date sticks to lab for testing or;
 - b) Test locally using approved methods, test equipment and competent, trained personnel.
- 2) Inspect Switch Sticks and Grounding Sticks for surface contamination, damage and proper operation.
 - a) Clean if necessary
- 3) Insure Switching and Grounding Sticks are stored properly.

7.20 Fire Equipment

- 1) Inspect fire extinguishers to be properly secured and in their marked locations.
- 2) Update inspection cards.
- 3) Record out of date fire extinguishers on the V&O and record for future replacement.
- 4) Discharged fire extinguishers shall be reported to the appropriate supervisor for recharging.
- 5) Discharged or partially discharged fire extinguisher shall be removed from the substation.

7.21 Phone Lists

- 1) Verify local and regional System Operator phone numbers are posted and correct.
- 2) Verify that the emergency telephone list is posted and clearly visible at each telephone location.

7.22 Cleanliness and General Condition -

- 1) Clean control house floors and sanitary facilities, empty wastebaskets and dust as necessary.
- 2) Inspect control house for water leaks.
- 3) Check for signs of animal entry into control house.

7.23 Turn on yard lights, so they can be checked during the Yard Inspection.

8. Yard Inspection

8.1 Unusual Noises

- 1) Be alert for arcing, gurgling and pinging noises which could indicate imminent and violent equipment failure.

8.2 Walk the fence and inspect:

- 1) Barbed wire - Strands to be intact and tight.
- 2) Fence fabric - Holes or breaks in the chain link.

- 3) Fence Ties - Loose or missing fence tie wires.
 - 4) Fence Erosion - Signs of erosion or digging under the fence.
 - a) Space below fence should be less than 3 inches.
 - 5) Grounding - Ground conductor and connections secure and connected at every other fence post. Posts on both sides of gates should be grounded.
 - 6) Fence Posts – Sound, not rusted through at ground level and not been raised by frost.
- 8.3 Gates
- 1) Test gates for proper operation.
 - a) Gates should swing easily out of the way.
 - 2) When closed, the gates should be chained tightly, or locked, with minimal space.
 - 3) Verify locking chains, hardware and locks present and in good condition.
- 8.4 Check for proper “Danger High Voltage” warning signs:
- 1) Every 50 feet along perimeter of fence.
 - 2) On gates and on non-hinged side of gate. (see National Grid Standard #0105)
- 8.5 Substation yard security problems shall be corrected or reported immediately to supervisor.
- 8.6 Vandalism related problems should be specifically recorded as such, and reported to supervisor.
- 8.7 Yard Lights
- 1) Check all yard lights working. (Yard lights should have been turned on during control house inspection.)
 - 2) Repair broken bulbs, glass fixtures, spot light heads, or other lighting that needs attention.
 - a) If work cannot be completed safely and while maintaining safe work clearances or if special equipment such as a bucket truck is needed, note on the V&O report.
- 8.8 Vegetation
- 1) Check for any growth of trees or vegetation in fence and gate areas that animals or people could use to climb over the fence.
 - a) Cut or record for the Arborist to have removed.
 - 2) Record vegetation growth within the substation that requires spraying or removal.
- 8.9 Bus and structure.
- 1) Record missing or damaged animal protection devices.
 - 2) Inspect insulators for:
 - a) Broken, chipped or damaged skirts.
 - b) Carbon tracking or flash over.
 - c) Surface contamination (dirt, rust, salt spray etc.).
 - d) Broken or damaged insulators should be recorded on V&O Report.
 - 3) Broken porcelain should be picked up off the ground.
 - 4) Visually inspect current and voltage transformers for damage or signs of overheating.
 - 5) Visually inspect arresters for:
 - a) Blown or damaged arresters
 - b) Surface contamination

- 6) Visually inspect potheads and cable terminators for:
 - a) Damage and leaking compound.
 - b) Surface contamination
- 7) Report unusual noises immediately and record them on the V&O Report.
- 8.10 Structure and apparatus ground connections
 - 1) Inspect for any cut, broken or missing ground connections to apparatus, structures and guy wires.
 - 2) Inspect static wires and record any problems.
 - 3) Visually Inspect Station Service Transformers for:
 - a) Evidence of oil leaks on transformer tank, and on the ground.
 - b) Bushing damage or surface contamination.
 - c) Damaged or improperly closed primary fuses.
 - d) Output Voltage if not previously measured at station service transfer switch.
- 8.11 Inspect equipment and structure foundations.
 - 1) Large cracks.
 - 2) Settling (not level).
 - 3) Deterioration (large areas of surface erosion, stone showing).
- 8.12 Inspect Cableways
- 8.13 Damage, missing or broken cover sections and deterioration.
- 8.14 Inspect buildings junction boxes, structures etc. for overall paint condition
 - a) Record items needing attention.
- 8.15 Clean up substation yard.
 - 1) Remove broken porcelain, debris, and trash
 - 2) If area requires major clean up or crushed stone requires leveling, note on V&O Report.
 - 3) If equipment or materials are intentionally stored in the yard insure that they are neatly placed and not a hazard to personal. Barricade area if necessary.
 - a) Storage should be in compliance with SMS 499.10.1 Substation Work Area Identification Procedure.

9. Oil Leak Reporting

- 9.1 Oil filled apparatus must be inspected for any signs of leaks.
 - 1) The oil leak status shall be recorded for each piece of oil filled apparatus that has an oil leak screen in the PDA.
 - 2) Leaks from small apparatus that do not have an oil leak screen in the PDA should be recorded in a PDA notes screen.
- 9.2 Oil Leak Status Codes
 - 1) Oil leaks are categorized as follows:
 - a) Unknown – Unknown is used to indicate that no information has been entered in AIMMS for this equipment.
 - b) Clean - Apparatus is dry and shows no evidence of oil leaks.

- c) Repaired – A leak is found and repaired, note the repairs made.
 - d) Weep - Anytime the external surface of a piece of apparatus is wet with oil. Note the location and, if possible, cause of the leak.
 - e) Leak - Oil is running off or about to run off the external surface of containers or electrical apparatus. Required Action
- 9.3 Leaks categorized as Leak require immediate action to stop the leak or contain the released oil.
- 9.4 All leaks require creation of a Leak Report Work Order.
- 1) When the supervisor reviews the V&O inspection work order round screen all leak status changes and notes will show up as exceptions.
 - 2) The Supervisor will then create a Leak Report Work order (Type LR) in Work Order Tracking or Quick Reporting.
- 9.5 Leaks from PCB Equipment
- 1) If a leak is discovered from equipment classified as over 500 ppm PCB cleanup must begin within 48 hours (40 CFR 761.30(a)(1)(x)).
 - 2) The inspection records must also include:
 - a) The location of the leak;
 - b) The estimate of fluid released;
 - c) The date and description of any cleanup, containment, repair or replacement;
 - d) The results of any containment (for example, was containment successful or not).
 - e) The daily inspection results required for uncorrected, active leaks (refer to Environmental Procedure EP-14).
 - f) The records must be available for inspection by the EPA and must be maintained for at least three years after disposal of the equipment.

10. Apparatus Inspections

Refer to the V&O Inspection sections of the following SMS's for apparatus inspections.

Circuit Breakers

- SMP 401.01.2 – Air Magnetic Circuit Breaker Maintenance Procedure
- SMP 401.02.2 – Oil Circuit Breaker Maintenance Procedure
- SMP 401.03.2 – Vacuum Circuit Breaker Maintenance Procedure
- SMP 401.04.2 – Air Blast Circuit Breaker Maintenance Procedure⁵
- SMP 401.05.2 – Two Pressure Gas Circuit Breaker Maintenance Procedure
- SMP 401.06.2 – Gas Puffer Circuit Breaker Maintenance Procedure
- SMP 401.07.2 – Station Recloser Maintenance Procedure
- SMP 401.08.2 – Vacuum Switch Maintenance Procedure

Transformers

- SMP 402.01.2 – Power – 15 MVA and above Maintenance Procedure
- SMP 402.02.2 – Power – Below 15 MVA Maintenance Procedure
- SMP 402.03.2 – Dry Type Transformer Maintenance Procedure

Instrument Transformers

- SMP 403.01.2 – Currents, Potentials and Metering Maintenance Procedure Voltage Regulators
- SMP 404.01.2 – Step Voltage Regulator Maintenance Procedure
- SMP 404.02.2 – Induction Voltage Regulator Procedure

Emergency Generators

- SMP 405.01.2 – Emergency Generators Maintenance Procedure

Batteries & Chargers

- SMP 406.01.2 – Lead/Acid Battery Maintenance Procedure
- SMP 406.03.2 – Static Chargers Maintenance Procedure

Sensing Devices

- SMP 407.01.2 – Bushing Potential Device Maintenance Procedure
- SMP 407.02.2 – Coupling Capacitors and CCVTs Maintenance Procedure
- SMP 407.03.2 – Wave Trap Maintenance Procedure
- SMP 407.04.2 – Resistive Coupled Potential Device Maintenance Procedure

Capacitors

- SMP 408.01.2 – Station Capacitor below 69kV Maintenance Procedure

Disconnect Switches

- SMP 409.01.2 – Disconnect Switches Maintenance Procedure
- SMP 409.02.2 – Circuit Switchers Maintenance Procedure
- SMP 409.03.2 – High Speed Grounding Switch Maintenance Procedure
- SMP 409.04.2 – Gas Insulated Disconnect Switch Maintenance Procedure
- SMP 409.05.2 – Gas Insulated Ground Switch Maintenance Procedure

Load Tap Changer

- SMP 412.01.2 – Load Tap Changer Maintenance Procedure

Reactors

- SMP 413.01.2 – Dry Type Reactor Maintenance Procedure
- SMP 413.02.2 – Oil Filled Reactor Maintenance Standard

Metal Clad Bus and Switchgear

- SMP 417.02.2 – Metal Clad Bus, Switchgear and Substation Maintenance Procedure

Surge Arresters

- SMP 419.01.2 – Surge Arrester Maintenance Procedure

Network Protectors

- SMP 421.03.2 – Network Transformers and Protectors Maintenance Procedure

11. Final Checklist

- 11.1 Turnoff yard lights
- 11.2 Verify all abnormal conditions found are entered in station log book.
- 11.3 Call the System Operator and notify them that the V&O Inspection has been completed and you will be leaving the station.
 - a) Report any abnormal conditions, alarms or relay targets found.
- 11.4 Turn control house lights off and lock doors.
- 11.5 Re-arm security alarms.
- 11.6 Close and securely lock gate.
- 11.7 Turn in completed V&O Inspection Report to supervisor.
- 11.8 Return PDA to cradle and upload Station Inspection "round".

12. Appendix A. - Additional Materials

Not all of the listed items will be required in all areas. It is suggested that the items required for a particular area be stocked in the vehicle used for V&O Inspections or a large container that can be taken when inspections are to be done.

- 12.1 Cleaning Supplies
 - 1) Broom and dust pan
 - 2) Rags
 - 3) Trash bags
- 12.2 Repair and Maintenance
 - 1) Shovel
 - 2) Ladder
 - 3) Electrical tape
 - 4) Small hand tools
- 12.3 Personal Protective Equipment
 - 1) Acid resistant gloves
 - 2) Face Shield and Apron
- 12.4 Station Supplies
 - 1) Spare Station Log Books
 - 2) System Operator (phone number) cards
 - 3) Spare operations counter cards
 - 4) Pen, pencils and erasers (red pencil for trouble)
 - 5) Clearance and Control Tags
 - a) Red Tags
 - b) Non-Reclose Assurance (NRA) Tags
 - c) Hold Tags
 - d) Station Control (SCT) Tags
 - e) Worker Placards
 - 6) Ground Device Identification Tickets (GDIT)
 - 7) Clearance and Control Switching forms

12.5 Security Supplies

- 1) Spare Padlocks Locks:
 - a) Long shank 5105873
 - b) Short shank 5105872
- 2) Chain for gates
- 3) Fence tie wire
- 4) Fence fabric
- 5) Warning signs 0810029

12.6 Indicating Lamps and Lenses:

- 1) Switchboard. LED (Red) S/C 5100183
- 2) Lens Cap (Red) S/C 5695322
- 3) Switchboard. LED (Green) S/C 5100184
- 4) Lens Cap (Green) S/C 5695321
- 5) Switchboard. LED (Amber & White) S/C 5100185
- 6) Lens Cap (Amber) S/C 5695320
- 7) Lens Cap (White) S/C 5100186
- 8) Switchboard Lamp 24EX S/C 5844590
- 9) Switchboard Lamp 145 Volt, 15W S/C 5841410
- 10) Indicating Bulb type 49 S/C 5843078
- 11) Indicating Bulb type 47 S/C 5843100
- 12) 18 Volt Miniature 0.11A Automotive S/C 5843110
- 13) Indicating 35V, .06A S/C 5843132
- 14) Indicating type 43A S/C 5843250
- 15) Switchboard Lamp 24X S/C 5844610
- 16) Switchboard Lamp 55C S/C 5844630
- 17) Indicating Lamp 120 P.S.B. S/C 5841359
- 18) (for V.S.A. Reclosers)

12.7 Incandescent Lamps:

- 1) Incandescent Lamp 75 Watt S/C 5841739
- 2) Incandescent Lamp 100 Watt S/C 5841840
- 3) Incandescent Lamp 135 Watt S/C 5842001
- 4) Incandescent Lamp 200 Watt S/C 5842150
- 5) Mogul Base Lamp 500 Watt S/C 5842390 Flood lamp PAR 38 100 Watt S/C 5842045
- 6) Fluorescent Lamps:
- 7) 8 FT Single Pin Lamp 75 Watt S/C 5841050
- 8) 4 FT Bi - Pin Lamp 40 Watt S/C 5840950
- 9) 4 FT Single Pin Lamp 40 Watt S/C 5840940
- 10) 8 FT Recessed Pin Lamp 105 Watt S/C 5841130

12.8 Spare emergency light batteries

12.9 Spare fuses

12.10 Recloser control and trip fuses

- a) Reclosers often use time delay fuses that are similar in appearance to AGC types. If the wrong type fuse is installed it will blow after a couple of operations.
- 2) Cartridge fuses
 - a) 5A
 - b) 10A
 - c) 15A
 - d) 20A
 - e) 30 A
- 3) AGC Fuses
 - a) 2 A slow blow and instantaneous
 - b) 5A slow blow and instantaneous
 - c) 10A slow blow and instantaneous
 - d) 20A slow blow and instantaneous

12.11 Spare nitrogen bottles

12.12 Battery Supplies

- a) 5 Gallon distilled water and battery filler S/C 5599778
- b) Battery NO SMOKING Signs S/C 5483448
- c) Extra hydrometer S/C 5474448
- d) Extra thermometer S/C 487304
- e) Baking Soda
- f) Spare eyewash bottles S/C 5890600
- g) Nylon brush to clean battery posts
- h) Battery grease

12.13 Spare recloser batteries

13. Appendix B – Trouble Reporting

13.1 Trouble

- 1) The term trouble is defined as any condition which occurs on the equipment that has or could affect the ability of that equipment to perform its required function.

13.2 Severe Trouble

- 1) A severe trouble condition is a situation that is immediately hazardous to the system operation and/or personnel. These troubles are immediately reported to the System Operator and to the person in charge of the substation. The employee shall secure the area and warn unauthorized people to stay clear of the danger.
- 2) Examples of Severe Trouble
 - a) Dead station battery
 - b) Blown bushings or cable terminator
 - c) Downed live lines
 - d) Multiple broken support insulators
 - e) Electrical fires
 - f) Grounds cut in station
 - g) Loss of station service power
 - h) Broken pole or structure
 - i) Blown by pass/shunt arresters on regulators
 - j) Low oil levels
 - k) Unusually noises

13.3 Not Immediately Fixable Trouble

- 1) These troubles are reported to the System Operator and the person in charge of the substation. They shall also be noted on the V&O form and station logbook in red and scheduled for repair at a later date.

13.4 Examples of Not Immediately Fixable Trouble

- a) Surge Arrester blown
- b) Broken operating rods on disconnects
- c) Damaged bus support insulators

13.5 Fixable Trouble

- 1) Fixable items should be repaired as they are discovered during the V&O Inspection. This insures that the station is maintained in the best possible operating condition and prevents unnecessary return trips. The items fixed should be noted on the V&O Report and in the station logbook.
- 2) Examples of Fixable Trouble
 - a) Low Battery electrolyte
 - b) Replacing blown lamps
 - c) Changing filters
 - d) Installing missing covers

- e) Installing signs
- f) Repairing holes in fence
- g) Installing new locks
- h) Cleaning and repairing oil leaks
- i) Tightening compressor belts
- j) Changing recloser batteries
- k) Replacing control fuses
- l) Changing nitrogen bottles
- m) Changing Silica Gel turned pink or white
- n) Cleaning and repairing leaks

14. Record of Revisions

Revision	Changes
08/20/2007	Reporting Changed – Section name to Reporting and Correcting Problems and Discrepancies Revised – Section extensively revised Materials Required Removed - Substation V&O Inspection Report form, Inspection Report from last V&O Inspection, Substation V&O Checklist form.
09/30/2007	Switch Sticks Added - or; Test locally using approved methods, test equipment and competent, trained personnel.

Appendix 16

NG-USA EOP G029 Tracking Temporary Repairs To Electric System

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G029 Page 1 of 5
	TRACKING TEMPORARY REPAIRS TO ELECTRIC SYSTEM	Version 1.0 – 05/07/10

INTRODUCTION

The purpose of this procedure is to outline the steps to be taken when a temporary repair is made to the electric system to restore service or maintain public safety until a permanent repair can be made. Every effort should be made to make permanent repairs within 90 days. For those rare exceptions when permanent repairs are not made within 90 days, special reporting and periodic site visits are required to monitor the temporary repairs until the permanent repairs are completed.

PURPOSE

This procedure applies to all personnel who are responsible for initiating temporary repairs along with employees who are responsible for designing, planning, scheduling and construction of permanent repairs made at locations where temporary repairs were made to restore service or maintain public safety.

ACCOUNTABILITY

1. Distribution Engineering Services
 - A. Update procedure as necessary.
2. Customer Operations
 - A. Ensure the components of the procedure are implemented.
 - B. Ensure workers are trained in this procedure.
 - C. Provide revision input as necessary.
3. Workers
 - A. Demonstrate the understanding of the procedure.
 - B. Comply with the requirements of the procedure.
4. Inspections
 - A. Ensure components of this procedure are implemented.
 - B. Track temporary repairs identified by Inspections
 - C. Provide periodic inspections of temporary repairs greater than 90 days.
 - D. Compile and submit report to PSC.

COORDINATION

Not Applicable

REFERENCES

State of New York Public Service Commission Order 04-M-0159
 State of New York Public Service Commission Order 04-M-0159 Adopting Changes to Electric Safety Standards Effective December 15, 2008.

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G029 Tracking Temporary Repairs to Electric System	Originating Department: Distribution Engineering Services	Sponsor: Patrick Hogan

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G029 Page 2 of 5
	TRACKING TEMPORARY REPAIRS TO ELECTRIC SYSTEM	Version 1.0 – 05/07/10

DEFINITIONS

Confirming Work Request: Any emergency work completed in the field, does not require scheduling and is not billable to a 3rd party.

Level 9: This priority category is used when a temporary repair is identified in the field by Inspections.

Non-confirming Work Request: Any emergency work not completed in the field, requires scheduling and is not billable to a 3rd party.

Permanent Repair: Repaired in accordance with National Grid Standards.

Property Damage Claim: Billable emergency work.

TRAINING

Provided by appropriate National Grid training program.

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G029 Tracking Temporary Repairs to Electric System	Originating Department: Distribution Engineering Services	Sponsor: Patrick Hogan

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G029 Page 3 of 5
	TRACKING TEMPORARY REPAIRS TO ELECTRIC SYSTEM	Version 1.0 – 05/07/10

DOCUMENT CONTENTS

Table of Contents

1.0 TEMPORARY REPAIRS MADE BY OPERATIONS 4

2.0 TEMPORARY REPAIRS DISCOVERED BY INSPECTIONS 4

3.0 TEMPORARY OVERHEAD REPAIRS (TOH) 4

4.0 TEMPORARY REPAIRS NOT COMPLETED WITHIN 90 DAYS 4

5.0 NYS PUBLIC SERVICE COMMISSION REPORTING 5

6.0 REVISION HISTORY 5

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G029 Tracking Temporary Repairs to Electric System	Originating Department: Distribution Engineering Services	Sponsor: Patrick Hogan

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G029 Page 4 of 5
	TRACKING TEMPORARY REPAIRS TO ELECTRIC SYSTEM	Version 1.0 – 05/07/10

1.0 TEMPORARY REPAIRS MADE BY OPERATIONS

Temporary repairs that are made by operations to restore service or maintain public safety until permanent repairs can be made; are recorded by Distribution Support Services utilizing a pre-formatted form that will require all pertinent information needed in order for the Temporary Repair to be entered into the Maintenance Database. The form will then be e-mailed to a 'group' mailbox that the Inspections Department Administrative staff will be authorized to access. Information from the attached form will be used by the admins to enter the Temporary Repair into the Maintenance Database with the appropriate maintenance code, and assigned a priority of Level 9. The Level 9 would indicate that this a temporary repair that should be completed within 90 days. Maintenance codes assigned a Level 9 will be downloaded from the maintenance database nightly into STORMS. Level 9 codes associated with a maintenance item will be assigned directly to Scheduling to be scheduled within 20 business days. Level 9 codes that require design will be downloaded from maintenance database and placed in the work queue for the Distribution Design Supervisor or Engineering Supervisor for the appropriate area. Scheduling will have 20 business days to schedule the Level 9 work request to the field for completion.

2.0 TEMPORARY REPAIRS DISCOVERED BY INSPECTIONS

Temporary repairs located by Inspections during an inspection are to be recorded in the Maintenance Database with the appropriate maintenance code and with an assigned priority Level 9. The Level 9 would indicate that this a temporary repair that should be completed within 90 days. Maintenance codes assigned a Level 9 will be downloaded from the maintenance database nightly into STORMS. Level 9 codes associated with a maintenance item will be assigned directly to Scheduling to be scheduled within 20 business days. Level 9 codes that require design will be downloaded from maintenance database and placed in the work queue for the Distribution Design Supervisor or Engineering Supervisor for the appropriate area. Scheduling will have 20 business days to schedule the Level 9 work request to the field for completion.

3.0 TEMPORARY OVERHEAD REPAIRS (TOH)

Temporary overhead repairs (TOH) are utilized by operations to restore service while the underground cable that generally serves the facilities is being repaired. TOH's that meet National Grid Overhead Standards for construction would not be considered a temporary repair that would need to be tracked under this procedure. TOH's not meeting National Grid Overhead Standards for construction are required to be tracked under this procedure as a temporary repair and follow the process outlined in paragraph 1 above.

4.0 TEMPORARY REPAIRS NOT COMPLETED WITHIN 90 DAYS

Every effort should be made to complete temporary repairs within 90 days. In extraordinary circumstances, which may include major storms, where repairs may extend beyond 90 days (exceptions), the company shall periodically perform site visits to monitor the condition of the temporary repairs. The company shall also report these exceptions as part of the reporting requirements outlined in the State of New York Public Service Commission Order 04-M-0159 Adopting Changes to Electric Safety Standards Effective December 15, 2008.

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G029 Tracking Temporary Repairs to Electric System	Originating Department: Distribution Engineering Services	Sponsor: Patrick Hogan

nationalgrid	ELECTRIC OPERATING PROCEDURE GENERAL	Doc. # NG-EOP G029 Page 5 of 5
	TRACKING TEMPORARY REPAIRS TO ELECTRIC SYSTEM	Version 1.0 – 05/07/10

The Inspections group is responsible for tracking all temporary repairs that extend beyond 90 days. The initial periodic inspection should take place after 90 days and every 45 days until the permanent repair is made. The Inspection supervisor should run a report from the maintenance database for open Level 9 codes. The periodic inspection time frame lines up with the periodic inspection requirements for the elevated voltage findings requirements and could be run at the same intervals.

It is strongly encouraged that these temporary repairs be completed as soon as practicable to limit the burden of tracking these repairs.

5.0 NYS PUBLIC SERVICE COMMISSION REPORTING

Temporary repairs that are beyond 90 days must be identified and justified as part of the reporting requirements of the PSC Orders referenced below. The 90 days time period commences on the day the temporary repair was made or the day the temporary repair was located. Inspections will be responsible for consolidating the temporary repair information from operations and from the maintenance database in order to prepare the report that will be submitted to the PSC. The report will identify the temporary repairs that exceeded 90 days, the periodic site visit information and the justification for the repair taking longer than 90 days. Inspections shall file the report by February 15 each year.

6.0 REVISION HISTORY

<u>Version</u>	<u>Date</u>	<u>Description of Revision</u>
1.0	05/07/10	This is a new document.

PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE OR DOCUMENTUM.		
File: NG-EOP G029 Tracking Temporary Repairs to Electric System	Originating Department: Distribution Engineering Services	Sponsor: Patrick Hogan

Appendix 17

Certifications

residential distribution (“URD”) facilities, overhead and underground transmission facilities, and substation fences owned by the Company at least once every five years (“Facilities”), all as identified through a good faith effort by the Company for stray voltage (the “Stray Voltage Testing Program”).

3. I am responsible for overseeing the Company’s Stray Voltage Testing Program.
4. I hereby certify that, to the best of my knowledge, information, and belief the Company has implemented and completed its Stray Voltage Testing Program for the Twelve Month Period. Except for untested structures that are identified as inaccessible in the Company’s Annual Report and those Facilities that were already tested at least once during the five-year period ended December 31, 2014, the Company is unaware of any Facilities, Underground Distribution Facilities, or Streetlights that were not tested during the Twelve-Month Period in accordance with the Stray Voltage Testing Program.
5. I make this certification subject to the condition and acknowledgement that it is reasonably possible that, notwithstanding the Company’s good faith implementation and completion of the Stray Voltage Testing Program, there may be Facilities, Underground Distribution Facilities, and Streetlights that, inadvertently, may not have been tested or were not discovered or known after reasonable review of Company records and reasonable visual inspection of the areas of the service territory where Facilities, Underground

Distribution Facilities, and Streetlights were known to exist or reasonably expected to be found.




Keith P. McAfee

Sworn to before me on this 13th day of February, 2015

Notary Public: 

DONALD M. DE BOIS
Notary Public, State of New York
Registration #01DE6272609
Qualified In Albany County
Commission Expires November 19, 2016

3. I am responsible for overseeing the Company's Facility Inspection Program.
4. I hereby certify that, to the best of my knowledge, information, and belief the Company has implemented and completed its Facility Inspection Program to inspect approximately 20 % of its Facilities during calendar year 2014, to comply with the five-year inspection cycle required under the Orders.
5. I further certify that, to the best of my knowledge, information, and belief, the Company has inspected 100% of its Facilities for the five-year period ended December 31, 2014, except for those identified in the Company's Annual Report.


Keith P. McAfee

Sworn to before me on this 13th day of February, 2015

Notary Public:



DONALD M. DE BOIS
Notary Public, State of New York
Registration #01DE6272609
Qualified In Albany County
Commission Expires November 19, 2016