

ADAM T. CONWAY, ESQ.
aconway@couchwhite.com 518.320.3423 **direct** 518.426.0376 **fax**

May 28, 2024

VIA DMM

Hon. Michelle L. Phillips
Secretary to the Commission
New York State Public Service Commission
Three Empire State Plaza
Albany, New York 12223-1350

Re: Case 23-E-0207 - Notice of Intent of Empire State Dairy LLC to Submeter Electricity at 2840 Atlantic Avenue, Brooklyn, Located in the Territory of Consolidated Edison Company of New York, Inc.

Case 11-M-0710 - In the Matter of Reviewing and Amending the Electric Submetering Regulations, 16 NYCRR Part 96

Correspondence - Meter Test Form

Dear Secretary Phillips:

Pursuant to the *Order Authorizing Submetering* issued on November 27, 2023 in Case 23-E-0207, attached please find a Meter Test Plan for 2840 Atlantic Avenue, Brooklyn, New York, for filing in the above captioned dockets.

Please contact me with any questions.

Respectfully submitted,

COUCH WHITE, LLP

Adam T. Conway

Adam T. Conway

Attachment

NYPSC ANNUAL IN-SERVICE SUBMETER TEST FORM

Please fill out this form completely. Use additional sheets if need.

Date: May 28th, 2024

Building Owner: Empire State Dairy LLC

Contact Name: Jeffrey Schon

Telephone Number: 917-570-4807

Email Address: jeffrey@bushburg.com

**Name of any third party
conducting testing on your
behalf:** SATEC Inc.
10 Milltown Court
Union, NJ 07083
solson@satecinc.com

**Meter Type (you must provide
a separate test plan form for each
unique meter type (“type”
includes make, model, grade,
class, and series)** SATEC BFM136-60Hz

Building Address where this 2840 Atlantic Avenue
Brooklyn NY 11207

Sampling Method Used (Circle One)

Periodic Selective **Variable** Statistical

a.) List the number of all meters of this type in use for customer billing:

320

b.) List how many meters of this type will be excluded from your test program:

307

Explain the reason(s) for exclusion (any excluded meters should be subject to a corrective action plan). We are only testing 4% of the meter population per year

c.) Number of meters included in test population: 13

d.) List the number of meters of this type to be tested: 13

Explain the basis for sample size. If you used a calculation to derive this number, show the calculation: Variable Sample Size of 4% of total meter population. Total Meter population of 320 meters * 4% = 12.8%, rounded up to 13 meters.

e.) Indicate the general location of this meter type in your building (e.g. apartments, meter room, etc.) Meters are located outside electrical distribution boards, in closets.

f.) Describe the meter test equipment that will be used: Dranetz EP 1 Power Analyzer. Device is calibrated annually and traceable to NIST. Calibration records are available upon request.

g.) Describe your test schedule, including any planned testing dates, and expected date of completion: The field testing will be conducted during September of 2024.

h.) Please provide any relevant additional information: N/A