

ELECTRIC EMERGENCY PLAN

December 15th, 2025



Statement of Compliance

Central Hudson Gas & Electric Corporation's (Central Hudson or Company) Electric Emergency Plan (the Plan) constitutes the policies, procedures and guidelines that will be followed by Central Hudson in response to a severe weather, cyber-attack, or other emergency event that results in, or is expected to result in, loss of power to a substantial number of customers in our service territory. In addition to the policies, procedures and guidelines that make up the Plan, the following principles of compliance, consistent with the New York Public Service Law, New York Compilation of Codes, Rules and Regulations, and the New York State Public Service Commission's ("NYS PSC" or the Commission) Orders will apply to this Plan:

1. The procedures, policies and guidelines herein will be followed by all personnel engaged in the emergency response, to the extent possible given the unique circumstances of the event.
2. The Plan will be saved electronically in a location accessible by all Company employees.
3. The Plan will be filed with the Secretary of the NYS PSC annually on Dec. 15, or, if no changes are made from the prior year's plan, a statement to that effect will be filed with the Secretary.
4. Any additional plan requirements ordered by the PSC will be incorporated into the Plan as directed.
5. Copies of the Plan, and all related documents, will be provided to the New York State Department of Public Service ("NYS DPS") Office of Resilience, Utility Security, Nuclear Affairs and Emergency Preparedness Director, or designee.
6. A printed copy of the current Plan (phone numbers redacted) will be available at the Company's main headquarters at 284 South Avenue, Poughkeepsie, NY for viewing by the public upon request.
7. Material changes to the Plan will be filed with the PSC Secretary within 60 days following the modification.
8. If, under emergency conditions, or other circumstances related to a national pandemic, the Company modifies our response from that in the Plan to the extent required to restore service in a safe and efficient manner, the modifications and the circumstances that caused them will be reported in writing to the PSC Secretary within 60 days from restoration of full service. Minor changes need not be reported but should be made to the Plan as soon as practical.
9. Within 30 days following an event lasting more than three days, or when requested by NYS DPS-Staff ("Staff") the Company will provide Staff with the data necessary to complete the Emergency Response Performance Measures scorecard or will apply to the PSC Secretary for an extension of time to provide the required data.

Contents

1	Overview	6
1.1	GLOSSARY OF ACRONYMS	6
1.2	Introduction	8
1.3	Safety	9
1.4	Annual Emergency Exercise	9
1.5	Training	11
1.6	Contact Lists.....	12
1.7	Critical Facilities.....	13
1.8	Contact with Local Municipal Officials	14
1.9	Customer Storm Preparedness Information	14
1.10	Mutual Assistance Group Membership	15
1.11	Storm/Incident Staffing.....	15
2	Incident Command System	17
2.1	Organization Charts	17
2.2	Position Descriptions	17
3	Pre-Event Planning.....	18
3.1	Pre-Event Staff Communication	18
3.2	Command Staff Responsibilities	18
3.3	General Staff Responsibilities.....	20
4	During Event.....	22
4.1	Assessment.....	22
4.1.1	Helicopter Patrols.....	23
4.1.2	Preliminary Assessment	23
4.1.3	Detailed Damage Assessment	24
4.2	Restoration.....	24
4.2.1	Restoration Priorities	26
4.2.2	Road Clearing Coordination.....	27
4.2.3	Mutual Assistance	28
4.2.4	Logistics	30
4.3	Emergency Materials.....	33
4.4	Flooding of Customer or Company Equipment	34
4.5	Estimated Time of Restoration (ETR)	34
4.6	Coordination with Bordering Utilities	34
4.7	De-mobilization.....	35
4.8	Storm Credit and Protection	36

- 5 Post Event 37
 - 5.1 Storm Scorecard 37
 - 5.2 Revisions to Electric Emergency Plan..... 38
- 6 Communication 39
 - 6.1 Estimated Time of Restoration 39
 - 6.2 IVR Upfront Messages..... 39
 - 6.3 DPS and State OEM Communication..... 40
 - 6.4 Municipal Conference Calls 41
 - 6.5 Telecom Communication 43
 - 6.6 County EOC and Municipal Official Support..... 43
 - 6.7 Critical Facilities and Managed Customers 45
 - 6.8 News Releases and Media Information 46
 - 6.9 Social Media, Email, Website, and Text Messaging 47
 - 6.10 Life Support Equipment and Special Needs Customer Contacts 49
 - 6.10.1 Definitions 49
 - 6.10.2 Communication Procedures..... 49
 - 6.11 Contact Center Staffing 49
 - 6.12 Call Routing and Customer Contact Methods 50
- 7 Procedures 52
 - 7.1 Estimated Time of Restoration Protocols 53
 - 7.1.1 Event Expected to Last 48 Hours or Less 54
 - 7.1.2 Event Expected to Last Greater Than 48 Hours 55
 - 7.2 ETR Procedure..... 57
 - 7.2.1 Blue Sky Day..... 57
 - 7.2.2 Class 1 Incident..... 58
 - 7.2.3 Class 2 Incident 59
 - 7.2.4 Class 3 Incident 60
 - 7.3 Life Support Equipment and Special Needs Customer Contact Procedure..... 62
 - 7.3.1 Identification 62
 - 7.3.2 LSE and Special Needs Customer Outreach 63
 - 7.3.3 LSE and Special Needs Incident Contact Details 63
 - 7.3.4 Sample Scripts for LSE and Special Needs Calls 65
 - 7.4 Wire Down Procedure 67
 - 7.5 Damage Assessment Process..... 72
 - 7.5.1 Wire Down Procedure for Damage Patrollers..... 73
 - 7.6 Outage Management System Support Procedure 76
 - 7.7 Flood Restoration Procedure..... 79

- 7.7.1 Activation 79
- 7.7.2 Pre-Event 79
- 7.7.3 During Event..... 80
- 7.7.4 Post-Event 81
- 7.7.5 Communication 81
- 7.8 Loop Crew Guidelines..... 82
 - 7.8.1 Purpose 82
 - 7.8.2 Personnel Available for Loop Crews 82
 - 7.8.3 Work Methods..... 83
 - 7.8.4 Loop Crew A Crew Complements..... 84
 - Loop Crew A: 84
 - 7.8.5 Loop Crew B Crew Complements..... 85
- 7.9 Mutual Assistance Procedures..... 86
 - 7.9.1 Overview of Mutual Assistance Process and National Response Events 86
 - 7.9.2 New York State Public/Private Utility Mutual Assistance Protocol Coordination 88
- Appendices 88
 - Appendix A – Emergency Organization ChartA-1
 - Appendix B – Position DescriptionsB-1
 - Appendix C – Emergency Services and Community AidC-1
 - Appendix D – Print and Broadcast Media Listing.....D-1
 - Appendix E – Municipal Leaders.....E-1
 - Appendix F – Lodging and Restaurants.....F-1
 - Appendix G – Office, Substation, Regulator, and Radio Listing.....G-1
 - Appendix H – Active Emergency Response ContractsH-1
 - Appendix I – Sample News Release.....I-1
 - Appendix J – Mutual Assistance, Material Sharing and EEI Agreements.....J-1
 - Appendix K – Guide for Mutual Assistance Crews.....K-1
 - Appendix L – Incident Command and General Staff Position Checklists.....L-1
 - Appendix M – ARCOS Callout Lists.....M-1
 - Appendix N - Telecom Facilities and Contacts.....N-1
 - Appendix O – Storm Response Materials List.....O-1
 - Appendix P – Storm Scorecard.....P-1
 - Appendix Q – Consumer Outreach Plan (selected sections)Q-1
 - Appendix R – Recommended Dry Ice Distribution LocationsR-1
 - Appendix S – Canadian Utility Contractor Activating AssistanceS-1

1 Overview

1.1 GLOSSARY OF ACRONYMS

Acronym	Term
ALS	Advanced Life Support
CHECK	Central Hudson Emergency Communication Network
CIS	Customer Information System
CSR	Customer Service Representative
DA	Damage Assessment
DHSES	Division of Homeland Security and Emergency Services
DPS	NYS Department of Public Service
EBD	Elderly, Blind, Disabled (special needs customers)
EEI	Edison Electric Institute
EEED	Electric Emergency Exercise Development
EEP	Electric Emergency Plan
EMS	Energy Management System
EOC	Emergency Operations Center
EOE	Electric Operating Engineer
ETR	Estimated Time of Restoration
FTE	Full Time Employee Equivalent
GIS	Geographic Information System
IAP	Incident Action Plan
ICS	Incident Command System
IT	Information Technology
IVR	Interactive Voice Response
LSE	Life Support Equipment
MEUA	Municipal Electric Utilities Association of New York State
NAMAG	North Atlantic Mutual Assistance Group
NMART	National Mutual Assistance Resource Team
NREC	National Response Executive Committee
NRE	National Response Event
NWS	National Weather Service
NYAPP	New York Association of Public Power
NYP/PUMA	New York Public/Private Utility Assistance Protocol
NYS	New York State

Acronym	Term
NYS DPS	New York State Department of Public Service
NYS PSC	New York State Public Service Commission (the Commission)
OEM	Office of Emergency Management
OMS	Outage Management System
OSHA	Occupational Safety and Health Administration
Overflow IVR	Overflow Interactive Voice Response Unit
POE	Port of Entry
PPE	Personal Protective Equipment
PSC	Public Service Commission
RMAG	Regional Mutual Assistance Group
RTUs	Remote Terminal Units
SCADA	Supervisory Control and Data Acquisition
UED	Utility Events Dashboard
URD	Underground Residential Distribution
VOIP	Voice Over Internet Protocol

1.2 Introduction

The Electric Emergency Plan (EEP) is the guide for responding to emergencies which affect electric service to Central Hudson Gas & Electric Corporation (Central Hudson) customers. Many of the policies, procedures and guidelines described in this plan use language tailored to storms or weather driven events as that is the primary cause of loss of electric service. However, several aspects of this plan can also be applied to other types of emergency events where there is a loss of power to a substantial number of customers in the service territory.

Throughout the year, Central Hudson performs many activities to increase readiness and reduce the number of customers impacted from electrical outages. This includes a vegetation management (hazardous tree/limb removal) program which reduces outages throughout the year and during storms. Our goal in emergency response is to protect the public, to restore electric service interrupted by the event as quickly as possible and to communicate our restoration progress to our customers, regulators, and municipal officials.

New York State defines three classifications of electric emergencies: Class 1, 2, and 3. The expected time to restore 90% of the affected customers is the determining criteria. The Incident Classification Guidelines and some other informational attributes are shown below:

Incident Classification Guidelines			
Description	Class 1	Class 2	Class 3
Expected Time to 90% Restoration	< 24 hours (~1 day)	>24 Hours & < 72 Hours (1-3 days)	>72 Hours (Over 3 days)
<u>Other Attributes (Estimated and for information only)</u>			
Number of Customers Predicted	5,000 - 10,000	10,000 - 50,000	> 50,000
Number of Predicted or Actual Cases of Trouble	< 150	150 – 750	>750
Number of Districts De-centrally Staffed	1 - 2	> 2	> 2
Mutual Aid Crews	Optional	Optional	Yes

Central Hudson has five operating districts: Catskill, Kingston, Poughkeepsie, Fishkill, and Newburgh. When districts are “staffed” or “manned,” it means that local operational control, including assigning and dispatching of crews, has been assumed (decentralized operations). However, overall event responsibility and authority remain centralized with the Incident Commander. The Operations Section Chief will determine which districts are to be staffed. If the extent of damage is such that decentralization beyond the district level is determined prudent, the District Operating Supervisor may elect to assign resources and dispatch personnel from one or more of our satellite offices within that district. (such as Greenville, Tannersville, Ellenville, Eltings Corners, or Stanfordville). It is not our practice to dispatch crews from substations.

This Electric Emergency Plan is used as the basis for our annual emergency exercises and employee Emergency Response training.

1.3 Safety

During emergencies, the safety of the public and of our workers is our highest concern. Our public announcements include information on safe practices during outages and severe weather events. Field conditions that pose a danger to the public are given highest assignment priority.

Safety awareness is also enhanced during emergencies by the following activities:

- All mutual assistance crews are given a safety briefing upon arrival at our headquarters.
- The Safety Officer makes field visits to field and office workers throughout the event.

Daily conference calls begin with a safety assessment and message. In emergencies, as well as during normal business, all employees are expected to perform their duties in accordance with our safety creed:

Our job is to plan and perform every job safely. No job is done well unless it is done safely.

1.4 Annual Emergency Exercise

In accordance with 16 NYCRR Part 105, Central Hudson will perform an Electric Emergency Exercise prior to June 1 of each year. At least 2 months prior to this annual exercise, the Manager - Emergency Preparedness will form a cross-functional Electric Emergency Exercise Development (EEED) group consisting of personnel from the Emergency Response group as well as representatives who take on storm roles in the Operations, Communications, and Liaison areas. This team will plan and execute the exercise and ensure that the objectives and required invitations mentioned below are completed. In addition, this team develops the exercise scenario and injects, handles exercise logistics, observes the actions of exercise participants, and compiles recommendations.

In order to satisfy the emergency exercise requirement, the event must include the mobilization of utility personnel with specific service restoration assignments and there must be contact with outside agencies, local governments, and others.

Central Hudson will conduct a minimum of one annual emergency exercise simulating a response to either a storm, or other storm-like electric emergency that would be classified at the highest or next highest level of severity. Exercise scenarios may also include wide-spread flooding as one of the emergency conditions. Each year, an inject which tests the manual backup process of a key storm application will be developed.

The Emergency Exercise objectives will be to:

- encourage demonstration of "best practices" among each operating division.
- provide participants with an understanding of how their assignments fit in with the overall response effort.
- identify areas where communications and/or record-keeping can be improved.
- Discover new opportunities for improving the restoration process.

Two weeks prior to the Emergency Exercise, the Manager - Emergency Preparedness or

designee will notify exercise participants of the date, time, and location of the exercise. Additionally, they will notify NYS PSC Staff of the exercise plans at least two weeks prior to the exercise and will invite local municipal and telecom company representatives to participate in the exercise. The exercise scenario will simulate the main aspects of responding to a Class 3 incident which includes the following actions:

1. Incident Commander is designated.
2. Incident Commander informs Section Chiefs of impending event.
3. Initial Utility Events Dashboard (UED) Incident notification is prepared.
4. NYS OEM is contacted.
5. EOC Representatives (Primary and Alternate) are mobilized to the County EOCs/911 Centers; these EOC Representatives may be assigned to a location that they are not typically assigned.
6. Emergency organization is developed and positions are assigned.
7. Simulated damage assessment information is reviewed and restoration plans are developed.
8. Global and District ETRs are developed based upon the restoration plan.
9. A simulated status conference call or meeting is held.
10. NYS 4-Hour PSC Situation Report is completed.
11. NAMAG conference call request is simulated - notification of exercise in progress.
12. Mock Municipal and Telecom conference calls are conducted or simulated in accordance with the Municipal and Telecom conference call agendas.
13. NYS 4-Hour PSC Situation report updates are prepared.
14. News releases are prepared.
15. The District Communications Liaison from the District where the event is hosted as well as the Company's other districts are included in the exercise.

Following the exercise, a hot wash is conducted to gather immediate feedback from the exercise participants. Then the EEED team performs an evaluation and organizes recommendations. Within 30 days following the conclusion of the exercise, the Manager - Emergency Preparedness, or designee will issue an Exercise Critique report. By April 1 of each year, the Manager - Emergency Preparedness or designee will certify the following in a report filed with the NYS PSC Secretary that within the past 12 months Central Hudson has:

- (a) periodically verified telephone contacts with and updated our lists of names of internal and external contact persons identified in 16 NYCRR Part 105.4
- (b) conducted at least one storm drill or emergency exercise involving key Company personnel assigned service restoration responsibilities.

In addition, in accordance with 16 NYCRR II A § 105.4, the Manager - Emergency Preparedness, or designee may waive this drill requirement if previous incidents during the calendar year provided sufficient experience only if approved in writing by the NYS DPS Director of the Office of Resilience, Utility Security, Nuclear Affairs and Emergency Preparedness, or designee. For actual preparations (a.k.a., real-world incident experience) in lieu of an exercise, the Company shall certify, in accordance with 16 NYCRR II A § 105.3: Submission of Electric Emergency Plans that all requirements of § 105.4(b)(4) were met.

1.5 Training

Emergency Response Training is performed annually for all employees who are new to the Company, or newly assigned to either Incident Command Staff or General Staff positions (described in Sections 3.2 and 3.3 of this Plan) or the key storm positions described later in this section; training is also performed as needed (for example, just-in-time training for employees prior to utilization). The Company utilizes multiple methods of training including, but not limited to classroom, web-based, on-the-job shadowing, drills/exercises, manuals, just-in-time, and procedural documents. Training outlines and/or guidebooks are prepared by experienced Operations personnel and are used consistently for in-person training. Manual storm processes are included in these training classes, when applicable. Classes are taught by department supervisors, Emergency Response personnel and/or the Safety Officer. The Manager – Emergency Preparedness is responsible for managing and evaluating the effectiveness of the training program. Staff within the Emergency Response group manage the training rosters and attendance is tracked by Human Resource staff using the Workday application.

The training includes a review of the current Electric Emergency Plan, and the location where the EEP can be accessed is provided to all attendees. The current Emergency Plan is available to all employees on Central Hudson's internal file sharing site.

Refresher training is required annually for key groups in the storm organization, when assigned storm role tasks are not performed as part of the employees' blue-sky job. These include Alternate Contact Center Personnel, Damage Assessment Coordinators, Damage Assessment Patrollers, Loop Crews, Crew Guides, EOC Representatives, Wire Responders and Wire Guards. There will be an annual wires down tabletop exercise to review the process and/or software used to protect the public from downed wires. Select Wire Down supervisors, coordinators, responders and/or guards shall be utilized during this drill. Training is conducted semi-annually for users of the Outage Management System.

Training for Damage Assessment Coordinators and Damage Assessment Patrollers is also required within 30 days of a change to damage assessment procedures. The company trains or maintains a minimum of 50 Damage Assessors and 60 Wire Guards each year.

All Central Hudson employees are provided annual Emergency Response awareness training. A link to the current Electric Emergency Plan is provided alongside a summary of changes to the Plan; storm roles are also discussed, as well as how to locate an assigned role. Contractors utilized for an assigned storm role (such as Wire Guards) are also provided training as part of the onboarding process.

1.6 Contact Lists

Contact lists for key positions to the emergency response effort are maintained as needed (when changes are known), or at least semi-annually by various personnel at Central Hudson.

The Manager of Resiliency Systems verifies that contact lists are reviewed as described below and posts the updates to an internal company website. The responsibility for reviewing and updating contact lists is as follows:

- Mutual aid companies and contractors – at least semi-annually by the Manager – Emergency Preparedness.
- Life Support Equipment (LSE) and Special Needs (EBD) customers – LSE codes are updated in the customer information system when the customer receives medical certification, and LSE customers are required to recertify annually. Customer contact information for both LSE and Special Needs customers is updated twice annually by the Manager – Consumer Outreach & Assistance Programs or designee according to the procedure found in Section 7.3 - Life Support Equipment and Special Needs Customer Contact Procedure.
- Human services agencies – updated at least semi-annually by the Manager – Consumer Outreach & Assistance Programs.
- Print and broadcast media – updated at least semi-annually by the Sr. Manager – Media Relations.
- Operators/managers of motels, restaurants, and dormitories, etc. – updated at least semi-annually by the Manager – Procurement & Stores.
- State, county, and local elected officials – updated by the Sr. Manager – Media Relations or designee. Contact lists are updated semi-annually.
- Law enforcement officials, and emergency management and response personnel – updated at least semi-annually by the District Communications Liaison.
- Medical facilities – updated at least semi-annually by the District Communications Liaison in each of the operating districts.
- Vendors – updated at least semi-annually by the Manager – Procurement & Stores.

Contact lists found in the appendices of this plan are Emergency Services and Community Aid; Print and Broadcast Media Listing; Municipal Leaders; Lodging and Restaurants; Office, Substation, Regulator, and Radio Listing; Active Emergency Response Contracts; ARCOS Callout Lists; and Telecom Facilities and Contacts.

1.7 Critical Facilities

Critical Facilities are typically those customers that provide essential services or functions for survival, continuation of public safety, and disaster recovery. Critical Facilities are coded in the customer information system with one of 26 codes that identify their critical facility type. These codes are as follows:

Critical Facility Level 1 facilities are critical to public health and safety. These include:

CODE	DEFINITION	LEVEL
2	Hospital/Emergency Medical Facilities	1
5	Main Utility and Communications Facilities	1
6	Airports	1
7	Water and Wastewater	1
9	Emergency Shelters/Cooling Centers	1
14	Fire, Police, Paramedics and Rescue Facilities	1
15	Emergency Management Offices	1
16	Fuel Transfer and Fuel Loading Facilities	1
17	Mass Transit	1
18	Military Bases	1
19	Main Flood Control Structures	1

Critical Facility Level 2 facilities provide significant public services but are considered to some extent less critical than Level 1. These include:

CODE	DEFINITION	LEVEL
3	Nursing Homes and Dialysis Centers	2
20	Support for Other Critical Government Functions	2
21	Prisons and Correctional Facilities	2
22	High-Rise Residential Buildings	2
23	Communications (radio, TV, etc.)	2

Critical Facility Level 3 facilities may provide public services but are considered to some extent less critical than Level 2. These include:

CODE	DEFINITION	LEVEL
11	Large Employers and Other Key Customers	3
12	Other Government Buildings, Schools, and Colleges	3
24	Event Specific Concerns	3
25	Customers Providing Key Products and Services	3
26	Residential developments with large elderly populations or other similarly vulnerable establishments as coordinated with county officials	3

Critical Facility account codes are maintained by the District Communications Liaison and are kept current as accounts change. The District Communications Liaisons proactively generate reports and perform outreach to critical facilities without power during an event.

1.8 Contact with Local Municipal Officials

During an event, the District Communications Liaison serves as the main point of contact for municipalities to communicate emergency needs and priority repairs with Central Hudson. District Communications Liaisons maintain two-way communications with local municipal officials to coordinate repairs and provide status updates when available. See section 6.4 for additional information on these communications.

During emergencies that occur during 'blue sky' days or smaller storms, and on an as-needed basis during larger storms or events, Central Hudson field personnel (Line Supervisors) will also communicate directly with local highway superintendents to coordinate road clearing efforts.

Throughout the course of routine business activities, municipal officials such as highway superintendents, building inspectors, and government leaders (mayors, supervisors) interact with District Communications Liaisons, whose role is to serve as the main point of contact for interaction with Central Hudson. The District Communications Liaisons are knowledgeable about the individual characteristics and needs of each municipality through these ongoing communications. The District Communications Liaisons will semi-annually invite county officials to in-person meetings to review storm readiness; said meetings may be held via phone or webinar if mutually agreed upon. Topics may include: a review of recent storm response(s), lists of critical facilities and roads, LSE contact procedures, lists of geographically appropriate potential dry ice distribution locations, event notifications and contact information of attendees, road closure protocols, circuit maps, and EOC interfaces. The District Communications Liaisons are responsible for maintaining these lists of critical facilities, critical roads, and dry ice distribution locations. If it is mutually agreed upon, an email from Central Hudson may serve as a substitute for the second meeting of the year. The email should describe any updates to storm readiness material, allow for an in-person or virtual meeting option, and provide the contact information for the District Communications Liaison. The Manager of New Business, or designee, is responsible for ensuring that these meetings and summary emails occur, notes are taken, and any follow-up actions are completed.

1.9 Customer Storm Preparedness Information

Throughout the year, the Director of Corporate Communications, or designee, ensures that storm preparedness information is distributed to customers by means of bill inserts, news releases, website updates and social media site updates. This information includes the phone number to contact to report loss of power as well as the following preparedness and safety tips:

- Pay attention to weather advisories and storm warnings.
- Keep a flashlight and fresh batteries handy.

- Have a battery-powered radio to keep informed of restoration efforts.
- Charge wireless phones or use a portable charger to maintain a means of communication.
- Double-check your supply of food, and stock your pantry with packaged or canned foods that require no refrigeration or cooking. Avoid opening your refrigerator unnecessarily during outages, so food lasts longer.
- Be sure you have a non-electric can opener. If you have an electric water pump, always keep an emergency supply of bottled water on hand for drinking and washing. If a major storm is forecast, fill your tub with water as an added reserve.
- Remember, never use outdoor gas or charcoal grills indoors. They pose a fire hazard, and over time can give off deadly carbon monoxide gas. Use these appliances only outdoors with proper ventilation.
- Be sure you know how to open your garage door manually, if you usually rely on an electrically- operated, automatic, remote control door opener.
- Use home generators safely and accordance with manufacturer’s instructions.
- Contact Central Hudson if anyone in your home depends on electrically operated life-support equipment.
- Stay clear of downed or low-hanging wires.

1.10 Mutual Assistance Group Membership

Central Hudson is a member of the North Atlantic Mutual Assistance Group (NAMAG). When additional resource needs are anticipated, requests for assistance will be made through this Regional Mutual Assistance Group (RMAG). Central Hudson personnel, typically those who act in the Incident Commander, Deputy Incident Commander or Planning Chief storm roles will participate in all conference calls, discussions, meetings, and drills conducted by this group throughout the year.

If the event is so large that resource needs cannot be fulfilled through the RMAG process, a National Response Event (NRE) may be declared by an executive of any utility affected. If an event of this magnitude is experienced at Central Hudson, the NRE declaration will be made by the CEO or designee.

See Section 4.2.3 for additional information on mutual assistance related activities that occur during an event. See Section 7.9 and Appendix J for additional information regarding mutual assistance and National Response Event protocols and procedures.

1.11 Storm/Incident Staffing

Each Central Hudson employee is assigned a primary and secondary storm role. These assignments are made through joint decision by representatives from the Emergency Response and Human Resources groups. Assignments are reviewed at least semi-annually to account for changes in personnel (new hires, termination, job movement) and storm role staffing needs. The Manager -

Emergency Preparedness has the responsibility of assigning personnel to maintain the Storm Staffing list. Staff who report to the Manager - Emergency Preparedness during blue sky operations, work with Human Resources to maintain the Storm Staffing list, notify employees of any changes, and to ensure that the list is updated at least semi- annually. However, due to the varying needs of a storm, any employee may be asked to perform any storm restoration function for which they have been properly trained and equipped. All storm role assignments are stored in Central Hudson’s mainframe system; a copy of full storm duty assignments is available for employees’ reference on Central Hudson’s internal website, and a hardcopy is maintained in Central Hudson’s Poughkeepsie office.

Field Resource Staffing – guidelines for securing certain field resources based on incident classification are found below:

Incident Classification	Internal Damage Assessors (FTE)	Internal Line (FTE)	On-site Contractors (FTE)	Mutual Assistance (FTE)	Designated Make Safe Crews	Wire Guards (FTE)
1	0	as needed	as needed	0	0	as needed
2	0 – 10	all available	as needed	0 – 150	0 – 10	0-20
3	20 – 60	all available	40-50	50 – 400	5 – 30	20-60

Notes:


1. The extent and type of damage will have a significant impact on the number of resources required for restoration.
2. Extreme damage caused by ice or flooding will typically result in increased resource needs.
3. Lesser damage caused by lightning strikes will typically result in decreased resource needs.
4. As the number of on-site contractors vary daily; the need for Mutual Assistance may be adjusted accordingly.
5. The ability to access the damaged facilities will have a significant impact on the Expected Duration. Mutual Assistance is defined as: All sources of resources brought in specifically for the event restoration.
6. Mutual assistance decisions will be adjusted based on the anticipated arrival time of crew resources.
7. A portion of the internal line FTEs will be assigned to work overnight to respond to emergencies.
8. The number of Internal Damage Assessors (FTE) needed are system wide; refer to Section 4.1.3 – Detailed Damage Assessment.
9. Designated Make Safe Crews may be staffed by internal (line crews, service workers) or external resources (contractors, mutual assistance crews) and are assigned by the District Operating Supervisor. Make Safe crews are focused on opening roadways and clearing downed wires or other electrical hazards.

2 Incident Command System

Central Hudson’s storm command structure primarily follows the FEMA Incident Command System (ICS). This structure allows storm responsibilities to be easily understood, eliminates confusion regarding chain of command, and improves communication during events. There are slight differences between the Central Hudson incident command structure and ICS which are a result of the unique nature of electric emergency response.

2.1 Organization Charts

The Incident Command Organization Chart is shown below:



Once an electric emergency has been declared, the Incident Command structure will begin to be put in place. Incident command may be transferred upwards through the chain as the original responders begin to narrow their responsibilities. When command is handed off, it will be clearly communicated by the person relinquishing command and the person accepting it.

As storm positions are filled throughout the organization, it is the responsibility of the person directly above each individual to clearly communicate the storm position and ensure that each person is familiar with the designated responsibilities.

2.2 Position Descriptions

The roles and responsibilities of each member of the Command Staff and Section Chiefs are found throughout each of the sections of this plan. Individual storm role position descriptions are listed in Appendix B.

3 Pre-Event Planning

For those events where advance warning is received, e.g. severe weather events, Central Hudson will undertake preparedness steps. These steps are as follows:

3.1 Pre-Event Staff Communication

As part of Pre-Event planning, Section Chiefs (General Staff) notify their respective units of the potential need to mobilize and will schedule additional staffing based on the expected timing and severity of the event. This is done using traditional means of communication such as email and phone calls. Depending on the expected impact and available notice, an email to all employees providing awareness of the potential need to participate in their assigned storm duties may also be sent out by the Deputy Public Information Officer or Designee. Additionally, utility employees who are asked to assist during emergencies are exempt from state and local travel bans.

When additional resources need to be mobilized in addition to these pre-event plans and outside of normal business hours, the ARCOS automated callout system is used. Employees working Dispatch or System Operations initiate individual callouts when needed to respond to specific emergencies. Additionally, Section Chiefs, Branch Directors, and Supervisors may initiate callouts for their respective group of personnel. Large scale callouts which cross multiple groups of employees may be initiated by the Incident Commander, Deputy Incident Commander, Operations Section Chief, or designees. The ARCOS system contains preloaded callout lists based on primary storm roles for field employees. Examples of these lists include: all qualified electric crews, loop crews, wire down staffing, damage assessors, and crew guides. Callouts can be run by district, if appropriate, or for the entire Company's territory.

Additionally, when initiated by the Incident Commander or other Command Staff, Central Hudson may utilize its AlertMedia system, which can be used to blast communicate an urgent security or event mobilization message to employees.

Should any unit require additional non field staffing beyond what is already mobilized, the Section Chief, Branch Director or Supervisors of that unit may contact the Staffing Unit, which will make the appropriate assignments of qualified available personnel and alert them of the assignment.

3.2 Command Staff Responsibilities¹

Incident Commander

- Notify Command and General Staff of the possibility of an impending event that would result in large numbers of outages across our service territory.
- Conduct Company conference call or meet with Command and General Staff to review preparations and assign storm positions.
- Notify DPS Staff and the State Office of Emergency Management that preparations are underway for a major event. Confirm contact name and phone number where these groups can obtain information and request assistance.
- Participate (or arrange for participation) in any scheduled North Atlantic Mutual Assistance Group (NAMAG) conference calls.
- After reviewing available weather forecast information, the Incident Commander and Operations Section Chief will determine if additional external line resources should be solicited, and how

¹ See Appendix B for additional detail on storm roles.

many crews are needed. If the weather forecast has a high level of certainty, and the prediction is severe enough to warrant additional crewing, then the Incident Commander will follow Section 4.2.3 - Mutual Assistance to obtain additional assistance.

Deputy Incident Commander

- Assist with the duties of the Incident Commander above as needed.

Liaison Officer

- Confirm name/phone numbers that facility managers and county and local officials should use to contact Central Hudson during the event.
- Per Sections 6.4 and 6.7, notify critical facilities and municipal officials of impending event. Provide information regarding the status of restoration to municipal leaders during Municipal Conference Calls.
- Respond to inquiries and requests from municipal officials or ensure inquiries/requests are being responded to.
- Develop staffing plan for County EOC representatives.

Public Information Officer

- Prepare news releases, public service announcements and employee information updates.
- Respond to media inquiries.
- Coordinate with the Liaison and Operation Units to gather relevant information and restoration status. Review outbound storm related messaging as needed for consistency. This includes messaging on the company website and social media sites.
- Interface with the Incident Commander to provide adequate information on restoration progress, ETRs, dry ice distribution locations, and shelter locations.
- Assign staff to initiate and moderate Municipal Conference Calls.
- Instruct Outreach Director to initiate outbound calls to Life Support Equipment (LSE) and Special Needs (EBD) customers. See Section 7.3 – Life Support Equipment and Special Needs Customer Contact Procedure.

Safety Officer

- Assist Operating Supervisor with delivering safety briefings to contractors and Mutual Aid crews.
- Address any safety concerns brought up by personnel working on the storm response.
- Perform OSHA reports of any OSHA reportable accidents.
- Perform safety inspections of field work sites.

Security Officer

- Initiate request for Taconic Parkway access and instructs Corporate Communications to remind employees that they will need to show identification in order to travel during a State of Emergency.
- Coordinate security needs for district offices, dry ice distribution locations, and alternate housing areas.
- Address any security concerns brought up by personnel working on the storm response.
- Establish liaison with the respective law enforcement agencies in order to promote prompt restoration of service in conjunction with any related investigations that may be underway.

3.3 General Staff Responsibilities²

Planning Section Chief

- Monitor weather reports and participate in National Weather Service briefings as necessary.
- Ensure that personnel are assigned to perform resource tracking, reporting and demobilization positions.
- Initiate Mutual Aid crew requests when instructed by the Incident Commander or Operations Section Chief.
- Ensure that ETRs are established within the required guidelines outlined in Section 7.1.

Operations Section Chief

- Ensure that all Operations Section positions are staffed, and all responsibilities are assigned. Provide back-up for Operations personnel as needed.
- In conjunction with the Incident Commander, develop the Incident Action Plan (IAP).
- Obtain contract line and line crew resources as needed.
- Provide restoration status information to the Public Information Officer and/or Incident Commander when requested.
- Obtain a system status report from System Operations including status of all transmission lines and distribution breaker abnormal conditions.
- When the event conditions warrant it, coordinate the start of damage assessment activities with the Intelligence Director.

Logistics Section Chief

- Assign employees to fill the Support, Service, Supply, and Information Technology Branch Director positions. If enough personnel are not available to staff all positions, reassign tasks to ensure that all support functions are being addressed.
- Supervise all support, service, supply, and IT activities. Resolve problems as necessary and provide backup coverage for all functions when needed.
- Communicate with Incident Commander and Operations Section Chief to fulfill daily logistics needs.
- Direct the Information Technology Branch Director to enter IT Storm Restricted mode and provide notification of an impending event as per Outage Management System Support Procedure (Section 7.6).
- Contact Wire Down contractors alerting them of the possible need for wire down personnel.
- Perform a preliminary evaluation to determine if there will be sufficient hotel space available to house out-of-town resources. Contact the alternate housing suppliers if needed.
- Obtain current list of all Company employees to be used for storm staffing.
- Direct Transportation Department to ready vehicles and equipment; expedite repairs of equipment, if possible, particularly aerial lift and pole setting equipment.
- Instruct Supply Branch Director to:
 - Check fuel availability.
 - Check dry ice/bottled water availability.
 - Review emergency stock levels.

Finance Section Chief

- Assign employees to fill the Time, Contracts, Cost, and Claims positions. If enough personnel are not available to staff all positions, reassign tasks to ensure that all support functions are being addressed.
- Supervise time, contracts, cost, and claims activities. Resolve problems as necessary and

² See Appendix B for additional information on storm roles.

- provide backup coverage for all functions when needed.
- Communicate with Incident Commander and Operations Section Chief to fulfill daily finance-related needs.
- Evaluate the need to increase Purchasing Card limits for key storm personnel.

Gas Operations Liaison

- Participate in storm planning meetings/conference calls.
- Ensure that Gas Operations staffing needs continue to be met as employees take on storm roles during the electric emergency.
- Respond to inquiries from the Incident Command team.
- Manage the overall Gas Operations response and facilitate communications with the Electric Emergency Incident Command during flooding or other gas-related emergencies.

Note: Incident Command and General Staff position checklists are found on the Central Hudson internal website under *Emergency Response & OMS, ICS Checklists*. They are also included in the Appendix L of this plan.

4 During Event

When an electric emergency causes power outages in our service territory, an Incident Commander will be designated if one is not already in place. Incident command may evolve as the event unfolds, i.e., event starts in one district, but then expands to other districts; command moves from the impacted District Operating Supervisor to a central Incident Commander. Central control will be established when more than two operating districts are staffed during an event. Details concerning the response and electric restoration activities due to a flood related event are discussed in Sections 4.4 - Flooding of Customer or Company Equipment and 7.7 – Flood Restoration Procedure.

The Incident Commander will initiate response by developing an Incident Action Plan (IAP). The IAP will contain the following:

Incident Classification – the Incident Commander will assess all available reports, maps, and data on the event. Using this information, they will classify the event in accordance with the Incident Classification Guidelines found in Section 1.2. Based on the Incident Classification, the Incident Commander will also define the Start of Restoration time based on the Estimated Time of Restoration Guidelines (see Section 7.1).

High-Level Storm Position Staffing – the Incident Commander will identify personnel to fill Command Staff and General Staff positions.

Establish Strategy – the Incident Commander will confer with the Operations Section Chief to determine if the restoration can be accomplished using internal company resources, or if contract and/or mutual assistance will be required. The Incident Commander and Planning Section Chief will then establish and target times for reports, conference calls and ETR communication.

Once the Incident Action Plan is developed, the Incident Commander will communicate the plan to the Central Hudson Executive Team and will provide updates as needed throughout the event. Section Chiefs will staff the remaining storm positions, ensuring that all positions are filled (some individuals may be assigned to more than one position). The subsequent response of each Section will be expected to follow the Incident Action Plan, and to adhere to all Company work practices, safety policies, and construction standards.

4.1 Assessment

Assessment of the nature and extent of damage to our electrical system is an essential step toward effective response. Information about damage locations and facilities affected is obtained from several sources:

1. Outage Management System (OMS). The OMS system receives trouble calls/reports from customers and sorts them into predicted cases. Equipment downstream from the predicted origin of these outage cases is a natural place to begin damage patrols.
2. Trouble Call Comments - Customer comments can sometimes be helpful in pinpointing damage locations. CSRs are trained to enter any information provided by customers about possible outage causes into the trouble order comments.
3. SCADA – The Energy Management System (EMS) receives SCADA information for both transmission and distribution breaker trips and lockouts. Any distribution circuit lockouts are

then communicated automatically with OMS by means of a SCADA/OMS interface. Lockout events will create confirmed outages in OMS. Breakers with dial-up Remote Terminal Units (RTUs) are not included in this interface, and the substation communication system can occasionally experience outages of its own. In these cases, System Operations will confirm device status via direct communications with field personnel and notify the appropriate district operating authority. Dispatching personnel may also predict breaker outages by analyzing individual trouble call locations directly and use that information to initiate the Company response.

4. Police/Fire/911 Calls – Emergency responders in our service territory have a priority line which allows them direct access to a telephone representative. Reports from police/fire are coded as 'emergency' orders in the OMS system.
5. Field Representatives – Company employees who are already working on restoration or those observing damage locations on their way in to work report their findings to the Dispatcher. Dispatchers locate the correct OMS case and enter the information provided by the field rep.
6. Electronic reclosers – When they operate, most electronic reclosers send a message to key operating personnel. From this notification, outage cases can be created or confirmed in OMS. Fault current information can also be obtained through a web interface which allows the opportunity for targeted patrolling.

In Class 1 and small Class 2 incidents, the damage severity can usually be determined using the above sources only. In larger Class 2 incidents, formal Damage Assessment will be mobilized only when a need is identified by an operating district or by the Incident Commander. Formal Damage Assessment is generally mobilized for all Class 3 incidents.

Damage Assessment is a critical part of the restoration operation as it provides the information needed to determine what level of resources are needed to restore service to customers in a timely fashion. Therefore, this function falls under the direction of the Operations Section Chief. See Emergency Organization Chart, Appendix A.

4.1.1 Helicopter Patrols

When the SCADA system has indicated that wide-spread damage has occurred to our transmission system, helicopter patrols will be performed when it becomes safe to do so. System Operations will contact the air patrol contractor and schedule the time and locations to be patrolled. If helicopter patrols are not possible due to weather conditions or other impediments, foot patrols of transmission lines will be performed.

In some unique cases when extreme distribution damage is suspected (possibly indicated by many distribution breaker lockouts), helicopter patrols may also be performed on the distribution network to rapidly assess the extent of the damage and to identify worst-affected areas.

4.1.2 Preliminary Assessment

The first phase of Damage Assessment is the Preliminary Assessment process which commences as soon as resources can be safely mobilized. The objective of Preliminary Assessment is to provide broad scale preliminary assessments of the nature and extent of system damage within 24 hours from the start of restoration. Depending on the event size and whether a centralized or decentralized approach is taken, this work is coordinated by Dispatch Operations, the District Operating Supervisor and/or the Damage Assessment (DA) Coordinator. Areas to be patrolled are determined by the DA Coordinator using OMS as a guide along with direction from the Operating Supervisor. Field data may

then be updated in the OMS system.

Preliminary Assessment patrollers are not intended to stand by all wires down found during their patrols. Instead, they will assess the severity of the wire down condition and will stand by only locations where there is determined to be a risk to public safety. Non-hazardous wires down will be barricaded, and the patroller will continue with patrolling their assigned area. Wire Guards will be requested by patrollers whenever one is deemed necessary. (See Wire Down procedure, Section 7.4.)

Preliminary Assessment begins upon receipt of a sufficient number of trouble cases on any one circuit to indicate severe damage may have occurred, and when it is safe to perform the patrols. Commercial Representatives and Line Supervisors also perform Preliminary Damage Assessment activities and are equipped with Company vehicles which makes them able to mobilize rapidly and provide quick insight into the extent and location of damage.

4.1.3 Detailed Damage Assessment

The Intelligence Director will initiate Detailed Damage Assessment activities while Preliminary Assessment is underway as directed by the Incident Commander, Deputy Incident Commander, Operations Section Chief, or designee. The Detailed Assessment is performed by employees assigned as Damage Assessment Patrollers, typically paired up in 2-person teams; for major events, some contract patrollers may be used. This effort takes longer to mobilize than Preliminary Assessment, as supplies and vehicles need to be obtained. The objective of Detailed Damage Assessment is to provide, within 48 hours of the start of restoration, more detailed estimates of system damage based on systematic field surveys. The most common impediment to completing Detailed Damage Assessment within 48 hours is blocked roadways, however, the Intelligence Director will monitor progress in each district and adjust staffing as reasonably practicable.

Damage Assessment Patrollers will be assigned to perform either outage case-specific or full circuit patrols and will mark the conditions found on the Damage Assessment software (If unavailable, printed circuit maps, direct entry into OMS and/or spreadsheets will be utilized). If Damage Assessment Patrollers have been assigned to work directly with a Line Supervisor, Crew Guide, or Substation Coordinator, damage locations found will be communicated to these personnel, in addition to providing this information to the Damage Assessment Coordinator via software or other means.

The full Damage Assessment Procedure, including the process for entering data into OMS, is found in Section 7.5.

4.2 Restoration

Restoration of the electric system following severe weather or other damaging events will require the coordinated effort of the entire storm organization. The Incident Commander, Command Staff, and Section Chiefs each have unique and distinct areas of responsibility during an event. One employee typically fills the same role for an entire event, but one or more substitutions can be made during a single event, to any position.

Incident Commander: The Incident Commander provides the overall leadership for the incident response. As an incident unfolds, command may move from one impacted district to a central incident command. The Incident Commander, in conjunction with Command and General Staff, assesses the severity of the event, determines the need for staff, and appoint individuals to fill high-level storm positions. The Incident Commander determines the incident objectives

and works with staff to develop the Incident Action Plan. The Incident Commander provides oversight of the incident response effort, ensuring that all actions are in accordance with the Incident Action Plan, regulatory requirements, and Company practices.

Deputy Incident Commander: In large scale events, a Deputy Incident Commander may be selected by the Incident Commander. The Deputy Incident Commander will perform specific tasks as requested by the Incident Commander and relieve the Incident Commander when needed.

Public Information Officer: The Public Information Officer advises the Incident Commander on information dissemination and media relations. The Public Information Officer provides information to and receives information from customers, the community, and media. This includes all call-taking and Customer Outreach activities within the Contact Center. All information released to the public will be approved by the Incident Commander.

Liaison Officer: The Liaison Officer is the primary point of contact between the Incident Commander, community leaders and regulatory officials. All information exchange between Central Hudson and the State Office of Emergency Management and municipal leaders will be done by, or approved by, the Liaison Officer. This information includes, but is not limited to, reviewing the number of customers impacted and restored, the type and extent of damage found, estimated restoration times, known shelter locations, and the status of critical customers and other high priority situations.

Safety Officer: The Safety Officer will advise the Incident Commander on issues regarding safety. They work with the Operations Section to ensure the safety of all personnel.

Operations Section Chief: The Operations Section Chief directs the field restoration work. They are responsible for staffing the field response sensibly to ensure fast and safe restoration of electric service. All line crews, line clearance crews, and damage assessment personnel fall under the command of the Operations Section Chief.

Planning Section Chief: The Planning Section Chief maintains records of all foreign crews/personnel. They are also responsible for monitoring weather conditions, ensuring that all PSC reporting is completed as required, and the demobilization effort at the conclusion of the event.

Logistics Section Chief: The Logistics Section Chief is responsible for supporting the Operations forces by providing all service, support, and supplies needed during the event. This includes computer systems, phones, radios, environmental support, lodging, meals, material, transportation, and dry ice distribution. The Wire Down Unit also falls under the direction of the Logistics Section Chief.

Finance Section Chief: The Finance Section Chief directs all activities related to time keeping, contracts, cost accounting, and claims.

The Incident Commander will brief each Section Chief daily on any adjustments to the Incident Action Plan for that day. Communication between Section Chiefs is also essential to ensure a coordinated response.

4.2.1 Restoration Priorities

Restoration and repair of electric service following an event will generally proceed according to the following priority:

1. Ensure public safety by working with emergency response personnel to respond to immediate hazards such as downed wires indicating burning, arcing/sparking or the restriction of ingress and egress from a building/vehicle or road closures blocking the ingress and egress to a neighborhood.
2. Electric transmission lines and substations that are resulting in customer outages.
3. Critical Facility Level 1 Customers. These include:
 - Hospitals and Emergency Medical Facilities
 - Critical Utility and Communications Facilities
 - Airports
 - Water and Wastewater
 - Emergency Shelters and Cooling Centers
 - Fire, Police, Paramedics, and Rescue Facilities
 - Emergency Management Offices
 - Fuel Transfer and Fuel Loading Facilities (ports)
 - Mass Transit (tunnels, bridges, ferry terminals, major rail facilities)
 - Military Bases
 - Critical Flood Control Structures
4. Critical Facility Level 2 Customers. These include:
 - Nursing Homes and Dialysis Centers
 - Facilities to support other critical government functions
 - Prisons and Correctional Facilities
 - Communications (radio, TV, etc.)
 - High-Rise Residential Buildings
5. Critical Facility Level 3 Customers. These include:
 - Managed Accounts, Large Employers, and Other Key Customers
 - Other Government Buildings, Schools, and Colleges
 - Event Specific Concerns
 - Customers providing key products and services (food warehouse)
6. Residential developments with large elderly populations or other similarly vulnerable establishments as coordinated with county officials.
7. All remaining customers whose power has not yet been restored. LSE customers will be given consideration when all other factors such as outage size, extent of damage, distance from available crews, are equal.
8. Electric transmission lines and substations that do not result in customer outages.
9. Permanent repairs to temporary conditions
10. Tree conditions not causing service interruptions.

While the priorities above represent a hierarchy, which is considered when establishing Incident Action Plans and assigning outage locations to crews, these priorities have to be balanced with the criticality of having large numbers of customers without service. When restoring large blocks of customers, most often this also restores the greatest number of critical facilities and high-priority customers. A general guideline for restoring the greatest number of customers first would follow the order below:

- Primary distribution – three phase
- Primary distribution – single or two-phase
- Secondary distribution
- House services

Deviations from the priority plan may occur as dictated by weather conditions, worksite accessibility, extent of damage to an individual circuit, the proximity of critical facility to the substation, and the progress of the restoration effort. Other exceptions to the listed priority include special events, the availability of backup generation, and seasonal issues. The overall goal in setting restoration priority is to ensure public and worker safety and to restore service to all customers as quickly as possible.

For PSC reporting purposes, critical facilities will be listed as Level 1, Level 2, and Level 3. Customer accounts that meet the criteria for these reporting levels have been indicated in our customer database. When directed by Staff, the Resources and Reports Coordinator will compile a listing of critical facilities that are confirmed or predicted to be without power and submit it as part of the 4-Hour PSC Situation Reports.

4.2.2 Road Clearing Coordination

The District Communications Liaison serves as the main point of contact for municipalities, counties, and state transportation agencies for coordinating emergency needs and priority repairs, such as road closures. The District Communications Liaison is also the main point of contact in instances where Central Hudson requires roadway clearing assistance in order to gain access to perform repair or restoration activities. In order to ensure proper coordination, all reports of road closures are routed through the District Communications Liaison, or designee. Priority of critical roads as communicated by the county or municipality is used to prioritize response of make safe crews. Roads closures blocking both ingress and egress to a neighborhood or area shall be marked as top priority for make safe clearing activity, as indicated in Section 4.2.1 – Restoration Priorities.

Municipal leaders or highway personnel report road closures due to wire or pole damage using various methods (phones calls to the contact center, direct communication with EOC Representatives and other Liaison staff or by directly entering reports in the Municipal Portal). For smaller incidents (typically class 1 and class 2), individual road clearing requests and status are maintained in OMS.

For larger incidents, (typically class 3), an appointed District Communications Liaison or designee confirms that known orders have been entered and that road closure summary information is available via the Municipal Portal. When the Municipal Portal is unavailable, a spreadsheet or table may be used to summarize the status of open road clearing requests. As the need arises during larger events, the Utility Field Liaison position is designated to manage make-safe and road clearing requests. The Utility Field Liaison, who reports to the District Communications Liaison, is focused on receiving notices of make-safe and road-clearing requests, confirming that the appropriate orders have been created, reviewing priority, and communicating status, both internally and with Municipal contacts. The Utility Field Liaison interfaces with the Make Safe Activities Coordinator, who reviews the available data, develops the operational response, and assigns crewing resources.

If a Wire Down Coordinator becomes aware of a road that is blocked by a damaged Central Hudson facility and/or wire and there is no alternative means of access to the area, then the coordinator will report it to the Utility Field Liaison for inclusion in the ongoing road closure prioritization and communication activities. Utility Field Liaisons and EOC Representatives have access to road closure summary data for orders already submitted and manage updates. As roads are reported clear by electric operations, the Utility Field Liaison confirms status updates in the Municipal Portal or other summary report. The EOC Representative can view these updates in real-time and communicate current status with county and other municipality officials, as appropriate.

4.2.3 Mutual Assistance

When the Incident Commander and the Operations Section Chief make the determination that the suspected or actual damage sustained by Central Hudson's facilities cannot be repaired within a reasonable amount of time using the existing internal and contract personnel, then additional outside resources will be sought. The Operations Section Chief will determine the number of additional crews needed, and the Incident Commander will work with the Planning Section Chief to secure mutual assistance crews.

The Incident Commander will utilize the North Atlantic Mutual Assistance Group (NAMAG) process to obtain the necessary crewing. Depending on the extent of the damage and areas affected, assistance may also be requested from the NY Municipal Electric Utilities Association, in accordance with the New York State Public/Private Utility Mutual Assistance Protocol (Appendix J). An overview of this process can be found in Section 7.9. Assistance may also be sought directly from line contractors with whom Central Hudson has contractual relationships, for example Central Hudson has agreements in place with other Fortis companies to supply resources if they are not preparing or responding to an event themselves and is investigating the use of retainer contracts to increase available crewing.

In the event that a storm has, or is predicted to have, a significant effect on utilities outside of the Northeastern part of the country, the Incident Commander can recommend to the CEO and/or their designee that they contact EEI and request a National Response Event (NRE). This process is discussed in detail in Section 7.9 – Mutual Assistance Procedures. These processes adhere to the EEI Mutual Assistance Governing Principles and NAMAG Guidelines, which can be found in Appendix J. The NAMAG guidelines include instructions for expediting crew movement between the US and Canada. A Central Hudson representative will continue to participate in all NAMAG calls until the event is no longer affecting any NAMAG companies.

If Central Hudson has exhausted all other resources (employees, contractors, and mutual assistance) to complete restoration tasks, assistance from the county/state government may be available. Requests for this assistance will be made by the Incident Commander, Deputy Incident Commander, or Operations Section Chief to the county EOC in which the resources are needed.

Once crew resources are committed, the Planning Section Chief will obtain rosters from the sending companies using Central Hudson's standard crew request form for import into ARCOS. This form is located within the Emergency Management folder structure on Central Hudson's file sharing software; required fields for entry on the form include the following: company; home office contact; home office phone; crew name; member first and last name; employee number; member job class; member union/non-union status; if the member is a supervisor; member type; crew type; vehicle number; vehicle phone number; and member gender. The Planning Section Chief will then compile a list of all contract and mutual aid personnel on the property, and maintain this list throughout the event, keeping it up to date for the current day's work assignments. This list will then be communicated to the Logistics Section Chief so that arrangements can be made for food and lodging in the proper location for all mutual assistance crews.

To facilitate the acquisition of Mutual Assistance and contractor crews from Canada, a procedure for crossing the US/Canada border has been developed by the New York State Office of Emergency Management. This procedure must be followed, or assistance will not be allowed to cross the border. Effective pass through the border requires coordination with the Port of Entry (POE), the New York State Office of Emergency Management, and New York Department of Public Service as described in the border crossing procedure included in Appendix S. It is the responsibility of the Planning Section Chief collaborating with the Resource and Reports Coordinator to implement this procedure.

Upon arrival at Company headquarters, each mutual assistance crew will receive a safety briefing. Given by an Operating Supervisor and/or the Safety Officer, or designee, the briefing will include:

1. List of required personal protective equipment
2. Weather update and impact on safety
3. Accident reporting process
4. Alcohol and drug policy
5. Operating voltages
6. Requirement for daily OSHA job briefing
7. Traffic control requirements
8. Tagging and switching
9. Copies of common construction standards
10. Customer owned equipment policy
11. Temporary repairs
12. Oil spills
13. Lyme disease prevention information
14. Hospital and Urgent Care Facilities Listing

The Guide for Mutual Assistance Crews document is found in Appendix K of this Plan and is also available on the Central Hudson internal website, Emergency Response & OMS page.

Crew resources will be assigned to each of the operating districts by Operations Section Chief. Crew resources are generally distributed to the districts based on the number of outage locations, and the extent of the damage. However, the 'formula' by which resources are assigned is unique to each event, and criteria can change throughout the duration of the event. Daily internal status calls are the basis for adjustment in crewing levels/assignments. Any crew movement between districts shall be recorded in ARCOS; the Operations Section Chief or Line Operations Director will notify the affected Operating Supervisors of the staffing changes, who will then arrange for the movement of the crews.

In order to efficiently employ mutual aid and contractor resources, Central Hudson pairs mutual aid crews with Crew Guides. Crew Guides are qualified to tag distribution facilities under the authority of the Operating Supervisor; see Appendix B for a complete description of the role. Contractors may be utilized as Crew Guides but must be trained and familiar with Central Hudson's switching and tagging procedures; these instances are evaluated on an individual basis.

Crew Guides report to the district dispatch center each morning. Here, the Crew Guide receives a work package for the day and discusses the day's restoration plan directly with the Operating Supervisor. Central Hudson believes this direct conversation each morning is a critical task in the overall restoration efforts. In order to minimize delays, this meeting takes place while the external crews are receiving breakfast at their hotel assignment; hotels are staged as close to the assigned dispatch center whenever possible. Once complete, the Crew Guide and assigned external crews shall proceed to the assigned work location. Job briefings are conducted at the work site. Additional work packages are delivered to crews by field resources throughout the day if needed in advance of the next work assignment; this process may be used in place of the initial in person discussion, if necessary.

Operating Supervisors in each district will keep accurate records of all non-company personnel working in their district during the event and ensure that Crew Guides are keeping proper time logs for their crews.

The decision to release crews is based on the status of the restoration effort and the effectiveness of company vs. mutual assistance crews. See Section 4.7 for additional information on demobilization. At such time as mutual aid or contractor crews are no longer needed, they will be released in accordance with the NAMAG guidelines.

4.2.4 Logistics

The Logistics Section Chief will direct the logistical support of the restoration operation, which includes the following areas: dry ice, lodging, meals, computer systems, Dispatch Operations, wire guarding, phones and radios, callbacks, environmental services, materials, and transportation. These functional areas will be organized into four branches – Service, Support, Supply, and Information Technology. Each of these Branches will have a Branch Director who will assign responsibilities for each unit to the appropriate Unit Leaders. Some units may have a single unit leader, or one unit leader may cover multiple functions.

4.2.4.1 Service Branch

The Service Branch Director will coordinate all activities pertaining to wire guarding, dispatch operations, customer information, environmental services, and drafting/GIS.

The Wire Down Unit directs the response to wire down reports which include the following tasks:

- Obtain staffing and supervision for responding to wire down reports and providing stand-by personnel.
- Contact contractors to obtain additional wire response personnel as needed.
- Using Avineonics, or OMS reports if needed, determine locations of wire down reports. Prioritize wire down orders based on determination of public safety, police/fire relief and road closures, in accordance with Section 7.4 of this plan.
- Assign locations to Wire Responders in priority order or contact Operating Supervisors to direct response to a line crew or Line Supervisors.
- Document Wire Responder and Wire Guards arrival times and communicate to Operating Supervisors where Wire Guards are standing by.

The Dispatch Operations Unit coordinates all assignments of dispatching personnel. Specifically, this includes:

- When not decentralized, determining the staffing levels needed to centrally manage gas and electric dispatching duties.
- When decentralized, determining which staff will be assigned to support decentralized electric operations, and which staff will be assigned to continue to centrally manage gas dispatching duties.
- Ensuring that each district, and the System Dispatch Center, has the staffing necessary to accomplish all dispatching functions.

The Customer Information Unit is responsible for coordinating consistent outage-related system messages, delivering messages using the outbound call systems and using OMS to support customer callback efforts. Specifically, this includes:

- Ensuring consistency between ETR information on all public sources and PSC reports. This includes the OMS feedback message available to CSRs, ETR information available to customers via the website, the IVR systems, UED Incident and the 4-Hour PSC Situation reports to PSC Staff, and radio/news broadcasts.

- Updating outage map alert messages, dry ice locations, and shelter locations daily or any time this information changes.
- Organizing Callback group(s) to make either manual or automated callbacks to customers believed to be restored.
- Making outbound calls to customers as directed by the Contact Center Branch Director or Incident Commander. Outbound calls are generally used to notify customers of major changes in estimated restoration time, or to notify them that their power is expected to remain off overnight.
- Making outbound calls to notify municipal leaders of time/date of Municipal Conference Calls.

The Environmental Services Unit provides support to the Operating Section by:

- Ensure compliance with all environmental regulations.
- Arrange for spill response as needed.

The Drafting/GIS Unit coordinates the availability of circuit maps for Operations personnel.

4.2.4.2 Support Branch

The Support Branch Director will coordinate all activities pertaining to lodging for foreign crews and meals for field workers. Knowing how/when meals will be provided and where crews will be housed at the end of each workday is a critical concern of the Operating Supervisors and it can cause great disruption when arrangements are not made in a timely fashion. It is the Support Branch Director's responsibility to adequately staff the Meals and Lodging Units so that meals are timely and that hotel arrangements are secure before 3 PM each day.

The Meals Unit will supply meals to field crews according to the following guidelines, when the meals unit is activated:

- Breakfast should be provided at hotel restaurants or will be catered at the hotel where mutual aid crews are lodged whenever possible. Central Hudson crews are provided breakfast at their local dispatch center. Crews driving to individual restaurants should be avoided.
- Lunch should be obtained from area restaurants/delicatessens. Meals are then delivered to work locations, or to a central location, e.g., district headquarters, substations, or staging area. Crew Guides or Runners can then pick up the meals at the central location where necessary.
- Dinner should be arranged in a manner which best meets operational needs. As available, dinner should be arranged at the hotel where crews are staying or at restaurants with sufficient capacity to serve large groups. When possible, preset mealtimes should be based on the anticipated work schedule of the crews. Meals Unit personnel will notify Operating Supervisors of the dinner location prior to 5 PM each workday. If a crew is not available for the preset meal, they may seek alternate arrangements and Crew Guides will provide logistical assistance as needed.

The Lodging Unit will arrange lodging according to the guidelines below:

- Verify crew locations with the Resource and Reports Coordinator daily.
- Make hotel reservations for crews at establishments as close as possible to the crews' work locations.
- Communicate lodging locations to Operating Supervisors and Crew Onboarding Coordinator daily or whenever changes occur.
- Make arrangements for transportation of crews' personal belongings if necessary.

The Staffing Unit will track personnel requests and assignments as follows:

- Obtain latest list of employees.
- Create a spreadsheet or database to track daily storm assignments of non-field personnel.
- Upon request, assign additional personnel to requesting area and inform the employee of the assignment.

The Alternate Housing Unit will arrange alternate housing for Mutual Assistance personnel (if needed), as per the guidelines below:

- Secure housing locations/sites.
- Arrange facilities for meals, bathing, and sanitary needs.
- Assign Alternate Housing Supervisor to oversee and coordinate needs at each site.
- Assign additional personnel to assist as needed.

The Facilities Unit manages the use and maintenance of all Central Hudson facilities.

4.2.4.3 Supply Branch

The Supply Branch Director will coordinate all activities related to dry ice distribution, material supply (including delivery of poles to job sites), transportation, and procurement.

The Dry Ice Unit will report to the Supply Branch Director and will distribute dry ice (and bottled water if directed by the Incident Commander) to customers when outages are expected to last more than 48 hours. This effort will include:

- Obtaining estimates of locations and numbers of customers who are expected to be out of power more than 2 days.
- Based on the above information, select distribution locations. Work with the Liaison Unit staff to notify available county EOC Staff of the selected dry ice distribution locations and discuss any concerns raised.
- Estimate the total dry ice needs. Dry ice needs can vary based on several factors, including: the seasonality of the event (summer vs. winter), the location of customers impacted (customers near urban centers typically have higher daily dry ice needs), and the losses that will occur between production and customer delivery. Central Hudson typically assumes that 5 percent of the impacted customers will desire dry ice and that each interested customer will be delivered about 10 pounds. The initial order is based on these approximations as well as factors unique to the storm. As the event progresses, the company monitors the usage rate at each distribution location and adjusts accordingly. A listing of recommended dry ice distribution locations is maintained by the District Communications Liaisons, which can be found in Appendix R. When national supplies of dry ice are limited or not available for purchase, the Company will supplement with regular/wet ice and communicate the type of ice being distributed.
- Work with the Procurement Unit to arrange delivery of supplies to the distribution locations. When outages resulting from anticipated events are expected to last more than 48 hours, the Company will commence dry ice distribution within 24 hours of the start of restoration, contingent upon availability from vendors and upon accessibility of distribution centers due to issues such as road closures, down wires, or debris as well as appropriate time-of-day for dry ice distribution.
- Assign personnel and obtain vehicles to transport personnel and supplies to the distribution location.
- Provide distribution location information to the Public Information Officer and Customer

- Information Coordinator for dissemination to the public.
- Continue to adjust the amounts and locations of dry ice/bottled water distribution as needed throughout the event.

The Material/Poles Unit will oversee all storeroom operations and arrange delivery of poles and other materials as requested by the Operating Supervisors or Substation Coordinators. This will include:

- Staffing and scheduling main storeroom operations; replenishing materials in district storerooms.
- Delivering poles to job sites.

The Transportation Unit will be responsible for obtaining and maintaining all vehicles needed in the storm response. This will include:

- Coordinating and expediting repairs of disabled vehicles.
- Obtaining rental cars for damage assessment, crew guides, or any other function as requested by the Section Chiefs.
- Arranging for fueling of vehicles, including mutual aid and contract crew trucks.

The Procurement Unit will be responsible for the purchasing function during storm events. This will include:

- Ensuring storm materials remain within order points; reordering and arranging for emergency delivery of storm stock and non-stock materials if needed.

4.2.4.4 Information Technology Branch

The Information Technology Branch will provide support for all hardware and systems that are essential to the restoration operation including the CIS, OMS, outage map, Energy Management System and outbound calling applications. Any requests for access, licenses, and problem resolution must be approved through the Information Technology Branch Director to ensure proper control over these core services.

4.3 Emergency Materials

As overseen by the Manager of Transportation and Stores, Central Hudson maintains a separate storeroom for storm restoration materials. The materials in this storeroom are automatically re-stocked at predetermined levels. A list of storm restoration materials and stocking levels is provided in Appendix O.

Central Hudson is a participating member of the New York Utilities Material Sharing Group (NYMSG) and will adhere to the procedures and protocols developed by this group, including attending meetings and drills, participating in storm conference calls, and providing materials to requesting members whenever possible. See Appendix J for the NYMSG protocols. In the event that Central Hudson experiences a need for materials that cannot be satisfied by traditional means of securing materials/supplies through vendors, the Company will follow the NYMSG process to obtain materials from this group.

4.4 Flooding of Customer or Company Equipment

During times of excessive rainfall, overhead, underground, and customer-owned gas and electric facilities can be subject to flooding. Because flooding has a high probability of affecting both gas and electric systems, the response to flooding should be a coordinated effort between both organizations. If flooding occurs during an electric emergency, the Gas Operations Liaison, or designee, will manage the overall Gas Operations response and facilitate communication between Gas Operations and the Incident Command team.

Flooding, whether predicted or not, can result in customers' homes and businesses being inaccessible. When weather related flooding is predicted in the vicinity of an electric or gas distribution system, consideration shall be given as to whether the customers that are predicted to be affected should be isolated in advance of the flooding to mitigate the potential damage to the electric and gas systems. The decision to isolate equipment should take into consideration potential public hazard, and possible damage to the equipment.

Central Hudson field representatives who discover potential flooding of Company or customer-owned equipment will notify the Dispatcher immediately. Operating Supervisors will make the determination as to whether the facilities should be shut down or if they can remain in operation. Operations Services will be consulted for any possible flood damage to substations or generators. Gas Engineering will be consulted for any possible flood damage to regulator stations.

Customer-owned equipment is often requested to be de-energized by police, fire, or rescue workers, or by local building inspectors. When this case occurs, the person receiving the request shall contact the Dispatcher for assignment to a Commercial Representative or line crew.

Restoration of Company- or customer-owned equipment after de-energization due to flooding will follow the Restoration of Flood Damaged Equipment procedure found in Section 7.7.

4.5 Estimated Time of Restoration (ETR)

Customers have indicated that communication of storm status and estimated restoration times is as important to them as having their service restored. Because of Central Hudson's commitment to Customer Satisfaction, a high level of attention needs to be given to the development and communication of ETRs. Procedures and policies for developing and communicating ETR information are found in the Section 7 – Procedures.

Operating Section and Planning Section personnel are expected to be familiar with these policies and guidelines, and to follow them during the restoration effort.

4.6 Coordination with Bordering Utilities

During major storms, it is essential for Central Hudson to maintain close communication with our neighboring utility companies in order to ensure that all 'borderline' customers are being addressed. It will first be necessary to determine if the damaged equipment is Central Hudson's or a neighboring utility's. This will require field verification in most cases. Borderline customers are coded within the customer information system. When one of these customers reports an outage, to alert Dispatchers, OMS displays the text "BDL" within the outage comments and a predicted circuit that references the neighboring utility.

If it is determined that the damage is not on Central Hudson's portion of the line, then Dispatch

Operations will call the supplying company dispatcher to report the damage location (if known) and to attempt to obtain an ETR. If decentralized, the district staff, such as the responding Line Supervisors or Operating Supervisor, coordinate this activity with Dispatch Operations. Dispatch Operations will continue to monitor the borderline outage cases and obtain regular updates from the supplying company dispatcher wherever possible. ETR times will be entered into OMS if known so that customers will be able to obtain this information via any of our standard communication channels (see Section 6.12 – Call Routing and Customer Contact Methods).

If the damage is found to be on Central Hudson facilities, then the outage case will be prioritized and repaired in accordance with our Incident Action Plan. When it is known, Dispatch Operations, or if decentralized district staff such as the responding Line Supervisor, Operating Supervisor, or designees will share restoration information with neighboring utilities for customers we supply, but who are outside our service territory. Open communication is encouraged between operating personnel between both companies when borderline customers are affected. In the event that any switching or coordination of crews between bordering utilities is necessary, Dispatch Operations will communicate this request with the neighboring company's dispatcher. The contact information of the neighboring utilities' 24x7 dispatch centers is maintained by Dispatch Operations. Any necessary switching is to be performed under the authority of the appropriate Operating Supervisor.

When necessary, the Central Hudson electric operations will also coordinate restoration efforts with its gas operations division, or neighboring utilities' gas operations which are within Central Hudson's service territory. Any coordination effort is led by the appropriate operating authority, i.e., Operating Supervisors or the Manager - Gas Operations. This would include assuming support roles for which the crews are properly trained, scheduling customer restoration, and supporting the Flood Restoration activities described in Section 7.7.

4.7 De-mobilization

The decision to release contract and mutual aid crews is made by the Operations Section Chief, or designee, in conjunction with the Incident Commander, or designee. Factors which are used to make this decision include: the number of remaining outages, outage cases, and critical customers impacted. The Planning Section Chief, or designee, will inform the contractor or mutual assistance company of their crews' release via phone and/or email. In storms with heavy damage, such as ice storms or severe wind damage, before releasing all crews, the Incident Commander or Operations Section Chief may direct Operating Supervisors to perform circuit sweeps of all affected distribution circuits in order to identify possible damage that could cause additional outages or safety concerns.

The Planning Section Chief, or designee, will obtain check-out times from Operating Supervisors, or designee, for each crew unit as they are released. The Incident Commander, or designee, will determine the end date/time of the incident and will instruct the Planning Section Chief to make final notifications to Company personnel and PSC Staff.

Each organizational unit supervisor will reallocate internal resources assigned to their unit across the service territory as needed to support restoration efforts. Section Chiefs and Supervisors will also offer resources back to the Staffing Unit to be reallocated to their secondary storm roles if they are no longer required in their primary role. As the restoration efforts continue, incident command meetings will be suspended at the direction of the Incident Commander. This occurs when the remaining restoration effort can be effectively managed by one or more of the local operating districts. The Operating Supervisor of the remaining district(s) leads this final phase of the storm restoration and is notified that formal incident command has been suspended. The remaining crews working the restoration effort report to their Line Supervisor who reports to the Operating Supervisor, just as they

did when the full incident command structure was in place. The organizational unit supervisors for support roles shall evaluate the remaining needs of the districts that are still in storm mode and dismiss employees from their storm duty accordingly.

4.8 Storm Credit and Protection

For every Widespread Prolonged Outage as defined in PSC Order dated July 14, 2022 in Case 22-M-0159 (the "Crediting Event"), it is the responsibility of the Contact Center Branch Director to ensure that Storm Credit and Protection procedures are followed in accordance with New York Public Service Law §73 and PSC Order dated July 14, 2022 in Case 22-M-0159 and November 18, 2013 in Case 13-M-0061 ("Statute and Orders").

Should a Crediting Event occur, a transaction will be initiated within the customer information system which stops collection activity on eligible customers as identified in the Statute and Orders who experience outages greater than 72 hours as calculated from data provided by the OMS System. After the Crediting Event, outage data will be reviewed by the engineering staff. This reviewed data becomes the basis for any credit and reimbursement activities. The daily credit is to be delivered in the form of a bill credit on the eligible customer's account, while any reimbursements for food and medicine spoilage is to be made by direct monetary payment to the customer upon submission by the customer of appropriate supporting documentation. If a Crediting Event occurs, the aforesaid compensation and reimbursement supersede all other remedies available to eligible customers under other tariff provisions or otherwise.

Should a Crediting Event occur, by noon of the following calendar day, the Deputy Public Information Officer or designee will incorporate language in a news release notifying customers that the 14-day window to file for reimbursement has begun and also set forth the date the application reimbursement period shall expire. This news release will be referenced on the Company's website and similar messaging will be communicated using a blast email. A sample news release is shown below:

Due to a Widespread Prolonged Outage, qualifying customers who have been without electric service for more than 72 hours are eligible for financial reimbursement for food and medication spoilage. Such customers must provide an itemized list of lost items, itemized cash register receipts, itemized credit card receipts or photographs of replacements goods that indicate the price of the item, or other verifiable documentation of the market value of the item ("proof of loss") within 14 days to qualify for reimbursement. This proof of loss must be received by Central Hudson on or before [insert date]. For more information, or to apply, visit [insert appropriate cenhud.com webpage].

5 Post Event

Following restoration of an event with a duration greater than 72 hours, Central Hudson will conduct a post-event assessment (a.k.a. After-Action meeting). This assessment will evaluate the effectiveness of our event response, with the intention of identifying areas that worked well and those that could have been improved. The Incident Commander or designee will schedule the After-Action meeting within 10 days of full restoration, and the meeting will take place within 30 days of full restoration. At a minimum, the After-Action meeting will include representatives from the Command Staff, as well as those who work in the following groups: Operations, Liaison, Communications and Logistics. If applicable, each unit will be encouraged to conduct separate advanced meetings and/or surveys to gather relevant feedback from staff. All survey results and minutes of the After-Action meeting will be retained for use in training and follow-up.

The post-event assessment will also evaluate the accuracy of ETRs provided. If ETRs are found to be inaccurate, then corrective measures shall be investigated as a result of the review. An evaluation of joint work coordination shall also take place during the post-event assessment. If necessary, corrective measures shall be investigated as a result of the review.

Implementation of agreed-upon recommendations will be the responsibility of the Manager - Emergency Preparedness.

For all events lasting more than 72 hours, NYCRR Part 105 requires all New York State utilities to submit to the Secretary of the Public Service Commission a review of all aspects of its preparation and system restoration performance. This report is due to the PSC Secretary within 60 days following the completion of service restoration.

This critique report will include:

1. Summary of the event – weather and cause of outages
2. Daily or hourly list of customers affected
3. Damage details such as transmission and distribution circuits affected, spans of wire down, number of broken poles, house services torn down, etc.
4. Number of restoration crews involved in the response effort (line, line clearance, other)
5. Number of additional personnel assisting with support, communications, and other storm-related duties
6. Number of phone calls answered and number of website hits
7. List of contacts made with municipal leaders, print and broadcast media
8. Summary of recommendations derived from internal post-event assessment

5.1 Storm Scorecard

For events lasting more than 72 hours, all of the New York State electric utilities also have the obligation to provide documentation that demonstrates the degree to which they achieved pre-determined Emergency Performance Metrics (also referred to as “the Scorecard”). Central Hudson will submit this documentation to DPS Staff within 30 days of the completion of customer restoration, as required. The Scorecard form is found in Appendix P.

5.2 Revisions to Electric Emergency Plan

Should any post-event recommendations result in a modification to this Plan, these will be done in a timely manner and an updated version filed with the PSC Secretary. It is our intention that this Plan is to be flexible and able to be modified as planning, restoration, and communication practices change. Please refer to the "Statement of Compliance" section for details regarding filing of updates to Electric Emergency Plans.

6 Communication

Effective communication during an event is crucial to the success of the restoration effort. Our customers have indicated that their satisfaction with Central Hudson during outages is highly dependent on the accuracy and availability of information about their restoration status.

This section includes guidelines for outbound customer messages, municipal and telecom conference calls, news releases, PSC reporting instructions, and staffing.

6.1 Estimated Time of Restoration

During the 2019 Electric Emergency Plan approval cycle, the PSC updated the guidelines for communication of Estimated Restoration Times during events. Central Hudson is expected to comply with the requirements contained within these protocols and to take steps to achieve the targets set within. See Section 7.1 – Estimated Time of Restoration Protocols.

In addition, internal procedures for developing and communicating ETR times have been developed, and these can be found in Section 7.2 – ETR Procedure.

6.2 IVR Upfront Messages

One of the first tasks of the Contact Center Branch Director or designee performs during an event is to arrange for the update of the IVR upfront message. This message should contain a date and time of the message update, event status, outage information and a global or regional restoration time, if available, and reference to the Company's website at CentralHudson.com for dry ice and safety messaging. Upfront messages must be updated within one hour of each news release, and information provided should be consistent with (but not an exact recording of) the news release. Care should be taken to keep the message under 60 seconds. The Public Information Officer or designee will review this upfront message before it is recorded so that customer communications remain concise, transparent, and aligned. The Contact Center Branch Director or designee shall document the following IVR related information and make it available for post-event analysis; transcript of the IVR, IVR implementation date/time, a copy of the related press release including date/time, (if release was issued). In some cases, the IVR message will be updated without a corresponding press release. This may be done to reflect more current information, or to provide a more customized overnight message.

Sample IVR messages are shown below:

Example 1 (Pre-Event):

This message was recorded on (Day, Date) at (Time). We would like to make you aware the forecast calls for the likelihood of severe weather in our area (timeframe) that may cause electric service interruptions brought about by (forecasted weather conditions). Central Hudson is preparing equipment and crews in anticipation of the storm. To report your power outage, check restoration status, or receive updated storm information, please visit our website CentralHudson.com, or our mobile app. To report an electric or gas emergency, please remain on the line to speak with a representative.

Example 2 (Early Stages During-Event):

This message was recorded on (Day, Date) at (Time). Widespread outages have been reported throughout our service territory as a result of the storm activity. We are actively working on assessing damage locations and will provide updated restoration information as it becomes available. We urge

residents to stay at least 30 feet away from downed power lines. To report your power outage, check restoration status, or receive updated storm information, please visit our website CentralHudson.com, or our mobile app. To report an electric or gas emergency, please remain on the line to speak with a representative.

Example 3 (Mid Stages During-Event):

This message was recorded on (Day, Date) at (Time). Central Hudson's restoration projections have improved over earlier estimates. Service restoration for approximately X% of impacted customers in (area/town/county) is expected by or before (timeframe). Electric service for approximately X% of impacted customers in (area/county/town) is now expected to return by or before (timeframe). Please use our automated system to report your power outage. You may also report an outage, check restoration status, and receive updated storm information by visiting our website, CentralHudson.com or on our mobile app. To report an electric or gas emergency, please remain on the line to speak with a representative. We sincerely appreciate your patience.

Example 4 (Later Stages During Event):

This message was recorded on (Day, Date) at (Time). Central Hudson estimates that electric service will be restored to X% of impacted customers by (Timeframe), with work in the hardest hit areas continuing through (Day, Date). Supplies of dry ice and bottled water will be available starting on (Day, Date). Locations and times will be announced as they become available. We urge residents to stay at least 30 feet away from downed power lines. To report your power outage, check restoration status, or receive updated storm information; please visit our website www.centralhudson.com, or on our mobile app. To report an electric or gas emergency, please remain on the line to speak with a representative. Thank you.

6.3 DPS and State OEM Communication

During events, the Liaison Officer will be responsible for initiating the proper notifications and responding to all inquiries from the State Office of Emergency Management (OEM), unless the inquiry is directed to another member of the ICS Team. The Liaison Officer will ensure that any answers provided to the State OEM are consistent with all other public communications and that accurate and timely information is provided. All responses should be approved by the Incident Commander.

The Liaison Officer is responsible for arranging to have Company employees staff the county 911 centers and for keeping these employees informed of restoration status. 911 Representatives will work with Operating Supervisors to provide assistance to municipalities who are requesting assistance with removal of hazards such as trees/wires blocking roadways or walkways.

Before or immediately after very large storms, the State Office of Emergency Management may elect to establish an EOC in Albany. A Central Hudson executive will typically be alerted to this decision by either the Department of Public Service or the Office of Emergency Management. Upon request, Central Hudson will provide a representative(s) to the State EOC, who is knowledgeable on how to obtain information that may be needed by state officials.

The Planning Section Chief is responsible for ensuring that the NYS 4-Hour PSC situation reports are submitted to DPS Staff according to requirements for that event. The initial UED Incident Report for storm events is submitted by Dispatch Operations. Additional UED Incident Report updates are also submitted to DPS Staff by the Dispatch Operations unit with content approved by the Incident Commander. The Manager – Emergency Preparedness, or designee, acts as a liaison with the NYS

DPS Office of Resilience, Utility Security, Nuclear Affairs and Emergency Preparedness to provide additional information or respond to inquiries when needed.

6.4 Municipal Conference Calls

When a Class 2 or greater event is expected and time allows, a pre-storm email blast will be sent to municipal officials notifying them of the expected event and providing contact information for the District Communications Liaison. If a Class 3 or greater event is expected and time allows, these officials will be invited to a pre-storm conference call. When time does not allow for pre-storm calls, the “during event” Municipal calls will be held as described below.

For Class 3 incidents where more than 10% of the affected customers are expected to experience outages greater than 48 hours in duration, Municipal Conference Calls will be scheduled by the Deputy Public Information Officer or designee. All listed municipal officials will be invited to participate in the calls which should begin as soon as reasonably possible after the storm impact has been assessed and the Incident Action Plan has been developed. Central Hudson is prepared to host multiple Municipal Conference Calls i.e., county or division, if warranted. However, it is a more typical practice to hold a single Company-wide Municipal Conference Call and have liaison staff available to participate in calls organized by the County Emergency Managers within the service territory.

In accordance with the ETR Protocols, Municipal Conference Calls shall be scheduled within 12 hours of the start of restoration and shall be conducted within 24 hours of the start of restoration. (See Section 7.1 – Estimated Time of Restoration Guidelines for definition of Start of Restoration.) During the restoration process, municipal calls will be held at a frequency of once per day. A second daily municipal call may be held when the need arises based on the severity of the event and interest level of participants.

The Municipal Conference Calls will be coordinated by the Deputy Public Information Officer or designee, who will inform municipal officials of the date, time, and connection details of the call. The Municipal Conference Call is held via a telephone conference line or web-enabled meeting application. The invitation to the call or meeting will include an agenda and contact information for the District Communications Liaisons for reporting or receiving updates on issues. A list of contact names and numbers to be invited to the calls is maintained in Corporate Communications. The contacts include:

- Municipal Officials
- County Emergency Management Offices
- DPS Staff
- State and County Elected Officials
- Local Congressional Offices

In preparation for the Municipal Conference Call, the Deputy Public Information Officer or designee and Liaison Officer or designee will confer with the Incident Commander, Operations Section Chief, and/or Contact Center Branch Director. All information shared in the call should have prior approval of the Incident Commander.

Call Agenda

- A. Introductions and ground rules for participation** – Deputy Public Information Officer
1. Questions from the participants will be taken at the end of the call.
 2. Questions should be general in nature; participants requesting information concerning specific locations, which cannot be immediately addressed, will be provided with a

contact name and telephone number for the appropriate District Communications Liaison following the call.

B. System information – Deputy Public Information Officer

1. Type of event and geographic areas affected (emphasize most impacted areas)
2. Total number of customers affected at peak of event
3. Total number of customers currently without service
4. Estimated global restoration time of event
5. Regional ETR information on a county basis
6. Local ETR information as requested
7. Weather update and impact of weather on restoration
8. Restoration accomplishments since the beginning of the event or previous call.
9. Restoration focus or goals expected prior to the next scheduled call.

C. Information for the event for the overall service territory – Liaison Officer

1. Number of customers affected at peak of event by district.
2. Number of customers restored by district
3. Number of customers still out by district
4. Final estimated restoration time of event by district
5. Overall Number of crews being utilized including mutual assistance, contractors, service crews, surveyors, etc.
6. Coordination of road clearing activities
7. Restoration of priority critical facilities
8. Areas where crews are working.
9. Areas where crews will be sent next.
10. Type and extent of damage found – number of poles and wires down, worst locations, etc.
11. Known shelter locations.
12. The storm restoration information will conclude with an appropriate safety message to the participants.

D. Entertain questions – Deputy Public Information Officer

E. Date, time, and call-in information for the next briefing – Deputy Public Info. Officer

When the Flood Restoration Procedure has been enacted, restoration status updates will be included in the Municipal Conference Calls, or will be communicated during a follow-up call, depending on the extent of the damaged locations.

The Deputy Public Information Officer or designee will record the calls/meeting or in the event of technical difficulties designate a person to act as scribe to the Conference Call. A record will be kept of the discussions that take place during the call, including questions posed by the participants. This documentation or recording will become part of the event file.

Municipal Conference Calls will continue to be held until the Deputy Public Information Officer and the Liaison Officer agree that the calls are no longer necessary near the end of the event. District Communications Liaisons will continue to address individual concerns and to proactively communicate with municipal officials in areas where restoration is ongoing after Municipal Conference Calls have ended. Contact information for the District Communication Liaisons will be provided. District Communications Liaisons will respond to specific questions from municipal officials as soon as practical; these liaisons strive to respond to all such inquiries with an answer or status update within 12 hours.

Municipal officials will also be encouraged to report specific issues to their county EOCs, leaving the municipal calls to serve as brief updates for the affected area(s) as a whole and leaving individual issues to be addressed through the District Communications Liaisons.

6.5 Telecom Communication

When a Class 2 or greater event is expected and time allows, a pre-storm email blast will be sent to telephone, wireless and cable TV suppliers notifying them of the expected event and providing contact information for the District Communications Liaison. If a Class 3 event is expected and time allows, these companies will be invited to a pre-storm conference call.

During an event for which Municipal Conference Calls are held, telephone, wireless and cable TV suppliers will be invited to participate in a daily Telecom Conference Call or web-enabled meeting application. This daily call will use the same agenda as the Municipal Call (see above). In addition, a section shall be added to the agenda to discuss utility coordination. Topics addressed in this section include co-location within Central Hudson's Storm Center, interface of companies' facilities, joint work coordination (i.e., pole setting activities), generator locations for telecom/cable facilities, and telecom/cable wires down. The Deputy Public Information Officer and Liaison Officer or designees will provide restoration status information to telecom company representatives on the call. Specific questions or needs by each of the telecom companies, which cannot be immediately addressed on the daily briefing call/meeting, will be referred to the local operations personnel, typically the District Communications Liaison.

A list of telecom contact names and numbers to be invited to the calls/meetings is maintained by the New Business group and is also contained as Appendix N of this Plan. Telecom Conference Calls or meetings will continue to be held until the Deputy Public Information Officer and the Liaison Officer agree that the calls/meetings are no longer necessary near the end of the event. Between scheduled calls, and after daily calls/meetings have been discontinued, the District Communications Liaison will be the point of contact for Telecom companies.

Telecom companies will also be invited by the Liaison Officer or designee, to send a representative to Central Hudson's Storm Center during all major events to facilitate communications between their company and Central Hudson; this topic is also discussed during the Telecom Conference Call/Meeting as noted above. In the absence of a representative in our Storm Center, telecom companies will address questions and needs for escalated repairs through their local District Communications Liaison. The District Communications Liaison will facilitate communications with telecom companies and our field personnel as needed and will respond to questions including items such as those discussed during the utility coordination section of the Telecom Conference Call/Meeting.

6.6 County EOC and Municipal Official Support

County EOC

County 911 Dispatchers all have their own unique "priority lines" that ring down directly to the 24x7 lines staffed by telephone representatives, who create any necessary trouble orders and communicate them to the Dispatch Center. There is also a backup priority line that is provided to all County emergency management offices.

County Emergency Managers can request a representative from Central Hudson be present in their command center, or 911 Dispatch offices. Central Hudson's EOC Representatives will have been alerted by the Liaison Officer prior to the event, and as such will be ready to respond as needed, and to provide 24-hour coverage if requested.

While in the County EOC or 911 Dispatch offices, Central Hudson's EOC Representatives use a VPN connection to gain access to Central Hudson systems including: the internal outage map, the Customer Information System, circuit maps, OMS reports [lists of critical customer and LSE outages, wires down, etc.], and company email where they are copied on each 4-Hour PSC Situation Report. The EOC Representatives can use these resources to create trouble reports, answer questions regarding ETRs and crewing, and respond to other general communications needs. Central Hudson EOC Representatives have direct dial numbers to the Storm Center and each of the district dispatch centers, Wire Down Coordinators, and Damage Assessment Coordinators; for escalated outages, coordinated response needs, or inquires on circuit configuration, the EOC Representative will contact the District Communications Liaison for direct follow-up. In the event of a total loss of phone communications, EOC Representatives or designated runners will use radio communications or physically travel between the County EOC locations to the company District offices to create orders and obtain status. Our EOC Representatives will endeavor to maintain proactive communications with County emergency officials whenever status information is known. Should the County EOC need to escalate an LSE issue, the Central Hudson EOC Representative will relay this information by phone to the Consumer Outreach department for follow-up and resolution; refer to Section 7.3 – Life Support Equipment and Special Needs Customer Contact Procedure for more information. Hard copies of accessible information will be made available to EOC representatives as appropriate.

EOC Representatives will also assist the state, county, and municipal highway crews in communicating to Central Hudson where downed wires need to be made safe so that roads can be cleared. If any individual location to be cleared is a high priority, the EOC Representative will coordinate with Central Hudson operations personnel to notify the 911 center when wires are secured, and road clearing efforts can begin. The District Communications Liaison will also assist with coordinating priority road clearing with local municipal officials. See "Municipal Officials" section below.

If, during a particular event, Central Hudson needs to obtain resources from the county or state, these requests would be coordinated through the EOC Representatives. If a wildfire occurs near utility infrastructure, or otherwise requires a response, Central Hudson will coordinate the efforts with the County EOC(s) in the affected area. Central Hudson will continue to staff the EOC or 911 centers until such time as the county emergency manager determines there is no longer a need.

It is the responsibility of the Manager – Emergency Preparedness to ensure that there are sufficient company personnel trained to staff all counties served by Central Hudson. Additional personnel will be trained for this duty to allow for multiple shifts, personnel unavailability, and staffing of municipal EOCs if needed.

Municipal Officials

Municipal Officials such as municipal highway superintendents, building inspectors, and government leaders (mayors, supervisors) must be provided with the most up-to-date information possible during events so that they can better serve their communities. It is the responsibility of the District Communications Liaison (who are the primary contact for Municipalities) in each of the operating districts, or their designee(s), to respond quickly to municipal official calls, and to provide timely information or assistance when requested. When needed, additional Company personnel should be assigned to assist the District Communications Liaison so that timely response to municipal official communication is maintained.

When sufficient notice is given for a severe weather event, outbound calls are made to all critical facilities, and municipal officials alerting them to the possibility of a loss of power due to the impending event. This message contains the contact number of their District Communications Liaison,

who they can call for information regarding restoration in their municipality. If a township or village EOC is opened, it is expected that all emergency conditions will continue to be reported through the County 911 center. This is essential so that the county office can prioritize and coordinate repairs with the Central Hudson representative assigned to that office. Emergency Managers can also escalate their priority restoration needs through the District Communications Liaison.

If damage in any individual municipality were to become so significant that a Central Hudson presence in their EOC is essential, a qualified representative may be provided, but County EOCs are to be staffed first. A qualified representative is an employee who has received EOC training or is an experienced employee whose blue-sky job duties include working with municipalities and critical accounts, such as those in the New Business group. Municipalities who do not require a Central Hudson presence in their EOC, or who cannot obtain one due to an excess of requests vs. available personnel, will still be able to escalate their priority repairs and receive updates through contacts with the District Communications Liaison in each district.

At any time, when District Communications Liaisons become aware of an update to the status of an escalated municipal emergency manager's concern (including priority road clearing jobs), they will proactively reach out to that municipal official and provide them with an update. Municipalities are encouraged to submit specific concerns to the District Communications Liaisons by 4 PM for potential inclusion into the next day's work plan.

If there is a widespread, prolonged outage that affects at least 20,000 customers in Central Hudson's service territory and the Company is unable to restore electric power within 24 hours to any qualified police department, fire department, ambulance service, or advanced life support (ALS) first response service facilities, additional outreach will be made. Qualified facilities must be pre-wired with an appropriate transfer switch for using alternate generated power and must be registered with the Division of Homeland Security and Emergency Services (DHSES). In these instances, the District Communications Liaison or designee will notify the Chief Operating Officer, or their designee, of the Village, Town, or City in which the facility resides as soon as practical after determining that the outage will last longer than 24 hours. The notification must be documented in the form of a call, text, or email and will include any known information about the outage cause or duration.

6.7 Critical Facilities and Managed Customers

Critical facilities and large industrial (managed) customers have contacts throughout the year with the District Communications Liaison. During storms and other emergencies, these customers would continue to use these contacts for assistance with estimated restoration times, escalation of emergency needs, or any other event-related issues.

When sufficient notice is available and the anticipated impact of an impending storm would result in a Class 2 or greater incident, an automated call is made to all critical facility managers reminding them to be prepared for the loss of power at their facilities. This automated call includes the name and phone number for the District Communications Liaison that each facility manager can call for any assistance related to an outage at their location.

In addition, information pertaining to storm preparation and electric and gas safety is provided to all customers, including critical facility owners, through various means such as bill inserts and social media during the year. These and other storm related customer communications are described in the Consumer Outreach Plan which is filed with DPS Staff annually. Selected sections from this plan are found in Appendix Q.

6.8 News Releases and Media Information

When sufficient notice is available and the anticipated impact of an impending storm would result in a Class 2 or greater incident or significant public interest is expected, a news release on safety and preparedness will be issued to the news media prior to the arrival of the storm. The timing of these releases ranges between 48 hours ahead to immediately prior of an expected event depending on the forecasted weather timing, severity, and confidence level.

The Public Information Officer will schedule and issue all news releases and paid media messages during major events. Per PSC guidelines, news releases must include the following essential information:

- Details of Storm or Event
- List of areas and numbers of customers affected, as available.
- Estimated restoration times, as available.
- How to report an outage
- Company phone numbers and website address
- Social Media links and handles (X)
- Customer assistance locations or referrals to outside assistance agencies such as the Red Cross, as available
- Safety information
- Location for dry ice, bottled water, and public shelters, as available

Common customer feedback and questions are also addressed in news releases issued by Central Hudson; see Section 1.9 – Customer Storm Preparedness Information. A sample printed press release can be found in Appendix I. News Releases are copied to all employees, to ensure that employees and crew guides are provided the same information that is being shared with customers and other stakeholders in the restoration process.

Corporate Communications maintains a contact list for all print and broadcast media to be used during events. This list is updated semi-annually by means of a mail or email request to each of the media agencies.

During a major event, the Public Information Officer, or designee, gathers storm or event impact and restoration information from the Incident Commander, or designee, and the Operations Unit. This information is used to issue timely and accurate news releases. To the greatest extent possible, these press releases are issued twice a day and timed to coincide with the morning and evening news cycle. News releases will also be provided outside of normal news cycles if the event conditions change significantly, such as the expected global ETR. Unless specified, news releases will apply to Central Hudson's entire service territory. News releases and social media posts will indicate the general locations of storm damage and restoration activities within the service area, including counties and regions affected by the storm or emergency. Towards the end of restoration, communications will be focused on the customers that have not been restored. If warranted, location specific news releases may be issued. All news releases will be expected to comply with ETR Protocols – Section 7.1.

The Central Hudson Emergency Communication Network (CHECK) will be activated at the discretion of the Public Information Officer. The CHECK system broadcasts messages on local AM and FM radio stations. CHECK messages are required mainly during the weekend when news staffs of broadcast media are often off duty. CHECK messages include restoration status updates, safety measures and dry ice and shelter locations.

All other public communication measures such as news conferences, interviews and website updates will also be coordinated by the Public Information Officer.

6.9 Social Media, Email, Website, and Text Messaging

Central Hudson's Public Information Officer will coordinate any event related outbound messaging using communication channels such as the company website, news releases, social media messaging, and blast emails to customers.

A news release on safety and preparedness will be issued prior to the impending storm as described in Section 6.8. Under the direction of the Public Information Officer or designee, similar messages will also be posted on social media sites as early as possible, urging customers to be prepared for the arrival of the storm. These social media messages will include a link to the news release for additional information.

When the anticipated impact of an impending storm would result in a Class 2 or greater incident or significant public interest is expected, an accompanying blast email will also be sent by the Deputy Public Information Officer or designee to all customers for whom email addresses have been provided. Both social media and blast emails will link to webpages with storm specific content. During and immediately following major storms, blast emails will be utilized. These emails will provide safety information, storm updates and the locations of dry ice and bottled water distribution centers and shelters, as well as links to Central Hudson's outage map, outage reporting, and other event-related information.

During the most severe events, under the direction of the Public Information Officer or designee, a webpage dedicated to the storm will be displayed, containing safety information, event updates, copies of news releases, dry ice/bottled water distribution and shelter locations once these are known, links to Central Hudson's social media pages, as well as outage reporting/outage restoration status options and information obtained from County EOCs or other officials, as warranted. Corporate Communications will indicate the time that this information was published as part of the message. This information is generally updated with the news release cycle, typically more often than every 8 hours during the day and evening. Under the direction of the Public Information Officer or designee, in circumstances when no new information is available over an 8-hour period, (or a 9-hour period when between 10pm and 7am), the website will be confirmed accurate with a revised timestamp. The webpage shall be featured prominently on the home page of the utility's main website during the storm and outage information will be updated at least every hour. The website will also have prominent language displayed that explains to customers what is meant by a global, regional, local, and job-specific ETR. Regional ETR information will be provided on a county basis and local ETR information will be provided on a town/municipality basis. The Customer Communications Branch Director or designee reviews recent company communications for important information, such as storm status, hardest hit areas, or contact methods, and places them in a banner at the top of the outage map page to increase visibility.

Under the direction of the Public Information Officer or designee, social media posts will continue during and immediately following the storm while restoration takes place. Posts will follow the news release cycle but also provide relevant information on a more frequent basis. Social media posts will indicate the general locations of storm damage and restoration activities within the service area, including counties and regions affected by the storm or emergency. Social media sites will be monitored from early morning through late night, with occasional posts overnight. Those working in the Social Media Team storm role will report common topics raised by customers to the Public Information Officer. Corporate Communications will develop a schedule to share the duties of monitoring social media sites outside of normal business hours. To the extent that Central Hudson is aware, pertinent storm information from other social media sources, such as a County EOC, will be shared by those working under the direction of the Public Information Officer.

Social Media platforms (such as Facebook & X) will be used, as necessary, during major events to provide the following:

- Storm alerts
- Contact information for reporting outages.
- Safety information
- Dry ice/bottled water distribution information
- Shelter locations
- Restoration progress
- Links for where to find individual Estimated Restoration Times
- Responses to frequent customer inquiries or common topics expressed in comment sections.
- Photos of storm damage and service restoration activities
- Videos of storm damage and restoration activities
- Interviews of utilities representatives describing restoration activities

In the early stages of restoration, press releases, the company website, and social media are the most effective methods for communicating restoration information as Global and Regional ETRs are applicable to most of the affected customers. As restoration efforts progress, those estimates apply to a smaller percentage of the remaining affected customers and case-specific and individualized communications are preferred. Customers are able to receive this case specific restoration information by speaking with a CSR, calling into the IVR, chatting with a CSR, viewing the outage map, using the mobile app, or registering for text alerts. At the end of storms lasting greater than 48 hours, banner messaging on the website and outage map will continue to guide customers to these options until 1000 or fewer customers remain affected.

Additionally, outage notifications including ETR updates will be sent to customers who have registered to use Central Hudson's texting and email alert notification system known as Notifi. This service will send proactive messages to registered customers and lets customers register, report outages, and receive recent status by texting keywords such as "REG", "OUT" or "STAT." Additional information on the Notifi alerts service can be found in the Service Interruptions section of Appendix Q.

The Central Hudson website, and any event-specific information pages, should be available around the clock unless critical issues force it to be down for repair. The outage map should also be available 24x7 unless critical repairs are needed to prevent unscheduled and possibly longer duration downtime. If possible, critical repairs/maintenance will be done after 10 PM or before 6 AM. Non-critical maintenance should be postponed until all customer outages have been restored. In the event that the company website or underlying data sources go down, the Service Branch Director or designee will notify the on-call IT personnel without intentional delay. IT personnel will work to resolve the issue and will provide updates on corrective action regularly. If needed, the Service Branch Director or designee will submit trouble tickets with third party vendors and facilitate any interactions between them and Central Hudson's IT group. When customer facing applications are experiencing a technical issue, the Public Information Officer or designee will post a message banner on the main website homepage, and the Customer Communications Branch Director will post a message banner on the outage map as appropriate, informing customers of the details and necessary steps for reporting outages and obtaining information. This message banner will also be used when needed to communicate status on system maintenance or outage map down time due to other issues, such as data quality. The Company will also use social media to inform customers when such issues exist.

6.10 Life Support Equipment and Special Needs Customer Contacts

6.10.1 Definitions

Special Needs – 16 NYCRR 105.4(b) (9) provides examples of special needs customers such as the elderly, the vision-impaired, the hearing and speech-impaired, and the mobility impaired and human service agencies representing these customers. On Sept. 30, 2013, DPS Staff issued a directive for customers with a documented Medical Emergency to also be treated as “Special Needs”.

Medical Emergency – Per 16 NYCRR 11.5(2), a medical emergency exists when a resident of a customer’s residence suffers from a serious illness or a medical condition that severely affects their well-being. 16 NYCRR 11.5(4) (i) states that a medical doctor or qualified official of the local board of health must state in writing to the utility the expected duration of the medical emergency and explain either the nature of the medical emergency or the reason the absence of utility service would aggravate the medical emergency.

Life Support Equipment – 16 NYCRR 105.4(b) (9) defines life support equipment customers as those who require electrically operated machinery to sustain basic life functions. This includes designated electrically operated medical equipment prescribed by a qualified physician to be used on a continuous basis or as circumstances require as specified by the physician to avoid the loss of life or serious medical complications requiring immediate hospitalization.

6.10.2 Communication Procedures

When the anticipated impact of an impending storm would result in a Class 2 or greater incident, a pre-storm warning outbound call is initiated. The Consumer Outreach department will work with the Emergency Response group to determine when the warning calls should be made. Pre-storm warning calls are made by the outbound communications call vendor to all Life Support Equipment and Special Needs customers. The text of the message is found in the Section 7.3 – Life Support Equipment and Special Needs Customer Contact Procedure.

When the anticipated impact of an impending storm would result in a Class 2 or greater event, a pre-storm email is sent to human service agencies that represent Special Needs customers. This email alerts the human service agencies of the expected event and provides contact information for the Consumer Outreach Department, who can assist with any inquiries.

When a Class 1 or greater incident is underway, the Life Support Equipment and Special Needs Customer Contact Procedure is followed. The Contact Center Branch Director is responsible for ensuring that all steps in the procedure are followed, reaching out to other departments for support if Consumer Outreach employees cannot accomplish all of the contacts in a timely fashion. For details of the Life Support Equipment and Special Needs Customer Contact Procedure, see Section 7.3.

6.11 Contact Center Staffing

The beginning of a major storm event drives volume in all contact channels from customers reporting their outages by phone, chat, e-mail, the website, and the Company’s mobile app. Voice channels receive an influx of storm-related contacts during the initial hours of a storm event. Using voice channels customers are able to report their outages through the IVR or supplemental outage IVR, or by speaking directly with a CSR. In all of these contacts, an outage can be reported, and a

subsequent order is entered into the Customer Information System (CIS).

The Contact Center Branch Director will schedule CSRs to work longer shifts and obtain additional trained personnel to answer customer calls based on the severity and duration of the event. Staffing levels will be determined based on the classification given to the event by the Incident Commander. The Contact Center Agent staffing levels in the table below are inclusive of all live internal and external resources trained to assist customers with storm related calls. The staffing guidelines below indicate the minimum staffing level for each event classification; however, the staffing plan may be adjusted based on the specific nature of the event, at the discretion of the Contact Center – Branch Director, who is responsible for managing customer contact volume in all contact channels (phone, web, IVR, chat, email, etc.). Staffing needs will also vary throughout the duration of the storm, as call volumes and travel conditions change.

	Class 1	Class 2	Class 3
12:00 a.m. – 6:00 a.m.	4	4	6
6:00 a.m. – 8:00 a.m.	6	8	16
8:00 a.m. – 6:00 p.m.	10	18	50
6:00 p.m. – midnight	6	8	16

Notes:

1. *The above staffing levels are for storm staffing outside of normal business hours. On normal workdays, all Contact Center staff (approximately 45 CSRs on average during business hours) are available to answer outage calls as needed. Staffing may be physically present at the Contact Center or at another location, including home locations.*
2. *The above staffing levels represent minimum levels that would coincide during the peak outage and call volume timeframe of an event. When call volumes are lower during the early stages or after significant restoration progress has been made, the Contact Center Branch Director will modify staffing levels as needed and redirect resources to interact with customers in all other contact channels.*
3. *Refer to Section 1.2 of this plan for incident classification definitions.*

The Central Hudson Contact Center strives to meet or exceed the performance measures described in the Utility Emergency Performance Metrics (NY-Scorecard) as clarified in the November 3, 2014 letter from the NY-PSC that defines call answer rate performance as 80% of calls related to the event answered in 90 seconds by a live representative. Phone statistics are maintained by Contact Center Supervisors for use in critique reports after the event and are available on a 30-minute interval basis. Abandonment rates are included in these statistics.

6.12 Call Routing and Customer Contact Methods

Customers can report their outages using our website, mobile app, text messaging, or by telephone. Incoming calls are answered by the IVR until such time as the call volume exceeds our incoming phone line capability. When all of Central Hudson’s IVR ports are in use simultaneously, additional calls are automatically routed to the IVR system of the overflow call vendor. Routing calls to the overflow call vendor increases the response time for those customers that prefer to report outages using automated methods. Calls received by the IVR are either handled by the automated system or transferred to a live agent if requested.

Additional live agents are available at our outsourced call center. Throughout the course of normal business, these representatives will receive calls automatically for customers currently in the collections process. During major events, the Contact Center Supervisor may elect to direct a percentage of calls from the Trouble and Emergency queue to these additional outsourced agents. During these times, these agents would handle electric emergency calls in addition to inbound collections and moving calls. The percentage used to split calls between outsourced and Central Hudson agents is based on staffing and anticipated inbound call volume and can be adjusted by the Contact Center Supervisors during the

event. Routing calls to this outsourced call vendor improves the customer experience and speed at which outages and other emergencies can be reported for customers who prefer to speak with a live agent. Additionally, this practice increases Central Hudson agent availability and reduces wait time for reporting outages and other emergencies.

Contact Center Supervisors continually monitor for instances of high abandon rates or reports of busy signals on its incoming call center lines. Abandonment rates are monitored by the VOIP phone system in an automated fashion and are displayed throughout the Contact Center for continual monitoring by the Contact Center Supervisors. When working virtually, Contact Center Supervisors are able to log in and view these metrics. Contact Center Supervisors also monitor the phone system for busy lines by performing manual checks and reviewing customer's reports of busy line signals, via other communication channels (such as e-mail, web chat or social media). This is a practice that is in place for both "blue sky" days and storm situations. Whenever a system-related issue is identified, the Contact Center Supervisors will initiate immediate resolution with the Information Technology Branch Director.

Contact Center staff are trained to inform customers that we are currently unable to handle normal business items at the onset of a storm based on witnessing a large buildup in the queue. During later stages in the storm, the Contact Center Supervisor instructs agents to resume normal business calls. Customer self-service options are promoted on our website and in the IVR at all times and remain available during storms.³

ETR information is available via the following means for each type of contact method:

- Central Hudson IVR and Overflow call vendor IVR – real time using direct call to OMS database.
- Online outage map
- Website/Mobile Web/Texting – real time web-service call to OMS database
- Live agents (including outsourced agents) – real time using interface between the customer information system and OMS.

³ Upfront IVR messaging will advise customers conducting non-storm business to seek assistance after the event. However, it is Central Hudson's practice to accept normal business calls via agents versus redirecting them in an automated fashion. Quite often, even during storms, there are periods of moderate call volume relative to the staffing levels and agents are able to conduct normal business with customers on the phone. The Contact Center attempts to assist as many of these customers as possible versus setting fixed time periods where normal business will not be conducted.

7 Procedures

The following Company procedures are contained in this section:

- 7.1 Estimated Time of Restoration Protocols
- 7.2 ETR Procedure
- 7.3 Life Support Equipment and Special Needs Customer Contact Procedure
- 7.4 Wire Down Procedure
- 7.5 Damage Assessment Process
- 7.6 Outage Management System Support Procedure
- 7.7 Flood Restoration Procedure
- 7.8 Loop Crew Guidelines
- 7.9 Mutual Assistance Procedures

7.1 Estimated Time of Restoration Protocols

The following ETR Protocols are activated when more than 5,000 customers are out of service in a division, or more than 20,000 customers are out of service companywide for more than 30 minutes. The ETR Protocols include minimum requirements for when, and at what level of detail an ETR will be communicated to the Department of Public Service (Department or DPS Staff). The tables below clarify the necessary actions to be taken by the involved utilities before and during the outage period for the specific outage event.⁴ Utility procedures and practices that require actions prior to those identified will continue to be used.

The protocols are considered minimum requirements necessary to ensure the public and the Department are adequately informed. **During restoration, utilities are to continuously refine ETRs and update DPS Staff and the public, customer representatives, IVR systems, and websites.** The utilities will also provide restoration information such as outage counts and ETRs to the press/media outlets and public officials in the affected areas. Additionally, utilities will issue at least one press release daily for all outage events with an expected restoration period of longer than 48 hours.

Regional and local ETRs will be used and applicable to at least 95% of the affected customers in the reported level. Regional ETRs are to be provided on a county basis and local ETRs are to be provided on a town or municipal basis. Global ETRs may be used initially for outage events expected to last greater than 48 hours and applicable to at least 90% of the affected customers. Once all regional ETRs have been issued references to the global ETR will be eliminated.

When adverse weather conditions exist, the start of the restoration period is the point in time when:

- Field personnel can be dispatched without unacceptable safety risks from continued severe weather conditions and
- When the potential additional damage to the electric system from the storm would be low in proportion to the expected level of damage already sustained.
- The start of the restoration period may be different for specific, local areas where the effect of a storm limits access to facilities for example severe flooding.

Initial notification to the Department will follow the *Event Notification Requirements* issued in Appendix B of Case 04-M-0159 on December 15, 2008. Any additional information that is available will be included in the initial notification even if the notification is required prior to the start of restoration. For widespread outage events, company-wide outage statistics will also be provided as part of the initial notification.

Reporting is required at 7:00 am, 11:00 am, 3:00 pm, and 7:00 pm unless otherwise specified. The reports will include, at a minimum:

- Utility information
- Summary of the outage event, for major storms summarize the weather and weather forecast
- Summary of outages
- Synopsis – discussion of major damage and work plans for restoring customers
- ETRs
- Resource summary – on-site and en route, planned crew relocation and mutual assistance activity
- Summary of the impacts to critical facility customers and Life Support Equipment customers

⁴ An outage event is either a major storm, as defined in 16 NYCRR §97.1(c), or another electric service interruption or electric emergency.

- Dry ice/bottled water activities

Report submissions may qualify as a notification to DPS Staff provided they contain the required information within the appropriate timeframe. Utilities, however, may need to make notifications to DPS Staff in addition to report submissions early in an outage event to satisfy the guidelines.

As seen in the procedures in Section 7.2, specific ETRs may be developed by different staff members based on the severity of the event. These individuals include, but are not limited to: Operations Section Chief, the ETR Development Coordinator, Line Operations Director, and Operating Supervisor.

For major events, global and regional ETRs are reviewed and agreed upon at Incident Command meetings; local and job specific ETRs are to be published by the Operating Section. The Customer Information Coordinator is responsible for verifying that the ETRs published on the outage map summary tables are current and match those developed by the various operating staff. This effort involves verifying Local and Regional ETRs and is performed several times a day during major storms.

For information on assessment of ETR accuracy see Section 5 – Post Event.

7.1.1 Event Expected to Last 48 Hours or Less

Within the first 6 hours of the restoration period
<ul style="list-style-type: none"> ▪ Notify DPS Staff that the outage event will last less than 48 hours. The notification to DPS Staff will state what the Company has defined as the start of the restoration period. For outage events expected to last less than 24 hours, notification may be via the Department’s information reporting system. ▪ Provide available information to the public. Update customer representative, IVR systems and websites. ▪ In certain situations, such as a nighttime outage event, only limited information may be available within the initial six-hour window. In these situations, the expectation is that the companies will inform DPS Staff of the delay in determining the initial outage duration within six hours and the notification will occur in an expedited manner as information becomes known. Following a nighttime outage event, the determination of whether the restoration period will be less than 48 hours will be communicated to DPS Staff as soon as possible, but no later than noon the following day. Any delay in establishing the initial expectations will not affect the time requirements below.
Within the first 12 hours of the restoration period
<ul style="list-style-type: none"> ▪ Provide DPS Staff and the public with any available regional/county ETRs and any available local/town or municipal ETRs. Update customer representatives, IVR systems, and websites. ▪ Issue a press release that includes known ETRs for the next upcoming news cycle ▪ Communicate with affected municipal and elected officials. This communication may or may not be by way of a municipal conference call.
Within the first 18 hours of the restoration period
<ul style="list-style-type: none"> ▪ Provide DPS Staff and the public remaining regional/county ETRs. Update customer representatives, IVR systems, and websites. ▪ Provide DPS Staff and the public with any additional local/town or municipal ETRs. Update customer representatives, IVR systems, and websites.
Within the first 24 hours of the restoration period
<ul style="list-style-type: none"> ▪ Consider issuing a press release for the next upcoming news cycle based on conditions.
Reporting guidelines during the event

- Provide restoration information updates four times daily to DPS Staff (7 am, 11 am, 3pm, and 7 pm) if requested by DPS Staff. Updates will continue until otherwise directed by DPS Staff.
- Notify DPS Staff when all outage event related interruptions have been restored.

7.1.2 Event Expected to Last Greater Than 48 Hours

Pre-event whenever sufficient notice of an impending weather event is available

- Make pre-event outbound calls to critical facilities customers, life support equipment customers, and special needs customers.
- Complete pre-storm communications with outreach to employees, the news media, social media sites, blast emails and text messages to customers, and advisories to municipal and elected officials.
- Consider having pre-event municipal conference calls based on the situation. An alternative municipal contact method may be used if it is more appropriate.
- Issue public statement and/or press releases.

Within the first 6 hours of the restoration period

- Notify DPS Staff that it will be a multi-day outage event lasting more than 48 hours. The notification to DPS Staff will state what the Company has defined as the start of the restoration period.
- Provide a public statement and/or press releases indicating the likelihood of extended outages and make this information available via customer representatives, IVR systems, and websites.
- In certain situations, such as nighttime outage event, only limited information may be available within the initial six-hour window. In these situations, the expectation is that the companies will inform DPS Staff of the delay in determining the initial outage duration within six hours and the notification will occur in an expedited manner as information becomes known. Following a nighttime outage event, the determination of whether the restoration period will be greater than 48 hours will be communicated to DPS Staff as soon as possible, but no later than noon the following day. Any delay in establishing the initial expectations will not affect the time requirements below.

Within the first 12 hours of the restoration period

- Issue press releases based on the predetermined time periods defined in the emergency plan.
- Communicate information such as system damage, outages, restoration status etc. with affected municipal and elected officials as appropriate.
- Schedule the first post-storm municipal conference call(s) unless an alternative municipal contact method is more appropriate. The first scheduled municipal conference call does not necessarily have to be held within the first 12 hours but will be held within the first 24 hours.
- Notify DPS Staff and the public of what areas sustained the most damage to the electric system and ETRs where known, on a county or regional basis.

Within the first 24 hours of the restoration period

- Complete the first scheduled municipal conference call.
- Provide DPS Staff and the public with a global ETR, any available regional/county ETRs, and any available local/town or municipal ETRs. Update customer representatives, IVR systems, and websites.
- Identify for DPS Staff and the public any heavily damaged areas where large numbers of customers may remain without service for more than a few days. If necessary, note that the situation is still unfolding, and more details will be provided as soon as they become available.

Within the first 48 hours of the restoration period

- Provide DPS Staff and the public remaining regional/county ETRs. Update customer representatives, IVR systems, and websites, eliminate all references to the global ETR.
- Provide DPS Staff and the public with any additional local/town or municipal ETRs. Update customer representatives, IVR systems, and websites, eliminate all references to the global ETR.

Within the first 60 hours of the restoration period

- Provide DPS Staff and the public remaining local/town or municipality ETRs. Update customer representatives, IVR systems.

Reporting guidelines during the outage event

- Provide restoration information updates four times daily to DPS Staff (7 am, 11 am, 3 pm, and 7 pm), unless directed otherwise. Updates will continue until otherwise directed by DPS Staff.
- Notify DPS Staff when all outage event related interruptions have been restored.

7.2 ETR Procedure

7.2.1 Blue Sky Day

Procedure:

1. Outage case is received in OMS. If the Auto-ETR function is active, OMS will populate a system generated ETR value based on historical data.
2. Dispatcher assesses outage information and determines best available crew (may require discussion with Line Supervisor for that crew area).
3. Dispatcher contacts the crew to be assigned to the outage case by radio or phone and relays the case information, e.g., location of trouble calls, circuit, and predicted device.
4. Dispatcher uses job knowledge and experience to make an estimate of when the case is likely to be picked up, taking into consideration where the crew is now, and assigns an ETR if there is none or updates the system generated ETR if needed.
5. When the crew arrives at the outage location, they enter an arrival time and an estimated time of restoration in their mobile computer. As an alternative, the crew will call the Dispatcher to report their arrival and give the Dispatcher an estimate of when the work will be complete, and power restored. If this time differs by more than one hour from the current ETR on the case, the Dispatcher will update the ETR on the case in OMS.
6. If the crew verbally reports their ETR instead of entering it into their mobile computer, then the Dispatcher will check the 'Field ETR' box on the OMS project when the ETR is communicated.
7. If at any time, other outage cases are received that are expected to be worked by a crew already on another case, the Dispatcher develops an estimate the ETR for the next case to be assigned based on the ETR for the first case, plus the projected time to restore the next case. The Dispatcher compares this estimate against any system generated ETRs and assigns an ETR if there is none or updates the system generated ETR if needed.
8. It is understood that the line crews have the primary responsibility for contacting the Dispatcher when an ETR time is not achievable. However, at times line crews may become highly involved in the restoration work and lose track of the time remaining until the ETR expiration. Therefore, it is also the responsibility of the Dispatcher to continually monitor ETRs. When any outage case is getting close to the ETR time (OMS will display a yellow "ETR Warning" symbol on that case in the Control Window), the Dispatcher will attempt to contact the crew to let them know the ETR is getting close.

Depending on the results of this call, the Dispatcher may elect to use the Log Entry feature in OMS to enter remarks explaining why ETR was revised, e.g., "Crew called at (xxxx time). Changed ETR due to (explanation)." These remarks will show on the ETR by Crew Report which is available on the OMS intranet.

Escalation Process –This process will remain in place until there is sufficient activity to require district support. When this threshold is reached, Dispatchers are required to contact Dispatch Supervisors. Dispatch supervision will contact Operating Supervisors to arrange for manning a district and will provide additional dispatch personnel as necessary. Dispatchers continue to assign ETRs and receive updates from the line crews until a district is manned. As soon as one or more districts are manned, the ETR process will then follow the Class 1, 2, or 3 procedures.

7.2.2 Class 1 Incident

Procedure:

As soon as a district is manned and/or >5000 customers are out of power, Dispatch Operations will contact Storm Center staff. Together, the Dispatcher and Storm Center staff will determine the restoration start time, using the definition provided in the PSC ETR Protocols.

Dispatch Operations will continue to provide ETRs for all districts that are not manned, following the Blue-Sky Day procedure.

For districts that are manned, the District Operating Team (generally made up of the Operating Supervisor and Electric Operating Engineer (EOE) in the district, or their designees) will assume responsibility for assigning and communicating ETRs according to the procedure below:

1. The District Operating Team will develop a restoration plan which will lay out what cases are to be assigned to which crew.
2. Storm Center staff will contact the District Operating Team and inform them of the official time that the storm restoration started. The Operating Team may provide a global ETR time, if available prior to regional or local ETR times, as well as regional and local ETR times per the protocols in Section 7.1. If the Operating Team determines that 90% restoration within 24 hours is not likely, the procedure for a Class 2 or 3 incident will then be followed.
3. The District Operating Team will use reasonable efforts to assign two cases to each crew according to the restoration plan and to set ETRs at the time of case assignment. These ETRs will be developed based on knowledge of weather/traffic conditions, any available damage assessment information which may have come in from Line Supervisors, 911 centers, etc. and knowledge of the circuit configuration (on/off road).
 - The Dispatcher will dispatch the cases to the line crews in the order determined by the District Operating Team, using ETR and size of the outage case as a guide.
 - Crews may use their mobile computers to report arrival times and estimated times of restoration or call the Dispatcher when arriving at the job site and report their expected ETR.
 - ETRs will be revised as needed, but not unless the new estimates exceed 1 hour from the existing value.
 - The field ETR box will be checked when the crew has verbally communicated the ETR for that project.
 - Crews will also be instructed to inform the Dispatcher if the predicted device is not open in the field. This is needed so that outage case adjustments can be made to more closely match field conditions, and accurately identify which customers belong in which case.
4. When information is available and time allows, Dispatchers will enter the ETR estimate as cases are assigned, change the crew status to 'dispatched' or 'en route' and update the ETR for the next case to be assigned to that crew.
5. If at any time, the global, regional, or local ETR is in danger of being exceeded, the District Operating Team will notify Storm Center staff and provide a revised estimate.

7.2.3 Class 2 Incident

Procedure:

As soon as the first district is manned, Dispatch Operations will contact Storm Center staff. Together, the Dispatcher and Storm Center staff will determine the date/time of the storm start, using the definition provided in the PSC ETR Protocols. Damage assessment will be initiated by Storm Center staff as needed. Storm Center staff will also determine if support teams should be assigned to the most heavily affected districts.

Dispatch Operations will continue to provide ETRs for all districts that are not manned, following the same procedure as Class 1 incidents above. Care will be taken to ensure that any district where customers will likely be out overnight is either manned, or that a consultation takes place with the Operating Supervisor. For districts that are manned, the District Operating Team will assume responsibility for assigning and communicating ETRs according to the procedure below:

1. The District Operating Team will develop a restoration plan which will lay out what cases are to be assigned to which crew. For storms on the high end of Class 2, this plan may begin to be laid out by circuit with a supervisor or crews assigned to each. For the purpose of simplification, the term "crew" in this section will be intended to include either the line crew, or the Line Supervisor who has assumed operational authority for a circuit.
2. Storm Center staff will contact the District Operating Team and inform them of the time that the storm officially started. The Operating Team will provide a global ETR time for 90% restoration per the protocols in Section 7.1. If the Operating Team determines that 90% restoration within 72 hours is not likely, the procedure for a Class 3 incident will then be followed.
3. The District Operating Team will use reasonable efforts to assign cases to each crew according to the restoration plan and to set ETRs at the time of case assignment. These ETRs will be developed based on knowledge of weather/traffic conditions, any available damage assessment information and knowledge of the circuit configuration.
4. Dispatcher will follow the same process as the Blue -Sky procedure, steps 4 – 7 above for all districts that are not manned.
 - Crews are expected to use their mobile computers or contact the dispatcher as soon as they arrive at the outage location and provide an ETR for that case; dispatchers will mark the crew Arrived and check the 'Field ETR' box at this time.
 - ETRs will be revised as needed based on crew updates.
 - Crews will also be asked to inform the dispatcher if the predicted device is not open in the field. This is needed so that outage case adjustments can be made to more closely match field conditions, which is needed to accurately identify which customers belong in which case.
5. When information is available and time allows, the Dispatcher will enter the ETR estimate, change the crew status to 'dispatched' or 'en route' and update the ETR for the next case to be assigned to that crew.
6. By 8 PM on each day of restoration, the District Operating Team will determine which cases will not be restored that day. They will then contact the Storm Center to confirm that cases

with no ETR are expected to be out overnight. ETRs for cases assigned to the overnight crews will be managed by Dispatch Operations. Revised case ETRs are provided on the outage map and made available to Customer Service Reps. Customers who have signed up for the texting service may also request the most recent ETR of their assigned case by sending a short code.

7. If at any time, the global, regional, or local ETR is in danger of being exceeded, the District Operating Team will notify Storm Center staff and provide a revised estimate.

7.2.4 Class 3 Incident

For Class 3 Incidents, the following assumptions are made:

- Most districts are manned.
- All storm positions are filled in the manned districts and support teams provided as necessary.
- Operational authority is assigned for most distribution circuits to a line supervisor or substation coordinator.
- Storm Center is staffed at South Road and support staff are available during all restoration operations (06:00 to 22:00 approximately).
- Damage assessment has been activated.

Procedure:

Any district under Dispatch Operations control will follow the procedure for unmanned districts in a Class 2 incident above. The District Operating Team in each manned district will:

1. Provide a global ETR per the ETR protocols provided in Section 7.1.
2. Assign ETRs on the first high priority cases upon assignment to the crew and set ETRs on the next cases to be assigned.
3. Develop a restoration plan by the end of the first full day following the storm.
4. Provide to the Storm Center the names of any Line Supervisors or substation coordinators who have been given operational authority on a distribution circuit. Preliminary ETR for each circuit should also be communicated by the Line Supervisors or substation coordinators to the District Operating Team as soon as possible.
5. District Operating Team will provide either Township or Circuit ETRs to the Storm Center before the time required by the ETR Protocol (Section 7.1). Storm Center will utilize the circuit-township conversion program to generate township ETRs if needed and will confirm results with the District Operating Team.
6. Storm Center will work with Corporate Communications and the Contact Center to ensure consistency in communication of ETR times with customers, automated systems, and websites.
7. District Operating Team will update ETRs on outage cases at the following times:
 - by 11:00 – cases that are expected to be restored by 14:00 that day.
 - by 20:00 – cases that are expected to be restored by the end of the day.
8. By 20:00 each workday, District Operating Team will:

- Meet or call Line Supervisors or substation coordinators and obtain the status of the restoration with emphasis on which customers have been restored, which will be off overnight and any known service loops or customer owned damage locations.
 - Confirm with the Storm Center the OMS cases or circuit devices that will remain out overnight. Revised case ETRs are provided on the Outage Map Summary tables and made available to Customer Service Reps. Customers who have signed up for the texting service may also request the most recent ETR of their assigned case by sending a short code.
9. District Operating Team will update circuit based ETR times in time for assimilation into PSC reports (times to be defined at the start of the event by Storm Center staff).
 10. Line Supervisors or substation coordinators will keep the District Operating Team informed whenever any case or circuit section will likely exceed the restoration time provided.
 11. Damage Assessment Coordinators will continually, throughout the event, work with EOE's to fine tune OMS case predictions to model as closely as possible the actual field conditions. This is necessary to ensure that customers are assigned to the correct cases and as such are getting correct ETR information.
 12. If at any time, the global, regional, or local ETR is in danger of being exceeded, the District Operating Team will notify Storm Center staff and provide a revised estimate.

7.3 Life Support Equipment and Special Needs Customer Contact Procedure

7.3.1 Identification

Life Support Equipment (LSE) customers are those who have documented a need for essential electricity based on medical needs, which shall include but not be limited to: apnea monitors for infants, cuirass respirators, hemodialysis machines, intravenous feeding machines, intravenous medical infusion machines, oxygen concentrators, positive pressure respirators, respirators/ventilators, rocking bed respirators, suction machines, and tank type respirators. These customers are required to submit a qualification form signed by a physician before they will be coded as such in CIS. Upon receiving this form, the Consumer Outreach department will update the customer's account in CIS to reflect the LSE status. LSE customers are required to recertify annually; however, all LSE accounts remain coded regardless of the recertification results. Central Hudson follows the PSC established process for removing customers from our LSE listing which requires the submission of a Utility Request for Removal Form along with substantiating documentation. Once permission is received via email by DPS Staff, Central Hudson removes the customer from our LSE listing. Additionally, if an account is closed at the request of the customer and/or a new customer takes over the premises, the LSE coding is removed by the Consumer Outreach department.

The annual recertification form includes a section requiring customers to provide their primary phone number, up to two alternate phone numbers (which Central Hudson strives to obtain), and emergency contact information. Any contact information changes that are provided on the form will be updated on the customer's account. Additionally, whenever Contact Center personnel speak with an LSE customer, the representative will ensure that all contact information on the account is correct, making updates as needed.

Special Needs (EBD) customers are given a Special Needs code on their CIS accounts when the customer applies for service, or whenever a CSR determines that an elderly, blind or disabled person is part of the household. Special Needs codes are as follows:

01 – Blind and Elderly	06 – Blind
02 – Disabled and Elderly	07 – Disabled
03 – Elderly	08 – Hearing/speech Impaired
05 – Elderly in Family	09 – Medical Condition, LSE Ineligible

Contact Center personnel will verify contact information for Special Needs customers any time they speak with these customers and make updates to the account as needed.

Semi-annual Contact Information Update

Attempts to update and verify LSE customer contact information are done at least twice a year, initiated by the Consumer Outreach Director. It is intended for this outreach to be performed near the time of the Annual Electric Exercise and Electric Emergency Plan update (on or before June 1 and December 1 every year). This update includes verifying all LSE customer phone numbers, and the name and phone numbers for two emergency contacts, as available. The semi-annual contact information update is to be performed via a mailed survey and/or outbound phone calls. When the semi-annual LSE outreach is completed, a certification letter will be sent the Department of Public Services' Director of the Office of Resilience, Utility Security, Nuclear Affairs and Emergency Preparedness.

Annual Contact with County EOCs

As part of the annual Electric Emergency Exercise, the Consumer Outreach Director or designee will contact the county EOCs to establish a point of contact and process for assistance with LSE field visits should these become necessary during a major event.

7.3.2 LSE and Special Needs Customer Outreach

Central Hudson publishes the Powering Connections newsletter, which is emailed or mailed to all Special Needs customers twice annually. This newsletter contains information about electric safety and other topics of interest for this customer group. We also have several pamphlets that are geared toward special needs customers that are mailed to customers when a Customer Service Representative or Consumer Outreach identifies a need.

LSE customers are provided with a dedicated priority hotline number to contact the Company at any time.

Central Hudson's Consumer Outreach plan is updated annually and is provided to DPS Staff. The section of this plan that pertains to Special Needs customers is attached as Appendix Q.

7.3.3 LSE and Special Needs Incident Contact Details

The Outreach Director, or designee, is responsible for coordinating and documenting the results of the required LSE communications as described below, including: "Pre-event," "During the event," and "After service is restored." Documentation of all LSE communications related to a storm event is centrally maintained using the LSE tracking spreadsheet and the results of telephone, text as reported outage, website, and other contact as practical are noted on the account in the CIS.

Pre-event LSE and Special Needs customers contact details: When the anticipated impact of an impending storm would result in a Class 2 or greater incident, the Outreach Director or designee, will initiate an outbound notification to all customers coded as Life Support Equipment (LSE), Special Needs, and Medical Condition (LSE Ineligible). This automated message informs the customer that severe weather is forecasted for their area, and their electric service may be affected. (See pre-storm warning call message below). Additionally, the Outreach Director, or designee, will coordinate notifications of EOC centers that LSE customers may be impacted during this event and that we may request assistance in performing wellness checks.

During the event LSE contact details: During an incident, and provided that electrical power has not been restored, the Company will attempt to contact LSE customers who have either reported an outage or who are predicted to be in an outage case. To identify these affected customers, the Outreach Director, or designee, shall run a report which reflects the most recent information at least every four hours except between the hours of 10 PM and 8 AM, until the last affected customer has been restored. The contacts are to be made as soon as possible after the affected customers are identified. However, depending on the timing of the event, consideration is given to minimize calls during the overnight period. The Outreach Coordinator, or designee, is responsible for ensuring that at least 80% of the LSE customers affected within 12 hours from the start of the event will be contacted within this 12-hour period and that at least two contact attempts, with at least one hour in between, will be made within this period to LSE customers that the Company is unable to contact.

A "contact" when referring to LSE customers during an outage event is now defined as: (1) a personal telephone call in which the LSE customer or guardian/representative/person in residence is directly spoken to; (2) a field visit performed by the utility or third-party in which a person in residence is directly spoken to; (3) a field visit performed by the utility or third-party to the address that the Company has on file from the certified LSE application where there is no response to a knock on the door or ringing of the doorbell. While in this scenario contact with the LSE customer was not made, the field visit will satisfy the requirements of the outreach; or (4) if technologically available, an automated phone call or text message to all contact numbers in which an interactive feature is available and a qualifying response is received, e.g., two-way texting that has LSE customers confirm

their safety or acknowledge their power has been restored. These contacts inform customers that Central Hudson is aware of their outage and will provide them with any known ETR times and sources of emergency help. Additionally, LSE customer contact information is reviewed and updated as necessary. All emergency contact numbers on the customer's account will be called if the customer cannot be reached at their main number.

If multiple contact attempts are unsuccessful, the Outreach Director, or designee, is responsible for coordinating a field visit (typically by a Central Hudson employee) or making a referral to the appropriate county Emergency Operations Center (EOC) within 24 hours of the start of the event. The Outreach Director, or designee, strives to make referrals to the EOC by 6 PM each day. Information received back from the EOC will be entered on the customer's account and LSE tracking spreadsheet. If by the end of the day that the customer is referred, no call has been received from the EOC, the Outreach Director, or designee, will follow up with that agency to determine the status of the customer contact and need for continued contacts.

Using the method described above, the Company will contact affected LSE customers daily until the last affected LSE customer is restored. At the Company's discretion, LSE customers will have the option to opt-out of daily calls and/or wellness visits for that particular event under the following conditions: (1) when informed by emergency contact or member of household that the LSE customer is deceased, the utility will note the account and will not be obligated to make further contact attempts (call/wellness visits); (2) when informed that the affected LSE customer is not at the premises (e.g., out of state for the winter); or, (3) the utility provides ETR information for that customer and either the LSE customer or emergency contact requests no further contact from the utility, the utility will note the account and will not be obligated to make further contact attempts (calls/wellness visits).

During the event Special Needs Customer contact details: During the event, Special Needs customers who are without power will be contacted daily by means of an automated outbound call, managed by the Customer Information Coordinator. This call will include where to obtain estimated restoration times and shelter locations, bottled water, and dry ice locations. Special Needs customers will be allowed to 'opt out' of these daily calls if desired. Medical Condition (LSE ineligible) customers will be included in any contacts made to Special Needs customers.

After service is restored LSE contact details: If the Company has not already verified restoration with the affected LSE customer during the emergency, a post restoration call is attempted to verify that each affected LSE customer has been restored. An automated outbound call with a response option may be used to verify restoration.

LSE Contact Staffing

The guidelines below indicate the recommended staffing levels for the personnel who perform the LSE phone contacts and in-person wellness checks based on the actual or anticipated number of affected LSE customers. The Outreach Branch Director, or designee, will adjust actual staffing levels as needed based on factors such as event timing and contact response rate.

Number of LSE Customers Affected/Anticipated	Recommended Staffing Office	Recommended Staffing Field
0-50	2	1
51 – 150	3	2
151 – 300	6	3
301 – 500	10	5
501+	11+	6+

7.3.4 Sample Scripts for LSE and Special Needs Calls

The CIS is used to initiate pre-storm outbound warning notification calls to LSE and Special Needs customers. When initiating this call, users can select an individual operating district or select 'ALL' to call customers with Life Support Equipment or Special Needs codes in the system. Sample text of the pre-storm warning call message is as follows:

Hello. This is Central Hudson calling. Our records show your account has special needs, meaning you have a senior or disabled person in your home, or someone who has a need for medical equipment. Central Hudson is calling to advise you that we are expecting severe weather in your area and that your electric service may be affected. Please plan accordingly in anticipation of a potential service interruption. The length of any outage depends on the severity of the weather and the number and the locations of interruptions. Should you experience a power loss, please call us at 1-800-527-2714 to report your outage. That number is 1-800-527-2714. We will attempt to restore service as soon as possible.

Sample text of the daily Special Needs call is as follows:

This is Central Hudson calling with an update regarding your power outage. Currently, Central Hudson expects the majority of our customers to be restored by (date/time), however many areas will be restored prior to this time.* Please check CentralHudson.com for individual restoration times, emergency shelter information, and dry ice distribution locations. You may also contact Customer Service by phone to obtain this information using the number provided later in this message. If you are in danger due to loss of heat or power, please *call 911 immediately*. Also, please keep at least 30 feet away from any downed wires and report this condition to Central Hudson right away. To opt out of these daily updates, please contact Customer Services at 845-452-2700 or 800-527-2714. Thank you.

**or, if no Global ETR is available: "Central Hudson is still assessing damage from this severe weather event, and we will provide estimates of when power will be restored as soon as this effort is complete."*

Sample text for the LSE Customer Contact Attempt is shown below:

This is an automated call from Central Hudson to customers whose accounts indicate they require Life Support Equipment. The purpose of this twice-a-year call is to confirm that we can successfully reach you and your emergency contact. There is no need to respond if your information and the information for your emergency contact is current. Our system will alert us that we have reached a working number. If you do wish to update your information or your

emergency contact's information, please call our LSE Hotline at 800-655-9356 or email ConsumerOutreach@cenhud.com. Thank you.

Sample text for the Special Needs (EBD) Customer Contact Attempt is shown below:

This is an automated call from Central Hudson to customers whose accounts indicate they are classified as a special needs customer. The purpose of this twice-a-year call is to confirm that we can successfully reach you. There is no need to respond if your information is current. Our system will alert us that we have reached a working number. If you do wish to update your information, please call Customer Service at 845-452-2700 or email us at ConsumerOutreach@cenhud.com. Thank you.

7.4 Wire Down Procedure

During normal business conditions or most Class 1 incidents, response to wires down and obtaining damage assessment information is the responsibility of Dispatch Operations. For these types of situations, reports of wire down are typically assigned directly to a line crew. If a line crew is not available, downed wires cases can also be checked by a Line Supervisor or Commercial Representative.

When a district is manned, response to wires down becomes the responsibility of the Wire Down Unit. The Wire Down Coordinator will coordinate the response to wire down reports with Operating Supervisor, Loop Crew Coordinators, and Damage Assessment Coordinators. The objective is for the Wire Down unit to dispatch trained employees or contractors to investigate wire down reports and arrange for standby personnel if needed to protect the public.

The objectives of Central Hudson's Wire Down Procedure are improved response to wire down locations, enhanced tracking of arrival times, documentation of actions taken, and compliance with NYS Public Service Law, Section 66 (21)(a)(xi). The procedure is as follows:

1. Wire down reports will be received from customers, police/fire dispatchers, 911 center reps, or field personnel.
2. Trouble orders will be created with one of the wire conditions marked: WIRES: POLE-TO-POLE, POLE TO BUILDING, DOWN/BURNING or SPARKING/BURNING. These trouble orders will be sent to OMS where the order comments will reflect a wire condition.
3. A file containing all wire down orders will be sent to the wires down dispatching system (Avineonics) on regular intervals. (If Avineonics, OMS, or other systems are unavailable, Wire Down Coordinators can pull a list of wire down reports periodically from available OMS reports. Additionally, to maintain business continuity if there is an OMS or Internet outage, Wire Down Coordinators can organize wire down orders and assignments using spreadsheets and/or paper notes)
4. Wire Down Coordinators will then determine resources to be assigned to evaluate and guard wires down. Wire Responders will be Estimators, Commercial Reps, Meter Testers, and contractors. Wire Guards will be Meter Readers, Collectors, Gas Mechanics, trained personnel, and contractors. The Wire Down Coordinators will prioritize and sort orders into manageable volumes per responder. Orders with the highest risk to public safety, based on order comments, will be assigned first. (See Priority below.)
5. Priority: Wire down reports where there is an immediate hazard such as a fire, or vehicle entrapment are assigned directly to a line crew or line supervisor to respond. When reviewing open wire down orders, Wire Down Coordinators will verify with the Operating Supervisor that these types of order have already been assigned.

As a general rule, the remaining wire down reports can then be assigned according to the **PRIORITY** below (highest to lowest). Factors such as bundling nearby orders to minimize travel time and spacing out Wire Responders to maximize coverage across the service territory are also considered when assigning orders.

- **Priority 1 – (HIGHEST)** Wire down reports where it is indicated that the wire is

burning, arcing/sparking, or similar hazard.

- **Priority 2** – Relief of fire departments, police departments, or other municipal agencies that are standing-by downed wires.
- **Priority 3** – Report of wire down from Emergency Organization. *
 - Reported to be affecting traffic flow on a major public highway
 - Reported to be blocking/near a pedestrian walkway or driveway
 - Reported to be primary conductor
 - Reported to be secondary conductor
- **Priority 4** – Report of wire down from other sources:
 - Primary conductor is indicated
 - Secondary conductor is indicated
- **Priority 5 – (LOWEST)** Report of wire down where type of wire is not indicated, or where it appears the wire is not likely an electric conductor

** Priority 3 includes reports from municipal emergency officials, defined as members of the 911-call center, police, fire, Office of Emergency Management (including Emergency Operations Center personnel), and municipal emergency managers. Wire down reports from these entities will be marked as "911" in the trouble order so that they will appear as Emergency projects in OMS. Consistent with Public Service Law § 66(21)(a)(xi) notifications from municipal emergency officials will be placed in Priority 3 unless the report received indicates they should be placed in Priority 1 or 2. Section 7.4 of Central Hudson's Electric Emergency Plan constitutes Central Hudson's plan to promptly secure wires within thirty-six hours of notification of the location of such downed wires from a municipal emergency official.*

Pursuant to Public Service Law § 66(21)(a)(xi) this is a plan, with which Central Hudson will maintain substantial compliance subject to its need to maintain the public safety and respond to emergency conditions.

6. Wire Down Coordinators will use Avineonics to track wire down orders that are assigned or still unassigned. In addition to tracking order assignments, the Avineonics software records Wire Responder and Wire Guard responder arrival times. (If Avineonics is unavailable, the wire down order assignment and documentation of Wire Responder and Wire Guard arrival times will be done manually using a spreadsheet or other manual list. The Wire Down Supervisor will assist and/or assign resources as needed to ensure that arrival times are captured.) Assignments will NOT be made in OMS, as this information is likely to be overwritten early in an event, and also, the "Crew" field in OMS should not be used for Wire Responder personnel.
7. Wire Responders that are specifically dispatched to safeguard downed wire situations will drive to the location of the wire down report. After assessing the situation, they will determine the severity of the wire down condition. Severity will be determined based on the following guidelines:

Severity 1 – (HIGHEST) – Wire down conductor that poses a high risk to public safety due to its location in a road or pedestrian-accessible area. These situations will require the responder to remain on-site and guard the wire until they can be relieved, or the wire has been made safe by a qualified employee(s) or contractor(s). The only qualified employees or contractors who can make primary safe are Line Supervisors and/or Line Crews.

Severity 2 – Wire down is a primary conductor but is not on a main road or other easily accessible location. In addition to primary wires, any pole-to-pole neutral wires would also be considered a “primary conductor.” These situations will also require the responder to remain on-site and guard the wire until they can be relieved or until the conductor can be verified de-energized by a qualified employee or contractor. Once the wire is known to be de-energized, the Wire Responder/Guard will barricade the area and then can move on to their next location.

Severity 3 – Wire down is a secondary service or secondary service neutral. In these situations, the responder will attempt to notify nearby customers and will barricade/tape off the area. If wire is either open wire secondary, or triplex service cable that has an exposed end (wire is broken), the responder will remain on-site until relieved, or a qualified employee or contractor has verified that the wire is not energized. Note: some Wire Responders have additional qualifications which would allow them to make certain downed secondary wires safe and move on to the next location.

Severity 4 – (LOWEST) Wire down is not an electric conductor and is not in contact with an electrical conductor, but is instead phone, cable, or other communications property. If the situation is safe, the responder will note the condition on the Avineonics order and/or inform the Wire Down Coordinator of this and move on to the next order.

8. Wire Responders will use Avineonics to report the assessment to the Wire Down Coordinator or call it in if cell coverage does not allow mobile communication. All Severity 4 orders can be closed.
9. Any Severity 1 order which exhibits signs of energization (i.e. arcing, sparking, lights flickering) or otherwise deemed to be an immediate hazard will be communicated IMMEDIATELY to the Operating Supervisor. Other Severity 1 orders will be organized and communicated to the Operating Supervisor regularly.
10. Severity 2 and 3 cases will be coordinated with the Operating Supervisors and the Loop Crew Coordinators to determine the best repair crew to be dispatched, e.g., line, loop, or tree crew.
11. The Wire Down Coordinator will assign Wire Responders or Guards to replace Damage Assessors as soon as possible so that Damage Assessors can move on to their next assignment. The goal is to have Wire Guards relieve Damage Assessors within 8 hours.
12. The Wire Down Coordinator will assign Wire Guards to replace Wire Responders when appropriate so that the Wire Responders can move on to their next assignment.

13. The Wire Down Coordinator will keep track of where personnel are standing by and will provide relief as needed.

The Operating Supervisor of the affected district determines when the remaining wire down cases can be addressed with line resources and coordinates demobilization with the Wires Down Unit. The Company will respond to and assess all reports of downed wires no later than 72 hours after the response to an emergency event ends.

Wire Down Coordinators will be identified in the Storm Staffing Plan and coordinators for each event will be assigned during pre-storm planning sessions.

Recommended staffing for Wire Down personnel:

Class 1 Incident – Operating Supervisors will evaluate the need and coordinate the activation of the Wire Down Unit with the Wire Down Supervisor. When activated, the Wire Down Supervisor assigns coordinators for each of the affected district(s). Throughout the event, the Wire Down Supervisor and coordinators monitor the number of orders and determine Wire Responder and Guard staffing levels. In small storms, many wire down reports will be assigned to line crews or supervisors. Available Wire Responders, and/or Wire Guards, will be assigned to locations which are not already assigned.

Class 2 Incident – Operating Supervisors will evaluate the need and coordinate the activation of the Wire Down Unit with the Wire Down Supervisor. When activated, the Wire Down Supervisor assigns coordinators for each of the affected district(s). Throughout the event, the Wire Down Supervisor and coordinators monitor the number of orders and determine Wire Responder and Guard staffing levels. Available Wire Responders, and/or Wire Guards, will be assigned to locations which are not already assigned. When preparing for Class 2 Incidents, the Wires Down Supervisor evaluates the need for additional wire guard staffing, such as non-field wire guards, and a preliminary assignment plan.

Class 3 Incident – Wire Down Coordinators will be assigned in each affected district. Whenever possible, the number of personnel available to become Wire Responders and Wire Guards will be determined during pre-storm planning sessions, and a preliminary assignment plan will be developed. Once the number of wire down reports is known for each district, available wire down personnel will be assigned to each of the districts by the Wire Down Supervisor based on the distribution of the number of wire down locations. The Wire Down Supervisor will also request a list of available personnel from contractors. These resources will be assigned and scheduled to each district by means of coordination with the contract companies and Wire Down Coordinators. In general, all available personnel qualified for wire down response can be effectively utilized during Class 3 incidents.

An area in the Kingston storeroom is dedicated to store bulk items which get consumed by the Wires Down Unit during storms such as cones, barricades, and caution tape. The storeroom is used to replenish inventory if supplies assigned to wire guards run low.

It is recognized that during major storms, the number of resources that are trained and readily available (both internal and external) is limited; therefore, it is critical to utilize Wire Responders and Guards to address the wire down reports in the priority listed in this procedure.

7.5 Damage Assessment Process

During non-storm or Class 1 incidents, damage assessment is usually performed by Commercial Reps or Line Supervisors. Any information about field conditions provided by these forces, or by other knowledgeable sources such as police/fire responders or company employees, will be entered into the OMS case by the Dispatcher.

For Class 2 and larger incidents, the Incident Commander and/or the Operations Section Chief, or designee, will determine if formal Damage Assessment is warranted. This decision is based on the number of operating districts affected, the number/severity of cases showing in OMS, the timing of the event and the portion of cases that can be directly assigned to crews.

Damage Assessment is a two-stage process. It begins with Preliminary Assessment and moves into Detailed Assessment. The timing of these assessment stages is described in Sections 4.1.2 and 4.1.3. The goal of Preliminary Assessment is to quickly get trained employees into the field in areas where damage is suspected based on OMS information and incoming trouble calls. The information gathered during the Preliminary Assessment patrol is made available to the Operating Supervisors so that they can begin to deploy crews effectively. Preliminary Assessment information is also used by the ETR Development Coordinator to formulate the Global ETR and by the Field Resource Coordinator who will evaluate the need for additional/mutual aid resources.

The Preliminary Assessment process is as follows:

- Operating Supervisors and EOE determine what areas need rapid assessment. These are usually the areas where a high number of customer outages are predicted in OMS.
- Dispatch Operations contacts Commercial Reps or Line Supervisors to proceed to those areas to obtain high-level assessment of the extent of the damage.
- Any adjustment of OMS cases that can be done based on incoming intelligence from the Preliminary Assessment should be done by the Dispatcher or EOE.
- The Commercial Reps or Line Supervisors will call in their findings to the Damage Assessment Coordinator who will share them quickly with the Operating Supervisors and the Line Operations Director, generally by means of a verbal report.
- Any detailed information such as broken pole locations that is obtained through the preliminary patrol can also be keyed into OMS.
- Employees performing Preliminary Assessment are not intended to stand by wires down. However, if they determine that a wire down found in the field is a hazard to public safety, they will contact the Dispatcher and request a Wire Guard. Once the Wire Guard arrives, the employee can continue with the preliminary assessment. If a Damage Assessment Patroller or team must stand by a downed wire for more than eight (8) hours, then they shall be reassigned to the wires down unit until they can be released from that location.

Detailed Assessment can begin coincidentally with Preliminary Assessment. However, because these patrol teams need to have additional supplies and they do not have company vehicles assigned to them, the ramp-up time for Detailed Assessment is longer. The Detailed Assessment procedure is as follows:

- Damage Assessment Coordinators work with Operating Supervisors to determine if case or circuit patrolling is desired based on the number of cases and expected damage extent. It is possible that some events might use a combination of case and circuit patrolling.
- Damage Assessment Coordinators will work with Operating Supervisors to determine which cases/circuits will be patrolled.

- Damage Assessment Coordinators then assign circuits/cases to patrol teams using the damage assessment software (if the software is unavailable, Damage Assessment Coordinators will review open OMS cases and/or specific trouble calls and assign cases or orders to Damage Assessment Patrollers by speaking to them in person, speaking to them on a telephone, speaking to them on a company radio, texting them on a cellphone or by physically handing printed orders. Patrollers will then complete their assignments and report back their findings to Damage Assessment Coordinators by speaking to them in person, speaking to them on a telephone, speaking to them on a company radio, texting them on a cellphone or by physically handing printed orders with notes and/or marked up circuit maps. The Damage Assessment Coordinators summarize these findings and communicate them to the Operating Supervisor and those performing dispatching functions.
- Teams may already be in place (if advance warning was sufficient to have patrollers mobilize early in the event), or they may need to be called out. Damage Assessment Patrollers typically work in two-person teams to best manage the large amount of driving, navigating, and recording of information that is needed for this operation.
- For case patrolling, damage locations will be surveyed and then input into the damage assessment software application or communicated back to the Damage Assessment Coordinators, via other means if the application is unavailable.
- For circuit patrolling, Damage Patrollers will start at the substation or other mainline device and inspect the mainline, three-phase portion of the circuit. They will mark damage locations and devices that are open in the damage assessment software application (if unavailable, these are marked on the circuit maps provided and patrollers periodically call this information into the Damage Assessment Coordinator). After the main line is patrolled, Damage Patrollers will move on to the single-phase portion of the circuit and continue to record and report damage locations.
- Damage Patrollers immediately call into the Damage Assessment Coordinator any time wires down, broken poles, or transformer spills are encountered to provide information and coordinate response.
- Damage Assessment Coordinators then take the information provided by the Damage Patrollers and update OMS, including confirming or adjusting predicted devices.

It is the responsibility of the Intelligence Director to determine if the number of Damage Patrollers is sufficient in each district. The Intelligence Director may transfer Damage Patrollers between districts in order to fulfill the need in areas that have sustained a higher level of damage. Central Hudson has contracts with one or more contractors to provide damage assessment; contracts are also in place to provide assistance with wire down response. If any individuals that have been trained as Wire Responders are not needed for that function, then they may be utilized for damage assessment. The Intelligence Director should request contract Damage Patrollers by contacting the Wire Down Supervisor.

Supply kits, also known as "Damage Assessment Kits," are available for use by Damage Patrol teams. These are stored centrally in storm storeroom located in Kingston and should be picked up by Patrollers prior to commencing their assessment assignment. A list of supplies that are included in these kits is provided inside each box – all reusable supplies (e.g., safety lights, binoculars, etc.) are expected to be returned following the event. Supplies that were used during the course of the storm (forms, tags, caution tape, etc.) will be restocked.

7.5.1 Wire Down Procedure for Damage Patrollers

The intent of this Wire Down Procedure is to identify downed/low-hanging conductor that is or may be energized. To the extent that there is reasonable certainty that the downed/low-hanging conductor is

not energized, instructions are provided to barricade the location with caution tape, barricades, and/or cones. At no time should these downed/low-hanging conductors be considered dead (only correctly installed grounds allow for downed/low-hanging conductors to be considered dead). Therefore, at all times, Damage Patrollers shall continue to maintain safe clearance distances, and at no time shall any conductors be moved.

Damage Assessment Patroller Wire Down Procedure

These guidelines cannot cover all potential situations. If there are any questions or doubt on the part of the Damage Patroller about circuit configuration, call the District EOE to confirm before proceeding. Additionally, if the Damage Patroller has any safety concerns, err on the side of caution, and call the Wire Down Coordinator and request a Wire Responder or Wire Guard.

1. You need to **stand by** the wire if:
 - You believe the down wire (PRIMARY or OPEN WIRE Secondary) to be energized, including possibly by a customer owned generator, or
 - You cannot verify that the PRIMARY protective device is open, and the PRIMARY wire is down or hanging low, or
 - There is open wire secondary on the ground or hanging low that is not disconnected at the pole.

2. For locations where a down or low-hanging PRIMARY wire is discovered:
 - Verify that the fuse(s) is visually open.
 - In the case of three-phase lines, all three fuses must be open as there is a risk of the energized phase(s) back feeding the downed conductor through downstream transformer banks.
 - In the case of the 4800 V delta system (phase-and-phase), both fuses must be open as there is a risk of the energized phase back feeding the downed conductor through downstream transformers.
 - Reclosers are not considered a visual open.

NOTE: Fuse doors that have not dropped open from the cutout are not considered a visual open. The fuse must fully drop into the open position to be considered a visual open. You need to stand by the wire until a Wire Responder or Wire Guard can relieve you if the fuse only partially drops.

- Once the fuse(s) is verified as visually open
 - Barricade the location with caution tape and/or cones.
 - Report the location to the Wire Down Coordinator
 - After you barricade and report the location, you may move on and continue patrolling.
3. For locations where a down or low-hanging TRIPLEX SECONDARY wire is discovered:
 - Verify that the conductor and its insulation appears intact from the pole to the meter.
 - Verify that no potentially energized bare / un-insulated parts (e.g., connections at weather head or house bracket) are within reach.
 - Barricade the location with caution tape and / or cones.
 - Report the location to the Damage Assessment Coordinator
 - Notify nearby customers.

If you are able to do all of these, you may move on and continue patrolling even if you believe the triplex secondary to be energized.

If the triplex SECONDARY (all hot legs) is disconnected at the pole, you may move on and continue patrolling. For this condition, there is no need to barricade the location.

4. For locations where a down or low-hanging OPEN WIRE SECONDARY wire is discovered:
If the Open Wire SECONDARY is disconnected at the pole (all hot legs), you may move on and continue patrolling. For this condition, there is no need to barricade the location.

7.6 Outage Management System Support Procedure

Outage Reporting and Communication Overview

Central Hudson utilizes a suite of integrated applications to collect, consolidate and determine outage status. These include systems that are operated by Central Hudson Gas & Electric Corporation and systems that are operated by third party vendors. The foundation of outage reporting is known as a trouble call (a.k.a. a trouble order). This order type is created in CIS and indicates that a single metered location has no power. (Note, these trouble orders may also be used to indicate that other types of urgent abnormal conditions are present such as a downed or low hanging wire.) These trouble reports can be created in CIS through various reporting channels. For example, trouble orders can be created when customers speak with a representative, use the Central Hudson IVR, or call overflow system, or enter data via the website, mobile app, Notifi texting application or Municipal Portal. In each of these cases, customer account information is used to assign a report of no power or other emergency to a specific location in Central Hudson's service territory. When using voice channels, representatives are able to enter additional detailed information into the call comments. In the event of a loss of CIS or issue with sending orders into OMS, representatives would enter similar information onto trouble order forms. These forms would be sent to the dispatchers directly who would use the information to send crews and track issues to completion.

The central data bus in this suite of applications is the PowerOn OMS system. The OMS system utilizes a call processor, to import trouble order data from CIS. This call data is compared against a circuit model which contains known customer locations, and a representation of distribution electric equipment, such as conductors, poles, transformers, and fault clearing devices. Prediction rules within this application, group the various calls into outage cases and predict the location where the circuit was opened to clear the fault condition. Those performing dispatch duties, assign the cases to field personnel and estimated times of restoration are entered when they become available.

PowerOn interfaces with several customer-facing applications that provide summary outage data and estimated restoration times. The outage map, a third-party application, displays outage information by outage case on an interactive map. Within this application, outage information consolidated by municipality and county is also available in a tabular form. The Municipal Portal contains similar information, but in a more customized manner for registered Municipal users. Additionally, status on certain emergency orders such as road closures reported using the portal is also visible. ETR information is also sent via web service calls and files transfers from PowerOn to the IVR, Notifi texting application, and CIS so that customers can receive updated ETRs when using those systems or calling back in to speak with a representative.

The Outage Management System (OMS) is a critical system during storms and other electric emergencies. The system is mature, stable, and very reliable. To maintain this reliability and ensure proper notification of personnel when problems occur, the following checks and procedures are followed:

Stress Testing

- The Resiliency Systems Manager, or designee, will design, plan, and execute an OMS stress test, which occurs in a test environment, prior to June 1st each year. A significant or major system change to the OMS after June 1st will require a second stress test within 90 calendar days of the major system change implementation.
- Stress testing will simulate the peak trouble order volume that would occur during a hypothetical storm that affects 90% of Central Hudson customers over a 24-hour period.
- During the test, the OMS input call processor performance, basic OMS functions such as case ownership, case manipulation, map navigation and OMS outputs to systems such as the

outage map, Municipal Portal, and internal OMS reports site will be monitored.

- Within twenty days of each test, the Manager of Resiliency Systems, or designee, will file a report with the NYS DPS Director of the Office of Resilience, Utility Security, Nuclear Affairs and Emergency Preparedness, or designee, which contains the detailed results for each of the test cases identified in the test plan.
- In the event of a failed stress test case that cannot be quickly resolved, the Manager of Resiliency Systems, or designee, will notify the NYS DPS Director of the Office of Resilience, Utility Security, Nuclear Affairs and Emergency Preparedness, or designee, within a week and produce a plan of action with measures that will be taken until such time as a permanent resolution to the root cause(s) has been implemented. Additionally, in the event of a stress test failure, the Manager of Resiliency Systems, or designee will provide a rescheduled test date that is within 30 days from the initial test.

Ongoing Diagnostic Testing

- The Information Technology Branch Director, or designee, is responsible for the ongoing monitoring of internal applications and for ensuring that corrective actions are taken when the Company is alerted of a failure.
- A separate internal application monitors the OMS system call processor and if a failure occurs, sends an email notification to personnel who can initiate an immediate response.
- A third-party vendor monitors the data feed between Central Hudson's OMS system and customer facing outage map. If a file is not properly transferred for an hour or longer, an email notification is sent to personnel who can initiate an immediate response.
- A third-party vendor monitors the data feed of the Central Hudson's OMS system and the wires down system. If the typical file transfer, which occurs periodically, is not completed properly, an email notification is sent to personnel who can initiate an immediate response.

Before event

- Logistics Section Chief will notify Information Technology (IT) of the impending event. The Service Branch Director, or designee, will provide the names and numbers of personnel to be contacted when any failures or issues arise as part of the pre-event checklist.
- As directed by the Incident Commander, Logistics Branch Chief, or designee, IT will enter IT Storm Restricted mode, typically two hours prior to the expected event. During IT Storm Restricted mode, production releases to applications which support customer communications or field operations (including OMS) are halted. This excludes high priority fixes when approved by the Information Technology Branch Director and the Incident Commander.
- The Information Technology Branch Director is responsible for confirming the technical support staffing levels for all applications that support field operations or customer communications. Additionally, the Information Technology Branch Director confirms that the on-call resources listed on the Company's Intranet site are accurate and available for each application category.

During event

- The Information Technology Branch Director or designee is responsible for managing 24-hour IT support for all outage systems. Support can be on-site, or off-site, as determined jointly by Information Technology Branch Director and the Logistics Section Chief, depending on the needs of the particular event, and the current stage of the response (early, middle, or late in the event).
- When problems with core outage systems first arise, the severity and nature of the problem may be unclear until troubleshooting steps are performed. Depending on the nature of the problem, the user who first experiences the issue will reach out to the IT service desk or specialized resources in the IT Support, Service Branch Director, or Outage Management

System storm roles. The contacted resource will perform initial troubleshooting without delay to determine if it is a user issue or something that can easily resolved. In some cases, the resource in the IT Support, Service Branch Director, or Outage Management System storm roles will contact an additional internal resource or the applicable third-party vendor for support. If the issue is determined to be system and not user related and significant in nature, the Information Technology Branch Director, or designee, will be notified. If the problem will result in loss of critical data, the Incident Commander will also be notified. The Information Technology Branch Director, or designee, will provide updates on corrective actions being taken to the Logistics Section Chief, or designee, regularly.

- The Information Technology Branch Director, or designee, will notify the Public Information Officer, or designee if the issue results in significant unavailability of updates to the outage map, or any major errors in or loss of data on this website.
- In the event of the OMS system becoming unresponsive to the point where it is affecting restoration efforts due to hardware or software failure, a collaborative decision between the Incident Commander, Service Branch Director, and Information Technology Branch Director, or designees will be made to invoke the OMS backup plan which would involve restoring OMS with data archived on a separate backup server or in the event of a complete loss of OMS, manually sorting paper trouble orders into outage cases.
- The Service Branch Director, or designee will make the decision to shut down the outage map site if necessary due to problems with OMS or the file update process. In this event, the company will seek to post customer messaging without delay which describes the situation and directs customers to alternate means of reporting outages and retrieving ETRs (i.e., static webpage, banner messaging, or by redirecting web traffic to another website). The Service Branch Director, Public Information Officer, or designees will develop appropriate messaging and coordinate this activity with IT resources. The Manager – Emergency Preparedness or designee will coordinate DPS notification.

After event

- The Logistics Section Chief, or designee, will inform Information Technology Branch Director or designee, that the event has concluded and normally scheduled updates to production systems can resume. The Incident Commander and/or the Deputy Incident Commander may also approve the resumption to normal operations, which allows IT to perform regularly scheduled production system updates after an event.
- If a significant system failure occurred during the event, the Information Technology Branch Director will assign an IT resource to prepare a written summary of the issue and steps taken to resolve it, along with recommendations for preventing or reducing the risk of the issue in future events. This summary will be included in the event critique report.

Phone numbers for OMS support personnel – both IT and user support – are found on Central Hudson’s internal website. The Manager of Resiliency Systems and Manager – Infrastructure have the responsibility for keeping the contact information on these lists up to date.

7.7 Flood Restoration Procedure

7.7.1 Activation

When any trained first level supervisor or above learns of a situation where 25 or more customers in any one operating district have been isolated, or are expected to be isolated, due to flooding the Central Hudson Flood Procedure will be enacted. Instances where fewer than 25 customers are affected, or potentially affected, will be addressed on an individual basis by the operating district personnel, or by Dispatch Operations if outside normal business hours.

7.7.2 Pre-Event

Following notification of potential large-scale flooding by the National Weather Service (NWS) or contract weather forecasters, the following steps will be initiated:

Incident Commander

- Work with Customer Account Services Operations, and Gas Engineering & Operations to discuss the options that are available to isolate individual customers, part, or all of a gas distribution system. If it is during a gas emergency, determine whether the gas system should be isolated.

Liaison Officer

- Notify critical facilities, municipal officials, and Emergency Management Offices in the areas where flooding is predicted of the potential for flood conditions and the need to take steps to protect critical equipment.
- Confirm name/phone numbers that facility managers and municipal officials should use to contact Central Hudson during the event.

Public Information Officer

- Develop news releases and website messages to provide customers and municipal leaders with advance warning of the possibility of flooding. News releases shall include flooding safety information.
- In the event that flooding is predicted as part of a significant weather event, information regarding flood preparation will be included in the major event news release (See Section 6.8 – News Releases and Media Information).

Operations Section Chief

- Identify resources available to respond to requests for isolation of facilities due to flooding. This may also be done in conjunction with resource planning for major storm preparation (See Section 3 – Pre-Event Planning).

Planning Section Chief

- For events expected to involve flooding:
 - Contact any bordering utilities where Central Hudson provides electric service, and the neighboring company provides gas service. Currently, this situation is present only in the Town of Coeymans, so the Planning Section Chief will contact National Grid to advise them of our plans and coordinate restoration efforts. When needed for flood or other gas emergency planning, contact with National Grid will be initiated with their dispatch center, which is manned 24/7.
 - Contact any bordering utilities where Central Hudson provides gas service, and the

- neighboring company provides electric service. Currently, this situation is present in the Town of Woodbury, Town of Highlands and Town of Carmel. The Planning Section Chief will contact Orange and Rockland for Woodbury and Highlands and NYSEG for Carmel to advise them of our plans and coordinate restoration efforts. When needed for flood or other gas emergency planning, contact with other utilities will be initiated with their dispatch center, which is manned 24/7.
- Contact any bordering utilities where Central Hudson supplies gas service to a subset of that utility's customers. Currently, this situation is present in the Village of Walden. The Planning Section Chief will contact NYSEG to advise them of our plans and coordinate restoration efforts. When needed for flood or other gas emergency planning, contact with NYSEG will be initiated with their dispatch center, which is manned 24/7.

Logistics Section Chief

- Work with the District Communications Liaison and the Gas Field Supervisor, if activated, in each operating district to begin identifying potential command center locations near areas where flooding is predicted, wherever possible.
- Verify that Field Command Center equipment is available and in good working order.

Gas Operations Liaison

- Participates in planning meetings, conference calls, makes staffing plans, and responds to inquiries from the Incident Command team.

7.7.3 During Event

Upon notice by a local emergency or municipal official that an area is experiencing flooding, the following procedures will be followed:

1. A Flood Area Coordinator will be identified, by the Incident Commander or designee, to coordinate the field response. This supervisor will have experience with the disconnect/reconnect process and have skills necessary to manage the field operation. Flood Area Coordinators will work closely with Wire Down and Damage Assessment Coordinators during major electric events.
2. Coordinate de-energization of flooded area with Operating Supervisors and local emergency/municipal officials. In gas emergencies, this is particularly important to eliminate potential sources of ignition if the flooding event occurred prior to the gas system being isolated.
3. Contact Logistics Chief to mobilize a Field Command Center, if needed.
4. Track customers affected. Use the customer information system and service orders to provide details.
5. When flood waters have receded and it is safe to enter the area, work with local emergency/municipal officials to determine which premises have damage. Damaged premises will be isolated from the power supply, in most cases by locking the meters, but a transformer or line fuse may also be opened to isolate the affected buildings.
6. Coordinate restoration of unaffected customers through the Operating Supervisor.
7. Track affected customers and work jointly with emergency officials, building and electrical inspectors to restore power and gas when premises are ready for service restoration (See note regarding electrical inspection below).

For extreme conditions where shortage of electrical inspectors would result in restoration delays of more than 48 hours after repairs are complete, if approved by the Manager of New Business or designee, Central Hudson will accept a signed 10-day waiver from the electrician that made the repairs declaring that the premise is safe to have power restored. An electrical inspection will still be required within 10 days.

Communication: Flood restoration status updates will be part of Municipal Briefing calls and will occur at the same frequency as these calls described in Section 6.4. Separate calls may also take place depending on the extent of damaged locations.

7.7.4 Post-Event

The Flood area Coordinator will continue to coordinate with local emergency/municipal officials until all customers have been restored, or buildings are determined to be permanently unsafe for service.

Provide summary of restoration process and details on customers affected by flooding to the Planning Chief for inclusion in event critique reports.

7.7.5 Communication

Central Hudson will communicate our flood procedures to local municipal officials annually, or after officials change due to local elections. This communication will be the responsibility of the District Communications Liaison in each district.

7.8 Loop Crew Guidelines

7.8.1 Purpose

Central Hudson is committed to providing safe and timely restoration of electric service to our customers following storm-related outages. In addition to normal line, splicer, and service worker personnel, loop crews comprised of trained personnel may be assembled and assigned to restore selected electric outages. Information is provided below to provide guidance for identifying the roles of those personnel.

The Loop Crew Coordinator will assign loop crews to outage cases based on the best intelligence available, such as the predicted device in the OMS outage case and reports from damage assessment. The qualified personnel and acceptable work tasks for Type A and Type B loop crews are defined below. If the outage case requires work tasks outside of the specific loop crew's capabilities, the Loop Crew shall notify their Loop Crew Coordinator; the outage case and the Loop Crew will be reassigned accordingly.

7.8.2 Personnel Available for Loop Crews

Loop Crew personnel are determined to be a Loop Crew A or Loop Crew B classifications based on the skills and qualifications associated with their current job classifications and the grade they hold. Training will vary for each crew classification, as will the work they may be assigned.

a. **Loop Crew A Personnel:**

Operations Services Chief 2/C LES&T (not including Testers)
Electrician 1/C

Loop Crew A personnel may be paired with other Loop Crew A personnel or certain Loop Crew B personnel for the purpose of closing in primary line fuses. Refer to the attached listing for the appropriate crew complements.

Work which may be assigned to Loop Crew A's: Loop Crew A personnel may be assigned to reattach service laterals at the pole and to reset CSP transformers. In addition, Loop Crew A personnel will be trained and may be assigned to close-in primary line fuses under the conditions listed below:

1. Single phase overhead conductors only.
2. Only primary feeds to radial lines.
3. Radial lines with fuse sizes up to and including 40 Amps.
4. NO fuses feeding URD's will be closed in by Loop Crews.
5. Loop Crews SHALL NOT refuse 4800V Delta circuits; these outages will only be assigned to line crews.
6. Loop crews SHALL NOT work in the primary position at any time.

In addition, Loop Crew A personnel may be assigned to perform any work which can be performed by Loop Crew B personnel.

b. Loop Crew B Personnel:

Electrician – 2/C, 3/C

Tester – Chief, 1/C, 2/C, 3/C

Commercial Representatives – Commercial Specialist, Commercial Rep Special, 1/C, 2/C, District Representative, District Representative Special

Instrumentation & Communications Technician – Chief, 1/C, 2/C, 3/C

Relay Technician – Chief, 1/C, 2/C, 3/C

Work which may be assigned to Loop Crew B's:

1. Remove limbs on service line.
2. Reattach service line at house.
3. Turn off secondary breaker on single phase CSP transformers; make repairs to services; turn transformer breaker back on. CSP transformers which are tripped upon arrival can be reset provided that the cause is identified and corrected. Reset should be attempted only one time – if transformer will not reset, leave breaker off and notify Dispatcher.

7.8.3 Work Methods

1. All work will be performed in compliance with existing safety procedures and using required safety equipment.
2. Use of 40-foot Telescoping Disconnect stick with standard safety equipment.
3. **Only specific Loop Crew personnel shall work in the elevated position.** Refer to the attached listing for the appropriate crew complements. Use of a squirt boom bucket requires the worker in the bucket to comply with all applicable safety standards while working in the elevated position.
4. Loop Crew A's shall patrol the entire length of the radial line to ensure the line is clear of faults and no one else is working on the line before closing in the cutout.
5. Loop Crew A's shall obtain clearance authority from the Operating Supervisor, or designee, before closing in any fuses.
6. Loop Crews may be assigned to provide support to any operating district. Once assigned to a specific district, they will check in with the Loop Crew Coordinator to receive work assignments and will check out with the Loop Crew Coordinator before returning to their normal work assignments.
7. Notify Dispatcher when transformer breakers are turned off if multiple customers are affected.

7.8.4 Loop Crew A Crew Complements

Loop Crew A:

Repair Service Laterals at the Pole - Elevated Position

1st Crew Member

Chief 2/C LES&T (No Tester)
Electrician 1/C

2nd Crew Member

Chief 2/C LES&T (No Tester)
Electrician 1/C
Electrician 2/C

Replace Primary Fuse - from the Ground ONLY

1st Crew Member

Chief 2/C LES&T (No Tester)
Electrician 1/C

2nd Crew Member

Chief 2/C LES&T (No Tester)
Electrician 1/C
Electrician 2/C
Commercial Specialist
District Representative
District Representative Special
Commercial Representative 1/C
Commercial Representative Special
Chief Tester
Tester 1/C
Tester 2/C
Chief Instrumentation & Communications Technician
Instrumentation & Communications Technician 1/C
Instrumentation & Communications Technician 2/C
Instrumentation & Communications Technician 3/C
Chief Relay Technician
Relay Technician 1/C
Relay Technician 2/C
Relay Technician 3/C

7.8.5 Loop Crew B Crew Complements

Loop Crew B:

Repair Service Laterals at the House; reset transformer if cause found/repared:

1st Crew Member

Chief 2/C LES&T (No Tester)
Electrician 1/C
Commercial Specialist
District Representative
District Representative Special
Commercial Representative 1/C
Commercial Representative Special
Chief Tester
Tester 1/C
Chief Instrumentation & Communications Technician
Instrumentation & Communications Technician 1/C
Chief Relay Technician
Relay Technician 1/C

2nd Crew Member

Chief 2/C LES&T (No Tester)
Electrician 1/C
Electrician 2/C
Electrician 3/C
Commercial Specialist
District Representative
District Representative Special
Commercial Representative 1/C
Commercial Representative 2/C
Commercial Representative Special
Chief Tester
Tester 1/C Tester 2/C Tester 3/C
Chief Roving Mechanic-Operator
Chief Instrumentation & Communications Technician
Instrumentation & Communications Technician 1/C
Instrumentation & Communications Technician 2/C
Instrumentation & Communications Technician 3/C
Chief Relay Technician
Relay Technician 1/C
Relay Technician 2/C
Relay Technician 3/C

7.9 Mutual Assistance Procedures

7.9.1 Overview of Mutual Assistance Process and National Response Events

Restoring power after a major storm is a complex task that must be completed as quickly as possible. A speedy restoration requires significant logistical expertise, along with skilled line workers and specialized equipment. Electric companies affected by significant outages frequently call on other utilities for assistance to help speed restoration. This practice is known as mutual assistance.

Mutual assistance is an essential part of electric utility business continuity planning: The affected company is able to increase the size of its workforce by "borrowing" line workers from other utilities but only has to pay for those extra crews during times of need.

The need for mutual assistance is determined by the level of event impacting the utility or utilities as described in the following table:

Level	Description
1	<i>Local Area</i> - Resources come from within a single company including sister companies.
2	<i>Local Region</i> – Resources come from one Regional Mutual Assistance Group (RMAG) and potentially neighboring utilities.
3	<i>Regional</i> – Resources come from more than one RMAG.
4	<i>National Response Event</i> – An NRE impacts a significant population and requires resources from multiple RMAGs or sources.

Requests for mutual assistance for Central Hudson are coordinated by the Manager – Emergency Preparedness or designee. Central Hudson is a member of the North Atlantic Mutual Assistance Group (NAMAG). The members of NAMAG are:

- Alectra Utilities
- Avangrid Networks (Central Maine Power, NYSEG, RG&E, United Illuminating)
- Fortis, Inc. (Central Hudson Gas & Electric)
- Consolidated Edison (Con Ed, O&R)
- Duquesne Light
- Emera Energy (Bangor Hydro, Nova Scotia Power)
- Eversource (CT, NH, MA)
- Exelon (BGE, PECO, Atlantic City Electric, Delmarva Power)
- First Energy (OH, PA, NJ, MD, WV)
- Green Mountain Power
- Hydro-One
- Hydro Ottawa
- Hydro Quebec
- Liberty Utilities
- National Grid (NY, NE)
- New Brunswick Power
- New Hampshire Electric Cooperative
- Pike County Light & Power Co.
- PPL Electric Utilities
- Public Service Electric & Gas (PSE&G LI, NJ)
- Saint John Energy
- South Norwalk Electric
- Toronto Hydro
- UGI Utilities
- Unitil Corp (NH, MA)

Once it is determined that external resources are required, the mutual assistance process will be implemented consistent with the "*North Atlantic Mutual Assistance Group Guidelines*" as follows:

- The requesting company(s) shall initiate an RMAG / Joint Mobilization Conference Call
- The weather forecast shall be presented by the requesting company(s) to provide all members with an opportunity to understand the emergency situation.

- An estimate of actual or predicted impact / damage and when these are expected to occur shall be presented by the requesting company(s)
- An estimate of resources needed shall be presented by the requesting company(s)
- All non-impacted companies shall state the numbers of resources available to assist once their service areas are no longer at risk.

If the resource needs cannot be met from within the NAMAG, the mutual assistance request may be expanded to encompass neighboring RMAGs. If the request for resources cannot be fulfilled by the neighboring RMAGs, a National Response Event (NRE) may be declared by the CEO, or designee, of an affected utility.

An NRE designation is reserved for only the most significant events, such as a major hurricane, earthquake, an act of war, or other occurrence that results in widespread power outages.

In the case of an NRE, the industry's mutual assistance process will be coordinated at the national level in order to ensure industry resources are seamlessly allocated in the most efficient manner possible.

A National Response Executive Committee (NREC), comprised of senior-level utility executives from all regions of the country, will govern the NRE allocation process. Upon request of an affected utility CEO, the NREC will declare an NRE and will activate the National Mutual Assistance Resource Team (NMART).


The NMART evaluates mutual assistance requests and assigns available resources to affected utilities in coordination with the RMAGs. When an NRE is declared, all available industry emergency restoration resources (including contractors) will be pooled and allocated to participating utilities to best meet restoration needs in a catastrophic event.

During an NRE, mutual assistance is provided in a coordinated, transparent, and equitable manner to restore power as efficiently and safely as possible for all customers and communities.

The NRE resource allocation process consists of the following high-level steps:

1. Any utility CEO (or an executive level designee) can request an NRE to be initiated.
2. The NREC will activate NMART and trigger the resource allocation process.
3. Utilities requesting mutual assistance will provide the NMART with the number and type of resources needed, the number of customers interrupted and the number of trouble spots or cases of trouble. Responding companies will provide the NMART with the number and type of resources available. The NMART will consolidate the information and assign available resources to each requesting utility based on a pre-defined methodology. The methodology considers the weighted averages of the portion of customer outages relative to all requesting utilities, as well as the portion of trouble spots relative to all requesting utilities. The allocation can further be refined to account for other specific factors including but not limited to: utilities with a large percentage of customer without power, geographic proximity and time of arrival, significant events (Inauguration, election, Super Bowl, etc.). Once the individual utility allocations have been determined, the NMART will communicate the allocations to the RMAGs.
4. The RMAGs will match the available resources to the specific utilities based on local requirements.
5. The process will continue periodically until all of the outstanding requests are fulfilled.

A simplified flow chart of the NRE process is shown below:



7.9.2 New York State Public/Private Utility Mutual Assistance Protocol Coordination


The New York Public/Private Utility Mutual Assistance Protocol (NYP/PUMA) is an outline of general principles and practices for the New York State (NYS) utilities to follow which will enable them to leverage a public/private partnership among the NYS utility companies. This partnership will provide access to critical resources to facilitate and expedite utility restoration following an emergency that has impacted customers in New York State.


The foundation of this protocol draws upon the concepts which have been utilized by members of mutual assistance organizations such as NAMAG, New England Public Power Association (NEPPA), and others. This protocol is intended to be flexible in every respect since it is not possible to predict exactly what the nature or scope of an emergency will be. The flexibility allows command personnel to call upon further reserves of personnel, supplies, equipment, and space when needed, but in an organized, documented, and logical manner.


In instances where Central Hudson requests mutual assistance through the NAMAG process, a formal notification will be made to the NYAPP and MEUA of NY organizations that the NAMAG process has been enacted, and that mutual assistance may be requested from the municipalities and electric cooperatives. This protocol is not intended to usurp any organization's primary means of securing additional assistance, rather to provide a supplemental source of additional potential resources within NYS.



Appendices


- Appendix A – Emergency Organization Chart
- Appendix B – Position Descriptions
- Appendix C – Emergency Services and Community Aid
- Appendix D – Print and Broadcast Media Listing
- Appendix E – Municipal Leaders
- Appendix F – Lodging and Restaurants
- Appendix G – Office, Substation, Regulator, and Radio Listing
- Appendix H – Active Emergency Response Contracts
- Appendix I – Sample News Release
- Appendix J – Mutual Assistance and EEI Agreements
- Appendix K – Guide for Mutual Assistance Crews
- Appendix L – Incident Command and General Staff Position Checklists
- Appendix M – ARCOS Callout Lists
- Appendix N - Telecom Facilities and Contacts
- Appendix O – Storm Response Materials List
- Appendix P – Storm Scorecard
- Appendix Q – Consumer Outreach Plan (selected sections)
- Appendix R – Recommended Dry Ice Distribution Locations
- Appendix S – Canadian Utility Contractor Activating Assistance

















POSITION DESCRIPTIONS

APPENDIX B

Command Staff

Incident Commander 5
Deputy Incident Commander..... 6
Public Information Officer..... 7
Liaison Officer 8
Safety Officer 9
Security Officer 10

General Staff:

Operations Section Chief 11
Planning Section Chief 12
Logistics Section Chief..... 13
Finance Section Chief..... 14
Gas Operations Liaison..... 14

Public Information Section:

Deputy Public Information Officer 15
Contact Center Branch Director 16
Customer Communications Branch Director 17
Customer Communications Branch Deputy/Team 17
Internal Communications Branch Director 18
Internal Communications Branch Deputy/Team 18
Outreach Branch Director 19
Outreach Coordinator 19
Life Support Equipment Contacts 20
Contact Center Supervisor 20
Contact Center Representative/Alternate/Alternate Bilingual 21
Contact Center – Support/Escalated Calls 21
Social Media Lead/Team 22
Call Backs..... 22
Videographer 23
District Communications Liaison..... 24
Associate District Communications Liaison 25
Utility Field Liaison 26
Emergency Operations Center (EOC) Representative 27
Governmental Affairs..... 28
District Clerical 28

POSITION DESCRIPTIONS

APPENDIX B

Safety Section:

Safety Advisor 29

Security Section:

Security Supervisor 30

Operations Section:

Field Resource Coordinator 31

ETR Development Coordinator 32

Line Operations Director 33

Transmission Director 34

Intelligence Director 35

Line Clearance Director 36

Make Safe Activities Coordinator 37

Operating Supervisor 38

Electric Operating Engineer 39

Substation Coordinator 40

Line Supervisor 41

Power Line Technician 42

Splicer 42

Crew Guide 43

Runner 44

System Operations 45

Chief Electrician 46

Electrician 46

Chief Construction Maintenance Worker 47

Construction Maintenance 47

Damage Assessment Coordinator 48

Damage Assessment Patroller 49

Loop Crew Coordinator 50

Loop Crew 51

Line Clearance Director 52

Line Clearance 52

Flood Area Coordinator 53

Planning Section:

Resources and Reports Coordinator 54

Resources and Reports 54

Situation and Demobilization Coordinator 55

POSITION DESCRIPTIONS

APPENDIX B

Crew Onboarding Coordinator..... 56

ARCOS Coordinator 57

Logistics Section:

Support Branch Director 58

Service Branch Director 59

Supply Branch Director 60

Information Technology Branch Director 61

Meals Supervisor..... 62

Meals..... 62

Lodging Supervisor 63

Lodging and Hotel Meals 63

Onsite Lodging Liaison 64

Staffing Supervisor 65

Staffing 65

Alternate Housing Supervisor 66

Facilities Supervisor 67

Facilities..... 67

Wire Down Supervisor 68

Wire Down Coordinator 69

Wire Responder 70

Wire Guard..... 71

Dispatch Operations Supervisor 72

Dispatcher 72

Customer Information Coordinator 73

Environmental Services Supervisor..... 74

Environmental..... 74

Drafting/GIS Supervisor 75

Dry Ice Supervisor 76

Dry Ice 76

Material/Pole Supervisor 77

Field Clerk/Storekeeper 78

Materials Assistant..... 78

Transportation Supervisor 79

Garage Mechanic 80

Garage Clerical 80

Procurement Supervisor 81

POSITION DESCRIPTIONS

APPENDIX B

Applications Support Coordinator 82

Infrastructure and Communications Coordinator 83

IT Support..... 83

Energy Management System 84

Outage Management System 84

Finance Section:

Time Supervisor 85

Payroll 85

Cost Supervisor 86

Accounting 86

Claims Supervisor 87

Claims..... 87

Contracts Supervisor 88

Incident Commander

The Incident Commander is the Incident Commander for the event, and as such provides the overall leadership for incident response. He/she assesses the severity of the event, determines the need for staff and appoints individuals to fill high-level storm positions. The Incident Commander determines the incident objectives and works with staff to develop the Incident Action Plan. The Incident Commander provides oversight of the storm response effort, ensuring that all actions are in accordance with the Incident Action Plan, regulatory requirements and Company practices.

Generally filled by: Vice President, Operations and Safety (primary)
Director – System Operations and Emergency Management (alternate)

Reports to: Central Hudson Executive Team

Responsibilities:

Perform all necessary notifications to Company personnel of impending storm events.

Make proper notifications to PSC and State Office of Emergency Management (SOEM) of any impending events, or arrange to have notifications made.

Participate in any scheduled NAMAG calls, or arrange for participation.

Initiate, develop schedule for, and participate in storm planning meetings and conference calls.

Classify event based on an evaluation of all available information, reports and data.

Establish "Start of Restoration" time for ETR Guidelines.

Assign employees to fill the Command Staff and General Staff roles. Arrange for relief for these individuals as needed.

Work with the Operations Section Chief to develop the Incident Action Plan for the event, which includes: plan for mutual aid or contractor resources, target times for PSC reports, schedule for conference calls, and requirements for ETR Guidelines compliance.

Following notification of potential large-scale flooding, work with Customer Account Services Operations, and Gas Engineering and Operations to discuss the options that are available to isolate individual customers, part, or all of a gas distribution system. If it is during a gas emergency, determine whether the gas system should be isolated.

Communicate Incident Action Plan and restoration status to Central Hudson Executive Team daily or as requested.

Approve all external communications regarding storm restoration including news releases and website messages. Provide information for news releases and website updates as requested.

Deputy Incident Commander

In large scale events, a Deputy Incident Commander may be selected by the Incident Commander. The Deputy Incident Commander will perform specific tasks as requested by the Incident Commander and relieve the Incident Commander when needed.

Generally filled by: Director - System Operations and Emergency Management (primary)
Manager – Emergency Preparedness, System Operations and Emergency Management
(alternate)

Reports to: Incident Commander

Responsibilities:

Assist with notifications to Company personnel of impending storm events, as directed.

Assist with notifications to PSC and SOEM of any impending events, as directed.

Participate in any scheduled NAMAG calls.

Participate in storm planning meetings/conference calls.

Evaluate all available information, reports and data on the event and assist with classification of the event.

Help develop "Start of Restoration" time for ETR Guidelines.

Assist the Incident Commander in filling the Command Staff and General Staff positions and arrange for relief for these individuals as needed.

Assist Incident Commander in developing the Incident Action Plan for the event.

Communicate Incident Action Plan and restoration status to Central Hudson Executive Team if requested.

If directed by the Incident Commander, approve all external communications regarding storm restoration including news releases and website messages. With approval by the Incident Commander, can provide information for news releases and website updates as requested.

Relieve Incident Commander as directed.

Public Information Officer

The Public Information Officer advises the Incident Commander on information dissemination and media relations. The Public Information Officer provides information to and receives information from the community, media, and customers. All information released to the public will be approved by the Incident Commander.

Generally filled by: Director, Public Relations and Corporate Communications (primary)
Sr. Manager, Media Relations (alternate)

Reports to: Incident Commander

Responsibilities:

Using information provided by the Incident Commander, oversee the preparation of external, media, customer, and employee communications. This includes news releases, public service announcements and employee information updates.

Respond to media inquiries. Responses must be approved by the Incident Commander or based on content previously approved (to ensure accuracy of response and consistency with all other external communications).

Coordinate and review outbound storm related messaging as needed for consistency. This includes messaging on the Company website and social media sites.

Interface with the Incident Commander to provide adequate information on restoration progress, ETRs, dry ice distribution locations, and shelter locations.

Provide media with dry ice distribution locations.

Provide media with flood preparation and safety information if flooding is predicted.

Initiate and moderate Municipal Conference Calls. Notify municipal officials of the date/time of the call.

Participate in storm planning meetings/conference calls.

Liaison Officer

The Liaison Officer is the primary point of contact between the Incident Commander, community leaders and emergency officials. All information exchange between Central Hudson and the State Office of Emergency Management and municipal leaders will be done by, or approved by, the Liaison Officer. This information includes reviewing the number of customers impacted and restored, the type and extent of damage found, estimated restoration times, known shelter locations, and the status of critical customers and other high priority situations.

Generally filled by: Director, New Business and Services (primary)
Manager, New Business(alternate)

Reports to: Incident Commander

Responsibilities:

Provide information regarding the status of restoration to municipal leaders during Municipal Conference Calls.

Respond to inquiries and requests from municipal officials, or ensure inquiries/requests are being responded to.

Following notification of potential large-scale flooding, notify critical facilities, municipal officials, and Emergency Management Offices in the areas where flooding is predicted of the potential for flood conditions and the need to take steps to protect critical equipment.

Ensure County EOCs are staffed upon request; develop plan to provide continuous staffing throughout the event.

Participate in storm planning meetings/conference calls.

Safety Officer

The Safety Officer will advise the Incident Commander on issues regarding safety. He/she works with the Operations Section to ensure the safety of field personnel.

Generally filled by: Director, Safety (primary)
Safety Specialist (alternate)

Reports to: Incident Commander

Responsibilities:

Assist Operating Supervisors with delivering safety briefings to contractor and Mutual Aid crews.

Participate in storm planning meetings/conference calls; provide safety report and safety message.

Address any safety concerns brought up by personnel working on the storm response.

Perform OSHA reports of any OSHA reportable accidents.

Perform safety inspections of field work sites, as available.

Security Officer

The Security Officer will advise the Incident Commander on issues regarding security. He/she works with the Operations Section to ensure the security of field personnel and advise of situations that may impact the response and restoration.

Generally filled by: Manager, Corporate Security (primary)
 Security Investigator (alternate)

Reports to: Incident Commander

Responsibilities:

Initiate request for Taconic Parkway access when necessary.

Coordinate security needs for district offices, dry ice distribution locations, and alternate housing areas.

Participate in storm planning meetings/conference calls.

Address any security concerns brought up by personnel working on the storm response.

Establish liaison with the respective law enforcement agencies in order to promote prompt restoration of service in conjunction with any related investigations that may be underway.

Stage temporary identification badges production for any Mutual Assistance personnel responding to assist with restoration efforts.

Operations Section Chief

The Operations Section Chief directs the field restoration work. He/she is responsible for staffing the field response to ensure fast and safe restoration of electric service. All line crews, line clearance crews, and damage assessment personnel work under the direction of the Operations Section Chief.

Generally filled by: Sr. Director, Electric Operations (primary)
Senior Manager, Electric District Operations (alternate)

Reports to: Incident Commander

Responsibilities:

Ensure that all Operations Section positions are staffed and all responsibilities are assigned, including identification of available resources for isolation of facilities due to flooding. Provide back-up for Operations personnel as needed.

In conjunction with the Incident Commander, develop the Incident Action Plan (IAP) which includes: plan for mutual aid or contractor resources, target times for PSC reports, isolation of facilities due to flooding, schedule for conference calls, and requirements for ETR Guidelines compliance.

Obtain contract line and line crew resources as needed (per the IAP).

Coordinate Mutual Aid crew requests in conjunction with the Planning Section Chief. Assign resources to operating districts when they arrive.

Ensure that all foreign crews receive a Safety Briefing upon arrival at Company headquarters.

Participate in storm planning meetings/conference calls.

Provide storm restoration status information to the Public Information Officer and/or Incident Commander when requested.

Provide crew location information and municipal ETR data to the Planning Section Chief for inclusion in 4-Hour PSC Situation Reports, through the Field Resource Coordinator and ETR Development Coordinator, respectively.

Planning Section Chief

The Planning Section Chief maintains records of all foreign crews/personnel. He/she is also responsible for monitoring weather conditions, ensuring that all PSC reporting is completed as required, and coordinating the demobilization effort at the conclusion of the event.

Generally filled by: Manager, Emergency Preparedness (primary)
Project Manager Operations (alternate)

Reports to: Incident Commander

Responsibilities:

Ensure that personnel are assigned to perform resource tracking, reporting and demobilization positions.

Monitor weather reports and participate in any NWS weather briefings.

Initiate Mutual Aid crew requests when instructed by the Incident Commander or Operations Section Chief.

Ensure that ETRs are established within the required guidelines outlined in Section 7.1.

Assign personnel to Crew Guide positions if requested by Operations Section Chief, through the Crew Onboarding Coordinator.

Participate in storm planning meetings/conference calls.

Communicate any changes in foreign crew locations to the Logistics Section Chief for relocation of lodging and meals.

Contact any bordering gas/electric utilities as needed when flood event is expected.

Receive daily crew log reports for all Mutual Aid and contractor crews. Maintain these spreadsheet records for use in validating billing and regular 4-Hour PSC Situation Reports reporting.

Notify utility or contractor mutual assistance companies when resources have been released.

Logistics Section Chief

The Logistics Section Chief is responsible for supporting the Operations forces by providing all service, support and supplies needed during the event. This includes wire guarding, computer systems, Dispatch Operations, phones, radios, environmental support, customer communications, lodging, meals, material, transportation and dry ice distribution.

Generally filled by: Director, Enterprise Support Services (primary)
Manager, Transportation and Contracts (alternate)

Reports to: Incident Commander

Responsibilities:

Assign employees to fill the Support, Service, Supply, and Information Technology Branch Director positions. If enough personnel are not available to staff all positions, reassign tasks to ensure that all support functions are being addressed.

Supervise all support, service, supply, and IT activities. Resolve problems as necessary and provide backup coverage for all functions when needed.

For flooding events, work with the District Communications Liaison and the Gas Field Supervisor, if activated, to identify potential command center locations as needed.

Participate in storm planning meetings/conference calls.

Communicate with Incident Commander and Operations Section Chief to fulfill daily logistics needs.

Finance Section Chief

The Finance Section Chief directs all activities related to time keeping, contracts, cost accounting and claims.

Generally filled by: Controller (primary)
Sr. Manager, Financial Reporting, Plant Accounting and Accounts Payable (alternate)

Reports to: Incident Commander

Responsibilities:

Assign employees to fill the Time, Contracts, Cost, and Claims positions. If enough personnel are not available to staff all positions, reassign tasks to ensure that all support functions are being addressed.

Supervise time, contracts, cost, and claims activities. Resolve problems as necessary and provide backup coverage for all functions when needed.

Participate in storm planning meetings/conference calls.

Communicate with Incident Commander and Operations Section Chief to fulfill daily finance-related needs.

Gas Operations Liaison

The Gas Operations Liaison Officer is the primary point of contact between the Electric Emergency Incident Command team and Central Hudson’s Gas Department.

Generally filled by: Sr. Director, Gas Engineering and Operations (primary)
Manager, Gas Operations (alternate)

Reports to: Incident Commander

Responsibilities:

Participate in storm planning meetings/conference calls.

Ensure that Gas Operations staffing needs continue to be met as employees take on storm roles during the electric emergency.

Respond to inquiries from the Incident Command team.

Manage the overall Gas Operations response and facilitate communications with the Electric Emergency Incident Command during flooding emergencies.

Deputy Public Information Officer

In large scale events, a Deputy Public Information Officer may be selected by the Public Information Officer. The Deputy Public Information Officer will perform specific tasks as requested by the Public Information Officer and relieve the Public Information Officer when needed.

Generally filled by: Sr. Manager, Media Relations (primary)
Manager, Corporate Communications (alternate)

Reports to: Public Information Officer

Responsibilities:

Assist with preparing news releases, public service announcements and employee information updates, as directed.

Assist with responding to media inquiries, as directed.

Assist with the initiation and moderation of Municipal Conference Calls, as directed.

Relieve Public Information Officer as directed.

Contact Center Branch Director

The Contact Center Branch Director manages all call-taking and Customer Outreach activities. He/she is responsible for staffing the Contact Center adequately to answer customer calls in a timely fashion. All CSRs, Alternate Call Center personnel, and Customer Outreach personnel fall under the direction of the Contact Center Branch Director.

Generally filled by: Director, Customer Experience (primary)
Director, Customer Transformation (alternate)

Reports to: Public Information Officer

Responsibilities:

Arrange for the initiation of the pre-storm WARN notification system when major events are expected (LSE/Special Needs Customer notifications).

Ensure that a detailed upfront message is available on the IVR, and that messages are updated regularly as per Section 6.2.

Staff all Contact Center storm positions and provide back-up resources as necessary.

Coordinate with the Service Branch Director to make outbound calls to customers regarding service restoration updates.

Participate in storm planning meetings/conference calls.

Arrange for Contact Center Supervisor(s) to be available to oversee Contact Center functions after hours.

Customer Communications Branch Director

The Customer Communications Branch Director prepares all information issued to customers, and the general public for dissemination through the Public Information Officer.

Generally filled by: Manager, Corporate Communications (primary)
Corporate Digital Content Manager (alternate)

Reports to: Public Information Officer

Responsibilities:

Draft news releases and public service announcements as directed by the Public Information Officer.

Disseminate photos and/or videos of Central Hudson’s storm preparation, related damage, and restoration efforts for dissemination to employees, customers, and the general public.

Coordinate with the Social Media team to confirm that all customer messaging is aligned.

During major events, create and maintain a webpage dedicated to the storm, containing safety information, storm updates, copies of news releases, dry ice/bottled water distribution and shelter locations once these are known, links to Central Hudson’s social media pages, as well as outage reporting/outage restoration status options and information obtained from County EOCs or other officials, as warranted. Ensure this website is updated regularly as per Section 6.9.

Customer Communications Branch Deputy/Team

The Customer Communications Deputy Director and Team members assist in preparation of information issued to customers, and the general public for dissemination through the Public Information Officer.

Generally filled by: Marketing Program Manager (primary)
Corporate Digital Content Manager (alternate)

Reports to: Customer Communications Branch Director

Responsibilities:

Assist drafting of news releases, public service announcements, as directed by the Communications Branch Director.

Assist in dissemination of photos and/or videos of Central Hudson’s storm preparation, related damage, and restoration efforts for dissemination to employees, customers, and the general public.

During major events, assist in creating and maintaining a webpage dedicated to the storm, containing safety information, storm updates, copies of news releases, dry ice/bottled water distribution and shelter locations once these are known, links to Central Hudson’s social media pages, as well as outage reporting/outage restoration status options and information obtained from County EOCs or other officials, as warranted. Ensure this website is updated regularly as per Section 6.9.

Internal Communications Branch Director

Under direction from the Public Information Officer, the Internal Communications Branch Director leads the internal information gathering effort and communicates it to employees and internal stakeholders.

Generally filled by: Communications Specialist
Corporate Digital Content Manager (alternate)

Reports to: Public Information Officer

Responsibilities:

Synthesize information from internal resources for use within the Communications group, draft employee information updates as directed by the Public Information Officer.

Direct the capture of photos and/or videos of Central Hudson’s storm preparation, related damage, and restoration efforts for dissemination to employees, customers, and the general public.

During major events, coordinate obtaining information from field and internal resources for use within the Communications group. This includes reaching out to departments such as Dispatch, District Operations, and Safety. Direct the production various media content such as photos, videos, and interviews. Draft and disseminate relevant storm updates, copies of news releases, dry ice/bottled water distribution and shelter locations once these are known, and information obtained from County EOCs or other officials, to employees.

Internal Communications Branch Deputy/Team

The Internal Communications Branch Deputy Director and Team members gather and share information to employees and internal stakeholders as directed.

Generally filled by: Corporate Digital Content Manager
Multimedia Specialist (alternate)

Reports to: Internal Communications Branch Director

Responsibilities:

Assist in synthesizing information from internal resources for use within the Communications group, draft employee information updates as directed by the Internal Communications Branch Director.

Capture photos and/or videos of Central Hudson’s storm preparation, related damage, and restoration efforts for dissemination to employees, customers, and the general public.

During major events, obtain information from field and internal resources, including safety information for use within the Communications groups. Produce various media content such as photos, videos, and interviews. Disseminate relevant storm updates, copies of news releases, dry ice/bottled water distribution and shelter locations once these are known, and information obtained from County EOCs or other officials, to employees as directed by the Internal Communications Branch Director.

Outreach Branch Director

The Outreach Branch Director has responsibility for all special needs customers including Life Support Equipment (LSE), Special Needs (EBD) and other customers needing additional assistance during storm events.

Generally filled by: Manager, Consumer Outreach and Assistance Programs (primary)
Director, Customer Experience (alternate)

Reports to: Public Information Officer

Responsibilities:

As directed, initiate pre-storm WARN notifications of LSE and Special Needs customers.

During the event, coordinate the LSE contact calls as per LSE Contact Procedure, and arrange for field visits as needed. This includes wellness calls after service has been restored.

Ensure that LSE contact attempts during an event are being documented via the LSE tracking spreadsheet or other methods.

Assist CSRs and Contact Center Supervisors with addressing customer special needs, as requested.

Ensures that county EOCs are contacted annually to review contact information and process for assistance with LSE field visits if necessary during a major event.

Outreach Coordinator

The Outreach Coordinator organizes the daily LSE Contact Procedure, including any necessary field visits.

Generally filled by: Consumer Outreach Representative (primary and alternate)

Reports to: Outreach Branch Director

Responsibilities:

Coordinate the LSE contact calls as per the LSE Contact Procedure, and arrange for field visits as needed.

Document all LSE contact attempts via the LSE tracking spreadsheet or other methods.

Coordinate with the Operating Supervisor for emergency conditions impacting a LSE customer.

Life Support Equipment Contacts

Those assigned to the Life Support Equipment Contacts role perform the daily LSE calls and/or the physical wellness checks when phone contact is unsuccessful during an event.

Generally filled by: Consumer Outreach Representatives (primary)
Various Customer Service Representatives and Commercial Representatives (alternate)

Reports to: Outreach Coordinator

Responsibilities:

Attempt regular daily contact with LSE customers, as directed by the Outreach Coordinator. This may include making wellness calls and/or making physical wellness visits. Report on the status of each attempt for documentation.

Address customer special needs, as required.

Contact Center Supervisor

Contact Center Supervisors provide supervision and scheduling of CSRs, and additional personnel assigned to the Contact Center during storms.

Generally filled by: Manager, Customer Contact (primary)
Various Contact Center Supervisors (alternate)

Reports to: Contact Center – Branch Director

Responsibilities:

Provide the scheduling to ensure that all Contact Center responsibility areas are properly staffed and that back up resources are available to fill all positions on a rotating basis.

Keep the Contact Center Branch Director informed of customer call volume information.

Ensure that the Contact Center is provided adequate information as to the restoration progress and estimated restoration times.

Monitor call volume, anticipated call volume, abandonment rates and customer wait times. Use this information to determine call percentage that is directed to outsource call vendor agents and advise internal agents when normal business may be conducted with customers.

Provide Call Answer Rate data to the Planning Section Chief for critique reports following the event.

Contact Center Representative/Alternate/Alternate Bilingual

The Contact Center Representative interacts with customers and emergency officials regarding reports of outages, emergency conditions, LSE contacts, and other inquiries.

Generally filled by: Customer Service Representative (primary)
Telephone Representative (primary)
Various qualified personnel (alternate or alternate bilingual)

Reports to: Contact Center Supervisor

Responsibilities:

Answer calls, emails, or online chat reports of power outages, emergency conditions, or other inquiries. Create the applicable outage/emergency order on CIS and note the customer’s account as required.

Provide customers information regarding their outage case, including any Estimated Time of Restoration.

Contact Center – Support/Escalated Calls

The Contact Center – Support/Escalated Calls role provides system support for CSRs and communicates with customers in instances when additional support is needed after the initial interaction. Communications include topics such as reports of outages, estimated restoration times, emergency conditions, LSE contacts, and other inquiries.

Generally filled by: Various management personnel (primary and alternate)

Reports to: Contact Center Supervisor

Responsibilities:

Answer calls, or respond to emails, or online chat reports which have been escalated for additional support. Topics include issues such as reports of outages, estimated restoration times, emergency conditions, LSE contacts, and other inquiries.

Ensure that any appropriate outage/emergency orders are created in CIS and that the customer’s account is noted if required.

Provide customers information regarding their outage case, including any Estimated Time of Restoration.

Provides CIS system or back-office support to any CSRs who need assistance.

Social Media Lead/Team

The Social Media Lead and Team members oversee and maintain Central Hudson’s activity on all applicable social networking sites during a restoration event.

Generally filled by: Various Corporate Communications personnel (primary and alternate)

Reports to: Customer Communications Branch Director/Social Media Lead

Responsibilities:

Post and share information surrounding Central Hudson’s storm preparation and response to social media feeds, as approved by the Public Information Officer.

Monitor and respond to customer feedback and/or questions as they are raised; communicate to the Customer Communications Branch Director any emergency information posted erroneously and redirect the customer to the proper channels.

Share pertinent storm information from other social media sources, such as a County EOC, to the extent Central Hudson is aware of such activity.

Call Backs

The Call Backs Storm roles contacts customers to confirm power restoration status, documents the results and communicates with operations as directed.

Generally filled by: Various qualified personnel (primary and alternate)

Reports to: Contact Center Supervisor

Responsibilities:

Look up necessary customer contact information and contact the customer to determine power restoration status.

Document and communicate results to OMS users or staff in Operations as directed.

Videographer

The Videographer is responsible for capturing photos and/or videos of storm damage and associated restoration activities for dissemination in press releases, social media posts, videos, and any other communications issued by the Public Information Office during an event.

Generally filled by: Multimedia Specialist (primary)
Communications Coordinator (alternate)

Reports to: Internal Communications Branch Director

Responsibilities:

Solicit for and capture photos and/or videos of storm damage and associated restoration activities. Includes performing interviews and 'on-the-ground' reporting and assisting in the production of any other multimedia communications issued by the Public Information Office during an event. Provide documented footage to the Customer Communications Branch Director for inclusion in published communications.

District Communications Liaison

The District Communications Liaison helps facilitate communication of restoration plans, status of restoration, special customer considerations, logistics needs, and ETR times between operating districts and central support groups.

Generally filled by: District Manager (primary)
Associate District Manager(alternate)

Reports to: Liaison Officer

Responsibilities:

Assist with development of restoration plan by providing information on affected critical facilities, LSE and Special Needs customers.

Serve as the primary point of contact for local municipal officials to communicate emergency needs and priority repairs with Central Hudson. Address outstanding questions/concerns from officials raised during the Municipal Conference Calls. Assist with coordinating priority road clearing with local municipal officials.

Respond to critical facility and LSE/Special Needs customer inquiries.

Serve as the primary point of contact for telecommunications companies. Address outstanding questions/concerns from telecom companies raised during the Telecom Call, as well as facilitate interaction between the companies and Central Hudson where coordination is required.

Ensure that the district "bat phone" is manned at all times and that all calls are addressed in a timely fashion.

As directed by Operating Supervisor, act as liaison between district operations and Section Chiefs or their personnel.

Associate District Communications Liaison

In large scale events, an Associate District Communications Liaison may be selected by the District Communications Liaison. The Associate District Communications Liaison will perform specific tasks as requested by the District Communications Liaison and relieve the District Communications Liaison when needed.

Generally filled by: Associate District Manager (primary)
Business Development Associates (alternate)

Reports to: District Communications Liaison

Responsibilities:

Assist with development of restoration plan by providing information on affected critical facilities, LSE and Special Needs customers.

Assists the District Communications Liaison with outstanding questions/concerns from municipal officials or telecom companies raised during conference calls.

Respond to critical facility and LSE/Special Needs customer inquiries.

Man the district "bat phone" and ensure that all calls are addressed in a timely fashion.

Utility Field Liaison

The Utility Field Liaison is responsible for interfacing with municipal officials and telecommunications providers regarding make-safe activities, including road clearing.

Generally filled by: Manager, Demand Side Management (primary)
Manager, Digital Customer Experience (alternate)

Reports to: District Communications Liaison

Responsibilities:

Receive reports of make-safe and road clearing activities through phone calls and/or online-enabled tools.

Prioritize necessary make-safe activities based on the hazard and impact to the public.

Report locations in need of operational response to Make Safe Activities Coordinator for crewing assignment.

Upon issues being reported cleared, update status on reporting systems.

Communicate status updates to EOC Representatives, municipal officials, and telecommunications providers as needed.

Emergency Operations Center (EOC) Representative

The EOC Representative facilitates communications between county EOCs and Central Hudson systems and personnel. EOC Reps are usually physically located at county EOCs; they remotely access Central Hudson systems to input trouble orders and provide status on status of restoration. EOC Reps leverage company knowledge and contact information to facilitate general emergency response, special customer considerations and other logistics needs.

Generally filled by: Various qualified personnel (primary/alternate)

Reports to: District Communications Liaison

Responsibilities:

Serve as a point of contact at the county Emergency Operations Center. Facilitate communication between the EOC and District Communications Liaison in support of general emergency response, wires down, making roads safe to clear, and critical customer needs.

Access the Customer Information System to create trouble orders remotely from the EOC.

Use published systems such as the latest 4-Hour PSC Situation Reports or internal outage map to communicate restoration status to the EOC.

Facilitate communication between the EOC and Consumer Outreach in support of LSE/Special Needs customer inquiries.

Governmental Affairs

Those assigned to the Governmental Affairs role are responsible for facilitating communication between Central Hudson and state and federal elected officials.

Generally filled by: Various Public Affairs personnel (primary)
Executive VP Public Affairs (alternate)

Reports to: Liaison Officer

Responsibilities:

Serve as the primary point of contact for state and federal elected officials. Address outstanding questions/concerns raised as necessary.

District Clerical

The District Clerical role provides coordination of meals for district office personnel, recordkeeping and other clerical-level duties as assigned.

Generally filled by: Clerical Assistants (primary and alternate)

Reports to: District Communications Liaison

Responsibilities:

Ensure that all office employees are fed during the work day by coordinating the delivery of meals to the district office.

Conduct recordkeeping and clerical-level duties.

Safety Advisor

The Safety Advisor is responsible for conducting safety briefings to incoming restoration crews, and ensuring the safety of field personnel.

Generally filled by: Sr. Safety Specialist (primary)
Safety Advocate (alternate)

Reports to: Safety Officer

Responsibilities:

Conduct safety briefings to contractors and mutual assistance crews as necessary.

Perform safety inspections of field work sites.

Address any safety concerns brought up by personnel working on the storm response.

Security Supervisor

The Security Supervisor coordinates the security needs of his/her designated area to ensure the security of all personnel working on the restoration efforts.

Generally filled by: Security Investigator (primary and alternate)

Reports to: Security Officer

Responsibilities:

Coordinate the security needs for the assigned district offices, dry ice distribution locations, and alternate housing areas.

Address any security concerns brought up by personnel working on the storm response, as directed by the Security Officer.

Field Resource Coordinator

The Field Resource Coordinator assists the Operations Section Chief and Operating Supervisors with assigning Crew Guide and Substation Coordinator personnel, tracking crew locations and interfacing with the Logistics Section Chief to address support needs.

Generally filled by: Manager, Capital Management (primary)
Manager, Distribution Maintenance and Transmission (alternate)

Reports to: Operations Section Chief

Responsibilities:

Coordinate staffing of Crew Guide positions with Planning Section Chief and Crew Onboarding Coordinator, as needed.

Assist Operations Section Chief with staffing of Substation Coordinator positions.

Assist Operations Section Chief and Operating Supervisors with determining areas to assign crews, Substation Coordinators and Chief Line Technicians.

Update Planning Section Chief daily (or more often if needed) with locations of foreign crews.

Provide the Resources and Reports Coordinator with a complete listing of crew information required for inclusion in the 4-Hour PSC Situation Reports.

Ensure that Substation Coordinators, Supervisors and Crew Guides are keeping accurate records of crew time, materials and equipment costs.

Assist with safety briefings to foreign crews, if requested.

ETR Development Coordinator

Using intelligence reports from field patrols and SCADA, the ETR Development Coordinator assists the Operations Section Chief and Operating Supervisors with deriving global, regional/county, and township Estimated Restoration Times.

Generally filled by: Associate Manager, Distribution Improvement (primary)
Manager, Distribution Maintenance and Transmission (secondary)

Reports to: Operations Section Chief

Responsibilities:

Assist the Intelligence Director with determining areas for Rapid Assessment and Detailed Damage Assessment patrols.

Assimilate information received from OMS, SCADA and field patrols to develop ETR times, taking into consideration current and planned crewing.

Make Operating Supervisors aware of published ETR times and track their progress on achieving these times.

Provide the Resources and Reports Coordinator with a complete listing of ETR times required for inclusion in the 4-Hour PSC Situation Reports.

Line Operations Director

The Line Operations Director has overall responsibility for restoring distribution circuits. He/she helps develop District Restoration Plans in accordance with the objectives of the event Incident Action Plan. All Operating Supervisors report to the Line Operations Director.

Generally filled by: Senior Manager, Electric District Operations (primary and alternate)

Reports to: Operations Section Chief

Responsibilities:

Staff Operating Supervisor, Make Safe Activities Coordinator, and supporting staff positions. Supervise the efforts of Operating Supervisors and Make Safe Activities Coordinators and provide back-up or relief as needed.

In conjunction with the Field Resource Coordinator and Line Clearance Director, assign line and line clearance crews to operating divisions in accordance with the Incident Action Plan.

Assist Operating Supervisors in developing District Restoration Plans.

Participate in storm planning meetings/conference calls; be able to report on restoration status for each division and plans for the remaining restoration effort.

Ensure that Operating Supervisors are getting accurate time, material and equipment logs from outside crews.

Assist with or assume the duties of the Operations Section Chief, as needed.

Transmission Director

The Transmission Director has responsibility for operating the electric transmission system during storm events.

Generally filled by: Director, System Operations and Emergency Management (primary)
Manager, Transmission Operations (alternate)

Reports to: Operations Section Chief

Responsibilities:

Perform emergency switching to restore transmission lines after trip out.

Provide the Incident Commander and Operations Section Chief with daily Transmission and Distribution trip-out sheets and notify them when transmission lines are restored.

Coordinate activities of Substation Electricians and transmission repair crews, keeping Operations Section Chief informed of all locations where personnel are working.

Arrange for air patrol flights when requested. The results of the patrols will be forwarded to the Incident Commander and Operations Section Chief.

Participate in storm planning meetings/conference calls.

Intelligence Director

The Intelligence Director manages all damage assessment patrol efforts and loop crew activities and is responsible for coordinating all resources assigned to these activities and reassigning personnel as the restoration progresses.

Generally filled by: Project Manager (primary)
Director, Gas Engineering Design and Services (alternate)

Reports to: Operations Section Chief

Responsibilities:

Staff Damage Assessment Coordinator and Loop Crew Coordinator positions in all districts where this effort is needed. These are essential positions and should be staffed as needed during any storms Class 2 or above.

Acquire the necessary number of vehicles for the Damage Assessment patrols. Coordinate with Transportation Unit for pool cars and/or rental cars.

Work closely with Operating Supervisors to develop the damage assessment process for the event. This should include a plan for reporting emergency situations, determining assessment types and areas, and documenting patrol results.

Assist Damage Assessment Coordinators and Loop Crew Coordinators with obtaining sufficient resources to perform patrolling functions.

As the storm progresses, reassign damage assessment personnel to other storm functions as needed. Upon completion of patrolling duties, Damage Assessment Patrollers should be assigned to work with Power Line Supervisors/Substation Coordinators in the area where the patroller had been doing assessment work.

Participate in storm planning meetings/conference calls; be able to report on damage assessment status for each division and plans for the remaining assessment effort.

Line Clearance Director

The Line Clearance Director has overall responsibility for line clearance activities during storm events. He/she supervises Line Clearance Supervisors and their crews.

Generally filled by: Manager, Vegetation Management (primary)
 Operating Supervisor Line Clearance (alternate)

Reports to: Operations Section Chief

Responsibilities:

Provide supervision of Line Clearance Supervisors and Line Clearance Crews.

Assist Operating Supervisors in coordinating assignment of Line Clearance Crews to trouble locations.

For outside crews, ensure that proper records are being kept of crew time, materials and equipment. Forward time logs to Planning Section Chief daily.

Inform Planning Section Chief of crew locations daily or when changes in location occur.

Make Safe Activities Coordinator

The Make Safe Activities Coordinator organizes the operational response to road clearing and other make-safe activities.

Generally filled by: Various qualified personnel (primary and alternate)

Reports to: Line Operations Director

Responsibilities:

Determine resources to be assigned to perform make-safe and road clearing activities.

Develop operational response to priority road closure incidents as reported by the Utility Field Liaison.

Work with the Wire Down Coordinator to identify locations for make-safe activities in order to clear Wire Guards.

Communicate crew locations to the Operating Supervisor for coordination of make-safe activities.

As activities are completed, update Utility Field Liaison with status and close case in OMS (as appropriate).

Operating Supervisor

Operating Supervisors provide direction for the restoration effort in each operating district. They are responsible for developing the District Restoration Plan, supervising all efforts in accordance with the plan and communicating restoration status throughout the event. All Line Supervisors, Substation Coordinators, and Crew Guides report to the Operating Supervisors.

Generally filled by: Manager, Electric District Operations (primary and alternate)

Reports to: Line Operations Director

Responsibilities:

Assess the magnitude of storm damage on the operating district.

Work with Dispatch Operations to respond to wires down and other public hazards.

Develop District Restoration Plan and recommended crewing levels.

Staff Electric Operating Engineer position. Provide relief and back-up as needed.

Assign outage cases to Line Supervisors, Substation Coordinators, or line crews as per the restoration plan. Communicate this assignment to dispatchers for radio communications with crews and OMS assignment as needed.

Assign work areas to Line Supervisors and assign crews to each.

Evaluate the need for and request Substation Coordinator personnel. Assign work areas to Substation Coordinators and indicate which line supervisors will be working in these areas. Provide a person to act as Runner for all Substation Coordinators whenever possible.

Communicate crew locations to the Line Operations Director for coordination of logistical support with the Logistics Chief. Inform Line Operations Director of all changes to work assignments that would affect lodging or meal locations.

Ensure that accurate records are being kept of restoration times as well as foreign crew time, equipment and material costs.

Maintain up-to-date employee records on the ARCOS callout system, with assistance from Dispatch Operations and ARCOS Coordinators as needed.

Ensure that the ETR Policy is being followed and ETR times are being communicated to and from the field operation.

Coordinate make-safe activities and crew locations with the Make Safe Activities Coordinator.

Communicate restoration status and plan for remaining restoration effort to the Line Operations Director.

Electric Operating Engineer

The Electric Operating Engineer (EOE) provides support to the Operating Supervisor in each district. The EOE works with the Operating Supervisor to develop the District Restoration Plan and helps to prioritize OMS cases for assignment to line crews. He/she manipulates OMS predictions to more accurately reflect actual field conditions. All restoration switching on distribution circuits is directed or approved by the EOE.

Generally filled by: Sr Engineer, Electric Operations Engineering (primary and alternate)

Reports to: Operating Supervisor

Responsibilities:

Assist Operating Supervisor with assessment of storm magnitude.

Assist with development of District Restoration Plan and staffing recommendations.

Coordinate entry of all intelligence information into OMS. This involves working with the Intelligence Director as well as individual Damage Assessment Coordinators and Loop Crew Coordinators to determine how information will be communicated and recorded.

Direct or approve all distribution switching.

Help prioritize OMS cases for assignment to line crews, line Supervisors and substation coordinators.

Relieve Operating Supervisor as needed.

Substation Coordinator

Substation Coordinators manage the efforts of several Line Supervisors, Crew Guides, and line crews in order to ensure safe and effective restoration of an assigned area. The decision to assign Substation Coordinators to a particular affected area is made by the Operating Supervisor when resources under his/her direction exceed the recommended span of control (no more than 5 direct reports).

Generally filled by: Various Senior Crew Guides (primary and alternate)

Reports to: Operating Supervisor

Responsibilities:

Supervise and direct the restoration effort in an assigned area. Areas will usually be distribution circuits out of the same substation, but could be adjoining or geographically close circuits.

Ensure that Line Supervisors and crews clearly understand their clearance areas and that daily "tailboard" discussions are being held.

Communicate restoration progress to Operating Supervisors throughout the day, with a formal report near the end of the work day.

Ensure that ETR Policy is being followed for circuits assigned. Respond to or direct the response to Contact Center inquiries on assigned circuits.

Coordinate repair of house services with Loop Crew Coordinator.

Line Supervisor

Line Supervisors directly supervise line crews in the restoration of electric service.

Generally filled by: Line Supervisors (primary and alternate)

Reports to: Substation Coordinator or Operating Supervisor

Responsibilities:

In the area assigned, ensure that repairs are being done effectively and safely.

Perform daily "tailboard" discussions with line crews, line clearance crews (if assigned), crew guides and flaggers.

Communicate restoration progress to Operating Supervisors or Substation Coordinators throughout the day, with a formal report near the end of the work day.

Ensure that ETR Policy is being followed for circuits assigned.

Coordinate repair of house services with Loop Crew Coordinator.

Ensure that accurate restoration records are being kept and turned in at the end of the day.

Power Line Technician

The Power Line Technician performs the restoration of electric service and makes any necessary repairs.

Generally filled by: Power Line Technicians (primary and alternate)

Reports to: Make Safe Activities Coordinator, Substation Coordinator, Line Supervisors, or Crew Guide

Responsibilities:

Perform electric service restoration and/or make-safe activity work safely and effectively as directed.

Participate in daily "tailboard" discussions at each job site prior to conducting restoration/repair activities.

Splicer

The Splicer performs the restoration of underground (and select overhead) electric service and makes any necessary repairs.

Generally filled by: Splicers (primary and alternate)

Reports to: Make Safe Activities Coordinator, Substation Coordinator, Line Supervisors, or Crew Guide

Responsibilities:

Perform electric service restoration and/or make-safe activity work safely and effectively as directed.

Participate in daily "tailboard" discussions at each job site prior to conducting restoration/repair activities.

Crew Guide

Crew Guides lead outside crews to/from their work locations and provide crews with general logistical support.

Generally filled by: Various qualified personnel (primary and alternate)

Reports to: Substation Coordinator or Operating Supervisor

Responsibilities:

Lead crews to and from work site, lodging, and meal locations.

Provide logistical support to foreign crews – lodging, meals, and other needs.

Provide communication between field and office including location of crews and status of restoration.

Call in restoration information to Dispatcher immediately after service is restored to each case/location, if requested. Otherwise, update Operating Supervisor or Substation Coordinator as cases or areas are restored.

Evaluate the performance of assigned mutual assistance crews following an event.

Tag distribution facilities under the authority of the Operating Supervisor. Request switching, if required, through the Operating Supervisor.

Ensure that interruption cards are completed and turned in at the end of the work period for all devices restored.

Communicate to the Operating Supervisor or Substation Coordinator any locations of transformer leaks or oil spills.

Report any accidents or injuries to Operating Supervisor or Substation Coordinator immediately.

Remain aware of published ETR times for areas assigned and report any cases where published ETR needs to be extended.

Record locations of customer owned equipment damage and communicate these locations to the Loop Crew Coordinator or Dispatcher.

Runner

Runners are assigned to work with Substation Coordinators to help with communications and logistical support.

Generally filled by: Various qualified personnel (primary and alternate)

Reports to: Substation Coordinator

Responsibilities:

Provide assistance to Substation Coordinator as assigned.

Deliver or pick up meals, maps, and paperwork to/from crews.

Provide another point of communication for Contact Center and Operating Supervisor contacts.

Act as driver for Substation Coordinators, Line Supervisors, or Crew Guides as required.

System Operations

System Operations is the operational authority for the electric transmission system, and is responsible for the isolation, clearance, and prompt restoration of all transmission lines upon trip out.

Generally filled by: Various Transmission Operators (primary and alternate)

Reports to: Transmission Director

Responsibilities:

Direct the emergency switching for the electric transmission system in order to isolate damaged areas and provide clearance to Electricians and transmission repair crews.

Promptly return all transmission lines to service via transmission switching upon repair of any damage.

Chief Electrician

The Chief Electrician supervises Electricians in the repair of substation equipment, as well as transmission and distribution restoration switching.

Generally filled by: Substation Supervisor (primary and alternate)

Reports to: Transmission Director

Responsibilities:

Ensure the prompt isolation and repair of any damaged substation equipment.

Coordinate the staffing of sufficient Electrician personnel to conduct transmission and distribution restoration switching.

Electrician

Those assigned to Electrician perform all substation equipment repair and transmission and distribution restoration switching activities.

Generally filled by: Electricians (primary and alternate)

Reports to: Chief Electrician

Responsibilities:

Perform transmission and distribution restoration switching safely and effectively as directed by the System Operator, including daily "tailboard" discussions.

Diagnose and repair damaged substation equipment as assigned.

Chief Construction Maintenance Worker

The Construction Maintenance Worker is responsible for ensuring all substations are accessible and that perimeter fencing is intact. In addition, he/she coordinates delivery of all large transformers and other equipment.

Generally filled by: Construction Maintenance and Rigging Supervisor (primary and alternate)

Reports to: Transmission Director

Responsibilities:

Coordinate the clearing of access paths to all substations, as required.

Ensure the prompt securing, and subsequent repair, of all substation perimeter fencing in the event of damage.

Provide delivery for all large transformers and other equipment, upon request.

Construction Maintenance

Those assigned to Construction Maintenance perform all substation access clearing, perimeter fencing repairs, and large transformer or other equipment delivery. Construction Maintenance also handles the delivery of dry ice to designated locations for distribution.

Generally filled by: Construction Maintenance Workers (primary and alternate)

Reports to: Construction Maintenance and Rigging Supervisor

Responsibilities:

Clear access paths to all substations and repair substation perimeter fencing as directed by the Construction Maintenance and Rigging Supervisor.

Deliver all large transformers and other equipment to job sites as requested.

Deliver dry ice to designated distribution locations as requested by the Dry Ice Supervisor.

Damage Assessment Coordinator

Damage Assessment Coordinators assign and direct the field patrol activities and ensure that patrol information is updated and communicated accurately.

Generally filled by: Various qualified personnel (primary and alternate)

Reports to: Intelligence Director

Responsibilities:

Consult with the Operating Supervisor and Loop Crew Coordinator to determine which areas should be patrolled. Consideration is given to areas already assigned to line crews, areas designated for Preliminary Assessment, and areas where extensive damage is suspected.

Contact Damage Assessment Patrollers and assign them to two-person teams.

Obtain necessary equipment and vehicles for patrol teams, consulting with Transportation Unit for transportation needs.

Clearly communicate requirements of the current patrol assignment to Patrollers and review safety practices.

Use damage assessment systems to track/assign orders. In the event that the damage assessment system is not available, assignments shall be tracked via paper or spreadsheets.

Validate results of patrol information if received wirelessly. If received via phone, input information into OMS or keep manual records if OMS is not available.

Modify OMS predictions where possible to reflect actual field conditions (move up, move down or confirm predicted devices). Obtain assistance from Electric Operating Engineer with this effort if needed.

Provide periodic reports of extent of damage found, status of patrol effort, and special conditions to Operating Supervisors.

Damage Assessment Patroller

Assess the circuit or area assigned by the Damage Assessment Coordinator.

Generally filled by: Various qualified personnel (primary and alternate)

Reports to: Damage Assessment Coordinator

Responsibilities:

If patrolling trouble cases, confirm or correct the predicted device location and pole number. Report the cause for the outage and location of damage. When needed, check customer meters to assess whether location has power or not.

If patrolling entire circuits, mark device states (open/closed) and damage location/description on the damage assessment system, or if not available, circuit maps.

Stand by and protect the public from any wires down that are a hazard to public safety until such time as a crew, Wire Responder, or Wire Guard arrives.

Provide the Damage Assessment Coordinator damage assessment reports via the damage assessment system, forms, or marked-up circuit maps, as directed. Wireless damage reports can be sent immediately. Phone reports should be done as per the direction of the Damage Assessment Coordinator at the time of assignment (e.g. report periodically, or report as each damage location is found).

Each Damage Assessment Patroller is responsible for coordinating their own meals.

Immediately report any broken poles and downed and/or leaking transformers to the Damage Assessment Coordinator.

Contact the Damage Assessment Coordinator if you will be patrolling off-road sections of the circuit.

Loop Crew Coordinator

Loop Crew Coordinators assign and direct the field activities of Rapid Assessment Patrollers and Loop Crews.

Generally filled by: Service Supervisors (primary)
Manager, Meter Services (alternate)
Estimating Supervisors (alternate)

Reports to: Operating Supervisor

Responsibilities:

Ensure that sufficient personnel remain in the Operating District to cover gas odor reports.

Consult with the Operating Supervisor to determine areas where Rapid Assessment is desired. Assign employees to perform patrols of this area. Collect information and communicate it to Operating Supervisor and Intelligence Director.

Receive service loop repair orders from Damage Assessment Coordinators, Wire Down Coordinators, and/or Line Supervisors. Assign to Loop Crews as crews become available. Track progress and close out cases in OMS as they are completed in the field.

Clearly communicate job assignments to Rapid Assessment patrollers and Loop Crews. Review safety considerations at the start of each assignment.

Report Loop Crew locations to Support Branch Director for meals.

Provide status reports on rapid assessment and loop restoration as directed.

Loop Crew

Loop Crews perform the make safe and restoration of selected electric outages as directed.

Generally filled by: Electricians (primary)
Meter Testers (primary)
Relay Technician (primary)
Instrument and Communications Technician (primary)
Commercial Representatives (primary)
Various other personnel including contractors (primary or alternate)

Reports to: Loop Crew Coordinator

Responsibilities:

Assess and restore selected outages as assigned by the Loop Crew Coordinator. If the outage requires work tasks outside of the Loop Crew's capabilities, notify the Loop Crew Coordinator for reassignment of the task.

Perform select make-safe activities to address wire down or road closure situations, as assigned by the Loop Crew Coordinator.

Report details of customer owned damage for documentation.

Line Clearance Director

Line Clearance Director directly supervises line clearance crews in the removal of trees and branches from electric facilities prior to line crew restoring service.

Generally filled by: Utility Forester (primary)

Reports to: Line Clearance Director

Responsibilities:

In the area assigned, ensure that line clearance work is being done effectively and safely.

Perform daily "tailboard" discussions with line clearance crews, crew guides (if assigned) and flaggers.

Ensure that accurate time and equipment records are being kept and turned in at the end of the day.

Line Clearance

Those assigned to the Line Clearance role perform all vegetation management activities in the field.

Generally filled by: Chief Line Clearance Technician (primary)
Various qualified personnel including contractors (primary)

Reports to: Line Clearance Director

Responsibilities:

Perform line clearance work safely and effectively as directed by the Line Clearance Director.

Participate in daily "tailboard" discussions at each job site prior to conducting line clearance activities.

Flood Area Coordinator

Coordinate the field response associated with disconnecting and reconnecting customers during a local emergency when an area is flooding or flooding is predicted.

Generally filled by: Service Supervisor (primary)
Associate Service Supervisor (alternate)

Reports to: District Operating Supervisor

Responsibilities:

Coordinate the de-energization of flooded areas with Operating Supervisors and local emergency/municipal officials. Supervise the personnel performing electric and gas disconnect activities.

Contact the Logistics Chief to mobilize a Field Command Center, if needed.

Track customers affected and note customer accounts to provide details. Provide a list of affected customers to the Customer Information Coordinator, as needed, to support outbound informational calls.

When flood waters have receded and it is safe to enter the area, work with local emergency/municipal officials to determine which premises have damage.

Coordinate restoration of unaffected customers through the Operating Supervisor.

Track affected customers and work jointly with emergency officials, building and electrical inspectors to restore power and gas when premises are ready for service restoration. Communicate any electrical inspection requirements to impacted customers.

Resources and Reports Coordinator

The Resources and Reports Coordinator documents all outside company crew locations and communicates these locations to the Support Branch Director and also files all storm-related PSC reports.

Generally filled by: Various qualified personnel (primary and alternate)

Reports to: Planning Section Chief

Responsibilities:

Assist with contacting Mutual Aid companies and contractors to obtain resources, as directed.

Obtain crew transfer sheets (rosters) from all responding contract and Mutual Aid crews.

Track locations of crews daily by means of talking with or receiving crew reports from the Field Resource Coordinator.

Communicate changes in work locations to Support Branch Director immediately so that meals and lodging locations can be adjusted.

Receive daily time/material logs from Operating Supervisors.

Compile a daily crew summary report for use in storm planning meetings.

Compile data for and submit 4-Hour PSC Situation Reports to PSC at times required.

Resources and Reports

Those assigned to the Resources and Reports role ensure the documentation of all contract and mutual aid activities, as well as timely filing of all storm-related PSC reports.

Generally filled by: Various qualified personnel (primary and alternate)

Reports to: Resources and Reports Coordinator

Responsibilities:

Assist with obtaining and documenting crew transfer sheets (rosters) from all responding contract and Mutual Aid crews.

Assist with the compiling of data for 4-Hour PSC Situation Reports to PSC at times required.

Situation and Demobilization Coordinator

The Situation and Demobilization Coordinator monitors weather reports and provides briefings to the Incident Commander and Operations Section Chief as needed. He/she also coordinates the release of contract and Mutual Aid crews.

Generally filled by: Various qualified personnel (primary and alternate)

Reports to: Planning Section Chief

Responsibilities:

Participate in all NWS weather briefings. Provide a summary of anticipated weather to the Incident Commander.

Save weather reports for use in post-event critique report.

Provide weather updates during storm planning meetings if requested.

Work with Operating Supervisors and Planning Section Chief to document and coordinate release of contract and Mutual Aid crews. Documentation should be saved for comparison to invoices from these companies.

Crew Onboarding Coordinator

When a mutual assistance crew is brought in to assist with the restoration effort, Central Hudson pairs these crews up with a Crew Guide, and also provides a Safety Briefing. It is the Crew Onboarding Coordinator's responsibility to attend these meetings, either in person or by proxy, draft Crew Guide assignments, and ensure that the roster that has been supplied by the responding utility or contractor is accurate.

Generally filled by: Various qualified personnel (primary and alternate)

Reports to: Planning Section Chief

Responsibilities:

Obtain Crew Guide personnel when directed by the Planning Section Chief, and provide crew guide assignments for arriving mutual assistance crews.

Ensure accurate count of mutual assistance employees who have arrived.

Document the name of the employees who arrived in each work group, when each member arrived, as well as the Crew Guide assigned to each mutual assistance crew. Document that each member has received a safety briefing.

Provide meals and logistics details to the mutual assistance crews and Crew Guides as necessary upon check-in.

Ensure the Planning Section Chief and Support Branch Director are kept abreast of crew check-ins and any changes.

ARCOS Coordinator

The ARCOS Coordinator is responsible for ensuring that ARCOS schedule and Crew Chief records are up to date so that it can be used to track field employees and contractor crews and determine which are currently working, where they are working, and when employees can be called out if necessary.

Generally filled by: Transmission and Distribution Maintenance Planner (primary)

Reports to: Planning Section Chief

Responsibilities:

Ensure that ARCOS is kept up to date.

Coordinate with Operating Supervisors and their staffs to ensure that ARCOS is being updated with the current status of all field employees and contractors.

The ARCOS Coordinator can update the system personally or it can be completed by other supervisors, but it is the Coordinator's responsibility to ensure that it is being maintained.

Support Branch Director

The Support Branch Director coordinates all activities pertaining to lodging and meals for foreign crews.

Generally filled by: Director, Talent Development (primary)
Senior HRIS Program Manager (alternate)

Reports to: Logistics Section Chief

Responsibilities:

Knowing how/when meals will be provided and where crews will be housed at the end of each workday is a critical concern of the Operating Supervisors and it can cause great disruption when arrangements are not made in a timely fashion. It is the Support Branch director's responsibility to adequately staff the Meals and Lodging Units so that meals are timely and that that hotel arrangements are secure before 3 PM each day.

The Meals Unit supplies meals to field crews according to the following guidelines:

- Breakfast should be provided at hotel restaurants or will be catered at the hotel where mutual aid crews are lodged whenever possible. Central Hudson crews are provided breakfast at their local dispatch center. Crews driving to individual restaurants should be avoided.
- Lunch will be obtained from area restaurants/delicatessens. Boxed lunches and hot soup should be provided and delivered to central location/locations by the supplying restaurant/deli. Central locations include: district headquarters, substations and other staging areas. Crew Guides or Runners will be used to deliver the meals to the crews from the central location where necessary.
- Dinner should be arranged in a manner which best meets operational needs. As available, dinner should be arranged at the hotel where crews are staying or at restaurants with sufficient capacity to serve large groups. When possible, preset mealtimes should be based on the anticipated work schedule of the crews. Meals Unit personnel will notify Operating Supervisors of the dinner location prior to 5 PM each workday. Crew Guides will be responsible for leading their crews to the restaurant location and back to their hotel each night.

The Lodging Unit arranges lodging according to the following guidelines:

- Verify crew locations with the Resource and Reports Coordinator daily
- Make hotel reservations for crews at establishments as close as possible to the crews' work locations.
- Communicate lodging locations to Operating Supervisors and Crew Onboarding Coordinator daily or whenever changes occur.
- Make arrangements for transportation of crews' personal belongings if necessary.

The Staffing Unit tracks personnel requests and assignments according to the following guidelines:

- Obtain latest list of employees.
- Create spreadsheet or database to track daily storm assignments of non-field personnel.
- Upon request, assign additional personnel to requesting area and make employee notification.

The Alternate Housing Unit will arrange alternate housing for Mutual Assistance personnel (if needed), according to the following guidelines:

- Secure housing locations/sites
- Arrange facilities for meals, bathing and sanitary needs.
- Assign Alternate Housing Supervisor to oversee and coordinate needs at each site.
- Assign additional personnel to assist as needed.

The Facilities Unit manages the use and maintenance of all Central Hudson facilities.

Service Branch Director

The Service Branch Director coordinates all activities pertaining to wire guarding, computer systems, dispatch operations, customer communications (including callbacks) and environmental services.

Generally filled by: Manager, Resiliency Systems (primary)
Associate Manager, GIS Data (alternate)

Reports to: Logistics Section Chief

Responsibilities:

Staffs and supervises the activities of the Wire Down, Computer Systems, Dispatch Operations, Customer Information and Environmental Units.

The Wire Down Unit directs the response to wire down reports which includes the following tasks:

- Obtain staffing and supervision for responding to wire down reports and providing stand-by personnel.
- Contact contractors to obtain additional wire response personnel as needed.
- Using Avineonics, or OMS reports if needed, determine locations where wire down reports have been received. Prioritize orders based on determination of public safety, police/fire relief and road closures.
- Assign locations to Wire Responders in priority order, or contact Operating Supervisors to direct response to a line crew or supervisor.
- Document Wire Responder and Wire Guards arrival times and communicate to Operating Supervisors where Wire Guards are standing by.

The Dispatch Operations Unit coordinates all assignments of dispatching personnel. He/she directs the allocation of cell phones and the repair of radios. All requests for phones and/or radios must be approved by the Dispatch Operations Supervisor in order to maintain a single point of control.

The Customer Information Unit is responsible for coordinating consistent outage-related system messages, delivering messages using the outbound call systems and using OMS to support customer callback efforts. Specifically, this includes:

- Ensuring consistency between ETR information on all public sources and PSC reports. This includes the OMS feedback message available to CSRs, ETR information available to customers via the website, IVR, 4-Hour PSC Situation Reports and UED to PSC Staff, and radio/news broadcasts.
- Updating StormCentral Alert messages, dry ice locations, shelter locations daily or any time this information changes.
- Organizing Callback group(s) to make manual callbacks to customers believed to be restored. Manual callbacks (MCLK) are preferred, during a major event, but automated callbacks (CLBK) may continue to be used when immediate feedback is needed or the volume make manual calls less feasible.
- Using West Alerts to make outbound calls to customers as directed by the Contact Center Branch Director or Incident Commander. Outbound calls are generally used to notify customers of major changes in estimated restoration time, or to notify them that their power is expected to remain off overnight.
- Using West Alerts to notify municipal leaders of time/date of Municipal Conference Calls

The Environmental Services Unit provides support to the Operating Section by:

- Ensure compliance with all environmental regulations.
- Arrange for spill response as needed.

The Drafting/GIS Unit coordinates the availability of circuit maps for operations personnel.

Supply Branch Director

The Supply Branch Director will coordinate all activities related to dry ice distribution, material supply (including delivery of poles to job sites), transportation, and procurement.

Generally filled by: Manager, Transportation and Contracts (primary)
Supervisor, Procurement and Stores (alternate)

Reports to: Logistics Section Chief

Responsibilities:

Staffs and supervises the activities of the Dry Ice, Materials/Poles, Transportation, and Procurement Units.

The Dry Ice Unit will report to the Supply Branch Director and will distribute dry ice (and bottled water if directed by the Incident Commander) to customers when outages are expected to last more than 48 hours. This effort will include:

- Obtaining estimates of locations and numbers of customers who expect to be out of power more than 2 days.
- Based on the above information, select distribution locations. Work with the Liaison Unit staff to notify available county EOC Staff of the selected dry ice distribution locations and discuss any concerns raised. If needed at a dry ice distribution site, portable lighting is to be made available.
- Estimate the total dry ice needs. Dry ice needs can vary based on several factors, including: the seasonality of the event (summer vs. winter), the location of customers impacted (customers near urban centers typically have higher daily dry ice needs), and the losses that will occur between production and customer delivery. Central Hudson typically assumes that 5 percent of the impacted customers will desire dry ice and that each interested customer will be delivered about 10 pounds. The initial order is based on these approximations as well as factors unique to the storm. As the event progresses, the company monitors the usage rate at each distribution location and adjusts accordingly. A listing of recommended dry ice distribution locations is maintained by the District Communications Liaisons, which can be found in Appendix R. When national supplies of dry ice are limited or not available for purchase, the Company will supplement with regular/wet ice and clearly communicate the type of ice being distributed.
- Work with the Procurement Unit to arrange delivery of supplies to the distribution locations. When outages resulting from anticipated events are expected to last more than 48 hours, the Company will commence dry ice distribution within 24 hours of the start of restoration, contingent upon availability from vendors and upon accessibility of distribution centers due to issues such as road closures, down wires, or debris as well as appropriate time-of-day for dry ice distribution.
- Once outages are anticipated to last more than 48 hours, initiate the dry ice order within 6 hours based on the methodology described above.
- Assign personnel and obtain vehicles to transport personnel and supplies to the distribution location.
- Provide distribution location information to the Public Information Officer and Customer Information Coordinator for dissemination to the public.
- Adjust the amounts and locations of dry ice/bottled water distribution as needed throughout the event.

The Material/Poles Unit will oversee all storeroom operations and arrange delivery of poles and other materials as requested by the Operating Supervisors or Substation Coordinators. This will include:

- Staff and schedule main storeroom operations; replenish materials in district storerooms.
- Deliver poles to job sites.

The Transportation Unit will be responsible for obtaining and maintaining all vehicles needed in the storm response. This will include:

- Coordinate and expedite repairs of disabled vehicles.
- Obtain rental cars for damage assessment, crew guides or any other function as requested by the Section Chiefs
- Arrange for fueling of vehicles including mutual aid and contract crew trucks.

The Procurement Unit will be responsible for the purchasing function during storm events. This will include:

- Ensure storm materials remain within order points; reorder and arrange for emergency delivery of storm stock and non-stock materials if needed.

Information Technology Branch Director

The continuous operation of internally and externally facing computer hardware, software, databases, and communications equipment is critical during the response to a major event. The Information Technology Branch Director has overall responsibility to ensure that these systems remain available throughout the event. Any requests for access, licenses and problem resolution must be approved through the Information Technology Branch Director to ensure proper control over these core services.

Generally filled by: Manager, Infrastructure and Operations (primary)
Director, Business Applications and Technology (alternate)

Reports to: Logistics Section Chief

Responsibilities:

Assemble the team that is necessary to keep the various systems functioning well during the event.

Ensure that all routine maintenance functions that involve systems that are related to the emergency response are postponed until the end of the event.

Oversee the response to any system failure that occurs during the event.

Meals Supervisor

The Meals Supervisor ensures that all field employees are provided meals throughout the event.

Generally filled by: Manager, Meter to Cash Field Operations (primary)
Supervisor Field Collections (alternate)

Reports to: Support Branch Director

Responsibilities:

Ensure that all field employees, mutual assistance, and contractors are fed during the work day. This can be accomplished by delivering meals or supplying bag lunches to take with them in the morning.

Coordinate with the Lodging Supervisors to ensure that all mutual assistance employees are fed breakfast and dinner at the beginning and end of their shifts (preferably at the facility where they will be spending the night). Arrange for meals if they are not provided.

If alternate housing is used, coordinate with the Alternate Housing Supervisor to ensure that all employees at the facility(s) are fed breakfast and dinner. Arrange for meals if they are not provided.

Ensure that food is procured, organized, and/or delivered as necessary.

Oversee the district Meals Coordinators.

Meals

Those assigned to the Meals role distribute the meals to field employees at their assigned districts.

Generally filled by: Supervisor, Meter Reading and Revenue Protection (primary)
Various qualified personnel (alternate)

Reports to: Meals Supervisor

Responsibilities

Distribute meals to field employees, mutual assistance, and contractors at locations and times designated by the Meals Supervisor.

Lodging Supervisor

The Lodging Supervisor is responsible to ensure that any employee, contractor, or mutual assistance worker who is in need of lodging is supplied a hotel bed or passed to the Alternate Housing Unit.

Generally filled by: Manager, Procurement and Stores (primary)
Supervisor, Procurement and Stores (alternate)

Reports to: Support Branch Director

Responsibilities:

Working with the General Staff determine how many rooms/beds are needed by district or area.

Secure the appropriate number of single and double occupancy rooms. Consider the male/female ratio and the number of supervisors.

Whenever possible, arrange for start-of-shift and end-of-shift meals at the hotels.

Oversee the check-in and check-out process.

Assist with the post-storm invoice processing to ensure that Central Hudson is invoiced for the appropriate number of rooms.

If Alternate Housing is mobilized:

Conventional hotels are preferred and often more cost effective than non-traditional housing; however, if alternate housing is necessary, work with the Support Branch Director and the Alternate Housing Supervisor to determine how many individuals will be housed in hotels, and how many will be housed in base camps or other non-traditional locations.

Lodging and Hotel Meals

Those assigned to the Lodging and Hotel Meals role assist in the securing of hotel accommodations and any associated meals at the hotel, and assign personnel to the hotel rooms.

Generally filled by: Associate Buyer (primary)
Various qualified personnel (alternate)

Reports to: Lodging Supervisor

Responsibilities:

Secure the appropriate number of single and double occupancy hotel rooms, as directed by the Lodging Supervisor.

Assign personnel needing lodging to the booked hotel accommodations and communicate the assignments to the impacted individuals and/or their supervisors as needed.

Onsite Lodging Liaison

The Onsite Lodging Liaison is responsible for ensuring that any employee, contractor, or mutual assistance worker that is assigned lodging is assigned a room key and has checked in.

Generally filled by: Various qualified personnel (primary and alternate)

Reports to: Lodging Supervisor

Responsibilities:

Assist Lodging Supervisor in tracking the number of rooms/beds that are utilized at assigned location.

Arrive at lodging location prior to arrival of personnel. Secure room listing from provider of rooms with occupancy capacity for each. Ensure the appropriate number of single and double occupancy rooms have been secured. Consider the male/female ratio and the number of supervisors.

Whenever possible, assist with ensuring that start-of-shift and end-of-shift meals at the hotels have been provided.

Oversee the check-in process to ensure that personnel are assigned to appropriate rooms (correct male/female splits, supervisor rooms, and any other special requirements).

Maintain a roster with room assignments for each person staying at assigned location.

Assist with the post-storm invoice processing to ensure that Central Hudson was invoiced for the correct number of rooms.

Work with hotel management and Lodging Supervisor to resolve any issues with hotel accommodations. Register any complaints, and assist with resolution as appropriate. (This will ensure utilization of the facilities in future events is set to the standards we require for our mutual assistance personnel.)

It is expected that in most cases, the Onsite Lodging Liaison will need to board at the hotel for the duration of the storm in order to ensure continuity of lodging support. When boarding at the hotel, room and meals will be provided by the Company. As restoration progresses, relocation to a new lodging location may be necessary.

Staffing Supervisor

The Incident Commander is responsible for assigning employees to all of the key emergency management roles. Most of the support level roles will be filled according to employees assigned storm duties. However, there may be some support level roles that require additional resources. When a Chief or Director requests additional resources to fill a specific role, the Staffing Supervisor will select the appropriate employee to fill that role. If all of the trained employees are otherwise occupied, it is the Staffing Supervisor’s responsibility to work with the appropriate Chiefs and/or Directors to balance the needs of each unit to achieve the optimum emergency response organization.

Generally filled by: Senior HRIS Program Manager (primary)
Talent Acquisition Employees (alternate)

Reports to: Support Branch Director

Responsibilities:

Balance the trained resources that are available with the needs of each operational unit.

Track the storm role assignments of non-field employees so that reassignments can be made.

If the event requires deployment of all Central Hudson employees, provide every employee a storm-related responsibility.

Retain non-field employee staffing assignment records for post-storm reporting and analysis.

Staffing

Those assigned to the Staffing role ensure that every employee is provided a storm related responsibility.

Generally filled by: Talent Acquisition Employees (primary and alternate)

Reports to: Staffing Supervisor

Responsibilities:

Track the storm role assignments of non-field employees so that reassignments can be made, as directed by the Staffing Supervisor.

Assist in providing every employee a storm related responsibility and identifying personnel not yet activated during an event.

Alternate Housing Supervisor

The Alternate Housing Supervisor has overall responsibility for the operation of base camp or a similar alternate housing location.

Generally filled by: Various qualified personnel (primary and alternate)

Reports to: Support Branch Director

Responsibilities:

After the decision has been made to utilize alternate housing, work with the Support Branch Director and the Lodging Supervisor to develop and maintain the list of mutual assistance and/or contractors who will stay at the base camp.

Supervise the employees that will interact with the operators of the base camp.

Serve as the primary contact for the base camp contractor.

Oversee the following activities at the camp:

- Bedding/linens
- Food
- Kitchen/Dinning facilities
- Water supply
- Toilet facilities
- Shower facilities
- First Aid
- Security
- Sewage
- Garbage/overall cleanliness
- Traffic flow and parking

Facilities Supervisor

The Facilities Supervisor manages the use and maintenance of all Central Hudson facilities.

Generally filled by: Manager, Facilities Management (primary)
Facilities Superintendent (alternate)

Reports to: Service Branch Director

Responsibilities:

Ensure all Central Hudson facilities are continuously available and in good working order for personnel to utilize.

In the event that a Central Hudson facility becomes incapacitated during the event, work with the Operations Section to determine if securing a temporary replacement is warranted.

Maintain the cleanliness of each facility throughout the event.

Facilities

Those assigned to Facilities are charged with keeping Central Hudson facilities clean and continuously operational.

Generally filled by: Buildings and Grounds Mechanic (primary)
Maintenance Worker (primary)
Cleaning Worker (primary)

Reports to: Facilities Supervisor

Responsibilities:

Troubleshoot and repair building plumbing/electrical/mechanical issues as required.

Maintain the cleanliness of the assigned facility throughout the event.

Wire Down Supervisor

The Wire Down Supervisor manages the response to wire down reports. He/she oversees the efforts of the Wire Down Coordinators and ensures adequate staffing of these positions.

Generally filled by: Sr. Manager, Engineering Standards and Compliance (primary)
Manager, Estimating and Real Property Services (alternate)

Reports to: Service Branch Director

Responsibilities:

Assign Wire Down Coordinators; provide relief as needed.

Contact outside vendors to obtain additional wire response personnel as needed. Maintain communication with contractor supervision throughout event.

Communicate with Incident Commander, Intelligence Director and Operating Supervisors on progress of Wire Down response.

Supervise the efforts of Coordinators and ensure that proper procedures are being followed, including the documentation of Wire Guard and Wire Responder arrival times.

Wire Down Coordinator

Wire Down Coordinators organize the response to wire down reports in an individual operating district and coordinate the efforts to investigate/standby wires down. They document the results of the wire down response and provide status reports as required.

Generally filled by: Service Supervisors (primary and alternate)
Estimating Supervisors (primary and alternate)
Various other qualified personnel (primary and alternate)

Reports to: Wire Down Supervisor

Responsibilities:

Use Avineonics to track open wire down orders. In the event that the Avineonics software is not available, develop list of locations where wires have been reported down using OMS and the Wires Down Calls Report on OMS.

Determine resources to be assigned to evaluate and guard wires down. Wire Responders will be Commercial Reps, Estimators, Meter Testers, and qualified contractors. Wire guards will be Collectors, Meter Readers, Gas Mechanics and contractors.

Prioritize and sort orders into manageable volumes per responder, with those where comments indicate have the highest priority (highest risk to public safety) being assigned first. Determine priority according to the Wire Down Procedure guidelines.

Using severity codes found in Wire Down Procedure, update severity of wire down condition on each t-log as it is reported by Wire Responder or other qualified field personnel.

Use Avineonics to assign and track the status (e.g. assigned, being guarded, etc.) of wire down orders. This includes tracking the arrival time of Wire Responders and Wire Guards. In the event that the Avineonics software is not available, maintain a list/spreadsheet of status of orders, including Wire Responder and Wire Guard arrival times.

Assign Wire Guards to replace Wire Responders when appropriate so that the Wire Responders can move on to their next assignment.

Keep track of where personnel are standing by and provide relief as needed.

Communicate Wire Guard locations to the Operating Supervisor and the Make Safe Activities Coordinator for coordination of make safe activities.

Wire Responder

Wire Responders travel to the site of a reported wire down incident which has been assigned to them. They assess the severity of the reported incident and document their findings using Avineonics or other means. Based on the conditions found, the Wire Down Responder will perform the proper response activities such as; contacting the Wire Down Coordinator to request a Wire Guard, remaining on scene until a qualified employee can verify that the wire is de-energized, and/or barricading the location.

Generally filled by: Commercial Representatives (primary)
Estimators (primary)
Meter Testers (primary)

Reports to: Wire Down Coordinator

Responsibilities:

Travel to the site of an assigned reported wires down incident. Record arrival and departure times, using Avineonics or other methods.

Assess the wires down incident; document and report the findings to the Wires Down Coordinator, using Avineonics or other methods.

Based on the conditions found, perform the required response actions, such as: contacting the Wire Down Coordinator to request a Wire Guard, remaining on scene until a qualified employee can verify that the wire is de-energized, and/or barricading the location.

While on the scene, ensure that yourself, other employees, emergency responders and the public remain a safe distance away from the downed wire.

When turning the wire down site over to a Wire Guard, communicate your findings and document the Wire Guard arrival time, using Avineonics or other means.

Wire Guard

Wire Guards travel to the site of a reported wire down incident which has been assigned to them. They remain on the scene until qualified personnel can verify that the wire is de-energized or until qualified personnel arrive to make repairs. Based on the conditions found, a Wire Guard may assist a Wire Responder with the proper wire down response activities such as barricading the location.

Generally filled by: Collectors (primary)
Gas Mechanics (primary)
Meter Readers (primary)
Various other qualified personnel including contractors (primary or alternate)

Reports to: Wire Down Coordinator

Responsibilities:

Travel to the site of an assigned reported wire down incident. Note your arrival time, which should be recorded by a Wire Responder or Wire Down Coordinator, via Avineonics or other methods.

Based on the conditions found, assist with Wire Down response actions, such as barricading the location.

While on the scene, ensure that yourself, other employees, emergency responders, and the public remain a safe distance away from the downed wire.

Remain on the scene until a qualified personnel can verify that the wire is de-energized or arrives to make repairs.

Notify the Wire Down Coordinator or Dispatcher of departure times when relieved by another wire guard, or when leaving the scene due to the arrival of other qualified personnel.

Dispatch Operations Supervisor

Depending upon the area affected by the storm, the dispatch function may be de-centralized for some or all areas of the company. In addition, dispatching of natural gas related emergencies may or may not be de-centralized along with the electric emergency functions. The decision of whether or not to decentralize is dynamic and may change by district each day of the event. It is the Dispatch Operations Supervisor’s responsibility to ensure that all gas and electric dispatching functions are covered in all Districts for each day of the event.

Generally filled by: Manager, Distribution System Operations (primary)
Sr Distribution Operator (alternate)

Reports to: Service Branch Director

Responsibilities:

After the initial decision is made to decentralize, determine how gas emergencies will be handled, throughout the course of the event.

Ensure that each district, and the System Dispatch Center, has the staffing necessary to accomplish all dispatching functions.

In the event that additional dispatching staff is required, work with the Support Branch to have the appropriate staffing reassigned.

Dispatcher

The Dispatcher is responsible for communicating job assignment details to restoration crews and maintaining the associated records on the Outage Management System.

Generally filled by: Dispatchers (primary)
Order Dispatchers (primary)

Reports to: Dispatch Supervisor

Responsibilities:

Communicate job assignment details to restoration crews via phone or radio; update OMS as necessary.

Obtain closeout/restoration information from crews as outages are completed and update cases in OMS.

Conduct callbacks on outage cases as they are restored; contact individual customers as necessary to communicate case-specific information.

Maintain up-to-date employee records on the ARCOS callout system, as directed by the Operating Supervisor.

Customer Information Coordinator

Central Hudson utilizes a software product to provide outage information to our customers and to the public. The customer-facing software uses input from our OMS to indicate the time, location, and available ETR for each interruption. Manual intervention is required to provide an alert message and to ensure that Township and County ETRs are accurate. During storms, important messages need to be communicated to groups of people. Central Hudson utilizes an automated outbound calling system to quickly convey information to certain groups of customer or officials.

Generally filled by: System Coordinator, Emergency Management (primary)
OMS Data Coordinator (alternate)

Reports to: Service Branch Director

Responsibilities:

Ensure that all messaging provided to our external stakeholders is consistent.

Coordinate with the Planning Section to ensure all PSC reporting is consistent with customer messaging.

Add a general alert on the customer-facing application when the event begins and update the message as the restoration progresses.

Ensure that Township and County level ETRs match the dates and times provided by Operations and publish.

Update and republish ETRs that change.

Publish important information on Central Hudson mapping applications such as dry-ice or warming center locations.

Organize Callback group(s) to make manual callbacks to customers believed to be restored. Manual callbacks (MCLK) are preferred, during a major event, but automated callbacks (CLBK) may continue to be used when immediate feedback is needed or the volume make manual calls less feasible.

Compose and record outbound call messages as directed by the Contact Center Branch Director or Incident Commander. Outbound calls are generally used to notify customers of major changes in estimated restoration time, or to notify them that their power is expected to remain off overnight.

Compose and record outbound call messages, as needed, to support Municipal Conference Calls.

Alert the Information Technology Branch Director and/or the software vendor of any performance issues, create help-desk tickets, and follow through with any modifications or updates required to restore system performance.

Environmental Services Supervisor

The Environmental Services Supervisor will oversee the reporting and clean-up of any oil spill or other incident that has the potential to contaminate the environment during the course of the emergency.

Generally filled by: Senior Manager, Environmental (primary)
Environmental Coordinator (alternate)

Reports to: Service Branch Director

Responsibilities:

Oversee the response to any environmental discharge that occurs during the course of the event.

Ensure any required regulatory reports are filed correctly and in a timely manner.

Ensure that any required documentation is produced and maintained.

Oversee the payment of invoices for environmental response after the completion of the storm.

Environmental

Those assigned to Environmental help coordinate the response, reporting, and clean-up of any oil spill or other potential contaminating incident.

Generally filled by: Sr. Environmental Coordinator (primary)
Environmental Coordinator (primary)

Reports to: Environmental Services Supervisor

Responsibilities:

Coordinate the response to any environmental discharge that occurs during the course of the event, as required.

Ensure proper documentation and reporting for each event is complete and accurate.

Drafting/GIS Supervisor

The Drafting/GIS Supervisor ensures that circuit maps are consistently available in all districts for operating crews.

Generally filled by: Supervisors, GIS (primary and alternate)

Reports to: Support Branch Director

Responsibilities:

Ensure that each district has adequate circuit maps on hand for restoration crews.

Print additional circuit maps as required and arrange for the delivery to the district as needed.

Dry Ice Supervisor

The Dry Ice Supervisor is responsible for the distribution of dry ice to our customers.

Generally filled by: Director, Finance and Planning (primary)
Assistant Financial Analyst (alternate)

Reports to: Supply Branch Director

Responsibilities:

Working with the Supply Branch Director and the Liaison Officer, determine how much ice to order for each day's distribution.

Working with the Supply Branch Director and the Liaison Officer, determine the locations that will be used for dry ice distribution.

Staff the distribution locations.

Arrange for the delivery of ice to the locations.

Work with the Public Information Officer and Customer Information Coordinator to provide public notification of the dry ice distribution locations and times.

Serve as the point of contact with the owners, or operators, of the facility that is being used for dry ice distribution.

Respond to the changing needs of each distribution location. For example, if traffic control becomes an issue, arrange to have additional resources assigned to the location for traffic control.

Dry Ice

Those assigned to Dry Ice distribute the dry ice to impacted customers at assigned locations.

Generally filled by: Various qualified personnel (primary and alternate)

Reports to: Dry Ice Supervisor

Responsibilities:

Distribute dry ice to impacted customers at locations and times designated by the Dry Ice Coordinator.

Material/Pole Supervisor

The Material/Pole Supervisor oversees all storeroom operations and ensures material is consistently stocked and issued to operating crews throughout the event. If the event has a sufficient number of broken poles to warrant a separate organization to spot and set poles in advance of the line organization, then the Material/Pole Supervisor will oversee the distribution of poles to the areas where they are required.

Generally filled by: Supervisor Storerooms, Procurement and Stores (primary and alternate)

Reports to: Supply Branch Director

Responsibilities:

Working with the Supply Branch Director and the Logistics Section Chief, ensure that there are sufficient poles, and related hardware, on hand and/or ordered to replace all broken poles.

Staff and schedule main storeroom operations. Ensure material in the district storerooms is replenished throughout the event.

Provide the staffing for and schedule bulk material deliveries to the district offices or remote locations as requested.

Establish a supply chain that will allow for the procurement and delivery of poles and/or hardware, preferably directly to the job site.

Provide line tools from secured stock at the request of the Operations Section Chief.

Field Clerk/Storekeeper

The Field Clerk/Storekeeper maintains and issues all material through the storerooms to crews.

Generally filled by: Field Clerk/Storekeepers (primary)

Reports to: Material/Poles Supervisor

Responsibilities:

Coordinate the distribution of necessary material from the storeroom to operating crews.

Maintain accurate records of material usage, including poles and transformers issued.

Manage local storm stock material levels and request additional material delivery when necessary.

Materials Assistant

The Materials Assistant helps issue material from the storerooms and delivers material to jobsites in the field when needed.

Generally filled by: Gas Mechanics (primary)

Reports to: Materials/Poles Supervisor

Responsibilities:

Issue material from the storerooms as directed by the Field Clerk/Storekeeper.

Deliver requested material to operating crews at job site locations as required.

Collect damaged equipment from jobsites for removal as requested by operating crews.

Transportation Supervisor

The Transportation Supervisor has overall responsibility to ensure the safe, continuous operation of the Central Hudson fleet during an event.

Generally filled by: Transportation Supervisor (primary and alternate)

Reports to: Supply Branch Director

Responsibilities:

Ensure proper staffing of the district and the central garages throughout the event.

Prioritize the repair work based on the necessity of the vehicle and the severity of the repair/maintenance that is required. The goal is to maximize the productivity of the field work force.

Obtain rental cars for damage assessment, Crew Guides, or any other function as requested.

In the event that a critical vehicle becomes incapacitated during the event, work with the Operations Section to determine if securing a temporary replacement is warranted.

If a temporary work vehicle (bucket truck, digger derricks, etc.) is required, secure the appropriate number of rental vehicles and have them delivered to the appropriate location.

Provide or arrange for training on any vehicle that an assigned operator is not familiar with.

Garage Mechanic

The Garage Mechanic ensures the safe and continuous operation of the Central Hudson fleet.

Generally filled by: Garage Mechanics (primary)

Reports to: Transportation Supervisor

Responsibilities:

Maintain a continuously operating fleet of Central Hudson vehicles. Prioritize the repair work based on the necessity of the vehicle and the severity of the repair/maintenance that is required.

Provide or arrange for training on any vehicle that an assigned operator is not familiar with.

Garage Clerical

The Garage Clerical role provides coordination of rental car reservation, recordkeeping and other clerical-level duties as assigned.

Generally filled by: Clerical Assistant (primary)

Reports to: Transportation Supervisor

Responsibilities:

Obtain rental cars for damage assessment, Crew Guides, or any other function as directed by the Transportation Supervisor.

Conduct recordkeeping and clerical-level duties.

Procurement Supervisor

The Procurement Supervisor directs the purchasing function during storm events.

Generally filled by: Buyer, Procurement (primary and alternate)

Reports to: Supply Branch Director

Responsibilities:

Ensure storm stock materials remain within order points; reorder and arrange for emergency delivery of storm stock materials if necessary.

Arrange for the purchase and delivery of non-stock materials if needed.

Applications Support Coordinator

The Applications Support Coordinator is responsible for ensuring that all of the software applications that are used during a storm remain functional.

Generally filled by: Director, Business Applications (primary)
Various other staff from IT department (alternate)

Reports to: Information Technology Branch Director

Responsibilities:

Respond to any software issues that occur to storm response related systems during the course of the event.

The Public Information Officer is responsible for the content that is available to the public on the website; however, the Applications Support Coordinator is responsible for ensuring that access to the website remains available for the duration of the event.

Critical storm applications include CIS, Material Management System (MMS), OMS, and StormCentral.

Maintain the links to vital systems that are hosted off site including ARCOS, Notifi, Avineonics (wires down), and Damage Assessment. Ensure that all files are being provided to/from these externally hosted systems.

Infrastructure and Communications Coordinator

The Infrastructure and Communications Coordinator is responsible for ensuring that all of the on-site servers and network components that support our emergency response systems remain functional. This includes all of the IP-based communications systems that are used during the event.

Generally filled by: Senior Manager, Networking and Communications (primary)
Manager, Corporate IT Networks (alternate)

Reports to: Information Technology Branch Director

Responsibilities:

Respond to any hardware issues that occur to storm response-related systems during the course of the event.

Critical storm applications include CIS, Material Management System (MMS), OMS, and StormCentral.

Customer Account Services is responsible for the content on the IVR. The Infrastructure and Communications Coordinator is responsible for the proper operation of the IVR and VOIP systems.

IT Support

The IT Support role provides critical hardware or software support to ensure that all IT-related systems remain functional.

Generally filled by: Various Information Technology personnel (primary and alternate)

Reports to: Applications Support Coordinator or Infrastructure and Communications Coordinator

Responsibilities:

Respond to any hardware or software issues that occur to storm-response related systems during the course of the event.

Energy Management System

Continuous and uninterrupted operation of the Energy Management System (EMS) is critical to the reliability of the transmission system, and to the bulk power system of New York as a whole. Those assigned to the Energy Management System role have overall responsibility to ensure that this system remains available throughout the event.

Generally filled by: Systems Analysts (primary and alternate)

Reports to: Information Technology Branch Director

Responsibilities:

Respond to any issues that occur to the EMS during the course of the event.

Outage Management System

The Outage Management System section has responsibility for maintaining the operation of several customer-centric systems utilized in an emergency event, including OMS, the outage map, the wires down dispatching system, and the damage assessment system.

Generally filled by: Various qualified personnel (primary)

Reports to: Information Technology Branch Director

Responsibilities:

In conjunction with the Applications Support Coordinator and Infrastructure and Communications Coordinator, respond to any issues that occur to critical storm applications including OMS, the outage map, the wires down dispatching system, and the damage assessment system.

Assist operators of these storm applications with troubleshooting and usage as required.

Time Supervisor

The Time Supervisor tracks employee time, via the payroll system, and responds to questions regarding time keeping and payroll.

Generally filled by: Payroll Supervisor (primary)
Various Payroll personnel (alternate)

Reports to: Finance Section Chief

Responsibilities:

Ensure timely completion of employee timesheets.

Answer questions and resolve problems with time records.

Payroll

Those assigned to the Payroll position ensure the payroll process continues to function during an event.

Generally filled by: Payroll Analysts (primary)

Reports to: Time Supervisor

Responsibilities:

Perform the timely review and approval of employee timesheets.

Cost Supervisor

The Cost Supervisor tracks equipment replacement and provides work orders as needed.

Generally filled by: Manager, Financial Reporting and Tax Accounting (primary)
Director, Internal Auditing (alternate)

Reports to: Finance Section Chief

Responsibilities:

Establishes collect-cost work order for event if applicable.

Arranges for work orders to be prepared for equipment replacement.

Provides cost accounting services as requested.

Accounting

Those assigned to the Accounting role manage the necessary bookkeeping of the Company, and assist the Cost Supervisor as needed.

Generally filled by: Accountants (primary)
Accounting Technicians (primary)

Reports to: Cost Supervisor

Responsibilities:

Provides cost accounting services as required.

Claims Supervisor

The Claims Supervisor responds to all requests for damage claims and personal injury cases.

Generally filled by: Associate Counsel, Litigation and Claims (primary)
Claims Adjuster (alternate)

Reports to: Finance Section Chief

Responsibilities:

Evaluate all claims from customers regarding damage or loss due to power conditions.

Respond to all personal injury situations involving public or customers.

Claims

Those assigned to the Claims role ensure the timely response to all claims-related activities.

Generally filled by: Claims Adjuster (primary)

Reports to: Claims Supervisor

Responsibilities:

Evaluate all claims from customers regarding damage or loss due to power conditions.

Respond to all personal injury situations involving public or customers.

Contracts Supervisor

The Contracts Supervisor directs the contract administration function during storm events.

Generally filled by: Contact Administrator (primary)
Project Manager (alternate)

Reports to: Finance Section Chief

Responsibilities:

Work with Logistics Section personnel to arrange contracts for line crew contractors, meal providers, dry ice and bottled water vendors, and other suppliers as needed.

Appendix removed from external copy to protect private information.

Appendix removed from external copy to protect private information.

Appendix removed from external copy to protect private information.

Appendix removed from external copy to protect private information.

Appendix removed from external copy to protect private information.

Appendix removed from external copy to protect private information.



News Release

March 12, 2024

For release: Immediately
Contact: Joe Jenkins, (845) 471-8323

Central Hudson Prepares for Powerful Winter Storm; Potential Service Interruptions

Central Hudson Gas & Electric Corporation is readying crews and advising customers to prepare for potentially severe winter weather that is expected to move through the region on starting on Monday and continuing through Wednesday. Forecasts are calling for significant accumulations of heavy, wet snow coupled with damaging wind gusts of up to 40 miles per hour. Snow accumulations are expected to exceed one foot in areas of higher elevation. These conditions could cause trees and tree limbs to fall onto power lines and cause service interruptions.

“There remains a degree of uncertainty regarding the path of the latest winter storm and the potential impacts it could have on our region, but we are monitoring conditions and are prepared to respond if outages do occur,” said Ryan Hawthorne, Vice President of Electric Engineering and Operations at Central Hudson. “We have a field force of more than 430 line and line clearance workers that includes internal crews, contractors and mutual assistance to help expedite repairs if the need arises.”

Central Hudson prepares for storms by preparing crews, stocking supplies and materials, communicating with community leaders and following an approved storm plan. Central Hudson also takes proactive steps before storms strike to minimize service interruptions, including enhanced vegetation management and danger tree removals, and regular maintenance and upgrades to power lines serving communities.

Residents are advised to **stay at least 30 feet away from downed power lines** and remember that lines may be entangled and hidden in fallen trees and limbs. Residents should also **assume all downed lines are live.**

Customers can prepare for the storm and potential electric service interruptions by:

- Paying attention to weather advisories, storm outage updates and/or shelter information. Visit hudsonvalleyweather.com for the latest forecast information.
- Charging electronic devices in order to connect with Storm Central, Central Hudson's outage information and reporting site;
- Keeping handy a flashlight and fresh batteries;
- Having a battery-powered radio to remain informed of restoration efforts;
- Confirming adequate packaged or canned foods that require no refrigeration or cooking;
- Avoiding opening a refrigerator unnecessarily during outages, so that food lasts longer, an unopened refrigerator can keep food fresh for 24 hours;
- Having a non-electric can opener;
- Keeping an emergency supply of bottled water on hand for drinking and washing; and
- Filling bathtubs with water as added reserves.

Residents are advised to keep safety in mind, particularly during power interruptions:

- Never use outdoor gas or charcoal grills indoors, as they pose a fire hazard and over time can give off carbon monoxide gas;
- Beware of fallen trees and limbs, and use caution when traveling;
- Avoid the use of candles for illumination due to fire hazards;
- Follow the manufacturer's safety instructions on the use of emergency generators, and be sure to shut off the main breaker when in use and operate the units outdoors;
- Operate cars and motor vehicles outdoors only, and never inside the garage; and
- Avoid travel along roadways as hazardous conditions may cause driving accidents, including those involving utility poles which may cause power interruptions.

Customers can stay informed of storm and restoration conditions in the following ways:

- **By text messaging:** Customers should enroll in Central Hudson's Texting Program to use text messaging to report their power condition and to obtain repair status. To enroll, visit CentralHudson.com/Alerts or text REG to 236483;
- **On the Web:** Visit CentralHudson.com/Storms to report outages and obtain restoration updates;
- **Via smart phones:** A mobile version of the Central Hudson's website can be accessed by web-enabled cell phones and mobile devices at <https://mobile.CenHud.com>. Free Central Hudson mobile applications for Android and Apple and are also available by logging onto www.cenhud.com/mobileapp;
- **Through social media:** "Like" Central Hudson on Facebook (Facebook.com/CentralHudson) and "Follow" on X (www.x.com/CentralHudson); and
- **By phone:** Call the Central Hudson PowerLine at (845) 452-2700 or 1-800-527-2714, and please use the automated system to report or monitor your power condition.
- If a member of your household needs electricity to operate life sustaining equipment, please contact customer service at (845) 452-2700.

More information on preparing for storms and emergencies and communicating with Central Hudson is available at www.CentralHudson.com; for information regarding electric and natural gas safety, visit www.CentralHudson.com/Safety.

Appendix removed from external copy to protect private information.

Central Hudson Gas & Electric Corporation

MUTUAL AID Guide


Revised December 2025

Contents:

- K-2 District Offices**
Addresses
Dispatch Phone Numbers
- K-3 Safety Guidelines**
- K-4 System**
- K-6 Temp. Repairs**
- K-7 Tagging & Switching**
- K-8 Material**
Storm Kits
Material Tracking
- K-9 Important Info.**
Restoration Reporting
Oil Spill Procedure
Damaged Property
- K-10 Conduct**
News Media
NYS DOT
Security
- K-11 Logistics Info.**
Work Hours
Lodging and Meals
Expenses
- K-12 Map Symbols**
- K-14 Emergency Facilities**
Hospitals
Urgent Care

*In case of emergency***DIAL 911**

Welcome to the Hudson Valley



Central Hudson appreciates and thanks you for your assistance during this emergency. The purpose of this guide is to provide you with some important information about Central Hudson's emergency operations. This guide provides information regarding our system (focusing on our overhead system), general safety, work policies and crew supervision.

Crew Guides

Crew guides who are familiar with our system and the local area will be assigned to mutual assistance crews to act as the liaison between your crew and Central Hudson's regional control center. Your crew guide will assist you in obtaining information, supplies and equipment.


Crew Guide Name: _____

Contact Information: _____

Central Hudson Service Territory

System Operations:
(845) 486-5600

DISTRICT OFFICES



Catskill

7964 Route 9W
Catskill, NY 12414
Dispatch: (845) 486-5801

Kingston

2001 Route 9W
Lake Katrine, NY 12449
Dispatch: (845) 486-5803

Poughkeepsie*

284 South Avenue
Poughkeepsie, NY 12601
Dispatch: (845) 486-5805

Newburgh

610 Little Britain Rd
Newburgh, NY 12553
Dispatch: (845) 486-5808

Fishkill

25 Central Hudson Way
Fishkill, NY 12524
Dispatch: (845) 486-5807

....Electric Service Territory

.... Combined Service Territory

....Gas Service Territory

* For GPS use "1 Phoenix Street"

Safety Guidelines

The following are required safety guidelines practiced at Central Hudson. As an outside utility employee assisting in restoring Central Hudson's service, you must follow the safety practices of your own company or those of Central Hudson, whichever is more stringent. If after reading the following, you have a question as to which is more stringent, please ask for clarification during your job briefing.

Fire resistant clothing - All Central Hudson and mutual aid crews shall wear outer clothing which adheres to all current OSHA requirements when working in areas where they may be exposed to flame or electric arc. Mutual aid crews shall also adhere to their individual corporate requirements. **Under no circumstances are synthetic fabrics acceptable.**

Fire retardant outer clothing shall be worn at all times when working.

Hard hats meeting the latest requirements of ANSI Z89.1 Type I/Class E must be worn by all workers.

Class 2 rubber gloves and sleeves must be worn whenever it is possible to reach, slip or fall into any conductors which are, or may become energized. Rubber gloves shall be used in a manner consistent with their approved voltage rating. Rubber gloves shall be inspected and air tested at the beginning of any work period, and at any other time when you have reason to believe that the gloves may be damaged. Rubber gloves shall be put on prior to leaving the ground or cradle, regardless of the status of the line (grounded or not grounded). Rubber gloves shall also be worn by all ground workers when handling downed conductors and setting poles in an energized area.

Eye protection meeting the latest requirements of ANSI Z87+ must be worn by all workers.

Work gloves shall be used when handling tools or materials unless their use constitutes a recognizable hazard or prevents the performance of work. Work gloves shall also be used when working with, or on, utility poles.

Reflective safety vests, minimum class 2, shall be worn by all workers exposed to vehicular traffic. An exception to this requirement is made when wearing reflectorized FR rain-gear, or when the work being performed involves exposure to an electric arc, or live gas.

Fall protection harnesses are mandatory whenever working in the elevated position. Harnesses shall be put on prior to leaving the ground or cradle, and shall not be removed until the boom is returned to the cradle.

General Safety Guidelines

General First Aid should be provided and certified first responders should be identified.

The use of alcohol, non-prescription drugs or controlled substances during working hours is explicitly prohibited and will not be tolerated. Anyone in violation this policy will be dismissed immediately.

Central Hudson System

Overview

Central Hudson Gas & Electric Corporation is a regulated transmission and distribution utility serving approximately 309,000 electric customers and 84,000 natural gas customers in a defined service territory of New York State's Mid-Hudson River Valley. Central Hudson delivers natural gas and electricity in a defined service territory that extends from the suburbs of metropolitan New York City north to the Capital District at Albany.

CUSTOMERS

- ⇒ Electric – 309,000
- ⇒ Gas – 84,000

ELECTRIC CIRCUIT MILES:

- ⇒ Transmission – 600 miles
- ⇒ Distribution – 7,200 miles
- ⇒ Underground – 1,600 miles

GAS SYSTEM MILES:

- ⇒ Transmission – 165 miles
- ⇒ Distribution – 1,287 miles

OPERATING VOLTAGES

Transmission Voltages	Distribution Voltages	Secondary Voltages
345 kV	34,500Y / 19,900 V	120 V up to 480
115 kV	13,200Y / 7,620 V	
69 kV	4,160Y / 2,400 V	
14,400Δ V	4,800Δ V	

In 4,800Δ V areas you will find 4,800Δ V / 7,620 V step-up transformers.

In an open-wire secondary scenario, the Central Hudson standard is that the neutral is the top-most conductor.

Minimum Approach Distances (MAD)

Nominal System Phase-Phase Voltage (kV)	Minimum Approach Distance (MAD)	
0.050 to 0.300	Avoid Contact	
0.301 to 0.750	1ft – 1 inch	0.33m
0.751 to 5.0	2ft – 1 inch	0.63m
5.1 to 15.0	2ft – 3 inches	0.68m
15.1 to 36.0	2ft – 7 inches	0.77m
46.1 to 72.5	3ft – 4 inches	1.0m
72.6 to 121.0	3ft – 9 inches	1.13m
242.0 to 362.0	7ft – 5 inches	2.26m

Note 1: For voltages between 50.0V - 15kV, MAD will be set using phase-to-phase voltage

Note 2: For voltages greater than 15kV, MAD will be determined using phase-to-ground voltage for energized exposure based on the assumption that work is performed one phase at a time. If live line or bare hand construction techniques are to be utilized at voltages above 15kV, the work practices shall be reviewed prior to commencing work. Note 2: All MAD values are rounded up to the nearest inch.

Note 3: Central Hudson Minimum Approach Distance Table for "Qualified Personnel" as determined by OSHA listed above. Any "Un-Qualified Personnel" should refer to their employers and OSHA definitions and requirements.

Construction Standards

The following figures are from Central Hudson’s Specifications and Requirements for Electric Installations (Blue Book). If you need further information please contact your Crew Guide.




Figure 1

Service definitions: Delineation between Central Hudson-owned facilities and customer-owned facilities




Figure 5

Typical overhead service connection




Figure 9

Load center meter pole

A printed copy of the following construction standards may be provided to you during the initial orientation and safety briefing or if requested.

- E01-01-001.0** Drafting Standards Distribution Circuit Map Symbols
- E01-01-006.0** Distribution Transformer, Regulator and Capacitor Index
- E01-02-007.0** Vertical Separation of Lines Attached on the Same Pole
- E01-03-006.0** Overhead (OH) Construction Pole Tagging
- E02-03-004.0** OH Open Wire 4.8 kV Const., 4.8kV Phase and Phase, Straight Line and Small Angles
- E02-05-001.0** OH Open Wire 15 kV Line Const., Single phase 7.6 kV – Straight Line and Small Angles, Pole Top Pin (PTP)
- E02-05-003.0** OH Open Wire 15 kV Line Const., Single phase 7.6 kV – Straight Line and Large Angles to 60°, 50' Pull Max -Suspension Corner
- E02-05-011.0** OH Open Wire 15 kV Line Const., Polyphase 13.2 kV Straight Line and Small Angles, Single Crossarm and PTP
- E05-05-012.0** OH Open Wire 15 kV Line Const., Polyphase 13.2 kV Straight Line and Medium Angles, Double Crossarms and PTP
- E02-05-013.0** OH Open Wire 15 kV Line Const., Polyphase 13.2 kV Straight Line and Medium Angles, Center Phase on Double Crossarm
- E02-05-014.0** OH Open Wire 15 kV Line Const., Polyphase 13.2 kV Large Angles to 60°, 50' Pull Max - Preferred Vertical Corner Construction
- E02-05-015.0** OH Open Wire 15 kV Line Const., Polyphase 13.2 kV Large Angles to 60°, 50' Pull Max - Alt. Horizontal Corner Construction
- E02-05-017.0** OH Open Wire 15 kV Line Const., Polyphase 13.2 kV Offset Construction Straight Line and Small Angles
- E02-05-035.0** OH Open Wire 15 kV Line Const., Polyphase 13.2 kV Offset Construction w/ 10' Crossarm Straight Line
- E02-06-004.0** 13.2 kV Three Phase Sectionalizing Cutouts with Deadends (Load Current 200Amp or less) – (Alternate Construction)
- E02-06-008.0** 13.2 kV Three Phase Primary CSP Transformer Installation on Line Pole with Crossarm
- E02-06-008.1** Conventional Transformer Installation on Pole with Crossarm Construction
- E02-06-021.0** 13.2 kV Three Phase Primary WYE Primary WYE Secondary (120/208) with CSP Transformers
- E02-06-024.0** Three Phase Primary Stepdown Transformer Installation 13.2 kV WYE to 4.16 kV WYE
- E02-07-021.0** OH Construction – Cable 7.6 kV Single phase URD riser for Extruded Concentric Neutral Cable
- E02-07-051.0** 13.2 kV Three Phase URD Riser for Extruded Concentric Neutral Cable

Temporary Electric Service Repair Tracking Procedure

All work performed during the restoration process shall be made permanent where possible. In the event that permanent repairs cannot be completed, all temporary repairs must be documented with a "Temporary Electric Service Repair Notice." This document can be obtained from your Crew Guide. This procedure is included below:

Objective:

Central Hudson does not assume responsibility for maintaining customer-owned electric services and equipment. However, in order to prevent possible undue hardship cause by the interruption of a customer's electric service, the company at times may elect to perform temporary repairs on customer and/or company owned electrical equipment.

This procedure has been developed to track electric service repairs performed by Central Hudson employees or contractors in order to temporarily restore a customer's electric service, until such time that a permanent repair is made in accordance with Central Hudson specifications and/or NYS Electric Code requirements.

Temporary Repairs on Customer Owned Equipment

When a company employee or contractor has made temporary repairs in order to maintain electric service to a customer's premises the following procedure will be followed:

1. The company or mutual assistance employee shall obtain the name, address, contact number, and account number of the customer and a "Temporary Electric Service Repair Notice," (referred to a Notice) will be completed. The Notice will identify the temporary repair made by the employee and direct the customer to contact the Company when the identified deficiency has been permanently corrected.
2. An attempt shall be made to obtain a signature from the customer of record acknowledging receipt of such notice. In multi-family dwellings (such as apartment buildings), the property owner or owner's agent shall be notified of the condition and the necessary required corrective action.
3. The completed Notice will be returned to the Central Hudson supervisor or Crew Guide.

Temporary Repairs on Central Hudson Owned Equipment

When a company or mutual assistance employee has made temporary electric repairs to Central Hudson owned equipment in order to maintain electric service to a customer's premises the following procedure will be followed:

1. The company or mutual assistance employees shall obtain the name, address, contact number, and account number of the customer and a "Temporary Electric Service Repair Notice" will be completed. The Notice will identify the temporary electric repair made and that the Company is responsible for completing permanent repairs.
2. The completed Notice will be returned to the Central Hudson crew supervisor or Crew Guide.

Tagging and Switching

Tagging of lines and equipment shall be done by means of tags approved by the local Operating Authority which shall be securely attached in a conspicuous position to each point which will be used as a clearance device for lines or equipment on which work is to be performed. A call to the proper Operating Authority will be completed by the Central Hudson Crew Guide.

All electric lines and equipment shall be considered energized at all times unless properly tagged and grounded.

Work Zone

OSHA REQUIRED JOB BRIEFING (TAILBOARD DISCUSSION)

Prior to the beginning each assignment, the crew leader must conduct a pre-job discussion with all involved workers to discuss the hazards associated with the job, the proper use of PPE, safe work practices, specific job assignments, traffic control, any special circumstances relating to the assignment, and to ensure that everyone involved understands their responsibilities. All questions or concerns should be immediately conveyed to your Central Hudson supervisor or crew guide.

WORK AREA PROTECTION - TRAFFIC CONTROL

When working alongside, or within a roadway or highway, the use of cones and signs are mandatory in order to protect the jobsite. Signs and cones should be placed an adequate distance away from the jobsite to warn oncoming traffic, in accordance with NYS and federal DOT regulations. Flagger should be used when working on all NYS highways, whenever a lane closure is required on any roadway, or whenever the specific nature of a job site warrants additional traffic control.

Work Practices

All electric lines and equipment shall be considered energized at all times unless properly tagged & grounded. No electric equipment shall be operated without approval of the local operating authority.

Backfeed

Customers may have auxiliary generators and/or various equipment that can cause power to backfeed. Use extreme caution and be sure that all backfeed or potential backfeed situations are identified. Equipment such as solar panels and electric vehicles can cause backfeed without any audio indication. **TEST FOR VOLTAGE PRIOR TO STARTING WORK.**

Material

Storm Kits

Our material deployment procedure for Mutual Aid Crews includes deployment of materials and supplies before field restoration efforts have begun. Central Hudson provides boxes to aid in the restoration process. Specific work plans and material requirements may not be known, which can result in the wrong mix or unreasonable volume of materials being withdrawn. In order to expedite initial crew deployments and ensure that common electric restoration materials are available on the first days of efforts, storm kits will be deployed. The kits consist of two durable plastic tote bins (measuring 40" long x 16" wide x 18" high) containing 53 commonly used materials for restoration work (links, splices, clamps, bolts, hand coils, etc.). Each tote bin weighs approximately 140 lbs or less and has metal handles so two crewmen can hand lift if necessary. Please make certain to return your boxes to any of the Central Hudson Storerooms before departure as we restock these for future deployments. The nearest storeroom location can be obtained from your Crew Guide.

Material Tracking

For all material installed, removed, or replaced, we will need the following information:

Transformers:

- Outage Project Number
- Central Hudson Pole Number
- Manufacturer's name
- Manufacturer's serial number
- Street location

Poles:

- Central Hudson Pole Number
- Size and Class
- Street Location
- Telephone Company Pole Number



Important Information

Restoration Reporting

Restoration status is periodically provided to customers, emergency management officials, the NYS Public Service Commission, and others throughout the restoration period. It is important to provide the most accurate information available. Once you have completed a field assessment for each job assignment, you should provide your Central Hudson supervisor or crew guide with an Estimated Restoration Time so that this information may be provided to our customers. You should also notify your Central Hudson supervisor or crew guide as soon as you have completed your work assignment so that all restoration information can be updated in Central Hudson’s outage management system in a timely manner. The following information should be provided:

<i>Outage Project Number</i>	<i>Central Hudson Pole Number</i>	<i>Street location</i>	<i>Time Restored</i>	<i>Cause of Outage</i>
----------------------------------	---------------------------------------	----------------------------	--------------------------	----------------------------

Also, you are required to notify your Central Hudson supervisor or crew guide immediately regarding personal property damage caused either as the result of the outage, or your restoration efforts.

Oil Spills

All oil spills must be reported immediately to your assigned Central Hudson Crew Guide or by calling (845) 486-5604. The following information is required when reporting a spill:

Location	<ul style="list-style-type: none"> Street name, nearest intersecting street, town name, and Central Hudson pole number or serial number of electrical equipment.
Type & Quantity of Oil Spilled	<ul style="list-style-type: none"> Type of oil (i.e. motor oil, transformer oil) PCB status (“Clor-n-oil” field test kits are available from the district office storeroom) Proximity to bodies of water, wetland areas, or drinking water. Description of spill area paved roadway, grassy area, etc.
Actions Take to Contain Spill	<ul style="list-style-type: none"> Prevent oil from reaching surface water, storm / sewer drains, possible wetland areas
Outage Project Number	

Damaged Property

All accidents/ injuries must be reported to your crew guide or the local operating authority as soon as possible.

Any damaged property must also be reported to your crew guide as soon as possible, if tools are damaged and require replacement, all supporting receipts must be saved and submitted to Central Hudson at the end of the event. Crew guides should at a minimum send the following to claims@cenhud.com:

1. A brief description including location of the damage (Pole Number, Address, etc.).
2. Any photos of the property damage.

Crew guides should also notify the appropriate Director of Electric District Operations of the damage.

Conduct

Basic Information

It is important to remember that while working in public areas you may be photographed or videotaped by members of the media or anyone with a smart-phone, which in turn can be posted online immediately, so pay particular attention to your behavior or comments. Be sure to wear your personal protection equipment and follow the necessary safety precautions. If approached by a customer, try to politely indicate that you must focus on your work and say as little else as possible.

NEWS MEDIA & SOCIAL MEDIA

All media inquiries should be directed to Corporate Communications. We provide reporters with our 24-hour Newline phone number, (845) 471-8323, which is to be shared with the news media only. Referring media inquiries to Corporate Communications protects employees, contractors (and the Company) from potential liability.

The news media may legally videotape or photograph on public property, and it is important that employees, contractors and mutual aid representatives are aware of their presence. The public may also photograph/video record and post our activities to social media. As such, always behave in a professional manner and focus on the work at hand.

Other than authorized Company representatives, employees, contractors and mutual aid crews may not post information regarding Central Hudson activities and policies on social media.

UNDER NO CIRCUMSTANCES SHOULD ANY EMPLOYEE, CONTRACTOR OR MUTUAL AID REPRESENTATIVE COMMIT CENTRAL HUDSON TO LIABILITY THROUGH AN ADMISSION OR IMPLIED ADMISSION OF RESPONSIBILITY.

NYS DOT: DRIVING RESTRICTIONS

All employees and contractors are expected comply with any Department of Transportation regulations and restrictions. If you encounter any DOT inspection check point **you must stop**. Inform the attending DOT officer that you are working for Central Hudson Gas & Electric to restore power.

SECURITY

All Central Hudson buildings are staffed with uniformed and plain clothes security personnel who adhere to strict security procedures. You must have identification to gain access to any Central Hudson facility or temporary staging area.

Uniformed Security personnel and/or Central Hudson employees will escort mutual aid crews to briefing rooms and other areas, within the building(s), where they have been instructed to report. Central Hudson employees and/ or Security will also assist mutual aid crews at designated staging and/or parking areas and, when necessary, coordinate with state and local law enforcement agencies to provide security for vehicles and equipment, when staged off Central Hudson property or outside of a temporary staging area.

Logistics Information

Work Hours

The typical Central Hudson Gas & Electric work schedule during storm restoration is 16 hours on, 8 hours off. At the discretion of Central Hudson, work hours may change or be reduced. Any changes will be communicated via your Crew Guide in advance.

FUELING

Mutual aid crews will have access to the Central Hudson on-site fuel supply. In some cases, Central Hudson personnel will meet crews at lodging sites and provide fueling on-site prior to departure for work. You will be informed when and where the fuel truck will be located.

LODGING

Central Hudson will make every attempt to provide satisfactory lodging facilities for crews aiding in restoration efforts. Crews will be lodged as close to their assigned work areas as possible.

MEALS

In an effort to maintain continuity of the crews' workday, along with the fact that much of our service territory is not conveniently located near restaurants, most meals will be delivered to all crews in the field during the day. The uninterrupted workday will allow the crews to restore power to as many customers as possible during daylight hours. At no time are crews permitted to leave their assigned work area for meals without prior approval from Central Hudson supervisor or crew guide.






EXPENSES









When you first arrive or prior to receiving your safety briefing (depending on arrival time), you will be asked to sign-in; this signature will be used to verify rosters when processing payments at the end of events.

Time sheets for each day worked should include-- name, classification, rate of pay, any equipment used and hours worked. Each time sheet will also need to be signed by a Central Hudson employee.

During restoration, if you purchase a meal where one was not provided by Central Hudson, this must be indicated as a separate charge and submitted with a supporting receipt. Any additional charges incurred while en route to or while working for Central Hudson, such as tolls, fuel, or damage tool replacement, should be submitted with a legible receipt.

Central Hudson Map Symbols Guide

Device	Map Symbol
Automatic Load Transfer Switch	84967 N.C. ALT 7011/7023 TYPE E 
Capacitor	150 KVAR 
Switched Capacitor	
Distributed Generation	Not on circuit map
Electric Service Point	Not on circuit map
Secondary Overhead Conductor (in OMS, only a 20' secondary "stub" is modeled)	Not on circuit map
Sectionalizer (three phase unit or three single phase sectionalizers)	 17194 400 A 3 COUNTS TO OPEN
Substation	

Device	Map Symbol
Fault Indicator	
Manhole	 MH 22
Cutout w/ 10k Fuse	 150460
Primary Meter	
Primary Overhead Conductor – Single Phase	
Primary Overhead Conductor – Three Phase	
Primary Overhead Conductor – Two Phase	 Δ 4.8 kV
Primary Underground Conductor – Single and Three Phase	

Central Hudson Map Symbols Guide (Con't)

Device	Map Symbol
Recloser (Three phase unit or one or more single phase Kyles)	<p>400 Amp Kyle w/ 200 Amp Bypass</p>
Switch (600A Disconnect, Airbreak or Oil Switch) - Normally Closed	<p>Air Break:</p> <p>600A Disconnect:</p> <p>Oil Switch:</p>
Overhead Transformer	Not on circuit map
Stepdown Transformer	<p>SHOW NO. OF TRF., KVA SIZE, AND VOLTAGES ie 3-167 ie 13.2/4.16 KV</p>
3 Phase Junction Box	<p>(URD Maps)</p>
Open 3 phase overhead automatic load transfer switch	

Device	Map Symbol
Voltage Regulator	<p>100A</p>
Switch (600A Disconnect, Airbreak or Oil Switch) - Normally Open	<p>Air Break:</p> <p>600A Disconnect:</p> <p>Oil Switch:</p>
Underground Transformer	<p>(URD Maps)</p>
Switch Cabinet (a.k.a. Padmounted Switch Gear)	
Closed 3 phase overhead automatic load transfer switch	
Generator	

Emergency Facilities – Hospitals

<i>Hospitals</i>	<i>Nearest Central Hudson District Office</i>	<i>Hospitals</i>	<i>Nearest Central Hudson District Office</i>
Columbia Memorial Health 71 Prospect Ave 12208 Hudson, NY 12534 Ph: (518) 828-7601	Catskill 9 miles	Vassar Brothers Medical Center 45 Reade Place Poughkeepsie, NY 12601 Ph: (845) 454-8500	Poughkeepsie 1 mile
Albany Medical Center 43 New Scotland Ave Albany, NY 12208 Ph: (518) 262-3125	Catskill/Greenville 33 miles	Mid-Hudson Regional Hospital 241 North Rd Poughkeepsie, NY 12601 Ph: (845) 483-5000	Poughkeepsie 4 miles
HealthAlliance Hospital Broadway Campus 396 Broadway Kingston, NY12401 Ph: (845) 331-3131	Kingston 5 miles	Montefiore St. Luke's Cornwall Newburgh Campus 70 Dubois St Newburgh, NY 12550 Ph: (845) 561-4400	Newburgh 4 miles
Health Alliance Hospital Mary's Avenue Campus 105 Mary's Ave Kingston, NY 12401 Ph: (845) 338-2500	Kingston 6 miles	New York-Presbyterian Hudson Valley Hospital 1980 Crompond Rd Cortlandt Manor, NY 10567 Ph: (914) 737-9000	Fishkill 22 miles
Northern Dutchess Hospital 6511 Springbrook Ave Rhinebeck, NY 12572 Ph: (845) 876-3001	Kingston 8 miles	Putnam Hospital - Nuvance 670 Stoneleigh Ave Carmel, NY 10512 Ph: (845) 279-6111	Fishkill 22 miles
Margaretville Hospital 42084 Route 28 Margaretville, NY 12455 Ph: (845) 586-2631	Kingston 47 miles	Westchester Medical Center 100 Woods Rd Valhalla, NY 10595 Ph: (914) 493-7000	Fishkill 44 miles
Ellenville Regional Hospital 10 Healthy Way Ellenville, NY 12428 Ph: (845) 647-6400	Ellenville 16 miles	Sharon Hospital - Nuvance 50 Hospital Hill Rd Sharon, CT 06069 Ph: (860) 364-4000	Stanfordville 16 miles
Poison Control (800) 222-1222 New York			

Emergency Facilities – Urgent Care

<i>Urgent Care</i>	<i>Nearest Central Hudson District Office</i>	<i>Urgent Care</i>	<i>Nearest Central Hudson District Office</i>
CMH Rapid Care 10 Grandview Ave Catskill, NY 12414 Ph: (518) 943-9100	Catskill 7 miles	Optum Urgent Care – Rhinebeck 6734 US-9 Rhinebeck, NY 12572 Ph: (844) 484-6564	Kingston 8 miles
WellNow Urgent Care 11 Maple Ave Catskill, NY 12414 Ph: (838) 836-6726	Catskill 2 miles	Emergency One Urgent Care 4274 Albany Post Rd Hyde Park, NY 12538 Ph: (845) 229-2602	Poughkeepsie 8 miles
Windham Medical Care 345 NY-296 Hensonville, NY 12439 Ph: (518) 734-3260	Tannersville 12 miles	Optum Urgent Care – Poughkeepsie Columbia 30 Columbia St Poughkeepsie, NY 12601 Ph: (845) 484-6564	Poughkeepsie 2 miles
Emergency One Urgent Care 40 Hurley Ave Kingston, NY 12401 Ph: (845) 338-5600	Kingston 10 miles	Emergency One Urgent Care 2555 South Rd Poughkeepsie, NY 12601 Ph: (845) 330-3200	Poughkeepsie 2 miles
Optum Urgent Care – Lake Katrine 1561 Ulster Ave Lake Katrine, NY 12449 Ph: (844) 484-6564	Kingston 1.3 miles	Nuvance Health – GoHealth Urgent Care 1530 US-9 Wappingers Falls, NY 12590 Ph: (845) 218-1892	Fishkill 6 miles
Nuvance Health-GoHealth Urgent Care Hudson Valley Mall 1240 Ulster Ave Kingston, NY 12401	Kingston 2.2 miles	Optum Urgent Care - Fishkill Westage 600 Westgate Business Center Dr Fishkill, NY 12524 Ph: (844) 484-6564	Fishkill 3 miles
FirstCare Walk-in Medical Center 222 NY-299 Highland, NY 12528 Ph: (845) 691-3627	Eltings Corners 2 miles	Excel Urgent Care 992 Main Street Fishkill, NY 12524 Ph: (845) 765-2240	Fishkill 1 mile
Crystal Run Healthcare Urgent Care 1200 NY-300 1 st Floor Newburgh, NY 12550 Ph: (845) 787-0863	Newburgh 2 miles		

This listing is as of 11/19/25. This is not a complete listing of Urgent Care facilities in the Central Hudson territory and additional facilities can be found online as needed by the individual.

Contact Information

EMERGENCIES

For emergency medical response **dial 911**

SYSTEM OPERATIONS

(24 Hours)

Phone: **845-486-5600** /Fax: 845-486-5736

Division Name: _____

Division Phone Number: _____

Division Contact Name: _____

Crew Guide Name: _____

Crew Guide Phone Number: _____

Crew Guide Vehicle #: _____

Hotel Name: _____

Hotel Phone Number: _____

District Offices

CATSKILL

7964 Route 9W
Catskill, NY 12414
Dispatch: (845) 486-5801

POUGHKEEPSIE

284 South Avenue
Poughkeepsie, NY 12601
Dispatch: (845) 486-5805

FISHKILL

25 Central Hudson Way
Fishkill, NY 12524
Dispatch: (845) 486-5807

NEWBURGH

610 Little Britain Rd
New Windsor, NY 12553
Dispatch: (845) 486-5808

KINGSTON

2001 Route 9W
Lake Katrine, NY 12449
Dispatch: (845) 486-5803

ELLENVILLE

43 Lower Greenfield Rd
Ellenville, NY 12428

TANNERSVILLE

21 Park Ln
Tannersville, NY 12485

GREENVILLE

11576 Rte 32
Greenville, NY 12083

STANFORDVILLE

71 Hunns Lake Rd
Stanfordville, NY 12581

ELTINGS CORNERS

25 South Street
Highland, NY 12528

Storm Checklist Incident Commander

Pre-Event

Complete

- Notify Section Chiefs and Command Staff of impending event _____
- Hold conference call or meeting with Command and General Staff to ensure all necessary preparation steps are being performed _____
- Ensure that Command and General Staff have performed the following tasks:
 - Check storm materials and fuel levels _____
 - Notify all employees and contractors _____
 - Perform all pre-storm customer communications _____
 - Notify municipal leaders _____
 - Notify telecom companies _____
 - Notify PSC and State OEM of preparations and provide CH contact information _____
 - Assign staff to support NAMAG mutual assistance calls _____
- Discuss need for outside resources with Operations Section Chief; If deemed necessary, authorize acquisition through NAMAG _____
- Discuss anticipated housing requirements with Logistics Section Chief; If needed, ensure that alternate housing contractors are notified _____

During Event

Complete

- Develop Incident Action Plan (IAP). Include the following:
 - Event Classification - Class 1, 2, or 3 _____
 - Start of Restoration (date) _____ (time) _____ _____
- Communicate IAP to CH Executives and Section Chiefs _____
- Ensure Command Staff and General Staff positions are fully staffed _____
- Participate in, or assign personnel to participate in all NAMAG calls; authorize additional crew requests as needed _____
- Establish target times for:
 - PSC reports (dates) _____ (times) _____ _____
 - Conference Calls (dates) _____ (times) _____ _____
 - Municipal Briefings (dates) _____ (times) _____ _____
- Develop target dates/times for all requirements of ETR Protocol (with Planning Chief)
 - Global ETR due by (date) _____ (time) _____ _____
 - Regional ETR due by (date) _____ (time) _____ _____
 - Township ETR due by (date) _____ (time) _____ _____
- Assign Operations Section Chief to mobilize Damage Assessment if needed _____
- Assign Logistics Section Chief to mobilize Wires Down program if needed _____
- Assign Logistics Section Chief to mobilize Dry Ice distribution if needed _____
- Assign Logistics Section Chief to mobilize Meal Delivery if needed _____
- Assign Logistics Section Chief to mobilize Lodging and Alternate Housing Units if needed _____
- Request materials from New York Utilities Material Sharing Group (NYMSG) if needed _____
- In a 72hr+ event: the Incident Command team will notify Emergency Response, Corporate Communications, Contact Center, Engineering, Operations, Claims, Treasurer, Customer Accounting to begin Storm Reimbursement and Storm Credit processes _____
- Demobilization: following discussion with Operations Section Chief, authorize release of outside crews _____

Post Event

Complete

- Ensure that critique survey is sent or meetings held to evaluate storm performance _____
- Ensure that the storm crediting, reimbursement and collections exclusion activities are completed as required. _____
- Ensure that Storm Scorecard is completed within 30 days following restoration _____
- Ensure that Critique Report is completed within 60 days following restoration _____

Storm Checklist Deputy Incident Commander

Pre-Event

Complete

Assist with notifications to Company personnel of impending storm events, as directed

Assist with notifications to PSC and SOEM of any impending events, as directed

Participate in any scheduled NAMAG calls

During Event

Complete

Assist Incident Commander in developing the Incident Action Plan (IAP) for the event

Event Classification - Class 1, 2, or 3

Start of Restoration (date) _____ (time) _____

Communicate IAP and restoration status to CH Executives if requested

Participate in any scheduled NAMAG calls; request additional crews as directed

If directed by the Incident Commander, approve all external communications regarding storm restoration including news releases and website messages

Relieve Incident Commander as directed

Post Event

Complete

Provide reporting statistics to Director - T&D Operations for storm scorecard and critique report

Storm Checklist

Public Information Officer

Pre-Event

Complete

Develop news release and website messages to provide customers and municipal leaders with advance warning of the possibility of system damage and power outages; Issue the release when appropriate (up to 48 hours ahead)

Arrange for blast emails regarding storm preparation to be sent to customers with email addresses on file

Alert all employees about impending event

Remind employees to show ID if/when traveling during a State of Emergency

Instruct Outreach Director to run WARN transaction

Direct Contact Center Branch Director to develop tentative staffing plan

During Event

Complete

Advise Incident Commander on information dissemination and media relations

Schedule and issue all Press Releases and paid media messages; Press releases to coincide with morning and evening news cycles

Review and approve IVR upfront messages as prepared by Contact Center; Ensure that IVR upfront message is updated at start of event, and changed as needed during event and within 1 hour of each news release

Arrange for blast emails regarding restoration to be sent to customers with email addresses on file

Create storm web page if needed

Monitor social media and reply as needed

Provide dry ice and shelter locations to public via press releases, website and social media

Coordinate news conferences and interviews as needed

Instruct Outreach Director to initiate outbound calls to Life Support Equipment and Special Needs (EBD) customers

Arrange for notification of municipal leaders regarding dates and times of municipal calls

Coordinate municipal calls and designate person to act as scribe

Arrange for notification of telecom companies regarding dates and times of telecom calls

Coordinate telecom calls and designate person to act as scribe

If there is a chance for a 72hr+ event, Contact Center to send training reminder to representatives regarding customer questions about Storm Credit/Reimbursement claims

In a 72hr+ event, Corporate Communications will generate press release and notifications to inform customers of Spoilage Reimbursement process and timeframe.

In a 72hr+ event, Contact Center to confirm that Late Fee/Collections exclusion process has been run for affected customers.

Post Event

Complete

Prepare documentation of all media, web, social media and broadcast messages, and phone and LSE/EBD contact statistics to Director - T&D Operations for inclusion in critique reports and storm scorecard

Storm Checklist Liaison Officer

Pre-Event

	Complete
Notify critical facilities of an impending event, via an outbound call	_____
Notify municipal officials of an impending event, via an email blast when Class 2 event or greater is expected	_____
Host a pre-storm conference call for municipal officials when a Class 3 event or greater is expected	_____
Notify telecom companies of an impending event, via an email blast when Class 2 event or greater is expected	_____
Host a pre-storm conference call for telecom companies when a Class 3 event or greater is expected	_____
Confirm name/phone numbers that facility managers and municipal officials should use to contact Central Hudson during the event	_____
Develop staffing plan for County EOC Representatives	_____

During Event

	Complete
Coordinate all information exchange between Central Hudson and State OEM and municipal leaders	_____
Conduct Municipal Conference Calls	_____
Conduct Telcom Conference Calls	_____

Post Event

	Complete
Provide documentation of municipal and telecom calls to Director - T&D Operations for storm scorecard and critique report	_____

Storm Checklist Safety Officer

Pre-Event

During Event

Complete

Perform safety briefing for all outside crews

Conduct field inspections to ensure all crews are following safety procedures

Provide safety messages to Public Information Officer for incorporation into press releases, customer communications, employee notices, and municipal/telecom briefings

Address any safety concerns brought up by personnel working on the storm response

Perform OSHA reports of any OSHA reportable accidents

Post Event

Complete

Provide storm safety statistics to Director - T&D Operations for storm scorecard and critique report

Storm Checklist Security Officer

Pre-Event

Complete

Initiate request for Taconic Parkway access, and instruct Corporate Communications to remind employees that they will need to show identification in order to travel during a State of Emergency

During Event

Complete

Coordinate security needs for district offices, dry ice distribution locations, and alternate housing areas

Address any security concerns brought up by personnel working on the storm response

Establish liaison with the respective law enforcement agencies in order to promote prompt restoration of service in conjunction with any related investigations that may be underway

Provide Mutual Assistance personnel with temporary identification badges as needed

Post Event

Complete

Provide reporting statistics to Director - T&D Operations for storm scorecard and critique report

Storm Checklist

Operations Section Chief

Pre-Event

Complete

- Participate in weather briefings as necessary _____
- Notify contract line and line clearance companies of the impending event; determine availability of crews _____
- Develop tentative staffing plan _____
- Obtain a system status report from System Operations including status of all transmission lines and distribution breaker abnormal conditions _____
- In conjunction with Incident Commander, determine number of additional external line resources should be solicited (if any) _____

During Event

Complete

- In conjunction with Incident Commander, determine if external crews will be needed; provide requested number of crews to Planning Chief _____
- Allocate incoming crew resources to each of the operating districts _____
- Ensure all incoming personnel receive a safety briefing (with Safety Officer) _____
- Provide crew location information to Logistics Section for use in securing meals and lodging; update daily _____
- Mobilize Damage Assessment, if needed _____
- Work with Operating Supervisors to determine Global ETR by (date)_____ (time)_____ _____
- Work with Operating Supervisors to determine Regional ETR by (date)_____ (time)_____ _____
- Work with Operating Supervisors to determine Township ETR by (date)_____ (time)_____ _____
- Request materials, supplies and tools from Logistics section as needed _____
- Provide crew data and ETR information to Planning Chief for regulatory reporting _____
- Provide information on locations of outages, extent of damage, and restoration update to Public Information Officer for use in press releases, municipal/telecom calls and other communication _____
- Ensure timely updates of ETRs are being provided to Customers Information Unit by district operating personnel _____
- Provide information to Customer Information Unit when outbound calls for ETR updates are required _____
- Direct Operating Supervisors to perform circuit sweeps prior to releasing crews as needed _____
- Work with Incident Commander and Planning Chief to arrange release of crews _____
- Flood Emergencies: Identify resources available to respond to requests for isolation of facilities due to flooding _____
- Request National Guard assistance (if all other resources are exhausted) _____

Post Event

Complete

- Provide crewing and restoration statistics to Director - T&D Operations for storm scorecard and critique report _____
- In a 72hr+ event, Electric Operating Engineers to identify outages which qualified for Credits/Reimbursements and submit fuse card data to Emergency Response _____

Storm Checklist

Planning Section Chief

Pre-Event

Complete

- Monitor weather reports _____
- Participate in National Weather Service briefings as necessary _____
- Assign personnel to perform resource tracking, reporting, and demobilization positions _____
- Notify National Grid of impending event and coordinate response plans (when flooding is anticipated in the Town of Coeymans) _____
- Notify Orange & Rockland of impending event and coordinate response plans (when flooding is anticipated in the Town of Woodbury and Town of Highlands) _____
- Notify NYSEG of impending event and coordiante response plans (when flooding is anticipated in the Town of Carmel) _____

- If directed, secure additional contract or utility mutual assistance crews according to NAMAG procedure _____

During Event

Complete

- Maintain records of all foreign crews/personnel _____
- Ensure that all PSC reporting is completed as required _____
- Ensure ETRs are established and published within the required guidelines _____
- Request National Guard assistance (if all other resources are exhausted) _____
- Obtain rosters from the sending companies; compile list of foreign crew personnel on the property _____
- Assign personnel to Crew Guide positions if requested by Operations Section Chief _____
- Communicate any changes in foreign crew locations to the Logistics Section Chief for relocation of lodging and meals _____
- Obtain check-out times from Operating Supervisors for each crew unit as they are released _____
- Coordinate demobilization effort at conclusion of event _____

Post Event

Complete

- Provide staffing and reporting statistics to Director - T&D Operations for storm scorecard and critique report _____

Storm Checklist Logistics Section Chief

Action	Employee Responsible	Completed (Y/N)	Date	Time	Notes
Pre-Event					
Support Branch Director					
Notify Meals Unit (districts / meals on wheels)					
Notify Staffing Unit					
Contact Drafting to check circuit map inventory					
Develop staffing plan for County EOC					
Service Branch Director					
Notify Wires Down Unit - Staffing Plan, Avineonics					
Notify Dispatch Operations Unit - Develop Dispatch Staffing					
Notify Customer Communications Unit - WARN Call, Critical Facilities					
Arrange for testing / verify operational computers, radios, generators in districts					
Notify Environmental Unit					
Disable Auto ETR Functionality					
Notify Facilities of Storm Mode. Postpone any non-essential work that would impact any potential storm response					
Supply Branch Director					
Confirm dry ice availability					
Review critical material inventory level					
Count of available truck storm boxes					
Notify Transportation Unit , expedite repairs, halt non-essential maintenance					
Check fuel levels at districts; Notify fuel supplier for off-site fueling at hotels					
Provide available vehicle listing (pool / rental)					
Lodging contracts in place / room availability					
Evaluate need to increase P-Card limits					
IT Branch Director					
Notify Computer Systems Unit - Cease production changes, request staffing plan					

Storm Checklist Logistics Section Chief

During Event

Complete

Direct Service Branch Directors to:

Dispatch Operations Unit

Provide staffing of dispatchers to district offices _____

Wires Down Unit

Provide staffing for Wires Down response _____

Contact contractors to obtain additional wire down personnel as needed _____

Respond to wire down locations in accordance with EEP Section 7.4 _____

Customer Information Unit

Set up a callback group to make manual callbacks _____

Support Callbacks as requested from Operations _____

Update Outage Map alert messages throughout the event _____

Make outbound calls when instructed by the Contact Center Branch Director or Incident Commander _____

Use outbound messaging to notify municipal leaders of time/date of municipal calls _____

Update County and/or Township ETRs on Storm Central to match all public information sources _____

Environmental Unit

Ensure that staffing is available to respond to oil spill and other environmental hazards _____

Direct Support Branch Directors to:

Meals Unit

Provide breakfast at hotel restaurants or cater at the hotel where crews are lodged _____

Provide lunch delivery to work locations _____

Arrange for dinner at restaurants with sufficient capacity to serve large groups _____

Lodging Unit

Verify daily crew locations with the Resource and Reports Coordinator daily _____

Make hotel reservations for crews as close as possible to the crews' work locations _____

Communicate lodging locations to Operating Supervisors daily or whenever changes occur _____

Make arrangements for transportation of crews' personal belongings if necessary _____

Staffing unit

Create spreadsheet or database to track daily employee assignments _____

Assign employees to positions when requested _____

Alternate Housing Unit

Secure alternate housing as needed; arrange facilities for meals and sanitary needs _____

Assign Alternate Housing Supervisor and additional employees as needed to site(s) _____

Facilities Unit

Ensure that all Central Hudson facilities are continuously available and in good working order _____

Drafting/GIS Unit

Ensure that staffing is available to respond to all requests for circuit maps and GIS information _____

During Event

Complete

Direct Supply Branch Directors to:

Dry Ice Unit

Establish dry ice distribution locations if required _____

Once outages are anticipated to last more than 48 hours, initiate the dry ice order within 6 hours _____

Work with procurement Unit to arrange for delivery of dry ice and bottled water to the distribution locations _____

Assign personnel and obtain vehicles for distribution of dry ice and bottled water _____

Provide distribution location information to the Public Information Officer and the Customer Information Unit for dissemination to the public _____

Material/Poles Unit

Replenish materials in district storerooms _____

Deliver poles to job sites _____

Provide line tools from secured stock at the request of the Operations Section Chief _____

Transportation Unit

Coordinate and expedite repairs of disabled vehicles _____

Obtain rental cars for damage assessment, crew guides or any other function as requested by the Section Chiefs _____

Arrange for fueling of vehicles including mutual aid and contract crew trucks _____

Direct Information Technology Branch Directors to:

Ensure that staffing is available to respond to all system failures _____

Flood emergencies: arrange for field command center if needed _____

Request materials from New York Utilities Material Sharing Group (NYMSG) if needed _____

Post Event

Complete

In a 72hr+ event, the Service Branch Director (group) will generate list of affected customers, using the engineering provided fuse card data. _____

Provide logistic data to Sr. Director - Emergency Preparedness for inclusion in storm scorecard and critique report _____

Storm Checklist

Finance Section Chief

Pre-Event

- | | |
|--|--------------------------|
| Evaluate the need to increase Purchasing Card limits for key storm personnel | Complete
_____ |
| Assign employees to fill the Time, Contracts, Cost, and Claims positions | _____ |

During Event

- | | |
|--|--------------------------|
| Develop a collect cost work order upon request from the Incident Commander for all storm charges | Complete
_____ |
| Develop staffing plan to adequately perform all time keeping, procurement, cost account, and claims activities | _____ |
| Communicate with Incident Commander and Operations Section Chief to fulfill daily finance-related needs | _____ |

Post Event

- | | |
|---|--------------------------|
| In a 72hr+ event: Finance Unit will process customer claims for Storm Credits and Reimbursements within 30 days | Complete
_____ |
| Claims will review and approve/reject customer claim submissions. Status information will be shared with the team and valid credit amounts provided to Customer Accounting. | _____ |
| Customer Accounting will remit reimbursements and credits to customers as required. | _____ |
| Provide storm finance statistics to Director - T&D Operations for storm scorecard and critique report | _____ |

Catskill
<u>CCOM- CATSKILL COMMERCIAL</u>
<u>CDRS- CATSKILL DISTRICT REP</u>
<u>CELQ- CATSKILL ELECTRIC QUALIFIED</u>
<u>CFRM- CATSKILL FOREMEN</u>
<u>CGSC- CATSKILL GAS CHIEFS</u>
<u>CGSM- CATSKILL GAS MECHANICS</u>
<u>CSTR - CATSKILL STOREKEEPER</u>
<u>CHLP- CATSKILL HELPERS</u>
<u>CFLG- CATSKILL FLAGGERS</u>
<u>CCLC-CATSKILL CAPITAL CONSTR.</u>
<u>CHLC-CATSKILL CAPITAL HELPERS</u>
<u>CCFL- CATSKILL CAPITAL FLAGGERS</u>
<u>CCMR- CATSKILL COLLECTOR/MTR READER</u>
<u>CGAR- CATSKILL GARAGE</u>
<u>CTST- CATSKILL TESTER</u>
<u>CEST- CASTKILL ESTIMATING</u>
<u>CCLK- CATSKILL CLERICAL</u>
<u>Catskill Line Supervision</u>
<u>CBGM- CATSKILL PRIMARY MAINTENANCE</u>
<u>CMTH- CATSKILL MAINTENANCE HELPER</u>
<u>SUPERVISOR- CATSKILL OUTAGE PATROLLER</u>
<u>SUPERVISOR - CATSKILL STOREROOM</u>
<u>SUPERVISOR- CATSKILL QUALIFIED LINE WORKER</u>
<u>SUPERVISOR- CATSKILL TRIMMING RESPONDER</u>
<u>SUPERVISOR- CATSKILL OUTAGE RESPONDER</u>

Greenville
<u>GELQ- GREENVILLE ELECTRIC QUALIFIED</u>
<u>GCLC- GREENVILLE CAPITAL CONSTR.</u>
<u>GHLP- GREENVILLE HELPERS</u>
<u>GHLC- GREENVILLE CAPITAL HELPERS</u>
<u>GFLG- GREENVILLE FLAGGERS</u>
<u>GCFL- GREENVILLE CAPITAL FLAGGERS</u>
<u>GSNO- GREENVILLE SNOW PLOW</u>

Tannersville
<u>TELQ- TANNERSVILLE ELECTRIC QUALIFIED</u>
<u>THLP- TANNERSVILLE HELPERS</u>
<u>TCLC- TANNERSVILLE CAPITAL CONSTR.</u>
<u>THLC- TANNERSVILLE CAPITAL HELPERS</u>
<u>TFLG- TANNERSVILLE FLAGGERS</u>
<u>TCFL- TANNERSVILLE CAPITAL FLAGGERS</u>

Kingston
<u>KCOM- KINGSTON COMMERCIAL</u>
<u>KELO- KINGSTON ELECTRIC QUALIFIED</u>
<u>KFRM- KINGSTON FOREMEN</u>
<u>KGSC- KINGSTON GAS CHIEFS</u>
<u>KGSM- KINGSTON GAS MECHANICS</u>
<u>KSPL- KINGSTON SPLICERS</u>
<u>KHLP- KINGSTON HELPERS</u>
<u>KFLG- KINGSTON FLAGGERS</u>
<u>KSTR - KINGSTON STOREKEEPER</u>
<u>KCLC -KINGSTON LINE CLEARANCE</u>
<u>KTST- KINGSTON TESTERS</u>
<u>MHLP- METER TESTER HELPERS</u>
<u>KGAR- KINGSTON GARAGE MECH.</u>
<u>KNGH - KINGSTON GARAGE HELPERS</u>
<u>KCLC- KINGSTON CAPITAL CONSTR.</u>
<u>KCMR- KINGSTON COLLECTOR/ MTR READER</u>
<u>KCFL- KINGSTON CAPITAL FLAGGERS</u>
<u>KHLC- KINGSTON CAPITAL HELPERS</u>
<u>MSTK- METER SHOP STOCK HANDLER</u>
<u>KCLK- KINGSTON CLERICAL</u>
<u>KEST- KINGSTON ESTIMATING</u>
<u>Kingston/Ellenville Line Supervision</u>
<u>KGSF- SAFETY ADVOCATE GAS OPERATIONS</u>
<u>KBGM- KINGSTON PRIMARY MAINTENANCE</u>
<u>KMTH- KINGSTON MAINTENANCE HELPER</u>
<u>PBGH- POUGHKEEPSIE BUILDING AND GROUNDS HELPER</u>
<u>KTCC - KINGSTON TRANSMISSION CONSTRUCTION CREW</u>
<u>KTCH - KINGSTON TRANSMISSION CONSTRUCTION HELPERS</u>
<u>ETRN - Electric T&D Trainer</u>
<u>SUPERVISOR - KINGSTON OUTAGE RESPONDER</u>
<u>SUPERVISOR - TRANSPORTATION</u>
<u>SUPERVISOR - KINGSTON STOREROOM</u>
<u>SUPERVISOR UPPER HUDSON GAS SYSTEM T&D RESPONDER</u>
<u>SUPERVISOR UPPER HUDSON GAS ODOR FIRST RESPONDER</u>
<u>All Testers</u>
<u>SUPERVISOR - KINGSTON TRIMMING RESPONDER</u>
<u>SUPERVISOR - KINGSTON OUTAGE PATROLLER</u>
<u>SUPERVISOR - KINGSTON NETWORK RESPONDER</u>
<u>SUPERVISOR - KINGSTON QUALIFIED LINE WORKER</u>

Ellenville
<u>ECOM- ELLENVILLE COMMERCIAL</u>

Ellenville (continued)
<u>EELQ- ELLENVILLE ELECTRIC QUALIFIED</u>
<u>Line Group 1</u>
<u>Line Group 2</u>
<u>EFRM- ELLENVILLE FOREMEN</u>
<u>EQCC-ELLENVILLE CAPITAL CONSTR.</u>
<u>EHLP- ELLENVILLE HELPERS</u>
<u>EHCC-ELLENVILLE CAPITAL HELPERS</u>
<u>ESTR- ELLENVILLE STOREKEEPERS</u>
<u>EFLG- ELLENVILLE FLAGGERS</u>
<u>ECFL- ELLENVILLE CAPITAL FLAGGERS</u>
<u>ECMR- ELLENVILLE MTR READER/ COLLECTOR</u>

Poughkeepsie
<u>PCOM- POK COMMERCIAL</u>
<u>PELQ- POK ELECTRIC QUALIFIED</u>
<u>PFRM- POUGHKEEPSIE FOREMEN</u>
<u>PGSC- POK GAS CHIEFS</u>
<u>PGSM- POK GAS MECHANICS</u>
<u>PSTR - POUGHKEEPSIE STOREKEEPER</u>
<u>PHLP- POK HELPERS</u>
<u>PFLG-POUGHKEEPSIE FLAGGERS</u>
<u>PSPL- POK SPLICERS</u>
<u>PCLC- POK CAPITAL CONSTR.</u>
<u>PHLC- POK CAPITAL HELPERS</u>
<u>PCFL-POUGHKEEPSIE CAPITAL FLAGGERS</u>
<u>PCMR- POK COLLECTOR/ MTR READER</u>
<u>PGAR- POK GARAGE</u>
<u>PKGh- POK GARAGE HELPERS</u>
<u>PTST- POK TESTER</u>
<u>PEST- POK ESTIMATING</u>
<u>PCLK- POK CLERICAL</u>
<u>PBGM- POUGHKEEPSIE PRIMARY MAINTENANCE</u>
<u>PMTH- POUGHKEEPSIE MAINTENANCE HELPER</u>
<u>PBGH- POUGHKEEPSIE BUIDLING AND GRONDS HELPER</u>
<u>Poughkeepsie Line Supervision</u>
<u>PSAF-Safety Advocate-Electric T&D/Op Services</u>
<u>Electric System Design</u>
<u>SUPERVISOR - POUGHKEEPSIE OUTAGE RESPONDER</u>
<u>SUPERVISOR - POUGHKEEPSIE STOREROOM</u>
<u>SUPERVISOR MID-HUDSON GAS SYSTEM T&D RESPONDER</u>
<u>SUPERVISOR MID-HUDSON GAS ODOR FIRST RESPONDER</u>
<u>SUPERVISOR - POUGHKEEPSIE OUTAGE PATROLLER</u>

Poughkeepsie (continued)
<u>SUPERVISOR - POUGHKEEPSIE TRIMMING RESPONDER</u>
<u>SUPERVISOR - POUGHKEEPSIE NETWORK RESPONDER</u>
<u>SUPERVISOR - POUGHKEEPSIE QUALIFIED LINE WORKER</u>

Stanfordville
<u>SCOM- STANF. COMMERCIAL</u>
<u>SELQ- STANF. ELECTRIC QUALIFIED</u>
<u>SFRM- STANFORDVILLE FOREMEN</u>
<u>SCLC- STANF. CAPITAL CONSTR.</u>
<u>SHLP- STANF. HELPERS</u>
<u>SHLC- STANF. CAPITAL HELPERS</u>
<u>SSTR- STANF. STOREKEEPERS</u>
<u>SFLG- STANFORDVILLE FLAGGERS</u>
<u>SCFL- STANFORDVILLE CAPITAL FLAGGERS</u>
<u>Line Group 1</u>
<u>Line Group 2</u>
<u>Line Group 3 (PC)</u>

South Road
<u>DRFT - DRAFTERS</u>
<u>MGMT Wire Guard A</u>
<u>COMPUTER ROOM GROUP</u>

Fishkill
<u>FCOM- FISHKILL COMMERCIAL</u>
<u>WFDR- WAPPINGERS FALLS DISTRICT REP</u>
<u>BCDR - BEACON DISTRICT REP</u>
<u>EFDR - EAST FISHKILL DISTRICT REP</u>
<u>FELQ- FISHKILL ELECTRIC QUALIFIED</u>
<u>FFRM- FISHKILL FOREMEN</u>
<u>FGSC- FISHKILL GAS CHIEFS</u>
<u>FGSM- FISHKILL GAS MECHANICS</u>
<u>FSPL-FISHKILL SPLICERS</u>
<u>FSTR - FISHKILL STOREKEEPER</u>
<u>FHLP- FISHKILL HELPERS</u>
<u>FFLG-FISHKILL FLAGGERS</u>
<u>FCLC- FISHKILL CAPITAL CONSTR.</u>
<u>FHLC- FISHKILL CAPITAL HELPERS</u>
<u>FGAR- FISHKILL GARAGE</u>
<u>FCMR- FISHKILL COLLECTOR/ MTR READER</u>
<u>FCLK- FISHKILL CLERICAL</u>
<u>FTST- FISHKILL TESTER</u>

Fishkill (continued)
<u>FEST- FISHKILL ESTIMATING</u>
<u>FCFL-FISHKILL CAPITAL FLAGGERS</u>
<u>Fishkill Line Supervision</u>
<u>FBGM- FISHKILL PRIMARY MAINTENANCE</u>
<u>FMTH- FISHKILL MAINTENANCE HELPER</u>
<u>SUPERVISOR - FISHKILL QUALIFIED LINE WORKER</u>
<u>SUPERVISOR - FISHKILL TRIMMING RESPONDER</u>
<u>SUPERVISOR - FISHKILL STOREROOM</u>
<u>SUPERVISOR - FISHKILL OUTAGE RESPONDER</u>
<u>SUPERVISOR - FISHKILL OUTAGE PATROLLER</u>

Mahopac
<u>MCOM- MAHOPAC COMMERCIAL</u>
<u>CARMEL MAHOPAC SOC RESPONDERS - GAS ONLY</u>

Newburgh
<u>NCOM - NEWBURGH COMMERCIAL</u>
<u>NCMS - NBG COMMERCIAL SOUTH</u>
<u>CNDR - CORNWALL DISTRICT REP</u>
<u>MGDR - MONTGOMERY DISTRICT REP</u>
<u>XCMS- ELTINGS CRNRS COMMERCIAL</u>
<u>NELQ- NEWBURGH ELECTRIC QUALIFIED</u>
<u>NFRM- NEWBURGH FOREMEN</u>
<u>NGSC- NEWBURGH GAS CHIEFS</u>
<u>NGSM- NEWBURGH GAS MECHANICS</u>
<u>NSPL- NEWBURGH SPLICERS</u>
<u>NHLP- NEWBURGH HELPERS</u>
<u>NFLG-NEWBURGH FLAGGERS</u>
<u>NBLC - NEWBURGH LINE CLEARANCE</u>
<u>NGAR- NEWBURGH GARAGE MECH.</u>
<u>NSTR - NEWBURGH STOREKEEPER</u>
<u>NTST- NEWBURGH TESTER</u>
<u>NCMR- NEWBURGH COLLECTOR/ MTR READER</u>
<u>NCLC- NEWBURGH CAPITAL CONSTR.</u>
<u>NHLC- NEWBURGH CAPITAL HELPERS</u>
<u>NCFL-NEWBURGH CAPITAL FLAGGERS</u>
<u>NCLK- NEWBURGH CLERICAL</u>
<u>NEST- NEWBURGH ESTIMATING</u>
<u>Newburgh Line Supervision</u>
<u>NBGM- NEWBURGH PRIMARY MAINTENANCE</u>
<u>NMTH- NEWBURGH MAINTENANCE HELPER</u>
<u>SUPERVISOR - NEWBURGH OUTAGE RESPONDER</u>

Newburgh (continued)
<u>SUPERVISOR - NEWBURGH STOREROOM</u>
<u>SUPERVISOR LOWER-HUDSON GAS SYSTEM T&D RESPONDER</u>
<u>SUPERVISOR LOWER HUDSON GAS ODOR FIRST RESPONDER</u>
<u>SUPERVISOR - NEWBURGH QUALIFIED LINE WORKER</u>
<u>SUPERVISOR - NEWBURGH OUTAGE PATROLLER</u>
<u>SUPERVISOR - NEWBURGH TRIMMING RESPONDER</u>
<u>SUPERVISOR - NEWBURGH NETWORK RESPONDER</u>

Eltings Corners
<u>XELQ- EC ELECTRIC QUALIFIED</u>
<u>XFRM- ELTINGS CORNERS FOREMEN</u>
<u>XHLP- EC HELPERS</u>
<u>XCLC- EC CAPITAL CONSTR.</u>
<u>XHLC- EC CAPITAL HELPERS</u>
<u>XSPL - EC SPLICERS</u>
<u>XSTR - EC STOREKEEPER</u>
<u>XFLG-ELTINGS CRNRS FLAGGERS</u>
<u>XCFL-ELTINGS CRNRS CAPITAL FLAGGERS</u>
<u>XEST - Eltings Corners Estimating</u>
<u>XCST- ELTING CRNS TESTERS</u>
<u>Line Group 1</u>
<u>Line Group 2</u>

EC Garage / Storeroom
<u>XSTR- EC MAIN STOREROOM</u>
<u>XCSK- EC CAPITAL STOREKEEPER</u>
<u>ELTR- EC GARAGE MECHANICS</u>
<u>ECPK- EC AUTO PARTSKEEPER</u>
<u>XSNR- EC SNOW REMOVAL</u>
<u>ESRH- EC SNOW REMOVAL- HELPERS</u>
<u>XSNO- EC SNOW SHOVEL</u>
<u>SUPERVISOR - ELTINGS CORNERS STOREROOM</u>

New Paltz
<u>XCOM- NEW PALTZ COMMERCIAL</u>

Upper Hudson
<u>KGNE- KINGSTON ELECTRICIANS</u>
<u>UPPER-HUDSON I&C/RELAY TECHNICIANS</u>
<u>KNEH - KNG ELECTRICIAN HELPERS</u>
<u>Ops Elec Group 2</u>
<u>Ops Elec Group 1</u>

Upper Hudson (continued)
<u>Relay Tech Group 1</u>
<u>SUPERVISOR - UPPER HUDSON SUBSTATIONS</u>

Mid Hudson
<u>POKE- POK ELECTRICIANS</u>
<u>PKEH- POK ELECTRICIAN HELPERS</u>
<u>MID-HUDSON I&C/RELAY TECHNICIANS</u>
<u>MID-HUDSON I&C/RELAY TECH HELPERS</u>
<u>Ops Elec Group 1</u>
<u>Ops Elec Group 2</u>
<u>Ops Relay Tech</u>
<u>SUPERVISOR - MID HUDSON SUBSTATIONS</u>

Lower Hudson
<u>NBGE- NEWBURGH ELECTRICIANS</u>
<u>LOWER-HUDSON I&C/RELAY TECHNICIANS</u>
<u>NBEH- NBG ELECTRICIAN HELPERS</u>
<u>OSFC - OPERATIONS SVCS SUBSTATION FIELD CLRK</u>
<u>ECRG-EC RIGGERS</u>
<u>ECCM- EC CONSTRUCTION MAINTENANCE</u>
<u>Ops Elec Group 1</u>
<u>Ops Elec Group 2</u>
<u>Ops Relay Tech</u>
<u>Riggers Crew A</u>
<u>Riggers Crew B</u>
<u>Construction Maint</u>
<u>SUPERVISOR - LOWER HUDSON SUBSTATIONS</u>

Hydro/GT
<u>RVMO- ROVING MECH. OPERATORS</u>
<u>ECHH- EC HYDRO HELPERS</u>
<u>SUPERVISOR - PRODUCTION & RIGGING</u>

Communications
<u>SUPERVISOR - RELAYS AND COMM</u>

Storm Crews
<u>UHDISP - UPPER HUDSON DISPATCHER</u>
<u>MHDISP - MID HUDSON DISPATCHER</u>
<u>LHDISP - LOWER HUDSON DISPATCHER</u>
<u>UWRC - UPPER HUDSON WIRE DOWN COORDINATOR</u>
<u>AUWRC - ALT UPPER HUDSON WIRE DOWN COORDINATOR</u>

Storm Crews (continued)
<u>MWRC - MID HUDSON WIRE DOWN COORDINATOR</u>
<u>AMWRC - ALT MID HUDSON WIRE DOWN COORDINATOR</u>
<u>LWRC - LOWER HUDSON WIRE DOWN COORDINATOR</u>
<u>ALWRC - ALT LOWER HUDSON WIRE DOWN COORDINATOR</u>
<u>CWRR - CATSKILL WIRE RESPONDERS</u>
<u>CWRG - CATSKILL WIRE GUARDS</u>
<u>KWRR - KINGSTON WIRE RESPONDERS</u>
<u>KWRG - KINGSTON WIRE GUARDS</u>
<u>PWRR - POUGHKEEPSIE WIRE RESPONDERS</u>
<u>PWRG - POUGHKEEPSIE WIRE GUARDS</u>
<u>FWRR - FISHKILL WIRE RESPONDERS</u>
<u>FWRG - FISHKILL WIRE GUARDS</u>
<u>NWRR - NEWBURGH WIRE RESPONDERS</u>
<u>NWRG - NEWBURGH WIRE GUARDS</u>
<u>UHLC - UPPER HUDSON LOOP CREWS</u>
<u>PKLC- POUGHKEEPSIE LOOP CREWS</u>
<u>FHLC- FISHKILL LOOP CREWS</u>
<u>NBLC- NEWBURGH LOOP CREWS</u>
<u>KCDAC - UPPER HUDSON DAMAGE ASSESSMENT COORDINATOR</u>
<u>KCDAP - UPPER HUDSON DAMAGE ASSESSMENT PATROLLERS</u>
<u>PDAC - POUGHKEEPSIE DAMAGE ASSESSMENT COORDINATOR</u>
<u>PDAP - POUGHKEEPSIE DAMAGE ASSESSMENT PATROLLERS</u>
<u>FDAC - FISHKILL DAMAGE ASSESSMENT COORDINATOR</u>
<u>FDAP - FISHKILL DAMAGE ASSESSMENT PATROLLERS</u>
<u>NDAC - NEWBURGH DAMAGE ASSESSMENT COORDINATOR</u>
<u>NDAP - NEWBURGH DAMAGE ASSESSMENT PATROLLERS</u>
<u>CRWP - PRIMARY CREW GUIDES</u>
<u>CRWS - SUPPORT CREW GUIDES</u>
<u>Storm Electric Mass Callout</u>
<u>WGSMA - SUPPORT WIRE GUARD- MGMT A</u>
<u>Supplemental - Wire Guard - MGMT A</u>
<u>CSAF- Safety Advocate List</u>

Notifications
<u>ALL - ALL EMPLOYEES</u>
<u>CEMP - All Catskill Employees</u>
<u>GEMP - All Greenville Employees</u>
<u>TEMP - All Tannersville Employees</u>
<u>KEMP - All Kingston Employees</u>
<u>EEMP - All Ellenville Employees</u>
<u>HEMP - All Sturgeon Pool Employees</u>
<u>PEMP - All Poughkeepsie Employees</u>

Notifications (continued)
<u>SEMP - All Stanfordville Employees</u>
<u>FEMP - All Fishkill Employees</u>
<u>NEMP - All Newburgh Employees</u>
<u>XEMP - All Eltings Corners Employees</u>
<u>MGMT - All Management Employees</u>

Mutual Aid
<u>SKMA-STOREKEEPER MUTUAL AID</u>
<u>TRMA - TRANSPORTATION MUTUAL AID</u>
<u>CCMA - CATSKILL COMMERCIAL MUTUAL AID</u>
<u>KCMA - KINGSTON COMMERCIAL MUTUAL AID</u>
<u>PCMA - POUGHKEEPSIE COMMERCIAL MUTUAL AID</u>
<u>FCMA - FISHKILL COMMERCIAL MUTUAL AID</u>
<u>NCMA - NEWBURGH COMMERCIAL MUTUAL AID</u>

System Operations
<u>TO/ATO - TRANSMISSION OPERATOR</u>
<u>CTO - CHIEF TRANSMISSION OPERATOR</u>
<u>SOC - SYSTEM OPERATIONS COORDINATOR</u>
<u>SUPERVISOR - SYSTEM OPERATIONS</u>
<u>SO/ASO - SYSTEM OPERATORS</u>
<u>CSO - CHIEF SYSTEM OPERATORS</u>

Dispatch Operations
<u>DD/ADD - DISTRIBUTION DISPATCHERS</u>
<u>SUPERVISOR - DISPATCH OPERATIONS</u>
<u>ESR- EMERGENCY SERVICE REP</u>
<u>DO/ADO - DISTRIBUTION OPERATOR</u>

Call Center
<u>PCSR- POK CUSTOMER SERVICE REPS</u>
<u>New Hire CSR Helper</u>
<u>PCSA- POK Customer Support Assistant</u>
<u>CCPT- CALL CENTER PART TIME LIST</u>
<u>Call Center Management</u>
<u>CLRK - ALL CLERICAL ASSISTANTS</u>
<u>Supplemental CSR Storm Duty</u>
<u>Supplemental Mgt Storm Duty</u>
<u>Collections (No Callout)</u>
<u>All Meter Reader Workgroup</u>
<u>EH CSR</u>
<u>Day CSR</u>

Call Center (continued)
<u>Part Time</u>
<u>Call Center</u>
<u>CCTR- CONTROL CENTER TELEPHONE REPS</u>
<u>SUPERVISOR - CALL CENTER BACKUP</u>

Appendix removed from external copy to protect private information.

STORM RESPONSE MATERIALS LIST

APPENDIX O

Items maintained in the Storm Storeroom (Storeroom 06)

STOCK CD	DESCRIPTION	UNIT OF MEASURE	ON HAND QUANTITY	LOCATION
3105025	BRACE,X-ARM WOOD 26 IN.	PC	200	BOX-009
3105032	BRACE, X-ARM WOOD 60IN, 18 IN. DROP	PR	25	BOX-009
3007080	CLAMP DEADEND STRAIGHT LINE 4-	PC	500	BOX-011
3007104	GRIP DE PRESH 34 GRN 15KV 1/0A	PC	25	BOX-006
3007105	GRIP DE PRESH 42 YEL 15KV 336A	PC	25	BOX-006
3007106	GRIP DE.SVC CABLE PRESH.1/0ACS	PC	100	BOX-006
3007115	GRIP DE PRESH 30 BLACK 5/16 ST	PC	100	BOX-006
3007118	CLAMP HOT LINE 6-400CU RUN	PC	300	BOX-018
3007121	GRIP DE PRESH 39 ORNGE 3/8 ST	PC	200	BOX-006
3007131	CLAMP SUSP. ANGLE AL .16-.73	PC	25	BOX-006
3007174	CLAMP HOT LINE 6-397AL RUN	PC	300	BOX-005
3010141	BLADE SOLID 300A F/7.2/14.	PC	24	BOX-018
3010152	CUTOUT OPEN 7.2/14.4 KV W/O DO	PC	108	BOX-012
3010154	TUBE FUSE 100A EHD F/7.2/14.	PC	102	BOX-017
3014315	LINK FUSE UNIVERSAL 10K	PC	300	BOX-003
3014324	LINK FUSE UNIVERSAL 65K	PC	500	BOX-003
3014326	LINK FUSE UNIVERSAL 100K	PC	500	BOX-018
3014327	LINK FUSE UNIVERSAL 140K	PC	500	BOX-003
3014328	LINK FUSE UNIVERSAL 200K	PC	102	BOX-018
3014338	LINK FUSE UNIVERSAL 6K	PC	300	BOX-003
3014339	LINK FUSE UNIVERSAL 15K	PC	600	BOX-003
3014340	LINK FUSE UNIVERSAL 25K	PC	500	BOX-003
3014341	LINK FUSE UNIVERSAL 40K	PC	1,100	BOX-003
3023107	INSUL SUSP 4-1/4" 10000#	PC	96	BOX-009
3023146	INSUL D.E. 15KV 10000# G	PC	300	BOX-013
3026054	ARRESTER DIST STD MTG 10KV MO	PC	90	BOX-010
3030045	PIN INSUL 1" THD 20" LONG PO	PC	100	BOX-008
3038011	ROPE POLY - 7/16"	FT	1,200	BOX-014
3038012	ROPE POLY - 5/8"	FT	1,200	BOX-014
3038013	ROPE POLY - 3/8"	FT	1,200	BOX-014
3040041	SPLICE AUTO FT #6 SOL - #8 ST	PC	3,000	BOX-016
3040042	SPLICE AUTO FT #4 SOL - #6 ST	PC	2,500	BOX-017
3040043	SPLICE AUTO FT #1 SOL - #2 ST	PC	1,000	BOX-016
3040044	SPLICE AUTO FT 2/0 SOL - 1/0	PC	200	BOX-018
3040100	SPLICE AUTO FT 336-397 AA & 3	PC	600	BOX-020
3040120	SPLICE AUTO FT 1/0 ASCR	PC	500	BOX-016
3040121	SPLICE AUTO FT 3/0 & 4/0 ACSR	PC	500	BOX-004
3040146	SPLICE AUTO FT #2 - #4 ACSR	PC	3,000	BOX-015
3050009	WIRE CU WR 6 HD SOLID	LB	1,500	BLDG
3050010	WIRE CU WR 4 HD SOLID	LB	2,106	BLDG
3050153	WIRE AA BARE 4 SOLID SOFT DRA	LB	1,000	BLDG
3050156	WIRE CU-BARE 6 SD SOLID	LB	2,000	BLDG
3050157	WIRE CU BARE 4 SD SOLID	LB	2,000	BLDG
3050159	WIRE STL BARE 3/8 EHS GALV 15	FT	8,000	BLDG
3050170	WIRE CU WR 4 SD SOLID	LB	2,030	BLDG
3066020	STORM KIT, F/ CONTRACTOR/MUTUAL AID USE	BX	50	BLDG
3066311	CLAMP DEADEND AUTO 6 SOL CU	PC	300	BOX-018
3066312	CLAMP DEADEND AUTO 4 SOL CU	PC	200	BOX-018
3066313	CLAMP DEADEND AUTO 2 STR CU	PC	25	BOX-006
3104013	BOLT MACHINE 5/8 X 12	PC	1,000	BOX-001
3104023	BOLT DOUBLE ARMING 5/8 X 18	PC	200	BOX-001
3105024	BRACE X-ARM STEEL 26 IN.	PC	200	BOX-010
3105025	BRACE X-ARM WOOD 26 IN.	PC	200	BOX-009

STORM RESPONSE MATERIALS LIST

APPENDIX O

3107180	GRIP DE.SVC CABLE PRESH. #2AAA	PC	1,400	BOX-018
3109132	CONN ALL PURPOSE 8CU - 4	PC	500	BOX-005
3109134	CONN ALL PURPOSE 6CU - 1/0	PC	2,000	BOX-005
3109135	CONN ALL PURPOSE 6CU - 336	PC	200	BOX-016
3109136	CONN ALL PURPOSE 2 - 4/0	PC	150	BOX-005
3109172	CONN VISE 1 SOL - 2 STR CU	PC	250	BOX-005
3123136	INSUL SPOOL RACK TYPE ANSI 53	PC	200	BOX-008
3130058	PIN INSUL 1" THD 6" PIN 5-3/4	PC	300	BOX-017
3135007	RACK SEC 1PT W/O SPOOL	PC	200	BOX-008
3145037	TAPE VINYL 3/4" X 66'	RO	300	BOX-001
3149027	TAPE VINYL 3/4" X 66'	PC	1,000	BOX-014
6506066	FLARE RED	PC	288	BOX-002
6507168	GLOVE LEATHER WORK SHORT CUFF	PR	144	BOX-007
6507169	GLOVE LEATHER WORK SHORT CUFF	PR	144	BOX-002
6507170	GLOVE LEATHER WORK LONG CUFF	PR	144	BOX-007
6507171	GLOVE LEATHER WORK LONG CUFF	PR	80	BOX-007
6507233	GLOVE COTTON STRING KNIT LIN	PR	144	BOX-002
6512116	LIGHT, TROUBLE RECHARGABLE	PC	12	BOX-002
6515010	OIL ENGINE TWO CYCLE - POWER C	CN	36	BOX-014
6515011	OIL BAR & CHAIN - POWER C	QT	24	BOX-014
6516187	PROTECTOR SIZE 11 LEATHER	PR	12	BOX-002
6516188	PROTECTOR SIZE 12 LEATHER	PR	12	BOX-002
6516189	PROTECTOR SIZE 10 LEATHER	PR	6	BOX-002
6516202	PROTECTOR SIZE 13 LEATHER	PR	12	BOX-002
6519304	RAINSUIT JACKET HI-VIS X-	PC	20	BOX-014
6519305	RAINSUIT JACKET HI-VIS XX-	PC	20	BOX-014
6519309	RAINSUIT PANTS HI-VIS X-L	PC	41	BOX-014
6519310	RAINSUIT PANTS HI-VIS XX-L	PC	20	BOX-014
6519310	RAINSUIT PANTS HI-VIS XX-L	PC	20	BOX-014

Critical Inventory Items Maintained in the Main Storeroom

STOCK CD	DESCRIPTION	UNIT OF MEASURE	REORDER POINT	LOCATION
3001107	ANCHOR,SCREW, SINGLE 10" HELIX 14000#	PC	800	2-G15/17AE
3007118	CLAMP,HOT LINE 6-400CU RUN 6-4/0CU T	PC	900	2-J35D
3007192	CONN WEDGE 336AL RUN, 4/0CU TAP	PC	400	2-J44G
3007195	CONN WEDGE 336AL RUN, 336AL TAP	PC	105	1-B32L
3007196	CONN WEDGE STIRRUP 336 RUN 2/0 CU BAIL	PC	375	2-H18/20D
3007217	CLAMP,HOT LINE 8-2/0CU RUN 8-2/0CU T	PC	200	2-K22D
3023117	INSUL, GUY,FIBERGLASS, 36" LENGTH	PC	400	3-S53AEJ
3023142	INSUL, VISETOP, 15KV,POLY,WR AL&BARE C	PC	1,800	2-G25AEJ
3023155	INSUL, GUY,FIBERGLASS,78"LG.,HEAVY DUTY	PC	8	3-V42/44A
3028001	MOLDING PLASTIC U 1/2 X 1/2 ID	FT	14,000	3-S47A
3029029	NUT, TRIPLE THIMBLE EYE F/1" THRD RODS	PC	1,000	2-H22/24A
3037002	ROD, GROUND SINGLE 5/8"X 8' F/DISTRIBUTI	PC	600	3-V48/50A
3037100	CLAMP, GROUND ROD 5/8" F/#8 & 1/0	PC	900	1-D16D
3037141	ROD, F/SCREW ANCHORS 1"X 7'	PC	500	3-T21/23A
3066019	STORM KIT, MANGEMENT WIRE GUARD MATL	KT	30	DOCK
3104003	BOLT, MACHINE 1/2 X 6	PC	1,400	2-G46E
3104014	BOLT, MACHINE 5/8 X 14	PC	3,600	2-K10/16A
3104016	BOLT, MACHINE 5/8 X 16	PC	750	2-K26A
3104024	BOLT, DOUBLE ARMING 5/8 X 20	PC	700	2-K44A
3104025	BOLT, DOUBLE ARMING 5/8 X 22	PC	250	2-H15E
3105032	BRACE, X-ARM WOOD 60IN, 18 IN. DROP	PR	400	2-G43/45 A
3107201	CARTRIDGE YELLOW BURNDY	BX	50	1-D19H
3107202	CARTRIDGE BLUE BURNDY	BX	25	1-E21I

STORM RESPONSE MATERIALS LIST**APPENDIX O**

3107203	CARTRIDGE RED BURNDY	BX	8	1-A10E
3123131	INSUL, PIN TOP GROOVE 15KV POLYMER	PC	1,480	2-H30-36A
3149018	SHER, ROUND FLAT 1/2"ID X 1-3/8"OD	PC	2,500	1-D34G
3149024	WASHER, SQ CURVED 3/4", 3-1/4"SQ	PC	2,500	2-H06/08D
3149027	WASHER, SQ FLAT 5/8, 2-1/4"	PC	10,000	2-J25/27D
3166338	STAPLE, GALV 1-3/4 X 3/8 X .148"	PC	10,000	1-E10D
3513163	TUBING 1/2" PLASTIC 120# 5	FT	28,000	6-PIPE05

DRAFT EMERGENCY RESPONSE PERFORMANCE MEASURES

PREPARATION (10% of Total)

Area of Interest	Definition of Measure	Measurement Criteria	Points
1. Event Anticipation	Complete steps to provide timely and accurate emergency event preparation in response to the NWS or the company's private weather service, in accordance with the company's PSC approved Electric Emergency Plan, for an event expected to impact the company's service territory.	1.1 Employees/Contractors planning	15
		1.2 Press Releases issued / text messages / emails sent	15
		1.3 Municipal Conference Calls held and highly effective	20
		----- Municipal Conference Calls held and effective	10
		1.4 LSE customers alerted	15
		1.5 Point of contact for Critical Facilities alerted	15
		1.6 Company compliance with Training Program as specified in Commission Approved Emergency Plan	15
		1.7 Participation in all pre-event mutual assistance group calls	15
		1.8 Verify Materials / Stockpiles level based on forecast. If materials are not on hand, correct situation within 24 hours	40

TOTAL 150

STORM SCORECARD

APPENDIX P

CASE 13-E-0140

OPERATIONAL RESPONSE (60% of Total)

Area of Interest	Definition of Measure	Measurement Criteria	Points
2. Down Wires	Response to downed wires reported by Municipal Emergency Official.	< 18 hours (3-5 day restoration) < 36 hours (> 5 day restoration)	60
3. Preliminary Damage Assessment	Completion of preliminary damage assessment	< 24 hours from start of restoration	30
4. Crewing	80% of the forecast crewing committed to the utility	< 48 hours from the start of restoration	30
5. Estimated Time of Restoration (Made available by utility on web, IVR, to CSR's, etc)	Publication of Global ETR in accordance with ETR Protocol	Exceeds expectation: < 24 hrs (3-5 day restoration) < 36 hrs (> 5 day restoration)	50
		Meets expectation: < 36 hrs (3-5 day restoration) < 48 hrs (> 5 day restoration)	30
	Publication of Regional/County ETRs in accordance with ETR Protocol	Exceeds expectation: < 24 hrs (regions with 3-5 day restoration) < 36 hrs (regions with > 5 day restoration)	50
		Meets expectation: < 36 hrs (regions with 3-5 day restoration) < 48 hrs (regions with > 5 day restoration)	30
	Publication of Local/ Municipal ETRs in accordance with ETR Protocol	Exceeds expectation: < 36 hrs (3-5 day restoration) < 48 hrs (> 5 day restoration)	50
		Meets expectation: < 48 hrs (3-5 day restoration) < 72 hrs (> 5 day restoration)	30

STORM SCORECARD

APPENDIX P

CASE 13-E-0140

OPERATIONAL RESPONSE (continued)

Area of Interest	Definition of Measure	Measurement Criteria	Points
6. ETR Accuracy	Global ETR accuracy as published in accordance with ETR requirement time	Accurate within +/- 24 hours	40
	Regional ETR accuracy as published in accordance with ETR requirement time	Accurate within +/- 12 hours (3-5 day restoration) Accurate within +/- 24 hours (> 5 day restoration)-	40
	Local ETR accuracy as published in accordance with ETR requirement time	Accurate within +/- 12 hours	40
7. Municipality Coordination	Coordination w/ Municipalities regarding hazards or electric utility equipment impeding road clearing, down wires, critical facilities, etc.	Execution of Coordination Protocols pursuant to Commission Approved Emergency Plan	20
8. County EOC Coordination	Coordination with County EOCs	Execution of Coordination Protocols pursuant to Commission Approved Emergency Plan	20
9. Utility Coordination	Electric Utility Coordination with other Utilities (Electric, gas, communications, water)	Execution of Coordination Protocols pursuant to Commission Approved Emergency Plan	20
10. Safety	Measure of any employee or contractor serious injury doing hazard work during storm/ outage and restoration.	Zero injuries	80
11. Mutual Assistance	Crew requests made through all sources of mutual assistance	Crew requests made within: 36 hrs (3-5 day restoration) 48 hrs (> 5 day restoration)	20
12. Restoration Times	Time it takes utility to restore power to 90% of customers affected	TBD	---

TOTAL 550

COMMUNICATION (30% of Total)

Area of Interest	Definition of Measure	Method of Measurement Criteria	Points
13. Call Answer Rates	Customer calls answered by properly staffing call centers	90%+ calls answered within 90 sec.	30
		80% to <90% calls answered within 90 sec.	20
14. Municipal Calls	Municipal call must be properly managed and provide, at minimum, baseline information, updates on road clearing activities, and allow for Q&A.	Municipal calls held and highly effective	30
		Municipal calls held and effective	20
		Successful implementation of an operator assisted calling system	10
15. Web Availability	Company's web site must be available around the clock, and must be updated at least hourly, until restoration is complete.	Websites should include the baseline restoration information, all press releases issued during the event, a complete list of safety tips, an outage location map of affected areas, summaries of outages and ETRs by municipality and county, and the locations and times of dry ice distribution.	40
16. LSE Customers	LSE customer contact	80% affected LSE customers contacted within 12 hours	15
		LSE customers that were unable to be contacted had at least two attempts made within 12 hours	15
		100% affected LSE customers contacted or referred to an emergency services agency within 24 hours	20

STORM SCORECARD

APPENDIX P

CASE 13-E-0140

COMMUNICATION (continued)

17. PSC Reporting	Provide storm event information to PSC in accordance with Electric Outage Reporting System (EORS) guideline requirements	All reporting on time, including at a minimum information required by existing EORS guidelines	40
18. Customer Communications	Press releases / text messaging / email / social media	Issue daily messages through the stated communications vehicles for each day of the utility restoration which must include information such as outages, ETRs, contact information, etc.)	60
19. Outgoing message on telephone line	Recorded message providing callers with outage information is updated within one hour of communication releases.	Message must be updated within an hour of communication releases that is consistent and coincides with the information contained in news releases	20
20. PSC Complaints	Number of storm/outage related PSC complaints received	≤ 20 per 100,000 customers affected	20
		----- ≤ 40 per 100,000 customers affected	10

TOTAL 300

2025 Outreach & Education Plan with 2024 Results NATURAL GAS/ELECTRIC SAFETY

New/Continuing Program:

Central Hudson offers educational resources about the safe use of electricity and natural gas to its customers, community organizations and local governments.

Safety information is included periodically in e-newsletters sent to customers for whom we have valid email (about 184,000 email addresses on file). Central Hudson's website offers on-line resources for both electric and natural gas safety. Also, bill inserts/onserts are sent for both electric and natural gas safety. Radio and social media messages also include natural gas and electric safety messages.

Electric Safety Education

Central Hudson educates the public on the potential hazards of electricity, and how to safely respond to electrical emergencies. Safety-related communications are continually issued via news releases, blast emails to customers, newsletters to elected officials and community stakeholders, paid radio spots and safety tips are posted on the website and social media (Facebook and X).

In addition to these public communications, Central Hudson offers training to police, fire, and other first responders on electrical and natural gas safety. The training program covers how to respond to wires down on vehicles, approaching electrical hazards, maintaining safe distances from downed wires (and how to address gas emergencies). In 2017, Central Hudson added a first responder portal to the website, covering online training for responding to downed wires and other emergencies.

Safety information is also included in all news releases and communications during storm or storm warnings and shared with elected and municipal officials.

Safety videos on storm preparation and downed wires were developed, recorded and promoted on social media and via direct emails to customers, and used in conjunction with storm messaging. These videos also reside on our YouTube channel.

Gas Safety Education

Central Hudson communicates regularly with customers on natural gas safety through a series of paid radio spots, social media outreach, bill inserts (including scratch-and-sniff brochures to educate the public to recognize gas odors), news releases, blast emails to customers and newsletters to elected officials and community stakeholders. Central Hudson also participates in a collaborative paid media campaign through the Northeast Gas Association (NGA).

In compliance with DOT Pipeline Safety requirements for natural gas, letters are sent to municipalities during the first half of the year; and in 2024 a biennial mailing was conducted in the summer to about 10,000 property owners adjacent to natural gas transmission rights-of-way (these mailings take place every two years, on even calendar years). Corporate Communications and Engineering initiates these mailings.

New in 2019, Central Hudson developed an on-site, hands-on training program for emergency responders, including local police and fire departments, utilizing a mobile training trailer that can be brought to responders' location. The program and equipment provide conditions and situations responders may encounter in the field. The program was suspended in 2020 due to the pandemic was reinstated in 2022. This will be performed in 2025.

During 2017, an outreach program was conducted to provide municipalities, counties, farms, excavating/construction companies and any entity that may perform excavating with safety information when working near natural gas and electric lines via direct mailings, delivery of training materials through a fulfillment service and on-line resources. Tree contractors and equipment rental companies are included in this outreach campaign (see above, under Electric Safety Education) with approximately 9,000 businesses, farms and municipalities identified and contacted. The mailing and outreach will again be conducted during 2025.

Central Hudson issues news releases and provides social media posts regarding gas safety and the importance of calling before digging during “Dig Safely” Month in April. All utilities together in the NGA 811 outreach informed the public that DIY and construction projects could place your families, contractors and community at risk.

Municipalities continue to be reminded of the need for safe digging practices in a monthly newsletter to municipal and elected officials.

Central Hudson actively participates in “Dig Safely New York” (DSNY), now called UDIG NY. A Central Hudson employee serves on the Board of Directors to provide input, as well as to stay aware of the latest trends/topics. Central Hudson is also actively involved with the Hudson Valley Damage Prevention Council. Both groups in the past raised awareness for excavation safety and underground utility damage prevention by conducting area safety presentations, participating at industry trade shows, hosting informational breakfasts, and providing a website containing information and videos. Annually, Central Hudson sends letters to all school districts within its service territory informing educators of its safety information on the Kids Corner section of the company’s website.

The Patroller Programs continues, in which company representatives contact individuals at job sites throughout Central Hudson’s gas service territory (including homeowners, professional and municipal excavators) to distribute materials promoting safe excavating practices and to educate/enforce 16 NYCRR Part 753 – Protection of Underground Facilities.

Central Hudson continues work with municipalities to prevent damage to utility facilities by contractors retained by municipalities. Appropriate points of contact are provided so that incident information can be shared.

Central Hudson requires all excavator operators working for the Company to be certified in dig-safe excavation safety through the DSNY/UDIG NY training program. Additionally, Central Hudson uses a field quality inspection organization team to provide inspection oversight on Central Hudson’s and its contractors’ construction projects.

To help ensure customer safety and to remain in compliance with 16 NYCRR Part 255, Central Hudson annually offers natural gas safety training to first responders (police and fire departments), supplemented this in-person training offer with an online offering. Working with the Northeast Gas Association, Central Hudson hosts a first responder portal to our corporate website, which contains online training for responding to natural gas emergencies. This approach provides training options for the first responders in our communities. An expanded on-site, hands-on training program for emergency responders, including local police and fire departments, utilizing a mobile training trailer that can be delivered to a municipal or county location is also offered. The program and equipment provide conditions and situations responders may encounter in the field.

Safety Communications

Thirty-second commercial scripts aired in 2024 on approximately two dozen local AM and FM radio stations across the Mid-Hudson Valley focused on many safety topics: CO, gas, generator, work zone, electrical fire, electrical lines, household wiring and right-of-way.

Summary of 2024 Results and Lessons Learned:

(Detailed evaluation in Appendix C of Central Hudson Outreach and Education Plan)

Central Hudson successfully completed the outreach and education programs in 2024. The Storm Central outage map included safety messages during storm events.

Central Hudson’s Public Safety Committee also continued, consisting of individuals from different areas of the Company to ensure maximum program coverage. This internal team meets regularly, and their discussions focus on issuing safety messages (news releases, web pages, social media posts) based on recent local and national events.

Goals for 2025:

- Continue to offer gas and electric safety on-line training programs.
- Continue in person training program for emergency responders, including local police

and fire departments, utilizing a mobile training trailer that can be brought to responders' location.

- Storm preparedness and safety tips to be issued on each of the following communication channels during 2025: website, radio advertisement, bill insert, news release, email newsletters to customers and legislative officials, and Facebook/X.
- Comply with the DOT Pipeline Safety requirements for natural gas: letters are sent to municipalities and to emergency responders during the first half of the year; and letters to about 10,000 property owners adjacent to natural gas transmission rights-of-way will be sent in 2024 (letters are sent every two years).
- Issue a news release and provide social media posts regarding gas safety and the importance of one-calls in April (during Dig Safely Month), and mail information to municipalities via a monthly newsletter.
- Participate in monthly and annual Hudson Valley Damage Prevention Council meetings and attend events during the year as they occur.

Participate in 2 Hudson Valley Damage Prevention Council events during the year

How Priority Was Set:

Central Hudson's Public Safety Committee meets regularly and drives many of our efforts in this area. In addition, the company participates in industry organizations such as the Northeast Gas Association, American Gas Association, and Edison Electric Institute where best practices are shared and learned.

Description of 2025 Program: Include program elements such as audience, messaging, schedule/frequency, evaluation plan, and materials/tools used as part of your outreach and education program such as bill inserts, publications, newsletter (physical and electronic), educational videos, mail (direct & email), media (digital, radio, television) and utility website. Provide distribution details such as when, frequency, and delivery method. Also attach copies of the materials, including screenshots of web, social media, and electronic communications in Appendix D of Outreach and Education Plan.

Central Hudson will:

- Track communications and customer comments to ensure messages resonate and are relevant.
- Participation in outreach programs will be evaluated. Feedback from First Responder training will be used to refine the training as needed.
- Begin executing the Public Awareness Effectiveness Study.

2025 Outreach & Education Plan with 2024 Results SERVICE INTERRUPTIONS

This section should include public awareness programs regarding storm preparations, safety tips and restoration efforts including ETRs. The Company should describe its outreach efforts to customers and stakeholders prior to, during and after an outage event including use of web, social media, etc.

New/Continuing Program:

Central Hudson communicates outage information to our customers in a variety of ways. We provide Estimated Restoration Times (ETRs) and outage status to customers via the following methods:

- Storm Central outage map
- News releases and media interviews
- Social Media (Facebook and X) updates and responses
- Storm outages webpage on corporate website
- Municipal and emergency officials conference calls
- Outbound calls
- SMS messaging to subscribed users
- Email blasts
- Upfront recorded messages for customers calling our Contact Center
- Pre-recorded radio announcements during major storms
- Municipal Portal for municipal and county emergency managers.

Elected and municipal officials also receive direct communication during storm events. Life Support Equipment (LSE) customers receive a call within 12 hours from a live agent, whenever they are affected by an outage.

Special Needs and Elderly, Blind or Disabled (SNEBD) customers receive a daily automated call during major storms which provides them with information on our restoration progress, directions for how to contact Central Hudson, and safety advisories.

When weather forecasts provide sufficient advance warning of weather likely to cause widespread outages, Central Hudson uses our outbound calling system to notify all LSE/SNEBD customers and Critical Facility managers to alert them of a possible severe weather event and encourage them to be prepared for potential loss of power at their home or business.

On an annual basis Central Hudson provides our Electric Emergency Plan to the highest elected official in each county we serve. This is sent via email and US mail with a link to the electronic version of the plan.

Summary of 2024 Results and Lessons Learned:

(Detailed evaluation in Appendix C of Central Hudson Outreach and Education Plan)

Central Hudson's highly responsive social media team is able address customer inquiries and concerns quickly via Facebook, X and Instagram, especially during storms. The communications team also provides updates and information constantly, using photos, videos – reaching out via social media, email, news media releases, media interviews

and the website. Customers tend to positively respond to this connectivity.

Enrollment in our text notification service continues to grow. While all surveys indicate the majority of customers prefer email communications from us, there's a growing population utilizing our text communication service.

In 2020 Central Hudson developed a new Municipal Portal software product. This gives various

municipal leaders and emergency responders enhanced outage information and a streamlined means for reporting & gaining status of road closure type incidents during storm events. This new application is used during storms and gives municipal leaders and emergency personnel (specifically those in the Emergency Operations Centers) the ability to report incidents quickly and receive the latest status

Goals for 2025:

During 2025, we will continue our outreach to enroll customers in the text notification service and encourage customers to “connect with us” by providing their email address to receive email communications. We also plan to utilize text broadcast notifications more often – to mass communicate about storms and other matters to those who prefer to receive communications by text.

This service is offered at no charge to our customers, and it provides text alerts when an outage is predicted, when ETRs are added or updated, and when the outage case is believed to be restored.

Customers can also report an outage using SMS texts and check their power status.

Central Hudson is also examining ways to get ETR information onto the outage map more quickly to help customers plan appropriately.

How Priority Was Set:

Results of our customer surveys continue to indicate that outage communication, and service reliability, is a high priority for our customers.

Description of 2025 Program: Include program elements such as audience, messaging, schedule/frequency, evaluation plan, and materials/tools used as part of your outreach and education program such as bill inserts, publications, newsletter (physical and electronic), educational videos, mail (direct & email), media (digital, radio, television) and utility website. Provide distribution details such as when, frequency, and delivery method. Also attach copies of the materials, including screenshots of web, social media, and electronic communications in Appendix D of Outreach and Education Plan.

In 2020, Central Hudson rolled out the Municipal Portal which is another resource for emergency managers. This two-way, interactive tool provides critical information, online desktop and mobile reporting for power interruptions and road closures/conditions, and customized alerts when addressing major storm events and other emergencies. User registration is required for the Municipal Portal and we will continue to promote widespread adoption and in use of this resource.

Measures to Evaluate the 2025 Program:

Continued use of the How Did We Do and other customer surveys

Periodic review of industry best practices for outage response and communication

2025 Outreach & Education Plan with 2024 Results SPECIAL NEEDS CUSTOMERS

This section includes messaging and communication efforts for a variety of special needs customers including Elderly, Blind and Disabled, and medical hardship/Life Sustaining Equipment users. Describe actions taken to identify the barriers to accessibility and expand customer access to print and digital materials, particularly those related to customer rights and responsibilities, safety, and bill assistance.

New/Continuing Program:

Central Hudson will continue to look for ways to reach and identify customers with special needs through outreach and education via phone, community events and outreach activities. Training is conducted in the spring and fall with our CSRs and public facing field employees, to provide education on how to further identify customers that may require special services. Our Consumer Outreach team continues to attend community events to promote programs available to this population Information pertaining to special needs programs and services is also available on our website for all our customers and provided via newsletters, radio ads and social media platforms. Central Hudson will continue to offer the following programs:

- **Senior ID Program:** Customers who are 62 years or older, can contact Central Hudson to self-identify themselves as a senior citizen. Once identified, their account will be coded with a senior code to receive special services and protections.
- **Extra Security Plan:** This program provides an extended billing due date to the 6th of the month following their 'normal' due date for customers that are on a fixed income. At the end of 2024 there were 1,505 customers actively enrolled in this program.
- **Powering Connections:** This newsletter is issued to vulnerable customers that are coded elderly, disabled or low income on their account. This newsletter is also mailed to Central Hudson retirees and provided to libraries, local agencies, and senior centers in our service area free of charge. Each edition offers information about Central Hudson's programs and services and safety and conservation articles. Powering Connections is also provided at local outreach events.
- **TTY Phone Service:** Available by dialing 711
- **Life Support Program:** Customers with life support equipment in-use are eligible for special coding on their account. These customers also receive continuous outreach during major outage events. If a field visit is necessary during storms, Central Hudson will leave a door tag with emergency contact phone numbers. At the end of 2024 there were 828 customers on the Life Support Equipment (LSE) program.
- **Third Party Notification:** As provided by HEFPA (Home Energy Fair Practices Act), Central Hudson offers a Third-Party designation for residential customers. With this protection, any final termination notice issued on an account is also mailed to the designated Third Party. Approximately 404 active residential accounts have Third Party designation on their account at the end of 2024. The Third-Party application form is printable from our website and is available in Spanish language.
- **Hospitalization Program:** Central Hudson provides a 30-day extension to customers that have been in the hospital. The form is available by phone or on our website and can be faxed, mailed, or e-mailed. Office and Field staff have been trained on the program and can assist customers in applying.
- **Large Print Bills:** These bills are sent to sight-impaired customers who request them. Annual notification offering this option is made via our Rights & Responsibilities bill insert and in the Powering Connections newsletter which is issued in the spring and fall of each year.
- **Interpreter Service:** This service is available in various languages. In 2024 it was used

approximately 1597 times in various languages including Spanish, Mandarin, French, Arabic, Albanian, Korean, Portuguese, Russian, Vietnamese, Haitian Creole, Bangali, Hindi, Qeqchi, Cantonese, Filipino Ukrainian and, Polish.

- Spanish-speaking CSRs: Central Hudson has 8 bilingual speaking CSRs to meet the needs to this population as well as an interpreter service for other languages. In 2024, 15,791 Spanish calls were received, and 14,388 calls were answered through our dedicated Spanish queue.
- Good Neighbor Fund (GNF): This program is administered by Central Hudson with the Salvation Army Corps being the fiscal intermediary. This grant is available to eligible customers as a last resort benefit. Typically, the GNF is communicated to customers via bill messages, bill inserts, Powering Connections, radio spots, PowerTalk, social media, the website, and various outreach events in the community and CSR referrals. Our customers donate to this fund and Central Hudson's shareholders match their donations up to \$50,000 each year. In 2024, Central Hudson provided 330 Veteran Grants totaling \$66,000 and 255 Regular Grants totaling \$29,400.
- Essential Service Program: Central Hudson voluntarily elects to provide Essential Service Apparatuses (a load-limiter device) to residential customers in the winter in lieu of shutting of the service for non-payment. This device is set to provide enough energy to operate on a limited basis some essential items such as a heating system and lights.
- Energy Affordability Program Bill Discount: Central Hudson customers who are eligible for HEAP, SNAP (Supplemental Nutrition Assistance Program), Lifeline, Medicaid, SSI (Supplemental Security Income), Federal Public Housing Assistance, Veteran's or Survivor's Pension or certain programs for Native Americans may be enrolled in the Low-Income Bill Discount Program (LIBDP) which provides a monthly credit to their account for 12 consecutive months. For customers heating by any other means such as oil, coal, propane, wood/wood pellets, kerosene or corn, Central Hudson receives a notification of HEAP, and the customer is automatically enrolled into the program. The amount of the benefit is based on service type.
- Low Income Reconnection Fee Waiver: Customers receiving a HEAP benefit applied towards their Central Hudson account during the HEAP season automatically receive one reconnection fee waived upon restoral of their services, should they be shut-off for non-payment. HEAP Awareness: We utilize several resources to communicate about HEAP availability to our customers such as bill inserts and bill messaging at the beginning of the HEAP year. In addition, we advertise through the Powering Connections newsletter, social media, outbound call campaigns, CSR referrals, radio advertisement and banner ads on our website. Our Outreach team goes out into the community to hold workshops with agencies and their clients and attend vendor events to bring awareness to HEAP. When HEAP is open, we include a banner on the homepage of our website linking customers to the Office of Temporary and Disability Assistance (OTDA) or to the payment assistance section of our website. HEAP flyers in English and Spanish are distributed at workshops and via email to customers and community partners. Outbound calls are made to customers who received HEAP or are enrolled in the monthly discount program during the prior year to encourage them to reapply, and calls are made to customers in arrears who have never received HEAP assistance in the past.
- Special Account Identifications: Our customer database system identifies our specially coded customers on a general information screen. Both office and field employees understand the identifications, where to find them, and how to update them.
- Gift Certificates: This program allows friends, family, or charitable organizations to purchase gift certificates to be applied to a customer's account. Ads are placed in the Powering Connections newsletter, in PowerTalk, on our website, and in radio ads to make customers aware of their availability. Gift Certificate information is also included in every payment assistance presentation given by Consumer Outreach.
- Website: The Payment Assistance section of our website provides explanations of our special needs' customer programs and services. Website banner ads during HEAP season, our

home page website banner is updated to inform customers of the availability of benefits and a direct link to the Office of Temporary Disability and Assistance website or Central Hudson's "Payment Assistance" section.

- News Releases: News releases on assistance programs, safety and HEAP availability are issued periodically.
- Radio Ads: Radio ads in both English and Spanish are released on assistance programs, safety, and HEAP availability periodically.
- Direct Mail Letters: Letters are sent to customers with a past due balance and life support or "fixed income" code(s) advising of the availability of HEAP assistance for winter heating costs

Summary of 2024 Results and Lessons Learned:

(Detailed evaluation in Appendix C of Central Hudson Outreach and Education Plan)

Central Hudson will continue to monitor the effectiveness of its special needs' programs through satisfaction surveys at outreach forums, in-person and virtual events and outreach presentations.

Goals for 2025:

Central Hudson understands the importance of identifying our special needs customers. Programs are designed to comply with HEFPA regulations and Company research findings through customer satisfaction surveys, outreach forums, outreach presentations, and employee engagement in community activities and non-profit organizations.

How Priority Was Set:

Central Hudson understands the importance of identifying our special needs customers. Programs are designed to comply with HEFPA regulations and Company research findings through customer satisfaction surveys, outreach forums, outreach presentations, and employee engagement in community activities and non-profit organizations.

Description of 2025 Program: Include program elements such as audience, messaging, schedule/frequency, evaluation plan, and materials/tools used as part of your outreach and education program such as bill inserts, publications, newsletter (physical and electronic), educational videos, mail (direct & email), media (digital, radio, television) and utility website. Provide distribution details such as when, frequency, and delivery method. Also attach copies of the materials, including screenshots of web, social media, and electronic communications in Appendix D of Outreach and Education Plan.

Central Hudson's goals are to promote awareness and understanding of programs and services, encourage customer participation in our special programs, and to afford customers all the rights outlined in HEFPA. We will continue to offer the above programs and continue our twice-yearly goal of verifying and updating all EBD (Elderly, Blind, Disabled) and LSE accounts as outlined above. In 2025, Central Hudson will use our Powering Connections newsletter, Coffee Buzz virtual presentations to educate agencies and our vulnerable customers on payment assistance and special assistance programs and energy efficiency savings programs. We expect to increase the number of in-person workshops and meetings with community partners and local agencies.

In 2025, our Outreach team will continue educating customers and community agencies on Central Hudson's payment assistance, bill explanation, gas safety, and energy efficiency programs in both virtual and live formats as well. This customer education is delivered in workshops normally conducted on-site in community agencies. In addition to discussing assistance programs, these workshops provide valuable information on safety, energy efficiency and help in understanding their Central Hudson bill.

In 2025, we will work to increase our engagement in our local communities' agencies, food banks, schools and senior events to educate them on the availability of our programs. We will partner with local agencies to provide wrap-around service for families in need. Central Hudson will continue working with OTDA on a file transfer of customer information to better identify our low-income customer population to enroll them into the Energy Affordability Program.

Central Hudson will continue to bring awareness to our non-heating customers and their potential eligibility in our new low-income program. We will create written and electronic material that will be provided to schools and other agencies to educate customers who do not heat with gas or electricity about the availability of HEAP for their Central Hudson bill.


RECOMMENDED DRY ICE DISTRIBUTION LOCATIONS

APPENDIX R

Appendix removed from external copy to protect private information.

**New York State Procedure for
NY Based Utilities Activating Canadian Utility Contractor Assistance During Extended Power Outage Events
January 2025**

To ensure compliance with U.S. Customs and Border Protection Guidelines for Activating Canadian Utility Contract Assistance for the Buffalo and New England (dated October 2018 and May 2018 respectively and attached below), the following procedures will be used by utilities within New York State. These procedures have been reviewed by the New York State Office of Emergency Management and the New York State Public Service Commission. For further details, please see U.S. Customs and Border Protection Guidelines in Attachment 2 and 3.



Important Notes:

1. CBP recommends using staggered arrival times and several ports of entry for large movements of crews in order to expedite processing.
2. The New York utility company who reassigns any previously paroled Canadian utility company crew is responsible for notifying the original paroling Port of Entry of their assignment location and a roster of the employees being reassigned AND notify the New York State Watch center of the re-assignment.
3. If a Canadian Utility Crew that was originally requested by a New York utility company is released and then reassigned to any other utility either within New York State or outside NYS, then the “receiving” NY utility company must seek an additional letter of support from that receiving State’s Emergency Management Director and the accompanying declaration of a State of Emergency from that State.

Contact Information:

Agency	Phone Number	E-Mail
New York State		
New York State Office of Emergency Management	518-292-2200	NY.StateWatchCenter@dhses.ny.gov
New York State Dept of Motor Vehicles	518-473-5595	
CBP Buffalo Area of Responsibility		
CBP Buffalo Field Office	716-626-0400	BUFCAN-UW-NewYork@cbp.dhs.gov
Buffalo, NY Area Port	716-843-8300	BUFCAN-UW-NewYork@cbp.dhs.gov
Alexandria Bay, NY Area Port	315-482-2065	BUFCAN-UW-NewYork@cbp.dhs.gov
Champlain, NY Area Port	518-298-8311	BUFCAN-UW-NewYork@cbp.dhs.gov
CBP Vermont Area of Responsibility		
CBP Vermont Field Office		BOSCAN-UW-Vermont@cbp.dhs.gov
New Hampshire Homeland Security and Emergency Management	603-271-2231	nheoc@dos.nh.gov
New Hampshire State Police Commercial Vehicle Unit	603-223-8778	
New Hampshire Bureau of Motor Vehicles	613-227-4000	
Vermont Emergency Management Agency	800-347-0488	Dps.secc@vermont.gov
Vermont Bureau of Motor Vehicles	888-998-3766	
St. Albans, VT Area Port	802-524-6527	
CBP Maine Area of Responsibility		
CBP Maine Field Office		BOSCAN-UW-Maine@cbp.dhs.gov
Maine Emergency Management Agency	207-624-4400	RCC.Augusta@Maine.gov
Maine State Police Commercial Vehicle Unit	207-624-8939	
Maine Bureau of Motor Vehicles	207-624-9000 Ext 52151	
Portland, ME Area Port	207-771-3600	

For any questions, please contact the NYS Office of Emergency Management at 518-292-2200.

Attachments:

1. CBP Pre-Arrival Spreadsheet (Example)
2. U.S. Customs and Border Protection Guidelines for Activating Canadian Utility Contract Assistance for Buffalo
3. U.S. Customs and Border Protection Guidelines for Activating Canadian Utility Contract

CBP Pre-Arrival Spreadsheet (Example)

	A	B	C	D	E	F	G	H	I	J	K	L	M
1	First Name	Middle Name	Last Name	DOB	Citizenship Country	Place of Birth Country	Place of Birth City	Gender	Passport Country Code	Passport Number	Passport Issue Date	Passport Expiration Date	Notes
2													
3													
4													
5													
6													
7													
8													
9													
10													
11													
12													
13													
14													
15													
16													
17													
18													
19													
20													
21													
22													
23													
24													
25													
26													
27													
28													
29													
30													
31													
32													
33													
34													
35													
36													
37													
38													
39													
40													

EXAMPLE

Input

Contact Info

ISO Country Codes

State Codes

Visa Site Codes



**Guidelines for Activating Canadian Utility Contractor Assistance
During Extended Power Outage Events
January 2022**

United States utility companies, such as National Grid, Eversource Energy, Green Mountain Power, Vermont Electric, Central Maine Power, and Versant Power, routinely contract for additional workers and equipment assets from Canadian companies when weather conditions indicate a possible large-scale or long duration, power outage. This is done on a contractual basis between private entities; however, state and federal agencies are notified and take steps to help facilitate the deployment of Canadian resources into the United States. When a specific utility company recognizes the need for supplemental crews and requests assistance from Canadian contractors, the process for providing advance notice of Canadian utility crews coming into the United States should be as follows:

1. The utility company which is requesting Canadian crews or to pre stage personnel and equipment in response to a specific emergency situation sends a letter of request to the State Emergency Management Director (EMA) and the Area Port Director at the Port of Entry at which they propose to have crews enter the U.S. The letter should identify a need for foreign utility workers and equipment to enter the United States and the letter should state the specific period of time for which assistance is needed.
2. The request should include the following information and it should be entered on the CBP Pre-Arrival-Name List spreadsheet.

On the Coversheet tab enter:

- a. Utility Company Name;
- b. Contact Person;
- c. Contact Phone Number;
- d. Event Reason;
- e. Date;
- f. Port of Entry at which processing is requested;
- g. Requested time of arrival at the Port of Entry. Note: the Port of Entry will confirm the time of arrival. CBP recommends utilizing staggered arrival times and several ports of entry for large movements of crews in order to expedite processing.**

On the Input tab enter for each subject:

- a. First and last name;
- b. Date of birth (MM-DD-YYYY)

- c. Two letter code for the person's country of citizenship (There is a searchable list of country codes on the spreadsheet)
 - d. Gender
3. The request should be sent via email using the address which corresponds to **the state in which the Port of Entry is located**

State of Maine:

BOSCAN-UW-Maine@cbp.dhs.gov

States of New Hampshire and Vermont:

BOSCAN-UW-Vermont@cbp.dhs.gov

4. Prior to CBP making a determination whether the workers will be allowed to enter, Emergency Management Directors must forward documentation to CBP in support of the utility's request. Acceptable documentation includes either a State of emergency (SOE) for the impending weather/event or a letter from the respective State's Emergency Management Director on behalf of the Governor. This letter will indicate that the U.S. utility company requesting the Canadian utility workers has canvassed a reasonable area and is unable to locate sufficient US workers to support their backfill requirements.
 - a. The Governor of the State requesting Canadian utility workers may or may not have declared a State of Emergency (SOE) for the impending weather/event.
 - b. If declared, the SOE may only waive the US Federal Motor Carrier Safety Administration rules on Hours of Service or may waive additional restrictions if explicitly noted in the SOE text.
 - c. The SOE will never waive regulations on subjects such as CDL requirements, drug/alcohol, hazardous materials, size/weight limitations, federal registration/taxes, etc
 - d. If a SOE has been declared in a specific state, the contractor is generally required to keep a copy of the SOE text in the vehicle at all times to prove the vehicle/personnel are responding in direct support to the State's declared emergency.
 - e. If the contractor is responding to assist a State for which they are being processed, then it is recommended that each vehicle keep a copy of the requesting State's SOE to prove the vehicle/personnel are responding in direct support to that State's declared emergency
 - f. This SOE does not negate any Federal Laws or Regulations enforced by CBP.

Helpful Reference Information:

1. MEMA: 207-624-4400
800-452-8735 toll free (in-state)
2. Maine SP Commercial Vehicle Unit: 207-624-8939
3. Maine Bureau of Motor Vehicles: 207-624-9000 ext 52151
4. New Hampshire HSEM: 603-271-2231
5. New Hampshire SP Commercial Vehicle Unit: 603-223-8778
6. New Hampshire Bureau of Motor Vehicles: 603-227-4000
7. Vermont EMA: 800-347-0488
8. Vermont Bureau of Motor Vehicles: 888-998-3766
9. CBP Boston Field Office: 617-565-6208
10. Portland, Maine Area Port 207-771-3600
11. St. Albans, Vermont Area Port 802-524-6527

Utility Company	Contact Person	Contact Phone #	Event Reason	Date Crossing	Time Crossing	Port Crossing At

Example CBP Pre-Arrival Spreadsheet for NY POE

Person Number	First Name	Last Name	DOB	Citizenship Country	Gender
1					
2					

Example CBP Pre-Approval Spreadsheet for ME & VT POE

Border Pre-Arrival List of Names for Emergency Events for USCBP & CBSA



Department / Utility Company Name:	<p style="text-align: center;">Email Completed Form(s) to:</p> <p style="text-align: center;"><u>Requests for State of Maine:</u></p> <p style="text-align: center;">BOSCAN-UW-Maine@cbp.dhs.gov</p> <p style="text-align: center;"><u>Requests for State of Vermont and New Hampshire:</u></p> <p style="text-align: center;">BOSCAN-UW-Vermont@cbp.dhs.gov</p> <p style="text-align: center;"><i>Note: Please forward this as far in advance as possible</i></p>
Contact person:	
Contact Phone #:	
Event Reason:	
Date:	<p style="text-align: center;">CBSA</p> <p>Entering New Brunswick at Route 95, Woodstock, NB Fax Form To: 506-325-3276 (Phone: 506-325-3160)</p> <p>Entering New Brunswick at 3rd Bridge St. Stephen, NB Fax Form To: 506-465-2029 (Phone: 506-465-2244)</p> <p>Entering Quebec at Highway 15, St.-Bernard-de-Lacolle, PQ Fax Form To: 450-###-#### (Phone: 450-###-####)</p> <p>Entering Quebec at Highway 133, Saint Armand, PQ Fax Form To: 506-###-#### (Phone: 450-###-####)</p>
CBP / CBSA Confirmation Number:	
Port of Entry Name (Arrival Location):	
Estimated time of arrival:	

Example CBP Pre-Approval Spreadsheet for ME & VT POE



Canada Border Services Agency

Agence des services frontaliers du Canada



U.S. Customs and Border Protection