

**STATE OF NEW YORK
DEPARTMENT OF PUBLIC SERVICE**

INVESTIGATIVE REPORT

April 24, 2026

TO: Michael Pasinella / Robert Jucha
FROM: Robert Draiss
SUBJECT: Part 753 Investigation at 200 Dosoris Lane, Glen Cove

Department of Public Service (DPS) Staff received a report of excavation work being performed at 200 Dosoris Lane, Glen Cove, on April 13, 2026, by Speedway Concrete Construction Corp. DPS Staff performed a one-call ticket search for notifications provided for excavation work at 200 Dosoris Lane, Glen Cove from April 13, 2025 to April 13, 2026 and could not locate a one-call ticket for excavation work provided by Speedway Concrete Construction Corp. Therefore, DPS Staff issued citation 26-0043-01 on April 27, 2026, to Speedway Concrete Construction Corp. for a violation of §753-3.1(a)(1).

The operator did not provide an estimate for the quantity of gas that was lost due to this damage. DPS Staff performed its own calculation and determined the amount of gas lost was likely 298,800.00 cubic feet. The following values were used in DPS Staff's determination:

Facility 1:

Pressure at Time of Failure:	60 psig
Diameter of Hole:	2 inches
Diameter Squared:	4 inches ²
Duration of Blowing Gas:	1 hours
Facility 1 Gas Loss:	298,800.00 cubic feet

Total Gas Loss:	298,800.00 cubic feet
-----------------	-----------------------