



April 24, 2026

Hon. Michele L. Phillips  
Secretary to the Commission  
New York State Public Service Commission  
Empire State Plaza  
Agency Building 3  
Albany, NY 12223-1350  
Secretary@dps.ny.gov

Re: Letter of Intent to use Aclara Meters kV2c RD Model Class200 Polyphase AMI Meter

Dear Secretary Phillips,

Con Edison and Orange & Rockland Utilities are submitting their intent to use the Aclara kV2c RD-Model AMI Electric Meter. Under separate cover, the application by Aclara Meters contains the American National Standards Institute (ANSI) C12.1 independent lab test documentation and the Part 93 Section 93.6 requested documentation. Accordingly, to allow this additional related documentation to be submitted on record, we respectfully request that a Case File be opened for this matter.

It is our intent to deploy the Aclara kV2c RD Model AMI Electric Meter in our service territory subject to approval by the State of New York Public Service Commission. The approved kV2c Model has been enhanced to include the capability to operate remote connect/disconnect (RD) switches which does not currently exist in the approved kV2c family of socket meters. The RD switches are built inside the meter base enclosure, which is identical to the kV2c base, and even with the added structural dimension the kV2c RD meter fits into a traditional meter socket.

The Aclara kV2c RD Model AMI Electric Meter will be deployed in our AMI system for metering services where use of the RD functionality is appropriate for conditions such as emergency load shedding, turn on/turn off, move in/out, temporary service, safety, etc. and eliminates the need to dispatch crews to the site. The kV2c RD Model meets the functional requirements of the AMI system and thus facilitates its incorporation into our AMI operations.

Very Truly Yours,

A handwritten signature in black ink that reads 'Jude Del Percio' in a cursive script.

Jude Del Percio  
Department Manager  
AMI PMO

Cc: Thomas Magee  
Adam Miller