



U.S. ENVIRONMENTAL PROTECTION AGENCY TIER I QUALIFIED FACILITY SPCC PLAN TEMPLATE

Instructions to Complete this Template

This template is intended to help the owner or operator of a Tier I qualified facility develop a self-certified Spill Prevention, Control, and Countermeasure (SPCC) Plan. To use this template, your facility must meet all of the applicability criteria of a Tier I qualified facility listed under §112.3(g)(1) of the SPCC rule. This template provides every SPCC rule requirement necessary for a Tier I qualified facility, which you must address and implement.

You may use this template to comply with the SPCC regulation or use it as a model and modify it as necessary to meet your facility-specific needs. If you modify the template, your Plan must include a section cross-referencing the location of each applicable requirement of the SPCC rule and you must ensure that your Plan is an equivalent Plan that meets all applicable rule requirements of 40 CFR 112.6(a)(3).

You may complete this template either electronically or by hand on a printed copy. This document is a reformatted version of the template found in Appendix G of 40 CFR part 112.^a No substantive changes have been made. Please note that a "Not Applicable" ("N/A") column has been added to both Table G-10 (General Rule Requirements for Onshore Facilities) and Table G-11 (General Rule Requirements for Onshore Oil Production Facilities). The "N/A" column should help you complete your self-certification when a required rule element does not apply to your facility. Use of the "N/A" column is optional and is not required by rule.

All Tier I qualified facility self-certifiers must complete Sections I, II, and III. Additionally, the owner or operator of an:

- Onshore facility (excluding production) must complete Section A.
- Onshore oil production facility (excluding drilling and workover facilities) must complete Section B.
- Onshore oil drilling and workover facility must complete Section C.

Complete and include with your Plan the appropriate attachments. You should consider printing copies of the attachments for use in implementing the SPCC Plan (e.g. Attachment 3.1 - Inspection Log & Schedule; Attachment 4 - Discharge Notification Form).

To complete the template, check the box next to the requirement to indicate that it has been adequately addressed. Either write "N/A" in the column or check the box under the "N/A" column to indicate those requirements that are not applicable to the facility. Where a section requires a description or listing, write in the spaces provided (or attach additional descriptions if more space is needed).

Below is a key for the colors used in the section headers:

| |
|--|
| Sections I, II, and III: Required for all Tier I qualified facilities |
| Section A: Onshore facilities (excluding production) |
| Section B: Onshore oil production facilities (excluding drilling and workover facilities) |
| Section C: Onshore oil drilling and workover facilities |
| Attachments: 1 - Five Year Review and Technical Amendment Logs 2 - Oil Spill Contingency Plan and Checklist 3 - Inspections, Dike Drainage and Personnel Training Logs 4 - Discharge Notification Form |

After you have completed all appropriate sections, certify and date your Plan, and then implement it by the compliance date. If your facility was in operation before August 16, 2002, and you do not already have a Plan, then implement this template immediately. Conduct inspections and tests in accordance with the written procedures that you have developed for your facility. You must keep with the SPCC Plan a record of these inspections and tests, signed by the appropriate supervisor or inspector, for a period of three years.

Do not forget to periodically review your Plan (at least once every five years) or to update it when you make changes to your

^a Please note that the use of this template is not mandatory for a Tier I qualified facility. You may also meet the SPCC Plan requirement by preparing a satisfactory Tier II qualified facility Plan, preparing a satisfactory Plan that is certified by a Professional Engineer, or by developing an equivalent Plan for a Tier I qualified facility. Further information on the requirements of these methods can be found in 40 CFR part 112.6(a)(1). If you use any of these alternative methods you must include a cross reference in your Plan that shows how the equivalent Plan meets all applicable 40 CFR part 112 requirements.

I also understand my other obligations relating to the storage of oil at this facility, including, among others:

1. To report any oil discharge to navigable waters or adjoining shorelines to the appropriate authorities. Notification information is included in this Plan.
2. To review and amend this Plan whenever there is a material change at the facility that affects the potential for an oil discharge, and at least once every five years. Reviews and amendments are recorded in an attached log [See Five Year Review Log and Technical Amendment Log in Attachments 1.1 and 1.2.]
3. Optional use of a contingency plan. A contingency plan:
 - a. May be used in lieu of secondary containment for qualified oil-filled operational equipment, in accordance with the requirements under §112.7(k), and;
 - b. Must be prepared for flowlines and/or intra-facility gathering lines which do not have secondary containment at an oil production facility, and;
 - c. Must include an established and documented inspection or monitoring program; must follow the provisions of 40 CFR part 109; and must include a written commitment of manpower, equipment and materials to expeditiously remove any quantity of oil discharged that may be harmful. If applicable, a copy of the contingency plan and any additional documentation will be attached to this Plan as Attachment 2.

I certify that I have satisfied the requirement to prepare and implement a Plan under §112.3 and all of the requirements under §112.6(a). I certify that the information contained in this Plan is true.

Signature _____

Title: Project Manager

Name Jon Campbell

Date: 5/25/2022

II. Record of Plan Review and Amendments

Five Year Review (§112.5(b)):

Complete a review and evaluation of this SPCC Plan at least once every five years. As a result of the review, amend this Plan within six months to include more effective prevention and control measures for the facility, if applicable. Implement any SPCC Plan amendment as soon as possible, but no later than six months following Plan amendment. Document completion of the review and evaluation and complete the Five Year Review Log in Attachment 1.1. If the facility no longer meets Tier I qualified facility eligibility, the owner or operator must revise the Plan to meet Tier II qualified facility requirements, or complete a full PE certified Plan.

| Table G-1 Technical Amendments (§§112.5(a), (c) and 112.6(a)(2)) | |
|---|-------------------------------------|
| This SPCC Plan will be amended when there is a change in the facility design, construction, operation, or maintenance that materially affects the potential for a discharge to navigable waters or adjoining shorelines. Examples include adding or removing containers, reconstruction, replacement, or installation of piping systems, changes to secondary containment systems, changes in product stored at this facility, or revisions to standard operating procedures. | <input checked="" type="checkbox"/> |
| Any technical amendments to this Plan will be re-certified in accordance with Section I of this Plan template. [§112.6(a)(2)] [See Technical Amendment Log in Attachment 1.2] | <input checked="" type="checkbox"/> |

III. Plan Requirements

1. Oil Storage Containers (§112.7(a)(3)(i)):

| Table G-2 Oil Storage Containers and Capacities | | | |
|--|----------------------|--------------------------|-------------------------------------|
| | | | <input checked="" type="checkbox"/> |
| Oil Storage Container <i>(indicate whether aboveground (A) or completely buried (B))</i> | Type of Oil | Shell Capacity (gallons) | Quantity Anticipated |
| Aboveground storage tank | Diesel | TBD | 1 |
| Mobile Refueler/Lubrication Truck | Diesel, Various Oils | TBD | 1 |
| Generator | Diesel | TBD | 10 |
| Portable Light Plant | Diesel | TBD | 60 |
| Truck Bed Slip Tank | Diesel | TBD | 10 |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

| | | | |
|--|-----|---------|---------|
| Total Aboveground Storage Capacity ^c | TBD | gallons | gallons |
| Total Completely Buried Storage Capacity | 0 | gallons | gallons |
| Facility Total Oil Storage Capacity | TBD | gallons | gallons |

^a Aboveground storage containers that must be included when calculating total facility oil storage capacity include: tanks and mobile or portable containers; oil-filled operational equipment (e.g. transformers); other oil-filled equipment, such as flow-through process equipment. Exempt containers that are not included in the capacity calculation include: any container with a storage capacity of less than 55 gallons of oil; containers used exclusively for wastewater treatment; permanently closed containers; motive power containers; hot-mix asphalt containers; heating oil containers used solely at a single-family residence; and pesticide application equipment or related mix containers.

^b Although the criteria to determine eligibility for qualified facilities focuses on the aboveground oil storage containers at the facility, the completely buried tanks at a qualified facility are still subject to the rule requirements and must be addressed in the template; however, they are not counted toward the qualified facility applicability threshold.

^c Counts toward qualified facility applicability threshold.

2. Secondary Containment and Oil Spill Control (§§112.6(a)(3)(i) and (ii), 112.7(c) and 112.9(c)(2)):

| Table G-3 Secondary Containment and Oil Spill Control | |
|--|-------------------------------------|
| Appropriate secondary containment and/or diversionary structures or equipment ^a is provided for all oil handling containers, equipment, and transfer areas to prevent a discharge to navigable waters or adjoining shorelines. The entire secondary containment system, including walls and floor, is capable of containing oil and is constructed so that any discharge from a primary containment system, such as a tank or pipe, will not escape the containment system before cleanup occurs. | <input checked="" type="checkbox"/> |

^a Use one of the following methods of secondary containment or its equivalent: (1) Dikes, berms, or retaining walls sufficiently impervious to contain oil; (2) Curbing; (3) Culverting, gutters, or other drainage systems; (4) Weirs, booms, or other barriers; (5) Spill diversion ponds; (6) Retention ponds; or (7) Sorbent materials.

Table G-4 below identifies the tanks and containers at the facility with the potential for an oil discharge; the mode of failure; the flow direction and potential quantity of the discharge; and the secondary containment method and containment capacity that is provided.

| Table G-4 Containers with Potential for an Oil Discharge | | | | | |
|---|--------------------------------------|--------------------------------------|---|---|--|
| Area | Type of failure (discharge scenario) | Potential discharge volume (gallons) | Direction of flow for uncontained discharge | Secondary containment method ^a | Secondary containment capacity (gallons) |
| <i>Bulk Storage Containers and Mobile/Portable Containers^b</i> | | | | | |
| Aboveground storage tank | Rupture, overfill | TBD | TBD | (1) Dike, berm, or retaining wall | TBD |
| Mobile Refueler/Lubrication Truck | Rupture, overfill | TBD | TBD | (1) Dike, berm, or retaining wall | TBD |
| Generator | Rupture, overfill | TBD | TBD | (1) Dike, berm, or retaining wall | TBD |
| Portable Light Plant | Overfill | TBD | TBD | (1) Dike, berm, or retaining wall | TBD |
| Truck Bed Slip Tanks | Rupture, overfill | TBD | TBD | (7) Sorbent Material | TBD |
| <i>Oil-filled Operational Equipment (e.g., hydraulic equipment, transformers)^c</i> | | | | | |
| | | | | | |
| <i>Piping, Valves, etc.</i> | | | | | |
| | | | | | |
| <i>Product Transfer Areas (location where oil is loaded to or from a container, pipe or other piece of equipment.)</i> | | | | | |
| | | | | | |
| <i>Other Oil-Handling Areas or Oil-Filled Equipment (e.g. flow-through process vessels at an oil production facility)</i> | | | | | |
| | | | | | |

^a Use one of the following methods of secondary containment or its equivalent: (1) Dikes, berms, or retaining walls sufficiently impervious to contain oil; (2) Curbing; (3) Culverting, gutters, or other drainage systems; (4) Weirs, booms, or other barriers; (5) Spill diversion ponds; (6) Retention ponds; or (7) Sorbent materials.

^b For storage tanks and bulk storage containers, the secondary containment capacity must be at least the capacity of the largest container plus additional capacity to contain rainfall or other precipitation.

^c For oil-filled operational equipment: Document in the table above if alternative measures to secondary containment (as described in §112.7(k)) are implemented at the facility.

3. Inspections, Testing, Recordkeeping and Personnel Training (§§112.7(e) and (f), 112.8(c)(6) and (d)(4), 112.9(c)(3), 112.12(c)(6) and (d)(4)):

| Table G-5 Inspections, Testing, Recordkeeping and Personnel Training | |
|---|-------------------------------------|
| An inspection and/or testing program is implemented for all aboveground bulk storage containers and piping at this facility. [§§112.8(c)(6) and (d)(4), 112.9(c)(3), 112.12(c)(6) and (d)(4)] | <input checked="" type="checkbox"/> |
| <p>The following is a description of the inspection and/or testing program (e.g. reference to industry standard utilized, scope, frequency, method of inspection or test, and person conducting the inspection) for all aboveground bulk storage containers and piping at this facility:</p> <p>Kiewit's Environmental Coordinator will conduct the required SPCC inspections monthly. Inspections of the facilities ASTs (including secondary containment), other storage containers and spill response equipment must be conducted to identify spills and/or defective equipment that could result in a release. Each container is inspected in accordance with its specifications, and the Steel Tank Institutes category. Inspections in general will consider the following items:</p> <ul style="list-style-type: none"> - Evidence of leaks or spills - Corrosion deterioration - Foundation deterioration - Tank equipment (valves, piping and pumps) - Tank and fueling security - Containment structures <p>Tank inspections will be documented on the Monthly SPCC Tank Integrity form. Maintenance areas, equipment fueling areas, and all tanks will be reviewed during this inspection. Inspections are retained for at least three years. Product inventory records are also maintained for a period of three years in the maintenance office. Completed copies of Inspection Forms are to be kept in the environmental inspection binder, file or in electronic compliance solution.</p> <p>The environmental orientation training, that all project personnel must attend, includes provisions for spill prevention, control and response that will be provided by the project Environmental Coordinator or designee. Records of those who attended each training will be documented in the form of sign in sheets and maintained in project files. Additional trainings are conducted throughout the project timeline that include topics such as SPCC background and contents, discharge prevention protocols, fueling procedures, SPCC equipment maintenance procedures, spill flow paths, and notification procedures.</p> | |
| Inspections, tests, and records are conducted in accordance with written procedures developed for the facility. Records of inspections and tests kept under usual and customary business practices will suffice for purposes of this paragraph. [§112.7(e)] | <input checked="" type="checkbox"/> |
| A record of the inspections and tests are kept at the facility or with the SPCC Plan for a period of three years. [§112.7(e)] [See Inspection Log and Schedule in Attachment 3.1] | <input checked="" type="checkbox"/> |
| Inspections and tests are signed by the appropriate supervisor or inspector. [§112.7(e)] | <input checked="" type="checkbox"/> |
| Personnel, training, and discharge prevention procedures [§112.7(f)] | |
| Oil-handling personnel are trained in the operation and maintenance of equipment to prevent discharges; discharge procedure protocols; applicable pollution control laws, rules, and regulations; general facility operations; and, the contents of the facility SPCC Plan. [§112.7(f)] | <input checked="" type="checkbox"/> |
| A person who reports to facility management is designated and accountable for discharge prevention. [§112.7(f)] Name/Title: <u>TBD– Project Environmental Coordinator</u> | <input checked="" type="checkbox"/> |
| Discharge prevention briefings are conducted for oil-handling personnel annually to assure adequate understanding of the SPCC Plan for that facility. Such briefings highlight and describe past reportable discharges or failures, malfunctioning components, and any recently developed precautionary measures. [§112.7(f)] [See Oil-handling Personnel Training and Briefing Log in Attachment 3.4] | <input checked="" type="checkbox"/> |

4. Security (excluding oil production facilities) §112.7(g):**Table G-6 Implementation and Description of Security Measures**

Security measures are implemented at this facility to prevent unauthorized access to oil handling, processing, and storage area.

The following is a description of how you secure and control access to the oil handling, processing and storage areas; secure master flow and drain valves; prevent unauthorized access to starter controls on oil pumps; secure out-of-service and loading/unloading connections of oil pipelines; address the appropriateness of security lighting to both prevent acts of vandalism and assist in the discovery of oil discharges:

The facility is normally in operation six days per week. Monday through Friday 0630 to 1730 and Saturdays 0630 to 1600. The facility is sufficiently lighted to allow for discovery of potential discharges.

Secondary containment drain valves, where present, are closed and locked to prevent unauthorized discharges. Pumps are locked wherever possible to prevent access, and fueling areas have adequate lighting.

5. Emergency Procedures and Notifications (§112.7(a)(3)(iv) and 112.7(a)(5)):**Table G-7 Description of Emergency Procedures and Notifications**

The following is a description of the immediate actions to be taken by facility personnel in the event of a discharge to navigable waters or adjoining shorelines *[§112.7(a)(3)(iv) and 112.7(a)(5)]*:

Spill Response - Small Spill

1. Stop the source of the spill/leak and contain it as soon as possible. Notify the equipment manager and the Project Environmental Coordinator (PEC) immediately.
2. If the spill is flowing, isolate and contain the spill by creating a dam or dike to prevent spread. Sorbent booms or "socks" can be used to create a containment dam.
3. Place absorbent pads, booms, or granular absorbent material on and/or around free product or area of spill.
4. Allow time for the absorbent material to soak up the spilled substance.
5. Once the spill is contained and free product absorbed, place used absorbent materials in a plastic bag and secure the bag with a zip tie. Place bag in labeled container for proper disposal.
6. Shovel all saturated soil into designated container removing enough soil to ensure all contaminated soil has been removed.
7. Label container with the appropriate label. The PEC can provide these.
8. Transport the container (drum/bucket) to project Waste Storage Area.

Spill Response - Large Spill

The following procedures should be followed in the event of a large oil or fuel spill caused by a tank overflow, tank failure, fuel or hydraulic line rupture or abnormal leak.

1. Assess the situation to determine if the spill is an incidental spill or that an emergency exists.
2. If an emergency situation exists and threatens the health or safety of anyone, evacuate the area and call 911 to notify the Fire Department.
3. If quantity of the spill is larger than facility personnel can handle, the PEC/Project Management will call Safety Kleen (330) 673-3340 to use in case of an emergency spill, to contain and/or remove spilled product and contaminated material.
4. If safe to do so, take all necessary steps to stop the leak/spill including turning off pump(s) or other equipment and closing any valves to isolate the overfilled/leaking tank or piping.
5. Isolate the spilled material and prevent the release from entering surface water or groundwater. Berms may be constructed to contain the spill, and/or excavation equipment may be used to promptly remove impacted soils, concrete, or asphalt. Storm drains will be blocked.
6. Alert and notify supervisory personnel of the situation. A supervisor will immediately notify the District Environmental Manager so that they can determine if it is a reportable event and make the needed agency and internal notifications.
7. When reporting a spill to environmental staff, provide the time, what was spilled, cause of the spill, whether the spill was to soil or water, if to soil, whether it has the potential to migrate to water and what action is being taken.
8. Take leaking tank/equipment out of service until leak is repaired.
9. Any fuel within the containment shall be removed and properly stored.
10. All affected areas shall be cleaned up and wastes containerized.
11. Inspect affected areas to ensure all contaminants are cleaned up and wastes containerized.
12. Repair or replace all affected equipment or tanks.
13. Conduct integrity testing on repaired/replaced sections if necessary
14. Return tank/equipment system to service once leak is repaired.

6. Contact List (§112.7(a)(3)(vi)):

| Table G-8 Contact List | |
|---|--|
| Contact Organization / Person | Telephone Number |
| National Response Center (NRC) | 1-800-424-8802 |
| Cleanup Contractor(s) Safety Kleen | (845) 353-0900 |
| Key Facility Personnel | |
| Designated Person Accountable for Discharge Prevention: TBD – Kiewit Environmental Coordinator | Mobile: TBD |
| | Emergency: same |
| TBD – Kiewit Construction Manager | Mobile: TBD |
| | Emergency: same |
| TBD – Kiewit Project Manager | Mobile: TBD |
| | Emergency: same |
| Ryan Jones – District Environmental Manager | Mobile: TBD |
| | Emergency: same |
| TBD – District Safety Manager | Mobile: TBD |
| | Emergency: same |
| TBD – Project Safety Manager | Mobile: TBD |
| | Emergency: same |
| TBD – Environmental Compliance Manager | Mobile: TBD |
| | Emergency: same |
| TBD – NextEra Construction Manager | Mobile: TBD |
| | Emergency: same |
| State Oil Pollution Control Agencies | |
| New York State (NYS) Spill Hotline | 1-800-457-7362 |
| New York State (NYS) Spill Hotline (out of state) | 1-518-457-7362 |
| Other State, Federal, and Local Agencies | |
| EPA Region 2 | 1-212-637-4040 |
| National Response Center (NRC) | 1-800-424-8802 |
| Local Fire Department Fire Department | 9-1-1 |
| Local Police Department Police Department | 9-1-1 |
| Clinic/Hospital | United Memorial Medical Center 585-343-6030 |
| Other Contact References (e.g., downstream water intakes or neighboring facilities) | |

7. NRC Notification Procedure (§112.7(a)(4) and (a)(5)):

| Table G-9 NRC Notification Procedure | |
|--|--|
| In the event of a discharge of oil to navigable waters or adjoining shorelines, the following information identified in Attachment 4 will be provided to the National Response Center immediately following identification of a discharge to navigable waters or adjoining shorelines [See Discharge Notification Form in Attachment 4]: [§112.7(a)(4)] | <input checked="" type="checkbox"/> |
| <ul style="list-style-type: none"> • The exact address or location and phone number of the facility; • Date and time of the discharge; • Type of material discharged; • Estimate of the total quantity discharged; • Estimate of the quantity discharged to navigable waters; • Source of the discharge; | <ul style="list-style-type: none"> • Description of all affected media; • Cause of the discharge; • Any damages or injuries caused by the discharge; • Actions being used to stop, remove, and mitigate the effects of the discharge; • Whether an evacuation may be needed; and • Names of individuals and/or organizations who have also been contacted. |

8. SPCC Spill Reporting Requirements (Report within 60 days) (§112.4):

Submit information to the EPA Regional Administrator (RA) and the appropriate agency or agencies in charge of oil pollution control activities in the State in which the facility is located within 60 days from one of the following discharge events:

- A single discharge of more than 1,000 U.S. gallons of oil to navigable waters or adjoining shorelines or
- Two discharges to navigable waters or adjoining shorelines each more than 42 U.S. gallons of oil occurring within any twelve month period

You must submit the following information to the RA:

- (1) Name of the facility;
- (2) Your name;
- (3) Location of the facility;
- (4) Maximum storage or handling capacity of the facility and normal daily throughput;
- (5) Corrective action and countermeasures you have taken, including a description of equipment repairs and replacements;
- (6) An adequate description of the facility, including maps, flow diagrams, and topographical maps, as necessary;
- (7) The cause of the reportable discharge, including a failure analysis of the system or subsystem in which the failure occurred; and
- (8) Additional preventive measures you have taken or contemplated to minimize the possibility of recurrence
- (9) Such other information as the Regional Administrator may reasonably require pertinent to the Plan or discharge

* * * * *

NOTE: Complete one of the following sections (A, B or C) as appropriate for the facility type.

A. Onshore Facilities (excluding production) (§§112.8(b) through (d), 112.12(b) through (d)):

The owner or operator must meet the general rule requirements as well as requirements under this section. Note that not all provisions may be applicable to all owners/operators. For example, a facility may not maintain completely buried metallic storage tanks installed after January 10, 1974, and thus would not have to abide by requirements in §§112.8(c)(4) and 112.12(c)(4), listed below. **In cases where a provision is not applicable, write "N/A".**

| Table G-10 General Rule Requirements for Onshore Facilities | N/A |
|---|--|
| Drainage from diked storage areas is restrained by valves to prevent a discharge into the drainage system or facility effluent treatment system, except where facility systems are designed to control such discharge. Diked areas may be emptied by pumps or ejectors that must be manually activated after inspecting the condition of the accumulation to ensure no oil will be discharged. [§§112.8(b)(1) and 112.12(b)(1)] | <input checked="" type="checkbox"/> <input type="checkbox"/> |
| Valves of manual, open-and-closed design are used for the drainage of diked areas. [§§112.8(b)(2) and 112.12(b)(2)] | <input type="checkbox"/> <input checked="" type="checkbox"/> |
| The containers at the facility are compatible with materials stored and conditions of storage such as pressure and temperature. [§§112.8(c)(1) and 112.12(c)(1)] | <input checked="" type="checkbox"/> <input type="checkbox"/> |
| Secondary containment for the bulk storage containers (including mobile/portable oil storage containers) holds the capacity of the largest container plus additional capacity to contain precipitation. Mobile or portable oil storage containers are positioned to prevent a discharge as described in §112.1(b). [§112.6(a)(3)(ii)] | <input checked="" type="checkbox"/> <input type="checkbox"/> |
| If uncontaminated rainwater from diked areas drains into a storm drain or open watercourse the following procedures will be implemented at the facility: [§§112.8(c)(3) and 112.12(c)(3)] <ul style="list-style-type: none"> • Bypass valve is normally sealed closed <input type="checkbox"/> <input checked="" type="checkbox"/> • Retained rainwater is inspected to ensure that its presence will not cause a discharge to navigable waters or adjoining shorelines <input checked="" type="checkbox"/> <input type="checkbox"/> • Bypass valve is opened and resealed under responsible supervision <input type="checkbox"/> <input checked="" type="checkbox"/> • Adequate records of drainage are kept [See Dike Drainage Log in Attachment 3.3] <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input checked="" type="checkbox"/> |
| For completely buried metallic tanks installed on or after January 10, 1974 at this facility [§§112.8(c)(4) and 112.12(c)(4)]: <ul style="list-style-type: none"> • Tanks have corrosion protection with coatings or cathodic protection compatible with local soil conditions. <input type="checkbox"/> <input checked="" type="checkbox"/> • Regular leak testing is conducted. <input type="checkbox"/> <input checked="" type="checkbox"/> | <input type="checkbox"/> <input checked="" type="checkbox"/> |
| For partially buried or bunkered metallic tanks [§112.8(c)(5) and §112.12(c)(5)]: <ul style="list-style-type: none"> • Tanks have corrosion protection with coatings or cathodic protection compatible with local soil conditions. <input type="checkbox"/> <input checked="" type="checkbox"/> | <input type="checkbox"/> <input checked="" type="checkbox"/> |
| Each aboveground bulk container is tested or inspected for integrity on a regular schedule and whenever material repairs are made. Scope and frequency of the inspections and inspector qualifications are in accordance with industry standards. Container supports and foundations are regularly inspected. [See Inspection Log and Schedule and Bulk Storage Container Inspection Schedule in Attachments 3.1 and 3.2] [§112.8(c)(6) and §112.12(c)(6)(i)] | <input checked="" type="checkbox"/> <input type="checkbox"/> |
| Outsides of bulk storage containers are frequently inspected for signs of deterioration, discharges, or accumulation of oil inside diked areas. [See Inspection Log and Schedule in Attachment 3.1] [§§112.8(c)(6) and 112.12(c)(6)] | <input checked="" type="checkbox"/> <input type="checkbox"/> |
| For bulk storage containers that are subject to 21 CFR part 110 which are shop-fabricated, constructed of austenitic stainless steel, elevated and have no external insulation, formal visual inspection is conducted on a regular schedule. Appropriate qualifications for personnel performing tests and inspections are documented. [See Inspection Log and Schedule and Bulk Storage Container Inspection Schedule in Attachments 3.1 and 3.2] [§112.12(c)(6)(ii)] | <input checked="" type="checkbox"/> <input type="checkbox"/> |

| Table G-10 General Rule Requirements for Onshore Facilities | | N/A |
|--|-------------------------------------|-------------------------------------|
| <p>Each container is provided with a system or documented procedure to prevent overfills for the container. Describe:</p> <p><u>Fueling Procedures</u></p> <p>The following procedures will be followed when fueling equipment on-site;</p> <ol style="list-style-type: none"> 1. Trucks will be parked at least 100 ft. from waterways. 2. Truck wheels will be chocked and trailer wheels (if applicable) will be air-locked. 3. A drip tray or suitable catchment basin will be placed under the fueling point. 4. A spill kit will be located near the fueling operation and be readily accessible. 5. Transfer line will be connected from truck to tank. 6. The transfer will be visually monitored by job site personnel at all times. 7. Lines, hoses and valves will be routinely checked during transfer. 8. Tank and truck valves will be confirmed to be closed before disconnecting hose. 9. Material collected in spill containers will be added to the tank or stored in a closed container for off-site disposal. | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Liquid level sensing devices are regularly tested to ensure proper operation [See Inspection Log and Schedule in Attachment 3.1]. [§112.6(a)(3)(iii)] | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Visible discharges which result in a loss of oil from the container, including but not limited to seams, gaskets, piping, pumps, valves, rivets, and bolts are promptly corrected and oil in diked areas is promptly removed. [§§112.8(c)(10) and 112.12(c)(10)] | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Aboveground valves, piping, and appurtenances such as flange joints, expansion joints, valve glands and bodies, catch pans, pipeline supports, locking of valves, and metal surfaces are inspected regularly. [See Inspection Log and Schedule in Attachment 3.1] [§§112.8(d)(4) and 112.12(d)(4)] | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Integrity and leak testing are conducted on buried piping at the time of installation, modification, construction, relocation, or replacement. [See Inspection Log and Schedule in Attachment 3.1] [§§112.8(d)(4) and 112.12(d)(4)] | <input type="checkbox"/> | <input checked="" type="checkbox"/> |

B. Onshore Oil Production Facilities (excluding drilling and workover facilities) (§112.9(b), (c), and (d)):

The owner or operator must meet the general rule requirements as well as the requirements under this section. Note that not all provisions may be applicable to all owners/operators. **In cases where a provision is not applicable, write "N/A".**

| Table G-11 General Rule Requirements for Onshore Oil Production Facilities | | N/A |
|--|--------------------------|-------------------------------------|
| At tank batteries, separation and treating areas, drainage is closed and sealed except when draining uncontaminated rainwater. Accumulated oil on the rainwater is returned to storage or disposed of in accordance with legally approved methods. [§112.9(b)(1)] | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Prior to drainage, diked areas are inspected and [§112.9(b)(1)]: | | |
| <ul style="list-style-type: none"> • Retained rainwater is inspected to ensure that its presence will not cause a discharge to navigable waters | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| <ul style="list-style-type: none"> • Bypass valve is opened and resealed under responsible supervision | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| <ul style="list-style-type: none"> • Adequate records of drainage are kept [See Dike Drainage Log in Attachment 3.3] | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Field drainage systems and oil traps, sumps, or skimmers are inspected at regularly scheduled intervals for oil, and accumulations of oil are promptly removed [See Inspection Log and Schedule in Attachment 3.1] [§112.9(b)(2)] | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| The containers used at this facility are compatible with materials stored and conditions of storage. [§112.9(c)(1)] | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| All tank battery, separation, and treating facility installations (except for flow-through process vessels) are constructed with a capacity to hold the largest single container plus additional capacity to contain rainfall. Drainage from undiked areas is safely confined in a catchment basin or holding pond. [§112.9(c)(2)] | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Except for flow-through process vessels, containers that are on or above the surface of the ground, including foundations and supports, are visually inspected for deterioration and maintenance needs on a regular schedule. [See Inspection Log and Schedule in Attachment 3.1] [§112.9(c)(3)] | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| New and old tank batteries at this facility are engineered/updated in accordance with good engineering practices to prevent discharges including at least one of the following: | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| <ul style="list-style-type: none"> i. adequate container capacity to prevent overflow if regular pumping/gauging is delayed; ii. overflow equalizing lines between containers so that a full container can overflow to an adjacent container; iii. vacuum protection to prevent container collapse; or iv. high level sensors to generate and transmit an alarm to the computer where the facility is subject to a computer production control system. [§112.9(c)(4)] | | |
| Flow-through process vessels and associated components are: | | |
| <ul style="list-style-type: none"> • Are constructed with a capacity to hold the largest single container plus additional capacity to contain rainfall. Drainage from undiked areas is safely confined in a catchment basin or holding pond; [§112.9(c)(2)] and | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| <ul style="list-style-type: none"> • That are on or above the surface of the ground, including foundations and supports, are visually inspected for deterioration and maintenance needs on a regular schedule. [See Inspection Log and Schedule in Attachment 3.1] [§112.9(c)(3)] | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Or | | |
| <ul style="list-style-type: none"> • Visually inspected and/or tested periodically and on a regular schedule for leaks, corrosion, or other conditions that could lead to a discharge to navigable waters; and | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| <ul style="list-style-type: none"> • Corrective action or repairs are applied to flow-through process vessels and any associated components as indicated by regularly scheduled visual inspections, tests, or evidence of an oil discharge; and | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| <ul style="list-style-type: none"> • Any accumulations of oil discharges associated with flow-through process vessels are promptly removed; and | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| <ul style="list-style-type: none"> • Flow-through process vessels are provided with a secondary means of containment for the entire capacity of the largest single container and sufficient freeboard to contain precipitation within six months of a discharge from flow-through process vessels of more than 1,000 U.S. gallons of oil in a single discharge as described in §112.1(b), or a discharge more than 42 U.S. gallons of oil in each of two discharges as described in §112.1(b) within any twelve month period. [§112.9(c)(5)] (Leave blank until such time that this provision is applicable.) | <input type="checkbox"/> | <input checked="" type="checkbox"/> |

| Table G-11 General Rule Requirements for Onshore Oil Production Facilities | | N/A |
|---|--------------------------|-------------------------------------|
| All aboveground valves and piping associated with transfer operations are inspected periodically and upon a regular schedule. The general condition of flange joints, valve glands and bodies, drip pans, pipe supports, pumping well polish rod stuffing boxes, bleeder and gauge valves, and other such items are included in the inspection. [See Inspection Log and Schedule in Attachment 3.1] [§112.9(d)(1)] | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| An oil spill contingency plan and written commitment of resources are provided for flowlines and intra-facility gathering lines [See Oil Spill Contingency Plan and Checklist in Attachment 2 and Inspection Log and Schedule in Attachment 3.1] [§112.9(d)(3)] or Appropriate secondary containment and/or diversionary structures or equipment is provided for flowlines and intra-facility gathering lines to prevent a discharge to navigable waters or adjoining shorelines. The entire secondary containment system, including walls and floor, is capable of containing oil and is constructed so that any discharge from the pipe, will not escape the containment system before cleanup occurs. | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| A flowline/intra-facility gathering line maintenance program to prevent discharges from each flowline has been established at this facility. The maintenance program addresses each of the following: <ul style="list-style-type: none"> Flowlines and intra-facility gathering lines and associated valves and equipment are compatible with the type of production fluids, their potential corrosivity, volume, and pressure, and other conditions expected in the operational environment; Flowlines, intra-facility gathering lines and associated appurtenances are visually inspected and/or tested on a periodic and regular schedule for leaks, oil discharges, corrosion, or other conditions that could lead to a discharge as described in §112.1(b). The frequency and type of testing allows for the implementation of a contingency plan as described under part 109 of this chapter. Corrective action and repairs to any flowlines and intra-facility gathering lines and associated appurtenances as indicated by regularly scheduled visual inspections, tests, or evidence of a discharge. Accumulations of oil discharges associated with flowlines, intra-facility gathering lines, and associated appurtenances are promptly removed. [§112.9(d)(4)] | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| The following is a description of the flowline/intra-facility gathering line maintenance program implemented at this facility: | <input type="checkbox"/> | <input checked="" type="checkbox"/> |

C. Onshore Oil Drilling and Workover Facilities (§112.10(b), (c) and (d)):

The owner or operator must meet the general rule requirements as well as the requirements under this section.

| Table G-12 General Rule Requirements for Onshore Oil Drilling and Workover Facilities | |
|---|--------------------------|
| Mobile drilling or worker equipment is positioned or located to prevent discharge as described in §112.1(b). [§112.10(b)] | <input type="checkbox"/> |
| Catchment basins or diversion structures are provided to intercept and contain discharges of fuel, crude oil, or oily drilling fluids. [§112.10(c)] | <input type="checkbox"/> |
| A blowout prevention (BOP) assembly and well control system was installed before drilling below any casing string or during workover operations. [§112.10(d)] | <input type="checkbox"/> |
| The BOP assembly and well control system is capable of controlling any well-head pressure that may be encountered while the BOP assembly and well control system are on the well. [§112.10(d)] | <input type="checkbox"/> |

ATTACHMENT 2 – Oil Spill Contingency Plan and Checklist

An oil spill contingency plan and written commitment of resources is required for:

- Flowlines and intra-facility gathering lines at oil production facilities and
- Qualified oil-filled operational equipment which has no secondary containment.

| | |
|--|--------------------------|
| An oil spill contingency plan meeting the provisions of 40 CFR part 109, as described below, and a written commitment of manpower, equipment and materials required to expeditiously control and remove any quantity of oil discharged that may be harmful is attached to this Plan. | <input type="checkbox"/> |
|--|--------------------------|

Complete the checklist below to verify that the necessary operations outlined in 40 CFR part 109 - Criteria for State, Local and Regional Oil Removal Contingency Plans - have been included.

Table G-15 Checklist of Development and Implementation Criteria for State, Local and Regional Oil Removal Contingency Plans (§109.5)^a

| | |
|--|--|
| (a) Definition of the authorities, responsibilities and duties of all persons, organizations or agencies which are to be involved in planning or directing oil removal operations. | <input type="checkbox"/> |
| (b) Establishment of notification procedures for the purpose of early detection and timely notification of an oil discharge including: <ul style="list-style-type: none"> (1) The identification of critical water use areas to facilitate the reporting of and response to oil discharges. (2) A current list of names, telephone numbers and addresses of the responsible persons (with alternates) and organizations to be notified when an oil discharge is discovered. (3) Provisions for access to a reliable communications system for timely notification of an oil discharge, and the capability of interconnection with the communications systems established under related oil removal contingency plans, particularly State and National plans (e.g., NCP). (4) An established, prearranged procedure for requesting assistance during a major disaster or when the situation exceeds the response capability of the State, local or regional authority. | <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> |
| (c) Provisions to assure that full resource capability is known and can be committed during an oil discharge situation including: <ul style="list-style-type: none"> (1) The identification and inventory of applicable equipment, materials and supplies which are available locally and regionally. (2) An estimate of the equipment, materials and supplies which would be required to remove the maximum oil discharge to be anticipated. (3) Development of agreements and arrangements in advance of an oil discharge for the acquisition of equipment, materials and supplies to be used in responding to such a discharge. | <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> |
| (d) Provisions for well defined and specific actions to be taken after discovery and notification of an oil discharge including: <ul style="list-style-type: none"> (1) Specification of an oil discharge response operating team consisting of trained, prepared and available operating personnel. (2) Predesignation of a properly qualified oil discharge response coordinator who is charged with the responsibility and delegated commensurate authority for directing and coordinating response operations and who knows how to request assistance from Federal authorities operating under existing national and regional contingency plans. (3) A preplanned location for an oil discharge response operations center and a reliable communications system for directing the coordinated overall response operations. (4) Provisions for varying degrees of response effort depending on the severity of the oil discharge. (5) Specification of the order of priority in which the various water uses are to be protected where more than one water use may be adversely affected as a result of an oil discharge and where response operations may not be adequate to protect all uses. (6) Specific and well defined procedures to facilitate recovery of damages and enforcement measures as provided for by State and local statutes and ordinances. | <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> |

^a The contingency plan must be consistent with all applicable state and local plans, Area Contingency Plans, and the National Contingency Plan (NCP)

ATTACHMENT 3 – Inspections, Dike Drainage and Personnel Training Logs

ATTACHMENT 3.1 – Inspection Log and Schedule

Table G-16 Inspection Log and Schedule
 This log is intended to document compliance with §§112.6(a)(3)(iii), 112.8(c)(6), 112.8(d)(4), 112.9(b)(2), 112.9(c)(3), 112.9(d)(1), 112.9(d)(4), 112.12.(c)(6), and 112.12(d)(4), as applicable.

| Date of Inspection | Container / Piping / Equipment | Describe Scope (or cite Industry Standard) | Observations | Name/ Signature of Inspector | Records maintained separately ^a |
|--------------------|--------------------------------|--|--------------|------------------------------|--|
| | | | | | <input type="checkbox"/> |
| | | | | | <input type="checkbox"/> |
| | | | | | <input type="checkbox"/> |
| | | | | | <input type="checkbox"/> |
| | | | | | <input type="checkbox"/> |

^a Indicate in the table above if records of facility inspections are maintained separately at this facility.

ATTACHMENT 3.2 – Bulk Storage Container Inspection Schedule – onshore facilities (excluding production):

To comply with integrity inspection requirement for bulk storage containers, inspect/test each shop-built aboveground bulk storage container on a regular schedule in accordance with a recognized container inspection standard based on the minimum requirements in the following table.

| Table G-17 Bulk Storage Container Inspection Schedule | |
|--|--|
| Container Size and Design Specification | Inspection requirement |
| Portable containers (including drums, totes, and intermodal bulk containers (IBC)) | Visually inspect monthly for signs of deterioration, discharges or accumulation of oil inside diked areas |
| 55 to 1,100 gallons with sized secondary containment | Visually inspect monthly for signs of deterioration, discharges or accumulation of oil inside diked areas plus any annual inspection elements per industry inspection standards |
| 1,101 to 5,000 gallons with sized secondary containment and a means of leak detection ^a | |
| 1,101 to 5,000 gallons with sized secondary containment and no method of leak detection ^a | Visually inspect monthly for signs of deterioration, discharges or accumulation of oil inside diked areas, plus any annual inspection elements and other specific integrity tests that may be required per industry inspection standards |

^a Examples of leak detection include, but are not limited to, double-walled tanks and elevated containers where a leak can be visually identified.

ATTACHMENT 3.3 – Dike Drainage Log

Table G-18 Dike Drainage Log

| Date | Bypass valve sealed closed | Rainwater inspected to be sure no oil (or sheen) is visible | Open bypass valve and reseal it following drainage | Drainage activity supervised | Observations | Signature of Inspector |
|------|----------------------------|---|--|------------------------------|--------------|------------------------|
| | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |

ATTACHMENT 3.4 – Oil-handling Personnel Training and Briefing Log

Table G-19 Oil-Handling Personnel Training and Briefing Log

| Date | Description / Scope | Attendees |
|------|---------------------|-----------|
| | | |
| | | |
| | | |
| | | |
| | | |

ATTACHMENT 4 – Discharge Notification Form

In the event of a discharge of oil to navigable waters or adjoining shorelines, the following information will be provided to the National Response Center [also see the notification information provided in Section 7 of the Plan]:

Table G-20 Information provided to the National Response Center in the Event of a Discharge

| | | | |
|---|---|-------------------------------------|--|
| Discharge/Discovery Date | | Time | |
| Facility Name | | | |
| Facility Location (Address/Lat-Long/Section Township Range) | | | |
| Name of reporting individual | | Telephone # | |
| Type of material discharged | | Estimated total quantity discharged | Gallons/Barrels |
| Source of the discharge | | Media affected | <input type="checkbox"/> Soil |
| | | | <input type="checkbox"/> Water (specify) |
| | | | <input type="checkbox"/> Other (specify) |
| Actions taken | | | |
| Damage or injuries | <input type="checkbox"/> No <input type="checkbox"/> Yes (specify) | Evacuation needed? | <input type="checkbox"/> No <input type="checkbox"/> Yes (specify) |
| Organizations and individuals contacted | <input type="checkbox"/> National Response Center 800-424-8802 Time | | |
| | <input type="checkbox"/> Cleanup contractor (Specify) Time | | |
| | <input type="checkbox"/> Facility personnel (Specify) Time | | |
| | <input type="checkbox"/> State Agency (Specify) Time | | |
| | <input type="checkbox"/> Other (Specify) Time | | |