

STATE OF NEW YORK
DEPARTMENT OF PUBLIC SERVICE
16 NYCRR PART 753 Citation

Date of Violation(s): 7/24/2026

Date Issued: 10/23/2026

Alleged Entity: CCI Companies, Inc.

Address: P.O. Box 186, 7138 Mount Pleasant Road

City: Canastota

State: NY

Zip Code: 13032

Violation Location: 240 East Colvin Street

City: Syracuse

County: ONONDAGA

Latitude: 43.026051879525895

Longitude: -76.14177836096886

Submitter/Other Party: Niagara Mohawk Power Corporation d/b/a National Grid

Impacted Facilities: 8-inch 1-PSIG Low Pressure Plastic Gas Distribution- Gas Loss: 4,551,744.00 cu ft. - Damaged

Was Excavation Occurring: True

Method of Excavation: Excavator

Nature of Project: Contractor

Description of Project: Water Line Replacement.

Origin of Investigation: Operator

Effect, Public Health, Safety
& Welfare:

Injuries: 0

Fatalities: 0

☐ Property Damage☐ Ignition☒ Blowing Gas☐ Evacuation☐ Road Closure☐ Asbestos Release☐ Emergency Response☐ Other:

Service Interruption: 1

Code Section(s) Violated: §753-3.8

Requirement: After verifying the location of an underground facility, the excavator shall not employ powered or mechanical excavating equipment closer than four inches in any direction from the staked, marked or otherwise designated or known outside diameter or perimeter of such facility or its protective coating unless agreed to in writing by the operator of the affected underground facility. Any such written agreement shall be furnished to the excavator by the operator, upon request.

Remarks: None

Citation Number #:	26-0199-01
One-Call Ticket Number #:	06096-001-915
Photographs:	Yes
Videos:	No
Booklet Provided:	Yes
Investigative Report:	Yes

DPS Investigator:

Robert Draiss

Robert Draiss

Method of Delivery:

NOPV Letter

Issued To:

CCI Companies, Inc.

Signature:

Signature acknowledges receipt only and does not
constitute an admission to the alleged violation(s).

No response to this citation is required. If you wish to respond, write to the New York State Department of Public Service, Pipeline Safety Section, Three Empire State Plaza, Albany, New York 12223-1350. If the Public Service Commission proposes to determine any penalties for the alleged violation(s), you will be notified by separate Notice of Probable Violation (NOPV) letter and provided an opportunity to respond.

Original: Alleged Entity

Copies: (1) Submitter/Other Party, and (2) DPS Files