

RORY M. CHRISTIAN Chief Executive Officer

December 5, 2024

**VIA EMAIL** 

Hon. Michelle L. Phillips Secretary to the Commission 3 Empire State Plaza Albany, NY 12223-1350

Re: Matter No. 21-01188 – In the Matter of the Indian Point Closure Task Force and Indian Point Decommissioning Oversight Board.

Dear Secretary Phillips:

Please accept for filing in the above-captioned matter, the December 5, 2024 presentation of the Indian Point Decommissioning Oversight Board. Should you have any questions regarding this filing, please contact me. Thank you.

Respectfully submitted,

don Jul

Tom Kaczmarek Executive Director Indian Point Decommissioning Oversight Board



## **Decommissioning Oversight Board**

Holtec Decommissioning International (HDI) **December 5, 2024** 

Frank Spagnuolo **Indian Point Site Vice President** 





## www.holtec.com



## Agenda

- Work completed since last DOB (June 13, 2024)
  - Notable changes to plan (RV Seg)
- Work activities planned in early 2025
- NRC updates
- EP Tabletop exercise
- Partial Site Release Process
- NYISO Filing

Safety







# **Vessel Segmentation activities since last DOB**


Notable schedule change: **Transitioned Reactor** Vessel segmentation to U2 due to segmentation equipment repair necessary in U3 cavity


## Unit 2

- V Completed reactor head segmentation and packaging
- ✓ Completed cavity repair and refilled
- ✓ Started upper internal segmentation – Type "A" waste

## Unit 3

✓ Continued segmentation of **Greater Than Class C material** (GTCC)





Upper Photos: U2 head segmentation work Lower Photo (L): U2 cavity during weld repairs Lower Photo (R): U2 cavity with reactor preparing for segmentation









# **Vessel Segmentation activities early 2025**


## Unit 2

- To complete phase 1 of upper internal segmentation - Type "A" waste harvesting
- Relocate team back to U3 VC

## Unit 3

- To complete segmenting all **GTCC** material
- Cask all GTCC material and relocate to the ISFSI Pad
- Invert, segment and package bottom internals head (Type A & B waste)










Upper Photos: U2 cavity segmentation use saw and under-water tools for packaging

Lower Photo: U3 cavity with GTCC segmented, awaiting packaging in 2025

# **Unit 1 Demolition activities since last DOB**

- Complete removal of RCS loop
- Commenced segmentation of 11 boiler steam drum
  - **W**Risers and downcomers
- Abatement tent set up for 13 boiler – both the upper and lower sections





Progress of 11 Boiler Steam Drum Segmentation






# **Unit 1 Demolition activities Early 2025**

Abatement of 13 Boiler

- Abatement Tent on 11 Boiler (Lower drums)
- Removal of U1 Head


Top: Unit 1 head in storage location on 108' (Legacy picture) Middle: Unit 1 Cavity from elevation 108' Right: 13 Boiler Abatement Tent in progress



www.holtec.com | Page 6








## **Unit 3 SFP activities since last DOB SFP Clean -out**

✓ 12 Racks Surveyed and Cleaned

✓ 12 Racks Removed and Shipped


Clean up and vacuum Pool bottom





www.holtec.com Page 7





Left: Inside the U3 FSB during rack removal Above: Inside and outside the U3 FSB prepping the SFP racks for shipment






## **Conventional Plant Demolition activities since last** DOB

- Unit 3 Power Conversion Equipment (PCE) Building
  - Internal Components Removed
- Unit 2 MOSF Tank Removal
  - 7 tanks removed
- Unit 2 Feedwater Heater removal
- Prepped for final removal Protected Area Access Facility (PAAF) equipment removed, prepped for demolition







- Top (L):Lay down area on Southern property for U3 Intake structure equipment Top (R): U3 Travelling screen
- Bottom (L): U2 Security Diesel Underground Fuel Tank
- Bottom (R): U3 Circulating water pump removal from intake structure








## **Conventional Plant Demolition activities Early 2025** INTFRNA

- PAAF Structure
- U2 Security Building
- U3 Security Building
- U3 PCE Building
- Preparation for Old Steam Generator Dismantling





Top (L): Unit 2 Security Buildings Top (R): Site PAAF Bottom (L): PCE Building Bottom (R): Unit 3 Security Building

www.holtec.com Page 9







## **NRC** inspections

- 2<sup>nd</sup> Quarter report dated August 6, 2024 listed no violations
- July Inspection (7/22 7/26)

✓ Joint US NRC & Taiwanese Regulator Inspection  $\sim$  Rad Environmental Monitoring Program (REMP) ✓ Groundwater Sampling plan & RETS Review


- August Inspection (8/19 8/22) ✓ Corrective Action Program & QA Plan ✓ ALARA Evaluations
- September Inspection (9/9 9/12) ✓ Unit 1 Part 61 Source term analysis

✓ Plant walkdowns/tours

November Inspection (11/4 – 11/7)

✓ Solid Rad Waste Management and Transportation









### HOLTEC INTERNATIONAL™



## **Emergency Planning Tabletop Exercise November 13**

- To demonstrate the ability of IPEC to perform adequately during a postulated event – included members from NYS, Westchester County, Rockland County, Verplank Fire, and NYSP
- The exercise focused on ISFSI Emergency Classification Levels, ISFSI Emergency Action Levels, ISFSI-Only Emergency Plan overview, timely/accurate notifications, developing appropriate mitigating actions, and effective communications
- There was an open dialogue among all parties and learning opportunities were captured for next year





**HOLTEC INTERNATIONAL™** 





## **10CFR 50.83 Release Process**

- To release part of a facility or site for unrestricted use, at any time before receiving approval of a license termination plan (LTP), is allowed provided:
  - Evaluate the effect of releasing the property to ensure dose to individual members of the public is less than 10 CFR Part 20 limit, there is no impact to emergency planning, physical security, effluent releases or the siting criteria of 10 CFR Part 100. Update the environmental monitoring program and offsite dose calculation manual and ensure all other applicable statutory and regulatory requirements continue to be met.
  - Perform a historical site assessment of the part of the facility or site to be released.

www.holtec.com | Page 12







## **NYISO Filing Information**

- In October 2024, Holtec submitted a request to New York Independent System Operator (NYISO) for 200 MW of power from the Con Edison transmission system, for future energy planning
- The request was a proactive measure to assess the availability of energy for potential highenergy commercial use
- Specifically, it sought to determine if sufficient energy would be available to support a potential data center at the site of the current IPEC training building property
- This inquiry is part of future business development efforts aimed at reusing the property. There currently is no offer or commitment for a data center or any other specific use of this area







## **Training Building Property Cesium (Cs) Discovery**

- In July, HDI performed surface soil sampling of the property around the training building to support a 50.83 submittal
- One soil sample was found to contain elevated Cs-137 concentration as compared to the rest of the soil samples and the background reference areas
- This area was previously not identified as an Area of Concern (AOC)
- This information was entered into our corrective action program, and we are in the process of developing a sample plan to fully characterize the extent of the condition
- Upon completion of characterization, the soils will be removed consistent with the requirements of 50.83
- More information on next steps will be provided as it becomes available







# Workforce safety updates

Date	Issue
10/28/24	The two individuals were tasked to move an argon bottle onto a (approximately 25 inches off the ground) when one of the work twisted his knee while attempting to position the bottle on the evaluated at the hospital and was cleared to return to work. Inj as a first aid.


The Decommissioning Team focuses workers on *Hazard Recognition*. Not all hazards are created equally, some are less obvious. At Holtec, we utilize the Hazard Wheel to identify potential sources of hidden hazards. The wheel consists of grouping of mechanical, sensory, industrial and societal factors that can challenge workers in the field.



www.holtec.com | Page 15



a tank pad kers fell and pad. Worker was jury was classified





# **Thank You**



Krishna P. Singh Technology Campus 1 Holtec Boulevard Camden, NJ 08104

> Tel: (856) 797-0900 www.holtec.com