



Date: June 8, 2026

Hon. Michelle L. Phillips
Secretary to the Commission
New York State Public Service Commission
Three Empire State Plaza
Albany, NY 12223-1350

Re: Meter Service Provider for Cape Advisors & Compass Development Marketing Group

Case #: 11-02802 [11-M-0710]

Dear Secretary Phillips:

As per the PSC requirements outlined in "16 NYCRR Part 92 Operating Manual dated March 14, 2003", SATEC Engineers have performed accuracy testing for the following residential dwellings:

Site address: 30-77 Vernon Blvd, Astoria, NY 11102

The meters under tests have been found compliant. Should you need any further information or have any questions about this petition, please feel free to contact us.

Respectively,

A handwritten signature in blue ink, appearing to read "Rodney Charles", written over a horizontal line.

Rodny Jean Charles
Project Manager
SATEC, Inc., 10 Milltown Ct, Union, NJ 07083
rcharles@satecinc.com|908-686-9510



Annual Report of Variable Interval Plan Test Status

Period Ending December 31, 2026
Residential Electric Sub-Meters

Building Name and Address:

30-77 Vernon Blvd, Astoria, NY 11102

MFR AND TYPE	Number In Service 1-Jan-2026	Number In Service 31-Dec-26	Net Change + or -	2026 Tests REQUIRED		2026 Tests COMPLETED	2026 METER PERFORMANCE				2027 Tests Required	
				%	#	#	FINAL AVERAGE PERCENT REG.				%	Number
							Outside 98-102%		More Than 102%			
#	%	#	%	#	%	#	%	#	%	#	%	
BFM136	534	534	0	4.0%	22	22	0	0.000%	0	0.000%	4.0%	22

*The above report is a correct summary of all wathour meter
Variable Interval Tests made by this utility, and all tests were conducted
according to the rules of the NY Public Service Commission.*

Signed By : Richel Iran
SATEC Engineer