



Carlos Gavilondo
Senior Counsel II

VIA ELECTRONIC DELIVERY

January 30, 2015

Hon. Kathleen H. Burgess, Secretary
New York State Department of Public Service
3 Empire State Plaza
Albany, New York 12223-1350

**Re: Case 12-E-0201, Proceeding on Motion of the Commission as to the Rates,
Charges, Rules and Regulations of Niagara Mohawk Power Corporation d/b/a
National Grid for Electric Service;
Five-Year Transmission and Distribution Capital Investment Plan, FY16-FY20**

Dear Secretary Burgess:

Pursuant to the Public Service Commission's Order Approving Electric and Gas Rate Plans in Accord with Joint Proposal, issued and effective March 15, 2013 in Case 12-E-0201, Niagara Mohawk Power Corporation d/b/a National Grid ("National Grid" or "Company") hereby submits its annual Transmission and Distribution Capital Investment Plan ("Plan"). The Plan sets forth the Company's projected capital spending on the electric transmission and distribution system for the 5-year period from April 1, 2015 through March 31, 2020 (fiscal years 2016 -2020).

A copy of this filing is also being provided directly to Christian Bonvin and William Lysogorski of Department of Public Service Staff. Please contact me if you have any questions regarding this filing.

Thank you for your attention to this matter.

Respectfully submitted,

/s/ Carlos Gavilondo

Carlos Gavilondo

Enc.

cc: C. Bonvin, DPS
W. Lysogorski, DPS

nationalgrid

**Electric
Transmission &
Distribution
System**

TRANSMISSION AND DISTRIBUTION CAPITAL INVESTMENT PLAN

CASE 12-E-0201

JANUARY 31, 2015

PREPARED FOR:

THE STATE OF NEW YORK PUBLIC SERVICE COMMISSION

THREE EMPIRE STATE PLAZA

ALBANY, NY 12223

2015 NY Capital Investment Plan

Table of Contents

| | | |
|----|--|-----|
| 1. | Executive Summary | 1 |
| | A. Capital Investment Plan Summary | 2 |
| | B. Investment by System | 5 |
| | C. Opportunities and Challenges | 8 |
| | D. Developing the Capital Investment Plan | 12 |
| | E. Organization of this Filing | 14 |
| 2. | Transmission System | 15 |
| | A. Customer Requests/Public Requirements | 16 |
| | B. Damage/Failure Strategies and Programs | 17 |
| | C. System Capacity and Performance Strategies and Programs | 19 |
| | D. Asset Condition | 39 |
| | E. Non-Infrastructure | 58 |
| 3. | Sub-Transmission System | 59 |
| | A. Customer Requests/Public Requirements | 60 |
| | B. Damage/Failure | 61 |
| | C. System Capacity and Performance | 62 |
| | D. Asset Condition | 67 |
| 4. | Distribution System | 73 |
| | A. Customer Requests/Public Requirements | 74 |
| | B. Damage/Failure | 76 |
| | C. System Capacity and Performance | 77 |
| | D. Asset Condition | 90 |
| | E. Non-Infrastructure | 102 |
| 5. | Investment by Transmission Study Area | 103 |
| | A. Northeast | 104 |
| | B. Capital and Hudson Valley | 106 |
| | C. Northern | 113 |
| | D. Syracuse Oswego Cortland | 116 |
| | E. Utica Rome | 121 |
| | F. Genesee | 124 |
| | G. Frontier | 128 |
| | H. Southwest | 134 |
| 6. | Exhibits | 138 |
| | 1. Transmission Investment | 138 |
| | 2. Sub-Transmission Investment | 153 |
| | 3. Distribution Investment | 163 |
| | 4. Revenue Requirement and Rate Impact | 196 |
| | 5. Non-Wires Alternatives | 199 |
| | 6. Overhead Line Refurbishment Projects | 201 |

Chapter 1. Executive Summary

Niagara Mohawk Power Corporation d/b/a National Grid (“Niagara Mohawk” or the “Company”) submits its Five Year Capital Investment Plan (the “Plan”) in compliance with the New York Public Service Commission (“PSC” or the “Commission”) Order issued March 15, 2013, in Case 12-E-0201.¹ The Plan submitted here relates to fiscal years 2016 to 2020 (FY16 to FY20).² The investment levels in the Plan are summarized by system in Table 1-1, below. The Plan reflects total investment levels agreed in the Company’s most recent electric rate case (12-E-0201) through FY16 and the Company’s present estimate of investment levels needed in FY17 – FY20 to meet its obligation to provide safe and adequate service at reasonable cost to customers.³

Table 1-1
Capital Investment Plan by System (\$millions)

| System | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------------------|--------------|--------------|--------------|--------------|--------------|---------------|
| Transmission | 166.8 | 172.0 | 189.0 | 206.0 | 210.0 | 943.8 |
| Sub-transmission | 27.3 | 29.0 | 39.1 | 42.5 | 44.0 | 181.9 |
| Distribution | 253.6 | 251.8 | 285.1 | 288.5 | 295.0 | 1374.0 |
| Total | 447.7 | 452.8 | 513.2 | 537.0 | 549.0 | 2499.7 |

National Grid’s commitment to safety, reliability and efficiency is paramount, and is the foundation for all we do. The five-year investment plan presented here balances the need to constrain infrastructure cost while simultaneously mitigating some of the significant risks on the system. The Company continuously reviews the Plan relative to current risks and information and will revise the Plan as required to meet emergent needs and provide safe and adequate service at reasonable cost to customers.

¹ Case 12-E-0201, *Proceeding on the Motion of the Commission as to the Rates, Charges, Rules and Regulations of Niagara Mohawk Power Corporation for Electric Service*, Order Approving Electric and Gas Rate Plans in Accord with Joint Proposal, issued and effective March 15, 2013 (“Rate Case Order”). Under Section 12.6.1(b) of the December 7, 2012 Joint Proposal adopted by the Rate Case Order, the Company agreed to continue to submit periodic reports as provided in Case 06-M-0878, *Joint Petition of National Grid PLC and KeySpan Corporation for Approval of Stock Acquisition and Other Regulatory Authorizations*, including the annual five-year investment plan.

² The period FY16 to FY20 covers April 1, 2015 - March 31, 2020.

³ Differences between FY15-FY16 system level sub-totals in this Plan and corresponding system level sub-totals in the Joint Proposal are primarily due to changes in investment timing during the period governed by the Joint Proposal and shifts in investment amounts between systems.

2015 NY Capital Investment Plan

1. A. Capital Investment Plan Summary

The Company's capital investment plan is presented by system and by spending rationale. A view of planned investments segmented by system is presented in Table 1-1 above, while a view of planned investments segmented by spending rationale is summarized below.

Investment by Spending Rationale

The Company classifies capital projects into five spending rationales based on their primary investment driver: (A) Customer Requests/Public Requirements; (B) Damage/Failure; (C) System Capacity and Performance; (D) Asset Condition; and (E) Non-infrastructure.

Customer Requests/Public Requirements

Customer Requests/Public Requirements projects are required to respond to, or comply with Customer Requests/Public Requirements mandates. This work includes capital expenditures required to ensure the contractual obligations of the Company adhere to customer and public requirements. These items include new business residential, new business commercial, outdoor lighting, third party attachments, land rights and public requirements including municipal, customer interconnections and wind farms.

Damage/Failure

Damage/Failure projects are required to replace failed or damaged equipment and to restore the electric system to its original configuration and capability following equipment damage or failure. Damage may be caused by storms, vehicle accidents, vandalism or other unplanned events. The Damage/Failure spending rationale is typically non-discretionary in terms of scope and timing. The Damage/Failure budget may also include the cost of purchasing strategic spares to respond to equipment failures.

System Capacity and Performance

System Capacity and Performance projects are required to ensure the electric network has sufficient capacity to meet the growing and/or shifting demands of our customers, as well as changes in the generation landscape. Projects in this category are intended to reduce degradation of equipment service lives due to thermal stress and to provide appropriate degrees of system configuration flexibility to limit adverse reliability impacts of large contingencies. In addition to accommodating load growth, the expenditures in this category are used to install new equipment such as capacitor banks to maintain the requisite power quality, and also include investments to adhere to NERC, NPCC and similar standards.

Asset Condition

Asset Condition projects are required to reduce the likelihood and consequences of failures of transmission and distribution assets. Replacing system elements such as overhead lines, underground cable or substation equipment are examples of such

2015 NY Capital Investment Plan

projects. Investments in the Asset Condition category reflect the targeted replacement of assets based on condition rather than wholesale replacement based on “end of useful life” criteria, especially for transmission line refurbishment projects.

Non-Infrastructure

Non-Infrastructure projects are ones that do not fit into one of the foregoing categories, but which are necessary to run the electric system. Examples in this rationale include substation physical security, radio system upgrades and the purchase of test equipment.


Investment by spending rationale for fiscal years FY16 to FY20 is provided in Table 1-2, and Figure 1-1.

Table 1-2
Investment by Spending Rationale (\$ millions)

| Spend Rationale | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|---------------------------------------|--------------|--------------|--------------|--------------|--------------|---------------|
| Customer Requests/Public Requirements | 87.6 | 86.4 | 91.7 | 93.4 | 94.1 | 453.1 |
| Damage/Failure | 40.2 | 40.1 | 38.1 | 38.6 | 38.4 | 195.4 |
| System Capacity and Performance | 166.8 | 125.2 | 159.4 | 140.0 | 93.2 | 684.7 |
| Asset Condition | 147.5 | 195.0 | 218.0 | 259.0 | 317.2 | 1136.7 |
| Non-Infrastructure | 5.5 | 6.2 | 6.0 | 6.0 | 6.1 | 29.9 |
| Total | 447.7 | 452.8 | 513.2 | 537.0 | 549.0 | 2499.7 |

2015 NY Capital Investment Plan

Figure 1-1
Investment by Spending Rationale by Year FY16-FY20



Spending Rationale Totals

Twenty six percent (\$648.5 million) of the planned infrastructure investment is in the Customer Requests/Public Requirements and Damage/Failure spending rationales. This work is required to address items that are mandatory and non-discretionary in terms of timing. Examples of such work include new business requests, municipal interconnections, capital work done to repair a portion of a distribution feeder damaged in a storm event, and facility relocations to accommodate municipal public works projects.

The System Capacity and Performance spending rationale accounts for approximately 27 percent (\$684.7 million) of the total investment in the Plan, and includes investments to ensure substations and feeders can reliably supply customer load within system design criteria. Examples of investments in this rationale include investments to bring substations into NPCC design, protection and operation standards, to address reliability issues identified as a result of system studies, and planned expansions and network upgrades to accommodate load growth associated with the Luther Forest industrial park expansion.

The Asset Condition portion of the Plan represents nearly 45 percent (\$1136.7 million) of total planned investment. Programs in this rationale aim to mitigate future risks and consequences of potential failures caused by deteriorated assets. An example of a program in this spending rationale is the rebuild of the Gardenville Station, which is a 230/115kV complex south of the Buffalo area.

2015 NY Capital Investment Plan

1. B. Investment by System

Following is a summary of planned investment by system. Chapters 2, 3 and 4 detail the transmission, sub-transmission and distribution system spending, respectively.

Transmission System Summary

The transmission system consists of approximately 6,000 miles of transmission line, 313 transmission substations, more than 500 large power transformers and over 700 circuit breakers at operating voltages above 69kV. To serve the needs of customers over the five year period covered by this Plan, the Company expects to invest approximately \$944 million on the transmission system, as shown in Table 1-3 below. The majority of planned transmission system investment is in the System Capacity and Performance and Asset Condition spending rationales. The System Capacity and Performance category includes spending to address generator retirements, NERC/NPCC standards and transmission owner led system studies. Substantial portions of the planned investment in the Asset Condition category relate to conductor clearance, substation rebuild and overhead line refurbishment programs.

Table 1-3
Transmission System Capital Expenditure by Spending Rationale (\$millions)

| Spend Rationale | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|---------------------------------------|--------------|--------------|--------------|--------------|--------------|--------------|
| Customer Requests/Public Requirements | 0.5 | 0.0 | 0.0 | 0.0 | 0.0 | 0.5 |
| Damage/ Failure | 9.0 | 8.5 | 6.0 | 6.0 | 6.0 | 35.4 |
| Non-Infrastructure | 2.6 | 3.2 | 3.0 | 3.0 | 3.0 | 14.8 |
| System Capacity /Performance | 93.3 | 58.6 | 76.7 | 57.7 | 11.9 | 298.2 |
| Asset Condition | 61.3 | 101.6 | 103.3 | 139.4 | 189.1 | 594.7 |
| Total | 166.8 | 172.0 | 189.0 | 206.0 | 210.0 | 943.8 |

2015 NY Capital Investment Plan

Sub-Transmission System Summary

The sub-transmission system includes approximately 4,240 miles of lines including: 290 miles of 69kV, 365 miles of 46kV, 2,332 miles of 34.5kV, 1,050 miles of 23kV and 200 miles of lines below 23kV. To serve the needs of customers over the five year period covered by this Plan, the Company expects to invest approximately \$182 million on the sub-transmission system, as shown in Table 1-4 below.

Table 1-4
Sub-Transmission System Capital Expenditure by Spending Rationale (\$millions)

| Spend Rationale | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|---------------------------------------|-------------|-------------|-------------|-------------|-------------|--------------|
| Customer Requests/Public Requirements | 1.6 | 1.5 | 2.3 | 3.7 | 3.2 | 12.3 |
| Damage/Failure | 3.4 | 3.5 | 3.5 | 3.6 | 3.0 | 16.9 |
| System Capacity & Performance | 3.3 | 3.6 | 1.2 | 2.0 | 2.9 | 12.9 |
| Asset Condition | 19.0 | 20.5 | 32.1 | 33.3 | 34.9 | 139.8 |
| Total | 27.3 | 29.0 | 39.1 | 42.5 | 44.0 | 181.9 |

This five year Plan envisions significant expenditures on the sub-transmission system in the areas of asset condition and system capacity and performance. Projects previously classified as sub-transmission station projects have now been redirected into transmission or distribution budgets.

2015 NY Capital Investment Plan

Distribution System Summary

The Company's distribution system consists of lines and substations typically operating at 15kV and below. There are nearly 36,000 circuit miles of overhead primary wire and nearly 7,500 circuit miles of underground primary cable on the system supplying approximately 400,000 overhead, padmount and underground distribution transformers. Additionally, there are 421 substations providing service to the Company's 1.6 million electric customers.⁴ The current five year plan for distribution is presented in Table 1-5.

Table 1-5
Distribution System Capital Expenditure by Spending Rationale (\$millions)

| Spend Rationale | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|---------------------------------------|--------------|--------------|--------------|--------------|--------------|---------------|
| Customer Requests/Public Requirements | 85.5 | 84.9 | 89.3 | 90.9 | 89.7 | 440.3 |
| Damage/Failure | 27.7 | 28.1 | 28.6 | 29.5 | 29.1 | 143.0 |
| System Capacity & Performance | 70.1 | 63.0 | 81.5 | 78.4 | 80.3 | 373.4 |
| Asset Condition | 67.3 | 72.9 | 82.6 | 93.2 | 86.3 | 402.2 |
| Non-Infrastructure | 3.0 | 3.0 | 3.0 | 3.1 | 3.0 | 15.1 |
| Total | 253.6 | 251.8 | 285.1 | 295.0 | 288.5 | 1374.0 |

This Plan envisions the majority of investment in the distribution system will be in the Customer Requests/Public Requirements, System Capacity and Performance, and Asset Condition spending rationales.

⁴ The distribution system data was taken January 24, 2015 from National Grid Asset Information Website located at <http://usinfo.net2/OurOrganization/NetworkStrategyUS/AssetManagement/Pages/AssetDetails.aspx>.

1. C. Opportunities and Challenges

Among the opportunities and challenges facing the Company and its customers over the period covered by this five year Plan are:

- Changing regulatory or compliance requirements requiring increased or different investments (e.g., changes in the definition of Bulk Electric System that will result in increased investment requirements, or accelerated remediation requirements resulting from NERC actions).
- Implementation of initiatives to accommodate increased deployment of distributed energy resources and electric vehicles, increase penetration of large-scale renewable resources and the infrastructure needs to accommodate those resources.
- Expansion of advanced grid applications.
- Investments in transmission upgrades to increase upstate to downstate transfer capacity.⁵
- Changes in the existing generation supply portfolio in the region, such as the potential closure of large generation units that may require electric delivery infrastructure solutions, the development of processes to evaluate and accommodate generation closures and repowering and potential growth in distributed generation including renewables.
- Challenges related to targeted replacement of assets whose overall condition is becoming degraded and that are well beyond typical asset lives, including increased operations and maintenance spending and service reliability issues.
- Introduction of large spot loads on the system that may require significant system reinforcements in relatively short timeframes.
- Investments to improve storm resilience (See discussion below).
- Investments to bring forward the goals and opportunities envisioned in the Commission's proceeding on Reforming the Energy Visions (See discussion below).

The Company will continue to monitor and evaluate developments in these and other areas and adjust its investment plans as appropriate to meet changing needs and maximize opportunities for greater efficiency consistent with providing safe and adequate service to customers.

⁵ The Company has been engaged in developing transmission project alternatives in connection with Case 13-E-0488 (the "AC Proceeding") and related proceedings. Capital investments associated with those project alternatives are not included in this Plan.

Storm Resilience Investments

The June 22, 2013 Report of the Moreland Commission on Utility Storm Preparation and Response (“Report”) reviewed the responses of the State’s utilities to several recent major weather events, including Superstorm Sandy, Tropical Storm Lee and Hurricane Irene. The Moreland Commission report included several recommendations regarding capital investment and utility operations intended to make utility systems more resilient to future storm events and mitigate the impacts of such events on customers. Recommendations to make the system more resilient include:

- Revised design standards
- Targeted response to flood potential
- Critical equipment location review
- Changes in material types and sizes
- Use of underground cables in specific areas or conditions

The Report recommended developing new standards for future replacement projects and the use of asset health assessments in determining the initial priority of capital investments. National Grid currently prepares and files with the PSC an annual Asset Condition Report and information developed for that report guides the Company’s capital investment plan. Increased resilience and infrastructure hardening have been consistent elements of past work plans. Such work includes:

- Additional line fusing
- Small wire replacement
- Tree wire installation
- Select feeder hardening
- Circuit automation
- EMS/communications
- Recloser installations
- Station flood mitigation

As resilience-related investments increase, future capital plans will likely reflect increased spending levels due to greater material and equipment costs. For example the Company may use underground cable in specific locations to avoid overhead damage risk where pole and overhead conductor may have ordinarily been used in the past. Undergrounding such facilities may provide greater storm resilience but also results in greater initial capital investment than an overhead installation.

Similarly, the Company has standardized the use of class 3 poles. Class 3 poles are larger diameter, stronger poles than the class 5 poles previously used by the Company in many standard applications. The Company is also looking at extending the locations that should be hardened by the use of grade B construction. Grade B construction is typically used in situations where a failure could cause significant impact, such as highway or waterway crossings. The Moreland Commission report recommended targeting critical infrastructure in communities and hardening those locations to reduce

outage risk. The Company has revised its standards to provide guidance on the use of grade B construction for different situations such as to reduce risk of service loss to critical community infrastructure. Such revisions include use of stronger H1 class poles for new recloser and loadbreak installations, the use of fiberglass crossarms for deadends rather than use of wood crossarm assemblies, and the use of grade B construction for all new double circuit construction.

The Company has standardized the use of tree wire and spacer cable construction for treed and heavily treed areas, respectively. Tree wire has more insulation than covered wires used in the past, providing improved performance in treed areas. Spacer cable construction uses a grounded messenger above conductors and a compact bundle construction to improved line performance in heavily treed areas.

In the fiscal year 2016 plan the following projects explicitly address storm hardening and resiliency efforts.

- Side Tap Fusing
- Blue Ridge Rd Storm Hardening
- Hoffman Rd Storm Hardening
- Chestertown 51 Storm Hardening
- Chestertown 52 Storm Hardening
- Battenkill 57 Storm Hardening
- Front St Flood Mitigation
- St. Johnsville Flood Mitigation
- Whiteboro Flood Mitigation
- Union Falls Flood Mitigation
- Lowville 77354 Storm Hardening
- East Pulaski 32451 Storm Hardening
- Alder Creek 70152 Storm hardening

Although some investments in the Plan explicitly address storm hardening and preparation for severe weather events, storm hardening-related costs are also reflected in other projects and programs in the form of enhanced standards or equipment costs. A hardened system will reduce reliability impacts caused by storm events, but will take many years to implement.

Reforming the Energy Vision (“REV”)

The Commission is undertaking a comprehensive examination of the State’s energy system with the aim of developing regulatory policies to promote more efficient use of energy, greater penetration of solar and wind resources, broader deployment of distributed energy resources, and greater use of advanced energy management products, among other things. Investments in this Plan are consistent with advancing the goals of REV. For example, the Company has identified a number of sub-transmission automation project candidates and a series of energy management system (“EMS”) projects that will add foundational capabilities to support REV objectives. In addition, all new substations will be incorporated into the Company’s SCADA

(supervisory control and data acquisition) system, and several substation projects provide for retirement of antiquated facilities to which our control centers currently have no visibility or control. As the REV process advances and new technologies and systems emerge, the Company will revise its investment plan as necessary to achieve an outcome that promotes the REV objectives and the interests of customers.

Non-Wires Alternatives

As part of its 2010 electric rate case (Case 10-E-0050), National Grid committed to developing a process to evaluate non-wires alternatives (NWAs) to traditional infrastructure investments. The Company has established a set of planning guidelines and criteria for the review and consideration of NWAs. These guidelines include two stages of review: one by transmission and distribution planners as they review potential capital investment needs; and another by the Product & Energy Services group project managers in the Company's customer organization. A further discussion of the NWA process is provided in Exhibit 5.

Bill Impacts

The Company prepared a simplified analysis to estimate the revenue requirement effects in fiscal years 2016, 2017 and 2018 associated with the proposed capital investment levels included here, as well as an estimate of the associated per kWh impact of the resulting revenue requirement on a residential SC1 customer. For a typical residential SC1 customer, the allocated per kWh cost resulting from the investment levels included in the Plan would be \$0.00271/kWh in FY2016; \$0.00433/kWh in FY2017; and \$0.00607/kWh in FY2018. Details of the simplified analysis are included in Exhibit 4 of this filing.

2015 NY Capital Investment Plan

1. D. Developing the Capital Investment Plan

The Capital Investment Plan is based on the Company's current assessment of the needs of the electric delivery system over the Plan period. The investments described in this Plan are needed to provide customers with safe and adequate electric service, meet regulatory requirements, address load growth/migration, and replace equipment that is damaged or that fails. The investment levels in the Plan do not reflect costs of investments that may be needed to implement or accommodate new public policy initiatives, new regulatory requirements, technological developments, or the integration of renewable technologies that are not explicitly covered in the Plan.

Mandatory programs and projects (i.e., those under Customer Requests/Public Requirements and Damage/Failure spending rationales) known at this time are included in the Plan. Such programs and projects include new customer and generator connections, regulatory commitments, public requirements that necessitate relocation or removal of facilities, safety and environmental compliance, and system integrity projects such as response to damage/failure and storms.

Programs and projects in the other categories (i.e., System Capacity and Performance and Asset Condition spending categories) are developed based on system studies and evaluation of existing assets by subject matter experts for inclusion into the Plan. Inclusion/exclusion for any given project is based on several different factors including, but not limited to: project in-progress status, risk score, scalability, and resource availability. In addition, when it can be accomplished, the bundling of work and/or projects is analyzed to optimize the total cost and outage planning. The Company's objective is to arrive at a five year capital budget that is the optimal balance in terms of making the investments necessary to maintain the performance of the system for customers, while also ensuring cost-effective use of available resources.

The Plan budget is developed in a manner that is consistent with, and influenced by, the programs and initiatives being implemented as a result of the management audit in Case 08-E-0827. Those programs and initiatives will continue to mature and improve with time, resulting in further improvements in the capital planning and delivery processes for the benefit of customers. In addition, because of the time horizon over which the Company must budget its infrastructure investments, there are inevitable changes in budgets and project estimates over time. Such changes may be due to changes in project scope, changing material or resource costs, changing customer needs, or a more refined estimate based on where the project is in its development. External factors, such as generation retirement announcements or new regulatory or legislative requirements, also drive changes in the Plan budget.

Cost estimates for projects that are already in-process, or are soon to be in-process, generally have +/- 10% cost estimates. Other projects at earlier stages in the project

2015 NY Capital Investment Plan

evolution process, and the budgets for those projects are accordingly less refined and are more susceptible to changes in scope and budget. The projects in the Company's portfolio are continuously reviewed for changes in assumptions, constraints, as well as project delays, accelerations, weather impacts, outage coordination, permitting/licensing/agency approvals, and system operations, performance, safety, and customer driven needs that arise; and is updated accordingly throughout the year.

The Company includes certain Reserve line items in its Capital Investment Plan to allow flexibility to accommodate contingencies not known at the time the plan is developed and to allocate funds for projects in future years whose scope and timing have not yet been determined. Reserve funds for budget years 1 and 2 are typically negative values and are established to acknowledge the risk associated with projects that may arise in response to unforeseen concerns such as the replacement of damaged or failed equipment, customer or generator requirements, regulatory mandates, or delays in licensing and permitting of larger projects. For future year budgets, typically years 3 through 5, historical trends are used to develop the appropriate reserve levels and are typically a positive value. As specific project details become available, emergent projects are added to the Plan with funding drawn from the reserve funds or individual projects in the plan are re-prioritized. The Company tracks and manages budgetary reserves and emergent work as part of its investment planning and current-year spending management processes, and reports that information quarterly to Staff.

The Company uses different approaches to deliver the investment Plan based on the differences in scope and character of Transmission and Distribution construction. With respect to the Transmission portion of the Company's investment plan, the Company will supplement its internal workforce with competitively procured contractor resources. On the Distribution side, the Company's internal workforce will continue to be primarily supplemented by the Company's Distribution Alliance contractor and competitively procured contractor resources.

The Company's risk-based approach to selecting projects and programs for inclusion in the Plan, coupled with its efforts to improve cost estimating and implement performance metrics that include substantial financial consequences, results in a capital investment budget that meets the needs of customers at reasonable cost.

1. E. Organization of this Filing

The remainder of this Plan provides detail on the programs and projects that comprise the Five Year Capital Investment Plan. The document is segmented into the following chapters:

Chapter 2 - Transmission System

Chapter 3 - Sub-Transmission System

Chapter 4 - Distribution System

Chapter 5 - Investment by Transmission Study Area

Chapter 6 – Exhibits

Chapter 2. Transmission System

The transmission system consists of approximately 6,000 miles of transmission line, 313 transmission substations, more than 500 large power transformers, and over 700 circuit breakers at operating voltages above 69kV. The Company expects to invest approximately \$944 million on the transmission system over the next five years as shown in Table 2-1 below.

Table 2-1
Transmission System Capital Investment by Spending Rationale (\$millions)

| Spend Rationale | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|---------------------------------------|--------------|--------------|--------------|--------------|--------------|--------------|
| Customer Requests/Public Requirements | 0.5 | 0.0 | 0.0 | 0.0 | 0.0 | 0.5 |
| Damage/ Failure | 9.0 | 8.5 | 6.0 | 6.0 | 6.0 | 35.4 |
| Non-Infrastructure | 2.6 | 3.2 | 3.0 | 3.0 | 3.0 | 14.8 |
| System Capacity /Performance | 93.3 | 58.6 | 76.7 | 57.7 | 11.9 | 298.2 |
| Asset Condition | 61.3 | 101.6 | 103.3 | 139.4 | 189.1 | 594.7 |
| Total | 166.8 | 172.0 | 189.0 | 206.0 | 210.0 | 943.8 |

The \$943.8 million 5-year transmission system investment level in this Plan is \$7.4 million more in total than the 5-year investment level of the 2014 Plan. The remainder of the chapter briefly describes major capital investment programs that comprise a significant portion of the Company's overall five-year transmission capital investment Plan. A complete list of all Transmission projects in the capital plan can be found in Exhibit 1.

The sections below describe the investment drivers and customer benefits along with a description of significant changes from last year's Plan. Specific asset condition and performance issues are described in further detail in the annual Report on the Condition of Physical Elements of Transmission and Distribution Systems filing to the PSC, most recently filed October 1, 2014.

2015 NY Capital Investment Plan

2. A. Customer Requests/Public Requirements

Transmission investments in this spending rationale can include land rights and public requirements including municipal, customer interconnections and wind farms. Because customer interconnection projects are typically reimbursable (i.e., costs incurred by the Company are paid for by the customer), there is no net effect to the capital plan from such projects. The Company does not anticipate any significant non-reimbursable Customer Requests/Public Requirements transmission system projects over the 5-year period of this Plan.

The New York Power Authority (NYPA) is working with New York State Electric & Gas (NYSEG) to install the “Marcy South Series Compensation” project on the 345kV transmission system as part of the Transmission Owners’ Transmission Solutions (TOTS) project in Central NY. During the development of this project, it was determined that protective relays and circuit breakers, located at Company-owned 345kV substations, would need to be modified / upgraded as a consequence of the project. These projects are included in the Customer Requests/Public Requirements spending rationale and expected to be reimbursable to the Company with no net effect on the projected capital investment in this Plan.

2015 NY Capital Investment Plan

2. B. Damage/Failure

The Damage/Failure investment levels for the transmission system are based on historical actual costs. The Company does not forecast any significant specific transmission system projects in the Damage/Failure spending rationale over the 5-year period of this Plan except for the Leeds Static Var Compensator ("SVC") Transformer and North Leroy Transformer replacement projects discussed below.

Leeds SVC B Phase Transformer Replacement

On June 25, 2014 the Leeds Station SVC B phase transformer tripped out on fault pressure due to animal contact on Switch 533. During testing of this transformer, it was determined that the B phase transformer failed internally. The transformer was replaced with a system spare single phase transformer and the SVC was returned to service. This project is to replace the installed system spare transformer at Leeds with a new 345-18kV; 60/80/100 MVA transformer.

Drivers:

The B phase transformer failed and a replacement is needed to replace the system spare.

Customer Benefits:

A re-wind of the failed transformer was investigated; however, the cost savings of the re-wind compared to the cost of a brand new transformer was minimal. A new transformer has a projected long term life span of 45-60 years where a rewind transformer usually has a life span of 25-35 years per industry standards.

2014 to 2015 Variance:

This damage/failure project was not in the 2014 Plan.

Table 2-2
Transmission – Leeds SVC B Phase Transformer Replacement
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | - | - | - | - | - | - | - |
| 2015 | - | 1.4 | - | - | - | - | 1.4 |

2015 NY Capital Investment Plan

North Leroy Transformer #1 Replacement

The North Leroy transformer has been tested through in-service and diagnostic analysis and is showing signs of internal deterioration. This transformer DGA analysis of the oil indicates it has been wet since 2007 due to a warped top lid. The transformer is being replaced with a larger 115-34.5kV;15/20/25 MVA transformer with an LTC and a new pad will be constructed with oil containment to meet current substation engineering specifications. The transformer protection equipment will also be upgraded to current engineering standards.

Drivers:

This transformer has experienced multiple oil spills in recent years and the substation is on the New York State Department of Environmental Conservation's ("NYDEC's") list as requesting a permanent solution. Since 2010, National Grid has reported four non-PCB oil spills to NYDEC associated with noted oil releases from the transformer (March 25, 2010; July 18, 2011; April 14, 2012; and May 18, 2012). The DGA analysis using Duval's triangle suggests the transformer has been subjected to thermal thru faults ranging from 300 to 700 degree C and the high side winding paper has shown significant paper deterioration.

Customer Benefits:

The benefit of this project will be assurance of the availability of the 34.5kV distribution load supplied in the South Genesee network area where North Leroy station is one of six sub-transmission stations serving the area. Otherwise customers would be exposed to radial supply and become susceptible to interruption or unacceptable low voltage after a single contingency.

2014 to 2015 Variance:

This damage/failure project was not in the 2014 Plan.

Table 2-3
Transmission – North Leroy Transformer #1 Replacement
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | - | - | - | - | - | - | - |
| 2015 | - | 0.4 | 1.8 | 0.1 | - | - | 2.3 |

2. C. System Capacity and Performance

There are three significant areas of transmission system investment in the System Capacity and Performance spending rationale in the next five years: generator retirements, NERC/NPCC standards, and transmission owner led system studies.

2 C.1 Generator Retirements

Generator retirement related projects are intended to reinforce the transmission system to avoid or mitigate reliance on market generators to maintain system reliability and performance. In this Plan, the Company has included several transmission projects intended to mitigate the impacts of the closure or potential closure of the Dunkirk, Cayuga and Syracuse Energy Project generating facilities.

Dunkirk

On March 14, 2012, NRG announced plans to mothball its coal fired generation located at Dunkirk. An analysis by National Grid (Part 1) identified near-term projects that would mitigate the system impact of the mothballing for all but one 115kV generating unit. These near-term projects were completed by June 1, 2013. A second analysis (Part 2) of a full generation shutdown was later completed that identified more long-term system reinforcements needed.

In January 2013, the Public Service Commission directed a comparative evaluation of generation repowering and transmission alternatives to address the issues that would result from shutdown of the Dunkirk plant. In February 2014, National Grid and Dunkirk reached a 10-year agreement between them whereby Dunkirk would add gas-fired capability to Units 2, 3 and 4 in exchange for payment from National Grid of approximately \$20 million per year. The agreement anticipates a target in-service date of September 2015 and would provide reliability benefits in National Grid's western New York service area, as well as promote a variety of economic, environmental, operational, and market benefits. The agreement would also increase the Company's flexibility with respect to the timing of certain transmission investments for western New York. The Commission approved the agreement in June. Nevertheless, the agreement does not eliminate the need for transmission investment in the area, and the following projects are included in the Plan:

- Reconductoring of two 115 kV lines between Five Mile Road and Homer Hill, each 7.4 miles in length. (C047319) - \$8.7m.
- Homer Hill Substation 115kV bus upgrade. (C059300) - \$0.2m.

Drivers:

A 2013 transmission study of Western New York tested both N-1 and N-1-1 design criteria, compliance with NERC TPL Standards, NPCC Directory #1, NYSRC Reliability

2015 NY Capital Investment Plan

Rules and the Company's Transmission Planning Guide (TGP 28). These standards require the entire transmission system to meet N-0 and N-1 voltage, thermal and stability criteria as well as the bulk power system and long lead time items to meet the same criteria for N-1-1 conditions. The transmission investments identified allow for the potential scenario where the Dunkirk units are unable to return to service as anticipated.

Customer Benefits:

Exposure to service interruptions and performance degradation, including potential load shedding in the event of certain key contingencies, would be reduced significantly. In addition, completing these projects would allow the RSS contract to be terminated before the refueled units are available.

2014 to 2015 Variance:

The difference in spend between the 2014 Plan and this year relates primarily to investment made in FY15 which is not included in this FY16-FY20 forecast. The installation of capacitor banks at Huntley (C047316) and Dunkirk (C047318) totaling \$1.4M combined was completed in FY15. The Five Mile - Homer Hill reconductoring project commenced in FY15 as well and will be completed in FY16.

Table 2-4
Transmission - Dunkirk Generation Mothballing
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 11.1 | 6.4 | | - | - | - | 17.5 |
| 2015 | - | 8.9 | - | - | - | - | 8.9 |

Cayuga

To meet existing needs within its Auburn region, NYSEG has proposed construction of a new 115kV line between the National Grid Elbridge substation and the NYSEG State Street substation. This new line would parallel the existing #5/#972 lines between the same two substations on the existing rights-of-way owned by the two companies respectively. The State Street substation predominately supplies load in the Auburn area of NYSEG service territory. The #5 line shares a single double-circuit tower with the #15 line in a right-of-way owned by National Grid. The #15 line serves load in the Geneva area of the NYSEG service territory. The National Grid right-of-way also includes other lines that connect to RG&E and National Grid facilities further to the west in New York State.

In September 2012, the owners of the Cayuga generating plant (within the NYSEG service territory) announced plans to mothball both units. A subsequent joint analysis by the NYISO, NYSEG, and National Grid determined that system performance would not meet regulatory reliability criteria if the two Cayuga generators were no longer available.

2015 NY Capital Investment Plan

The long term solution that was identified by the joint analysis team to mitigate both the existing problems in the Auburn area as well as the reliability problems resulting from mothballing of Cayuga generation comprises the following major components with investment levels greater than \$2 million:

- Construct a new 115kV line on the National Grid right-of-way (10.3 miles) between Elbridge and the NYSEG right-of-way to the State Street substation (C047298) - \$8.9m (this project is proposed to be built and owned by NYSEG).
- Add a second set of new conductors onto the new double-circuit towers built to hold the new line between the Elbridge substation and the NYSEG right-of-way to State Street; connect this second set of new conductors so as to serve as the #15 line over this 10.3 mile section of right-of-way; bus together on existing towers the old conductor of the #15 line and the existing conductor of the #5 line over the 10.3 mile section of the National Grid right-of-way between the Elbridge substation and the NYSEG right-of-way to State Street (C047297) - \$3.6M (this project is to be reimbursed by NYSEG).
- Add two breaker positions in the Elbridge substation for the new 115kV line to State Street and the relocated #15 line (C047299) - \$3.1m (this project is to be reimbursed by NYSEG).

Drivers:

The new 115kV line between Elbridge and State Street is driven by NYSEG's needs to serve its customer load in the Auburn area. These needs relate to load growth and to voltage performance and existed prior to the announcement of Cayuga generator mothballing.

Customer Benefits:

These projects are in support of NYSEG to maintain reliable service to its customers.

2014 to 2015 Variance:

The primary variance between the 2014 and 2015 Plans results from a delay in the Article VII approval process and a refinement of cost estimates. The capital forecast in Table 2-4 below includes only those projects that are fully reimbursable by NYSEG. Because such projects are expected to be fully reimbursable, they will not affect National Grid's net capital spending in the long run.

Table 2-5
Transmission - Cayuga Generation Shutdown
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 19.6 | 3.1 | 0.3 | - | | | 23.0 |
| 2015 | - | 12.0 | 1.0 | 2.6 | - | - | 15.6 |

2015 NY Capital Investment Plan

Syracuse Energy

In June 2013 GDF SUEZ announced plans to retire its Syracuse Energy Generation facility. A subsequent joint analysis by the NYISO and National Grid determined that system performance would not meet regulatory reliability criteria if this plant were retired.

Performance of portions of the Syracuse area transmission system was shown to be dependent upon the output of local area generation. The major project triggered by the Syracuse Energy facility retirement is reconductoring the Clay – GE #14 115kV line (C045253 - \$5.1m).

Drivers:

With Syracuse Energy retired, the Clay – GE #14 line was found to become loaded beyond LTE and STE ratings for certain applicable N-1-1 criteria contingency testing. To bring this line back into compliance with criteria, 4.67 miles of 4/0 copper conductor will need to be replaced with 795 ACSR.

Customer Benefits:

This project will eliminate the exposure to potential service interruptions including load shedding in the event of certain key contingencies.

2014 to 2015 Variance:

Reconductoring the Clay – GE#14 line began in FY15 and will conclude in FY16.

Table 2-6
Transmission – Syracuse Energy Generation Retirement
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 10.1 | 3.3 | - | - | - | - | 13.4 |
| 2015 | - | 5.1 | - | - | - | - | 5.1 |

The Company does not control, and has limited ability to project, future generator retirements. As a result, investment plans related to unannounced retirements are difficult to develop. The Company participates actively in NYISO working groups that monitor generator retirements, and is working with the NYISO and other transmission owners in an effort to assess impacts of potential generator retirements across the state. To the extent future generator retirement announcements affect the Company's investment needs, the Company's subsequent investment plans will reflect those investment needs.

2 C.2 NERC/NPCC Standards

Projects in this investment area are designed to bring the Company into compliance with applicable regulatory planning standards.

Substation Compliance Upgrades and Critical Infrastructure Protection

Projects to upgrade the Clay 115kV (C028705) and Porter 115kV (C028686) substations to meet recently applicable NPCC criteria have mostly been completed with only \$100K forecasted to be spent in FY16 on Porter's 115kV rebuild. Upgrades to 230kV circuit breakers, disconnect switches and potential transformers at Porter are also needed to comply with applicable system standards (C036866 - \$16.3m).

NERC's Critical Infrastructure Protection v5 Reliability Standards specify that consistent and sustainable security management controls must be established to protect Bulk Electric System ("BES") cyber systems against compromise that could lead to instability in the BES.

Drivers:

In accordance with NPCC criteria adopted in April 2007, testing of qualifying substations across New York State was performed by the NYISO. The results indicated Clay and Porter 115 kV substations as facilities that were required to be brought into compliance with specific NPCC design, protection and operation requirements. Critical Infrastructure Protection v5 applies to National Grid and has an enforcement date of April 1, 2016.

Customer Benefits:

In addition to compliance with NPCC and NYSRC requirements, the benefits of completing these projects are reductions in system vulnerability to certain severe contingencies identified in system studies. Customers throughout central New York will benefit from reduced vulnerability of the transmission system to such contingencies. Implementing the proper cyber security hardware and software systems protects the BES.

2014 to 2015 Variance:

The current construction sequence has the Clay and Porter 115kV projects completing by FY16. The 230kV breakers, disconnects and potential transformers at Porter are on track to be replaced by FY19. The Critical Infrastructure Protection v5 work is scheduled to be completed in FY16 to meet the April 1, 2016 deadline.

2015 NY Capital Investment Plan

Table 2-7
Transmission – Substation Compliance Upgrades
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 3.4 | 0.1 | 0.3 | 1.0 | 15.0 | - | 19.8 |
| 2015 | - | 2.1 | 0.9 | 1.0 | 15.0 | - | 18.9 |

2 C.3 Transmission Owner Led System Studies

These projects are the result of studies performed by the Company's Transmission Planning department. Needs and alternative solutions are investigated during periodic area studies to determine whether the system complies with reliability standards. Included in this testing are; compliance with NERC TPL Standards, NPCC Regional Reliability Reference Directory #1, NYSRC Reliability Rules and the Company's Transmission Planning Guide (TGP 28). These standards require the entire transmission system to meet voltage, thermal, and stability criteria.

Eastern NY Division Reinforcements

Reinforcements in the Northeast region are focused on the Saratoga and Glens Falls areas of the Company's eastern division. These reinforcements address thermal and voltage needs that arise from accelerated load growth, particularly at Luther Forest Technology Campus ("LFTC"). The major components in this program include:

- Installation of a new Eastover Road 230/115kV substation near where the existing Rotterdam-Bear Swamp 230kV line crosses the existing Mohican-North Troy #3 line and the Battenkill-North Troy #10 115kV lines. This station would serve as a primary source to 115kV lines serving the east side of the Northeast Region. (C031326 - \$3.3m & C031419 - \$1.2m)
- Installation of a second 230/115kV transformer in the Eastover Road substation. This second transformer will relieve loading of the Rotterdam 230/115kV transformers. (C060247 - \$5.5m)
- Rebuild the Mohican-Battenkill #3 and #15 lines between Mohican and Battenkill substations and reconductor 14.2 miles of the #15. This project requires an Article VII application on which the Company is currently working. (C034528 - \$32.8m)
- Installation of the Ballston Tap Switching Station and line tap (C060250 - \$9.2m and C060251 - \$1.1m respectively) and the Mulberry Tap Switching Station and line tap (C060252 - \$9.2m and C060253 - \$1.1m respectively). These switching stations are associated with the load growth at LFTC.
- Installation of a cap bank at Ticonderoga. (C060254 - \$1.9m)
- Reconfigure the Rotterdam 115kV connections of the TB6 and TB7 transformers on the 99G and 33G buses. This reconfiguration will relieve stress on all the Rotterdam 230/115kV transformer banks. (C060255 - \$2.1m)

2015 NY Capital Investment Plan

Other reinforcements in the Company's eastern division are focused in the Capital and Hudson areas. The major components in this program include:

- Installation of reactors in #19 and #20 lines. The reactors will increase the impedance of these lines, thus reducing power flow on them to a level that is within their thermal rating. (C060246 - \$1.6m)
- Reconductor twelve miles of the Rotterdam-Menands line (#11/8/10) to relieve potential contingency overloads. (C060243 - \$1.2m)

Drivers:

The transmission system serving the Northeast Region is currently exposed to post contingency thermal overloads during summer peak periods, on certain transformers at Rotterdam and the Mohican-Battenkill 115kV Circuit. These conditions present a need to relieve 115kV thermal overloads which affect the transmission supply to the Northeast Region and to add transformation capacity.

Projected load growth at the Global Foundries (GF) chip-manufacturing plant at the Luther Forest Technology Campus (LFTC) site further exacerbates transmission system performance issues within the Northeast Region. This drives the addition of the second Eastover transformer and the addition of the Ballston and Mulberry Tap Switching Stations.

The transmission system serving the Capital/Hudson area is also currently exposed to post contingency thermal overloads during summer peak periods. These overloads affect the #19 and #20 lines, and the #11/8/10 Rotterdam–Menands line.

Customer Benefits:

These improvements will strengthen the transmission network and ensure adherence to reliability standards. They will correct existing asset condition, safety, and environmental concerns, and resolve existing thermal and voltage problems, and allow for accelerated load growth currently projected at LFTC. Significant load shedding would otherwise be necessary to relieve projected overloads without the proposed projects.

In addition, the reinforcements in Eastern NY will reduce dependence on local generation for reliability of service within the region. Without local generation available during the summer periods, the Spier-Rotterdam 115 kV circuits will be exposed to single contingency overloads until the local generation is returned to service. This in turn could require load shedding at or near LFTC for relief. This situation will be resolved with the addition of Eastover Road Substation and the Mohican-Battenkill reconductoring.

2014 to 2015 Variance:

The variance between the 2014 and the 2015 Capital Investment Plans (CIP) results in part from the shift forward of the five year timeframe in this CIP compared to the previous CIP, such that projects nearing completion have less spending left in the

2015 NY Capital Investment Plan

current five year timeframe. Completion of other projects such as the Eastover substation and Mohican-Battenkill #15 has been delayed. This results in a spending shift and in some cases a net increase in project cost.

The variance also results from new projects that were not included in the 2014 CIP. New projects include the second Eastover transformer, the Ballston and Mulberry Tap Switching Stations, the Ticonderoga cap bank, the reconfiguration of the Rotterdam substation, reactors in #19 and #20 lines, and the reconductoring of the Rotterdam-Menands line.

Table 2-8
Transmission – Eastern NY Region Reinforcement
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 27.4 | 17.5 | 1.6 | 4.7 | 8.8 | - | 59.9 |
| 2015 | - | 33.7 | 17.9 | 16.9 | 1.6 | 1.2 | 71.4 |

Western NY Region Reinforcements

This program involves significant capital expenditure over the next five years and beyond to construct major reinforcements of the 115kV transmission systems in western New York, including the Southwest and Genesee regions that extend from the Buffalo area east to Mortimer Station and south to the Pennsylvania border. This program will strengthen the transmission network and ensure adherence to reliability standards. It will correct existing asset condition, safety, and environmental concerns resulting in improved reliability of several circuits and reflects a gas addition agreement for the Dunkirk generating plant.

The major components in this program with investment levels greater than \$1 million (costs shown are for the period covered by this Plan) include:

- Constructing the new 345/115kV Five Mile Station near the Homer Hill Station tying into the Homer City-Stolle 345kV line #37 and the Gardenville-Homer Hill 115kV lines #151 and #152 to support area voltage (C024015 and C024016 - \$17.5m)
- Reconductoring 14 miles of the Erie-Packard 115kV #181 circuit due to loading concerns for loss of the #182 line or the Homer City 345 kV source. (C050744 - \$49.1m)
- Constructing a new 115kV substation and ring bus at West Golah that ties together the National Grid #119 and NYSEG # 906 lines (C050695 - \$7.3m)

Drivers:

Studies of the 115kV and 230kV transmission systems were conducted for the Frontier, Southwest and Genesee regions of western New York, to determine compliance with

2015 NY Capital Investment Plan

applicable reliability standards. Studies initially performed in 2007 and repeated in 2012, 2013, and 2014 evaluated the system for existing load levels up to a 15 year forecasted load level. Included within each of these evaluations was testing of both N-1 and N-1-1 design criteria, ensuring compliance with NERC TPL Standards, NPCC Directory #1, NYSRC Reliability Rules and the Company's Transmission Planning Guide (TGP 28). These standards require the entire transmission system to meet N-0 and N-1 voltage, thermal and stability criteria as well as the bulk power system and long lead time items to meet the same criteria for N-1-1 conditions. Several reliability criteria issues for the area were discovered under various study conditions. In the Southwest Region, multiple reinforcement projects are required to correct all N-1 conditions.

Customer Benefits:

Customers will benefit from this program in several ways, including:

- Exposure to service interruptions, including load shedding, in the event of certain key contingencies would be reduced significantly. The need to dispatch generation out of merit order to ensure voltage support and stability will be reduced or avoided.
- Circuits that are normally open, which provide a backup source to loads in the Homer Hill area will be operated normally closed, reducing the frequency and length of outages for certain contingencies.
- Some capability to accommodate new or expanding load will be added to the system.

2014 to 2015 Variance:

The variance between the 2014 and 2015 Plans is due to shifts in timing of the construction of the projects above. Also the project to add a phase angle regulator (PAR) to the 171 line was removed from the Plan as further studies are being conducted to define the need and any other possible options.

Table 2-9
Transmission – Western NY Region Reinforcements
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 24.3 | 9.7 | 24.6 | 14.1 | 7.0 | - | 79.7 |
| 2015 | - | 15.2 | 4.4 | 28.7 | 20.5 | 5.0 | 73.9 |

Central NY Region Reinforcements

Syracuse Area Reinforcements

The Syracuse Area Reinforcements program is focused on system improvements in and around the Syracuse area that resulted from annual studies performed prior to 2014. These reinforcements are necessary to respond to system capacity and performance needs and to avoid thermal overloads during contingency conditions.

The program scope includes:

- Reconductoring two separate parts of the Clay–Teall 115kV Line #10, 6.75 miles and 6.08 miles sections, as well as 10.24 miles of the Clay-Dewitt 115kV #3 line. This project is required for compliance with mandatory NERC standards (C043995 - \$37.3m)
- Reconfiguring Transformer connection at Clay Substation (C047275 - \$7.9m)

Drivers:

Annual studies of the 115kV and 345kV transmission systems are conducted for the Central region of New York, which extends from Elbridge Substation in the West to Oneida Station in the East, to determine whether the systems comply with reliability standards. Included in this testing are compliance with NERC TPL Standards, NPCC Regional Reliability Reference Directory #1, NYSRC Reliability Rules and the Company's Transmission Planning Guide (TGP 28). These standards require the entire transmission system to meet voltage, thermal, and stability criteria.

Several reliability criteria issues for the area were discovered under study conditions. Issues include thermal overloads on 115kV circuits in the Central Region, and a reinforcement and reconfiguration of the Clay substation 345/115kV transformer capacity.

Customer Benefits:

Customers will benefit from this program in several ways, including:

- Significantly reduced exposure to service interruptions, some resulting from load shedding, in the event that certain key contingencies were to occur.
- Added capability to accommodate new or expanding load to the system.

2014 to 2015 Variance:

The primary variance between the 2014 and 2015 Plans results from spend in FY15 on reconfiguring the transformer connection at the Clay substation which is not included in the timeframe of this Plan and the start of the reconductoring of the Clay-Teall #10 and Clay-Dewitt #3 lines.

2015 NY Capital Investment Plan

Table 2-10
Transmission – Syracuse Area Reinforcements
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 9.5 | 5.7 | 22.5 | 8.5 | - | - | 46.2 |
| 2015 | - | 13.2 | 11.1 | 19.1 | 1.7 | - | 45.2 |

New Bay at Edic 345kV Station (C044674 - \$3.1m)

This project will create a new breaker bay by adding two (2) new 345kV circuit breakers. Transformer TB2 will then be reconnected from bus “B” into the new position in the bay.

Drivers:

The reconnection of TB2 into a new breaker bay relieves thermal overloads on the 115kV system that occur as a result of an N-1-1 contingency.

Customer Benefit:

This project will eliminate the potential constraints on Central-East interface transfers when TB3 is out of service. Such relief of interface flow constraints improves security of system operations.

2014 to 2015 Variance:

The installation complexity of the new bay due to the need to change all breaker backup circuits for breaker failure inclusion on both bus A & B and the need to undo some of the old breaker failure scheme in disconnecting transformer TB2 directly from the bus resulted in higher than expected costs.

Table 2-11
Transmission – New Bay at Edic 345kV Station
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 0.9 | 0.6 | - | - | - | - | 1.5 |
| 2015 | - | 2.5 | 0.6 | - | - | - | 3.1 |

Porter #3/#7 Reactors (C060241 - \$1.2m)

The Porter – Yahnundasis #3 line was found to be overloaded for N-1 conditions and above STE for N-1-1 conditions. In addition, the Oneida – Yahnundasis #7 line was found to be overloaded above LTE for N-1-1 contingencies. To address these overloads, a reactor (8%) should be installed in series with the #3 line, along with a second reactor

2015 NY Capital Investment Plan

(6%) installed on the #7 line. As these lines are in parallel, it is important that any solution for these lines be studied in tandem to prevent the solution for one problem to worsen the other.

Drivers:

Presently, a number of contingencies, including single-element outages, result in thermal overloads on the Oneida – Porter #7 and Porter - Yahnundasis #3 lines.

Customer Benefit:

This project will resolve normal loading and contingency outage exposure and improve reliability of the Oneida 115kV Transmission system.

2014 to 2015 Variance:

This project was not in the 2014 Plan.

Table 2-12
Transmission – Porter #3/#7 Reactors
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | - | - | - | - | - | - | - |
| 2015 | - | 0.4 | 0.8 | - | - | - | 1.2 |

2C.4 Transmission Projects in Support of Distribution

Riverside-Reynolds Road #4 Forbes Tap (C043592 - \$2.6m)

This project provides for a loop-in-and-out supply to the new 115-13.2kV Forbes Ave substation in Rensselaer. The new substation will have two – 20/32/40MVA transformers and four feeders initially.

Drivers:

The Substation and related distribution feeder projects are to provide capacity for load growth in the City of Rensselaer and to address flood risk and asset issues at the existing 34.5-13.2kV portion of the Rensselaer station.

2015 NY Capital Investment Plan

Customer Benefit:

The benefit of this project will be capacity to support load growth in the City of Rensselaer. It was also improve system resiliency by eliminating the flooding risk for the distribution portion of the existing substation.

2014 to 2015 Variance:

The projected investment is shown in the table below and variation year on year is due to the scope and timing of the specific project.

Table 2-13
Transmission – Riverside-Reynolds Road #4 Forbes Tap
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 0.3 | 1.5 | - | - | - | - | 1.8 |
| 2015 | - | 0.1 | 1.5 | 1.0 | - | - | 2.6 |

Randall Road Transmission Line (C043672 - \$1.6m)

This project provides for two 115 kV supplies to the new 115-13.2kV Randall Road from the adjacent transmission circuits in Ballston. The new substation will have one – 15/20/25MVA transformer and four feeders initially.

Drivers:

The driver is the deteriorated condition of the 34.5kV Ballston-Randall #9 Line. The line crosses very difficult terrain including wetlands. This project will also improve the outage criteria violations as per the distribution Planning Guidelines at Ballston substation.

Customer Benefit:

The removal of approximately two (2) miles of a deteriorated 34.5kV line from wetlands areas would improve the service reliability of customers served from the existing Randall Road substation.

2014 to 2015 Variance:

The projected investment is shown in the table below and variation year on year is due to the scope and timing of the specific project.

2015 NY Capital Investment Plan

Table 2-14
Transmission – Randall Road Transmission Line
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|-------|------|------|------|------|------|-------|
| 2014 | 0.001 | 0.1 | 1.2 | 0.2 | - | - | 1.5 |
| 2015 | - | 0.1 | 0.7 | 0.7 | - | - | 1.6 |

West Ashville Substation (C043833 - \$4.7m)

This project provides a 115-34.5kV station with one 15/20/25 MVA transformer and two 34.5kV circuits. The 115kV supply will be looped in-and-out of the new station and require less than 1 mile of new construction. There is a related sub-transmission project to connect the new station to the existing Ashville-Sherman Line 863 (C043832 - \$0.2m).

Drivers:

The sub-transmission network in Chautauqua County is supplied by three 115-34.5kV stations. Certain line or transformer outages will result in voltages below 31kV on parts of the system.

Customer Benefit:

These projects will resolve contingency outage and voltage exposure and improve reliability of the Chautauqua South 34.5kV sub-transmission system. The project will also add approximately 14MVA of capacity to the system to provide for future load growth.

2014 to 2015 Variance:

The projected investment is shown in the table below and variation year on year is due to the scope and timing of the specific project.

Table 2-15
Transmission – West Ashville Substation
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 0.5 | 1.2 | 0.6 | - | - | - | 2.3 |
| 2015 | - | 0.6 | 0.4 | 0.6 | 3.1 | - | 4.7 |

2015 NY Capital Investment Plan

Mountain Upgrade 115-34.5kV Transformer (C044359 - \$3.8m)

This project upgrades Mountain 115-34.5kV station by replacing the existing transformers with two 20/26/33MVA transformers with Load Tap Changers. Associated support equipment will also be upgraded.

Drivers:

Existing loading plus future load growth will overload the existing transformers for normal operation as well as overload the remaining transformer at Mountain station for loss of the other transformer at Mountain station. Mountain station is one of two supplies to the Niagara 34.5kV sub-transmission loop

Customer Benefit:

This project will resolve normal loading and contingency outage and voltage exposure and improve reliability of the Niagara 34.5kV sub-transmission system.

2014 to 2015 Variance:

The projected investment is shown in the table below and variation year on year is due to the scope and timing of the specific project.

Table 2-16
Transmission – Mountain Upgrade 115-34.5kV Transformer
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 1.2 | 2.6 | 0.02 | - | - | - | 3.8 |
| 2015 | - | 3.8 | 0.05 | - | - | - | 3.8 |

Sanborn Upgrade 115-34.5kV Transformer (C044361 - \$2.0m)

This project upgrades the Sanborn 115-34.5kV station by replacing the existing transformer with one 15/20/25MVA transformer with Load Tap Changer. Associated support equipment will also be upgraded.

Drivers:

Existing loading plus load growth will overload the existing transformer for normal operation as well as overload the remaining transformer station for loss of one of the transformers at Mountain station. Sanborn station is one of two supplies to the Niagara 34.5kV sub-transmission loop

2015 NY Capital Investment Plan

Customer Benefit:

This project will resolve normal loading and contingency outage and voltage exposure and improve reliability of the Niagara 34.5kV sub-transmission system.

2014 to 2015 Variance:

The projected investment is shown in the table below and variation year on year is due to the scope and timing of the specific project.

Table 2-17
Transmission – Sanborn Upgrade 115-34.5kV Transformer
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 0.5 | 1.1 | 0.02 | - | - | - | 1.6 |
| 2015 | - | 2.0 | 0.04 | - | - | - | 2.0 |

New Harper Substation (“Royal Ave Station”) (C044874 - \$8.6m)

This project and associated projects relate to a new 115-13.2kV substation with two 24/32/40 MVA transformers and eight 13.2kV feeders will replace the existing Harper station. This substation will become the supply to two industrial customers as well as three new distribution substations to replace three indoor substations.

Drivers:

The project is driven by the deteriorated asset condition of the transformers, breakers, support structure and other items at the existing Harper 115-12kV station located in Niagara Falls. There are no available spares for the present 115-12kV transformers in Niagara Mohawk.

Customer Benefit:

This project will improve reliability by removing deteriorated assets from the system and, by utilizing standard distribution voltages, allow for the use of system spare equipment in the event of a failure.

2014 to 2015 Variance:

The projected investment is shown in the table below and variation year on year is due to the scope and timing of the specific project.

2015 NY Capital Investment Plan

Table 2-18
Transmission – New Harper Substation (“Royal Ave Station”)
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 4.1 | 3.3 | 0.05 | - | - | - | 7.4 |
| 2015 | - | 1.2 | 5.6 | 1.8 | - | - | 8.6 |

Mohawk 69kV Area

Drivers:

The deteriorated condition of several sub-transmission lines, the removal from service of Amsterdam Station due to floods in 2011, and Rotterdam Station asset condition have prompted a study of the Mohawk area 69kV system. The review also involves whether a reconfigured or partially converted to 115kV system could resolve reliability concerns on the 115kV system in the area.

These projects include:

Ephratah Substation Rebuild (C046486 - \$2.6m) – Build a new 115-13.2kV substation at Ephratah and eliminate the 69-23kV station.

Schoharie Substation Reconfiguration (C046494 - \$1.9m) – Build a new 115-69kV station at Schoharie to connect the converted transmission line from Rotterdam to the existing 69kV from Marshville.

Customer Benefit:

Customers will benefit from improved reliability on the 115kV system and additional capacity for load growth.

2014 to 2015 Variance:

The projected investment is shown in the table below and variation year on year is due to the scope and timing of the specific project.

Table 2-19
Transmission – Ephratah Substation Rebuild
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | - | 0.05 | 1.2 | 1.3 | - | - | 2.6 |
| 2015 | - | - | - | 0.05 | 1.2 | 1.3 | 2.6 |

2015 NY Capital Investment Plan

Table 2-20
Transmission – Schoharie Reconfiguration Rebuild
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | - | - | 0.9 | 0.9 | - | - | 1.9 |
| 2015 | - | - | - | - | 0.9 | 0.9 | 1.8 |

Elm Street Relief – Add 4th Transformer (C049594 - \$8.6m)

This project adds the fourth 230-23kV transformer to Elm Street Station in downtown Buffalo as well as replaces all 23kV breakers with an interrupting rating of less than 40kA.

Drivers:

Elm Street station supplies the Buffalo LVAC network, spot network loads and several distribution stations. The station has three transformers and is designed for double contingency operation due to its supply to the downtown core. However, the existing load is above the summer emergency rating of one transformer in-service.

Customer Benefit:

This project restores the capability of the station to supply the load for two transformers in service and provides for some limited load growth.

2014 to 2015 Variance:

The projected investment is shown in the table below and variation year on year is due to the scope and timing of the specific project.

Table 2-21
Transmission – Elm Street Relief – Add 4th Transformer
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 1.1 | 3.3 | 3.0 | 3.0 | - | - | 10.4 |
| 2015 | - | 4.3 | 2.3 | 2.0 | 0.05 | - | 8.6 |

Sawyer 4th 230-23kV Bank (C053147 - \$2.3m)

This project installs a fourth 230-23 100MVA transformer and related equipment at Sawyer Station in the Town of Tonawanda

2015 NY Capital Investment Plan

Drivers:

Presently, several double circuit contingencies will remove two of three transformers from service at Sawyer. The remaining transformer is not sufficient to carry the existing load in that situation.

Customer Benefit:

The benefit is improved reliability of the 23kV system supplying parts of the Town of Tonawanda and approximately one-third of the City of Buffalo,

2014 to 2015 Variance:

The projected investment is shown in the table below and variation year on year is due to the scope and timing of the specific project.

Table 2-22
Transmission – Sawyer 4th 230-23kV Bank
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | - | - | 0.1 | 0.7 | 0.8 | - | 1.6 |
| 2015 | - | - | 0.1 | 0.7 | 0.8 | 0.7 | 2.3 |

Riverbend Area Reinforcements

These projects reinforce the 34.5kV system in the Ridge-Riverbend-Outer Harbor area. This area has experienced significant development due to New York State investment in certain key projects. The transmission line projects and Ohio Street 115-34.5kV station with two 30/40/50MVA transformers and six (6) 34.5kV feeders will provide a new supply to the existing and future sub-transmission customers and new distribution station in the area. The existing 34.5kV as supplied from Ridge is not capable of supplying the new loads. The existing 34.5kV system also has reliability issues due to trees and animals as it crosses wetlands in a nature preserve near the Lake Erie shore. These projects will provide limited relief to the 23kV system supplied from Seneca Terminal Station.

This suite of projects includes:

- Airco-Buffalo River 147 Adv Metal Tap (C054711 - \$1.6m)
- Gardenville-Buffalo River 146 Tap Ohio Station (C054713 - \$3.1m)
- Ohio Street New 115-34.5kV Substation (C055263 - \$10.7m)

Customer Benefit:

These projects will provide sufficient capacity for the new industrial, commercial and residential customers supplied from the 34.5kV system directly or indirectly through a

2015 NY Capital Investment Plan

new distribution station. These projects will improve the 34.5kV system reliability by completing a new supply on the customer side of the nature preserve.

2014 to 2015 Variance:

These projects were not in last year's Plan.

Table 2-23
Transmission –Riverbend Area Reinforcements
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | - | - | - | - | - | - | - |
| 2015 | - | 1.0 | 9.8 | 4.6 | - | - | 15.4 |

Terminal Station Relocation (C059672 - \$2.0m)

Build a new 115kV line from the existing circuit to the location of the new 115-13.2kV Terminal station.

Drivers:

This 115kV line relocation coupled with a new Terminal 115-13,2kV station will address asset condition, fault-duty and environmental concerns with existing Terminal Station.

Customer Benefit:

These projects will provide customers with more reliable service and eliminate the fault duty and environmental concerns with the existing station.

2014 to 2015 Variance:

This project was not in last year's Plan.

Table 2-24
Transmission – Terminal Station Line Relocation
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | - | - | - | - | - | - | - |
| 2015 | - | - | 0.2 | 1.2 | 0.6 | - | 2.0 |

2. D. Asset Condition

Asset Condition expenditures are those investments required to reduce the likelihood and consequence of the failures of transmission assets, such as replacing elements of overhead lines, underground cable or substation equipment. The Company presents an approach in this Plan that keeps near-term capital costs for asset condition projects in line with spending limits approved in its most recent electric rate case (12-E-0201) while still addressing system needs. The result is greater reliance on the purchase of spare equipment to replace damaged equipment that may fail in service for certain elements of the transmission and distribution system. This approach calls for more targeted replacement of assets based on their condition versus wholesale replacement based on “end of useful life” criteria, especially for transmission line refurbishment projects. Close monitoring of system performance as it relates to asset condition causes will remain necessary.

For overhead lines specifically, this Plan seeks to achieve compliance with National Electrical Safety Code (“NESC”) requirements, and will continue to implement the recommendation from Staff’s 2010 rate case testimony to refurbish overhead transmission line facilities that are in unacceptably severe deteriorated condition (i.e. Niagara Mohawk’s defined Level 1, Level 2 and Level 3 conditions), as opposed to entire lines, unless a compelling justification can be provided for the full refurbishment. Any overhead line proposed for a refurbishment will undergo a field inspection by qualified transmission line engineers and will usually be supported by comprehensive aerial inspection using stabilized video cameras. As part of the conceptual engineering process, refurbishment options will be thoroughly evaluated on a case-by-case basis and the engineering economics of various options such as a complete reconductoring versus a life extension are reviewed in the project sanctioning process. In addition, longer term impacts such as a greater number of visits to the same right-of-way, improved access to right-of-ways with roads, multiple site establishment costs, increased storm hardening, additional permitting and licensing costs, greater levels of environmental impact, and more disturbance to property abutters, among other things will be evaluated to determine if it is the most economical scope of work for the benefit of customers. Further detail on specific asset condition programs and projects is given below.

NY Inspection Repairs - Capital

The goal of this program (C026923 - \$22.8m) is to replace those damaged or failed components on the transmission overhead line system identified during field inspections (five-year foot patrols). A 2012 (FY13) foot patrol inspection of the Homer Hill-Bennett #157 115kV line revealed 136 level 3 wood structures requiring replacement. A design package is being prepared for completion of this work by FY16. For construction efficiencies this work will be bundled with the asset condition refurbishment work on the line for project C027429 in this Plan.

2015 NY Capital Investment Plan

Drivers:

These programs assure that both steel tower and wood pole transmission lines meet the governing NESC standards by replacing hardware, wood poles, and structure components that no longer meet the governing code requirements. This follows standard industry practice and the Commission's 2005 Safety Order in Case 04-M-0159.

Customer Benefits:

This program enhances public safety by assuring that damaged or failed transmission overhead line components are replaced and continue to meet the governing NESC under which they were built. Replacement of damaged and failed components discovered during inspection also promotes reliable service performance.

2014 to 2015 Variance:

Future spending levels are expected to remain consistent to the prior plan.

Table 2-25
Transmission – New York Inspection Projects
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 6.2 | 12.3 | 4.3 | 3.0 | 3.0 | - | 28.8 |
| 2015 | - | 11.3 | 4.3 | 3.0 | 3.0 | 1.2 | 22.8 |

Wood Pole Management

This program (C011640 - \$8.2m) assures that transmission lines meet the governing NESC under which they were constructed by replacing wood poles and wooden structures that no longer meet the governing code requirements due to damage or failure of the pole or structure.

Drivers:

As discussed in the Report on the Condition of Physical Elements of Transmission and Distribution Systems, Case 12-E-0201, October 1, 2014, wood poles that are either priority rejects or reject poles (as classified following a wood pole ground line inspection and treatment performed on behalf of the Company by Osmose Utilities Services Inc, of Buffalo, NY) as well as those damaged by woodpecker or insect activity will be replaced. The ground line inspection and treatment of wood poles is performed approximately every 10 years. These inspections are in addition to the 5 year foot patrol which is required under the Commission's 2005 Safety Order in Case 04-M-0159.

2015 NY Capital Investment Plan

The wood poles targeted through this initiative are deemed to be beyond restoration by either re-treatment or placement of some form of additional pole support, usually at the ground line. Similarly, “reject equivalent” refers to deteriorated wood poles from such things as woodpecker damage, insect damage, or rotting and therefore these poles are included in the Wood Pole Management Program.

Reject and priority reject poles generally do not meet NESC requirements. In a limited number of cases when an extra margin of safety was added into the design, some of this margin may still be available before failing to meet the Code. However, this usually provides only a limited amount of extra time to replace the damaged or deteriorated wood pole(s) or structures before potential failure.

Customer Benefits:

Customers will benefit from the maintenance of the appropriate public safety level by assuring that transmission wood structures continue to meet the governing Code. In addition to the public safety benefit, unplanned failures of wood poles or structures can reduce service reliability, and may reduce overall system integrity making the transmission system vulnerable to widespread disruption.

2014 to 2015 Variance:

Future spending levels are expected to remain consistent to the prior plan.

Table 2-26
Transmission – Wood Pole Management
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 1.0 | 2.0 | 2.5 | 1.5 | 1.5 | - | 8.5 |
| 2015 | - | 1.0 | 2.6 | 1.6 | 1.5 | 1.5 | 8.2 |

Conductor Clearance Strategy

The conductor clearance correction program will increase the clearance of certain overhead conductors to address locations that may not meet clearance standards prescribed by the NESC under certain loading conditions. The need for greater clearances has been identified as a result of an ongoing Aerial Laser Survey (ALS), also known as LiDAR for Light Detection and Ranging, being conducted on the transmission system. Clearances are in the process of being measured with aerial surveys providing an accuracy which was previously available by ground inspection only. The project will continue between FY14 and FY22 to address conductor clearance issues for 115kV lines newly classified as BES followed by non-BES 115kV circuits. This timeline assumes there will be no further directives from FERC similar to the October 7, 2010 a NERC Alert (Recommendation to Industry: Consideration of Actual Field Conditions in

2015 NY Capital Investment Plan

Determination of Facility Ratings) that would prescribe a specific correction period for circuits newly classified as BES.

Drivers:

The primary driver for this work is safety of the public and Company personnel as they work and travel under the overhead lines. The NESC sets required conductor clearances of overhead lines from the ground and other ground based objects. This program assures that transmission lines meet the governing NESC under which they were constructed by improving ground to conductor clearances in substandard spans. This follows standard industry practice and a Public Service Commission Order (Case 04-M-0159, effective January 5, 2005) that the Company shall adhere to the NESC.

Customer Benefits:

While safety events caused by substandard clearance conductors are rare, their consequences can be very serious and are difficult to quantify. Application of the NESC criteria provides a reasonable means to manage the issue and mitigate the risk from such events.

2014 and 2015 Variance:

The Browns Falls-Taylorville #3 (C048218) and Browns Falls-Taylorville #4 (C048221) 115kV conductor clearance projects will conclude in FY16 of this Plan. Beyond that, project C048678 will capture all future conductor clearance projects on NY's transmission system with future spend expected to remain consistent with levels in the prior Plan.

Table 2-27
Transmission – Conductor Clearance Strategy
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 7.4 | 10.7 | 10.7 | 10.7 | 15.0 | - | 54.6 |
| 2015 | - | 10.3 | 10.7 | 10.7 | 10.0 | 10.0 | 51.7 |

Relay Replacement Strategy

Protective relays are maintained in accordance with Company substation maintenance standards and NERC or NPCC requirements, where applicable. Overall the population of approximately 4,000 relay packages remains adequate, but approximately 6% of the population requires investment based on condition, performance or obsolescence. This program will commence by replacing the worst 6% of the relays over the next eight years. Beyond that, studies and pilot programs will be initiated to explore the most efficient and cost effective approach to addressing the remaining population. The long-term objective is to have an asset management approach that allows a more

2015 NY Capital Investment Plan

commoditized approach to relay replacement. This approach will be necessary for modern microprocessor relays that are expected to have only 15 to 20 year asset lives.

Drivers:

This strategy ensures that reliable protective relay systems are in place to preserve the integrity and stability of the transmission system following a fault. This strategy is needed now because properly functioning protective relays are essential for rapid isolation of faults on the system thus protecting customers from potential outages and protecting equipment from damage.

Customer Benefits:

Properly functioning elements of relay protection schemes limit the extent and duration of outages. Further, the protection system is designed to protect high value assets against failure in the event of system anomalies thereby reducing the potential investment needed to recover from an event. The primary benefit of this strategy will be to maintain the reliability performance of the system and customer satisfaction as known poor performing relay families are replaced with modern microprocessor based relays.

2014 to 2015 Variance:

The Company continues to move forward with its relay replacement program (C034690 - \$6m) and is projecting multiple individual relay replacement projects being completed in FY17 and FY18, including a large scale project at Menands Station in FY17 (C049601 - \$4.5M).

Table 2-28
Transmission Relay Replacement Strategy
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 4.8 | 6.8 | 2.8 | 4.8 | 8.0 | - | 27.2 |
| 2015 | - | 1.5 | 9.1 | 5.5 | 2.0 | 4.0 | 22.1 |

Substation Rebuilds

The majority of the 313 transmission substations are in satisfactory condition, however, investment is recommended to rebuild substations whose overall condition has deteriorated to the point that wholesale refurbishment is required. In these circumstances, a standard substation design layout will typically be utilized to provide greater operational flexibility and increase reliability for customers served in the area. Where substation rebuilds are proposed, creative and innovative solutions and improvements, such as re-configurations of the layout, will be evaluated.

2015 NY Capital Investment Plan

The Gardenville, Lighthouse Hill, Rotterdam, Inghams, Oswego Lockport, and Huntley stations are now proposed to be rebuilt, or engineering started, during the FY16 – FY20 period with most of the spending occurring in the later years of the Plan as the Company continues to study alternatives. At remaining substation sites the Company will only replace those assets that cannot be repaired economically. Although a more coordinated, integrated approach is more consistent with long-term sustainability of the system, the ad hoc “fix on fail” approach results in lower capital costs in the short term.

Drivers:

The substations mentioned above have all been identified as having asset condition or configuration issues that warrant a major station rebuild or upgrade.¹ Included with the station name is the forecasted spend amount within this Plan.

Gardenville (C005156 & C030084) \$49.1m

Gardenville is a 230/115kV station south of Buffalo that has two 115kV stations in close proximity that are referred to respectively as New Gardenville and Old Gardenville, and which both serve over 750MW of regional load. New Gardenville was built between 1959 and 1969 and has asset condition issues such as faulty control cables, deteriorated foundations and many disconnects which have deteriorated beyond repair. Old Gardenville, built in the 1930s, feeds regional load via eleven 115kV lines. The station has serious asset condition issues including, but not limited to, control cable, breaker, disconnect and foundation problems. The station has had no major updates since it was built. There have been a number of misoperations that can be directly attributed to control cable issues in the past several years alone.

A new breaker-and-a-half 115kV station is to be built between the two existing stations to replace them. A new 115kV switchyard will be constructed in the western section of the site and there will be rerouting of approximately seventeen 115kV lines for the project to eliminate the current “criss-cross” arrangement outside of the station and eliminate line to ground clearance issues.

Rotterdam (C034850) \$27.1m

The Rotterdam substation is a supply source to the surrounding transmission and sub-transmission system. A number of alternative plans for rebuilding the Rotterdam substation are under consideration. One of these plans involved removal of the existing 69kV and 34.5kV yards to make room for building a new 115kV yard while the existing 115kV yard remains in service. Studies of the long term transmission and sub-transmission needs of the areas east and west of Rotterdam are beginning to examine the impact of removing the Rotterdam 69kV and 34.5kV supplies. For example, projects associated with the Ephratah substation (C046486 and C053144) are, in part, related to the expected rebuild of Rotterdam.

¹ “Report on the Condition of Physical Elements of Transmission and Distribution Systems,” October 1, 2014, Page 70 through 77.

2015 NY Capital Investment Plan

Given the uncertainty over the 230kV station as it relates to the Energy Highway projects and the possible need to supply large loads in the Luther Forest campus, the Company has postponed both the 230kV and 115kV rebuilds at Rotterdam. Any asset issues that arise will now be managed through the normal damage / failure process.

Engineering analysis with respect to the rebuild itself is expected to begin in FY17.

Lockport (C035464) \$12.0m

Lockport is a 115 kV transmission station with thirteen 115 kV transmission lines tying through the East and West bus sections and serving the 115 kV system in Western New York. The overall condition of the station yard and control room is poor. Work is required on control cable duct banks, breaker operators, structure painting and concrete equipment foundations that are significantly deteriorated.

The control room building is also in very poor condition and requires repairs. Existing peeling paint is likely lead contaminated. It is an oversized building with continued maintenance costs for the original roof and the intricate brickwork. It contains a 90 ton overhead crane in the old 25 cycle frequency changer portion of the building which is presently used only to store old cable. The control house roof was repaired in the 1990s and brick pointing was also done to limit deterioration within the last 5 years.

Conceptual engineering to rebuild the station in place was completed in June 2010, but then deferred for further consideration until FY17.

Huntley (C049902) \$18.3m

Among the Huntley substation asset condition needs are: permanent capacitor banks at the Huntley 115 kV bus to replace the mobile banks currently there; improved grounding in the switchyard; removal of all National Grid controls, batteries and communications equipment from inside the Huntley Generating Station to a control house in the yard (both 115kV & 230kV); adding a second station service supply; refurbishing the existing oil circuit breakers; replacing the potential transformers; installing new CCVTs for 115 kV and 230 kV relaying; and refurbishing the 230 kV cable pumping plant.

Conceptual engineering was completed in 2011, but the project deferred until FY17 to reduce and manage short-term capital investment.

Inghams Station Re-Vitalization (C050917 and C060240) \$6.7m

Inghams station is located in the town of Oppenheim, NY and is a connection between a hydro generating station and the transmission and distribution electric system. The transmission voltages at Inghams are 115kV and 46kV, and the distribution voltage at Inghams is 13.2kV. The Inghams station helps to moderate the electrical system as it has a phase angle regulator (PAR) type transformer.

The transmission planning department is looking to improve the capabilities of the PAR by specifying a replacement unit with a wider adjustment range.

The Inghams station was flooded in 2006 and remains a flood concern. After the station was repaired a new stone wall approximately five (5) feet tall was constructed along the station perimeter that is shared with the river boundary. The stone wall is considered a temporary measure as it will limit the current flow of the river if the river rises to flood heights again, but will not keep the station from being flooded.

The recommendation for the station is that the PAR be replaced and the existing PAR be kept as a spare unit, for emergency use. Also, the station will be relocated outside the current flood zone to be above the 500year flood zone line.

Oswego (C043426) \$9.3m

Three substations are located on the generation site owned by NRG which include a large 345kV switchyard (that was recently upgraded and is in overall very good asset condition, except for the control house which is scheduled for future replacement) and 115kV and 34.5kV yards originally designed and integrated when the generating station and substations were owned by the same utility.

The 115kV substation is in poor condition with out-of-service equipment that has not been formally retired. Bus sections have been cut, rerouted, and breakers out of service with yellow hold cards. The disconnect switches to the OCBs are original to the station and are the pin and cap design that has an industry recommendation for replacement. The electro-mechanical relays and batteries for this yard and the 34.5kV yard are still inside the generation plant which limits the Company's control and access to these assets.

The 34.5kV yard is the original to the 1940s plant 1&2 (retired decades ago). All equipment in the yard is of original vintage, is obsolete, and is in poor condition.

Lighthouse Hill (C031662) \$21.8m

The Lighthouse Hill facility consists of a switching station with two 115 kV buses and seven transmission lines connecting to the station, allowing power to flow from generation located on Lake Ontario to the Watertown area and Clay Station in Syracuse.

Seven OCBs are located 200 feet from the Salmon River located about 70 feet below the yard elevation. The station is located a mile up-stream of the New York State Wildlife Fish Hatchery. Although the risk is low, any significant oil spill in the station would have a detrimental environmental impact. Even at 70 feet above the river level there is also the risk of a flooding event at the station given its proximity to the river. In addition, the disconnect switches are in a very poor condition.

2015 NY Capital Investment Plan

Another significant issue at Lighthouse Hill is that the land is owned by Brookfield Power and operated as a shared facility under a contractual agreement. The lack of direct access to Brookfield's control room at Lighthouse Hill is not ideal as it limits the Company's control over the housing conditions for the battery and relay systems. The Company has controls on the first floor of the control house which is immediately adjacent and downstream of Brookfield's hydroelectric dam. An uncontrolled release from the dam could flood the control room area. Flooding in the area occurred as recently as October 1, 2010 due to a rain event.

The recommended option of a conceptual engineering analysis is a new substation located about 1.5 miles west adjacent to Tar Hill Road in the clearing on land already owned in fee by the Company. This will eliminate the risks of oil contamination to the Salmon River and greatly reduce the likelihood of station flooding.

Conceptual engineering was originally completed in 2012, and refreshed in 2014 in anticipation of beginning preliminary engineering in FY17.

Customer Benefits:

The planned replacement of these stations reduces the likelihood of an in-service failure which can lead to long-term interruptions of the transmission system as well as significant customer outages.

2014 to 2015 Variance:

Apart from Gardenville, all of the previously recommended station rebuilds were deferred as the Company evaluated additional options for addressing needs at other stations and to manage short term capital investment. The variance between Plans below is now due to station rebuilds becoming more certain to begin spending in the latter half of this Plan.

Table 2-29
Transmission – Substation Rebuilds
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2104 | 2.9 | 6.4 | 20.8 | 31.9 | 40.6 | - | 102.6 |
| 2015 | - | 7.4 | 25.3 | 27.2 | 23.2 | 61.9 | 145.0 |

Overhead Line Refurbishment Program

Over the next five years the Company will refurbish a number of overhead lines based on their condition. During this period we will continue to work towards developing an overhead line refurbishment approach that, to the greatest extent possible, addresses only the most deteriorated condition equipment. This modified approach to SG080 only considers refurbishing an entire line when the conductor requires replacement. In general, as part of conceptual engineering, conductor testing will determine whether or

2015 NY Capital Investment Plan

not the conductor tensile strength fails to meet appropriate NESC heavy loading requirements. There is a risk that a number of the identified lines in our overhead line refurbishment program will fall within this category as conductor testing is pursued over the upcoming year. When possible, shield wire testing will also be performed.

For overhead lines with acceptable conductor strength, this program will assure that transmission lines meet the minimum governing NESC under which they were built. This will be accomplished through the replacement of deteriorating structures and line components that no longer structurally or electrically adhere to the governing NESC.

The costs projected for lines prior to the completion of the conceptual engineering process are preliminary in nature. As part of conceptual engineering process, a line will be field evaluated and refurbishment options more thoroughly evaluated on case-by-case basis. The value of various options (e.g., complete reconductoring versus a life extension) will be reviewed; however, cost estimates may continue to differ due to unforeseen circumstances, such as additional swamp matting needs due to weather conditions or environmental requirements.

To reduce costs during the period of this five-year Plan, the Company is implementing an approach recommended by DPS Staff in the Company's 2010 rate case to refurbish only those overhead transmission line facilities that are in unacceptably deteriorated condition (i.e. Niagara Mohawk's defined Level 1, Level 2 and Level 3 condition). Although this approach allows for reduced investment amounts in the five years covered by this Plan, the approach must be evaluated against longer term issues such as a greater number of visits to the same right-of-way, multiple site establishment costs, increased susceptibility to storm damage, additional permitting and licensing costs, greater levels of environmental impact, and more disturbance to abutters among other things to evaluate the most economical solution for the benefit of customers. Therefore, for certain overhead line condition projects, a larger work scope to replace assets that are deteriorated, yet serviceable, may be more appropriate and cost effective.

This Plan is based on the assumption that issues identified during routine foot patrols (Level 1, 2 or 3 issues) will be addressed through the Damage / Failure program. Where we suspect a systemic problem, an engineering inspection and an aerial comprehensive survey will be initiated. Any issues arising from these condition assessments will be addressed through this overhead line refurbishment program.

The more significant OHL refurbishment projects in this capital plan are listed below. Details are included in Exhibit 6 – Overhead Line Refurbishment Projects.

- Alabama-Telegraph 115 (C033014 - \$5.1m)
- Batavia-Golah 119 (C060217 - \$1.3m)
- Boonville-Rome 3 & 4 (C047795 - \$8.9m)
- Boonville-Porter 1 2 (C047818 - \$5.2m)
- Brockport Tap (C055531 - \$1.2m)
- Browns Falls-Taylorville 3 & 4 (C024359 - \$9.1m)
- Colton-Browns Falls 1 & 2 (C036164 - \$10.7m)

2015 NY Capital Investment Plan

Dunkirk-Falconer 161 162 (C047831 - \$1m)
 Gardenville-Dunkirk 141 & 142 (C003389 - \$56.1m)
 Gardenville 180 & 182 (C027436 - \$1.1m)
 GE-Geres Lock 8 (C047835 - \$14.9m)
 Homer Hill-Bennett 157 (C027429 - \$7.2m)
 Lockport 103 104 (C027432 - \$1.7m)
 Lockport-Batavia 112 (C003422 - \$60.7M)
 Mortimer-Pannell 24 25 (C047816 - \$5.3m)
 Pannell-Geneva 4 4A (C030889 - \$5.8m)
 Porter-Rotterdam 31 (C030890 - \$14.1m)
 Spier-Rotterdam 1 2 (C060212 - \$1.3m)
 Taylorville-Boonville 5 & 6 (C027437 - \$9.0m)
 Terminal-Schuyler 7 (C047833 - \$1.4m)
 Ticonderoga 2 & 3 (C039521 - \$48.1m)

Drivers:

The Company has over 6,000 circuit miles of transmission overhead lines and many of these overhead line assets are approaching, and some are beyond, the end of their anticipated lives. The program will ensure the Company's transmission lines meet the minimum requirements of the governing code under which they were built as required by the Commission's 2005 Safety Order (Case 04-M-0159).

Customer Benefits:

This program promotes safety and reliability by assuring transmission lines meet the governing NESC under which they were built by replacing deteriorating structures and line components that no longer structurally or electrically conform to the Code.

2014 to 2015 Variance:

The Company re-phased much of the overhead line refurbishment to manage short term capital investment. Overhead line equipment failures will be managed through the Damage / Failure budget and any Level 1, 2 or 3 issues identified during foot patrols will also be addressed through the Damage / Failure budget.

Driving the increase from FY19 to FY20 in the table below is the spend forecasted in FY20 for the Gardenville-Dunkirk 141 142 (C003389 - \$25m in FY20) and Ticonderoga 2 3 (C039521 - \$28m in FY20) lines which are both large scale projects.

Table 2-30
Transmission – Overhead Line Refurbishment Program
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|-------|-------|
| 2014 | 14.0 | 33.3 | 66.1 | 92.9 | 85.4 | - | 291.8 |
| 2015 | - | 14.6 | 26.9 | 43.7 | 87.7 | 103.3 | 276.3 |

Transformer Replacement Strategy

Power transformers are managed through routine visual inspection, annual dissolved gas analysis (“DGA”) and electrical testing where required. Transformers with tap-changers are also maintained in accordance with our substation maintenance standards.

With the previous exceptions, this Plan utilizes a replace on fail approach with failures managed through the use of strategic spares. In this context, failure means either DGA results that suggest an immediate need for replacement or actual physical / electrical failure. Sufficient strategic spares are available to cover the probability of failure for the majority of the fleet.

Drivers:

In the next five years the investment plan is to replace six transformers with anomalous DGA results that have been or are expected to be confirmed as in poor condition through electrical testing.

Teal Ave (C047865 - \$5.1m) - Two 115/34.5kV 24/33/40MVA transformers are needed to replace the existing single phase 1930, 1941, & 1945 transformers due to their asset condition and DGA analysis. These transformers are also on the NY transformer watch list.² This upgrade would also provide adequate capacity for future load as determined by distribution planning. This is currently in preliminary engineering, and the transformers should be in service by FY18.

Seneca Terminal (C049744 - \$2.1m) - The summer emergency rating of the four 115-23kV ; 30 MVA LTC transformers with one transformer out of service matches the SE rating of the 115kV supply for one line out of service. Two of the four transformers are on the NY transformer watch list and the other two are currently under DGA review. The plan is to replace the four 1938/1950 transformers with 115-23kV; 55 MVA LTC units. The transformers should be in service by FY17.

Inghams (C047864 - \$3.0m) –The allowable phase shifting transformer angle range is limited during high Central-East transfer conditions with Fairfield wind generation at full output. For design contingencies associated with losing parallel 345kV or 230kV lines in the Central East interface, and if Fairfield generation is at full output, line #3 becomes overloaded and the phase shifting transformer is out of adjusting range. Under an N-1-1 condition, with a long term outage of the phase shifting transformer and when breaker R81 cannot be closed separating the Ingham's 77G and 99G buses, voltages at various 115kV buses east of Ingham's station will be at 0.91~0.92 pu. This is not acceptable if the outage lasts for an extended period.

There is not a spare phase shifting transformer in the New York system and if it were to fail it would take between 18-24 months to replace due to its specialty internal design.

² See “Report on the Condition of Physical Elements of Transmission and Distribution Systems,” October 1, 2014, Page 61.

2015 NY Capital Investment Plan

This would not be acceptable for system reliability and system stability. Asset Management has purchased a spare phase shifting transformer that will be designed to meet the needs of the Transmission Planning study for future growth of the 115kV system east of Ingham's.

Woodlawn (C051986 - \$3.6m) – TB1 has had hotspots and arcing under oil in the past. The oil quality is below the acceptable threshold with inter-facial tension, moisture and dielectric strength being outside expected in-service values. The main tank appears to be taking in moisture at a slow rate. Electrical tests show deterioration of the winding insulation. The tight physical clearances between the low voltage and high voltage structure make an emergency replacement difficult. TB2 A, B and C phase units all have partial discharge problems as indicated by increased Hydrogen in DGA results. All three have high moisture-in-oil levels which can lead to low dielectric strength and contribute to chemical reactions that degrade the oil quality. A three single-phase transformer design makes emergency replacement with a three-phase unit very difficult. TB1 and TB2 replacements are expected to be completed by FY18.

Hoosick (C053132 - \$4.1m) and Mohican (C053133 - \$4.0m) – both are transformers on the NY watch list; they have hotspots and arcing under their oil and high moisture-in-oil levels. Engineering has started to replace them by FY18 & FY19 respectively.

Customer Benefits:

The failure of an average sized distribution station transformer could lead to a loss of power for approximately 17,000 residential customers. The prolonged time needed for restoration (either through the installation of a spare or a mobile sub) can translate into millions of customer minutes interrupted.

2014 to 2015 Variance:

The Company is, in the short-term, adopting a 'replace on fail' approach for transformers where failure includes DGA results that suggest immediate replacement is necessary or where actual failure takes place. Four transformers were identified for replacement within the term of the 2014 plan and capital spending for their replacements began in FY15 (Teal Ave, Seneca Terminal, Inghams and Woodlawn). Hoosick and Mohican are new to this 2015 Plan.

Table 2-31
Transmission – Transformer Replacement Program
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 6.7 | 8.2 | 3.5 | 3.0 | - | - | 21.3 |
| 2015 | - | 6.0 | 7.6 | 5.2 | 3.0 | - | 21.8 |

2015 NY Capital Investment Plan

Circuit Breaker Replacements

The circuit breaker population is managed through ongoing inspection and maintenance activity along with routine preventative maintenance activities and electrical testing. In general, the circuit breaker population continues to be adequate for our needs; however, there are a number of obsolete circuit breakers that require investment. During the Plan, obsolete oil circuit breakers will be replaced with modern equivalent circuit breakers. Typically, these breakers will be replaced with circuit breakers employing SF6 gas as an arc interrupting medium. SF6 will be employed until a replacement arc interrupting gas with a lower global warming potential is developed.

Drivers:

There are 734 circuit breakers installed on the transmission system. Of these, 350 are large oil volume types. The majority of the circuit breakers addressed in the circuit breaker replacement strategy were installed between 1948 and 1969, are in poor condition or are the last remaining members of problematic families. There is an increasing trend of problems associated with the large volume oil circuit breaker population. Common problems include oil leaks, air leaks, bushing hot spots, high power factors and poor insulation. There have also been failures of pressure valves, hoses, gauges, motors, compressors, pulleys, O-rings, control cables, trip coils, close coils, lift rods and contacts.

Customer Benefits:

The planned replacement of circuit breakers reduces the likelihood of an in-service failure which can lead to long-term interruptions of the transmission system as well as significant customer outages. The circuit breaker replacement strategy promotes reliability of the transmission network in terms of CAIDI and SAIFI performance.

2014 to 2015 Variance:

The Company is committed to planned replacement of oil circuit breakers to maintain the reliability of its transmission system through its NY Oil Circuit Breaker Replacement Program (C037882). Individual projects created from this program and included in this Plan include Battle Hill (C049543 – \$1m), Marshville (C049547 - \$0.4m), Ticonderoga (C049552 - \$0.4m), New Scotland (C049553 - \$1.1m), Queensbury (C049554 - \$1.1m), Tilden (C049556 - \$1.1m), Schuyler (C049562 - \$1.1m), Whitehall (C049564 - \$1.1m).

Table 2-32
Transmission – Circuit Breaker Replacements
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 0.2 | 3.6 | 3.6 | - | 1.6 | - | 9.0 |
| 2015 | | 3.2 | 4.8 | 1.0 | 1.6 | 2.0 | 12.6 |

2015 NY Capital Investment Plan

Hook Road-Elbridge Polymer Insulator Replacement (C056626 - \$1.2m) The Company began installing polymer insulators on its transmission system in the mid-1980s due to their advantages of being lighter weight and easy to handle, lower installation costs, smaller viewing profile and improved resistance to vandalism. Since then, however, the utility industry has noticed some key disadvantages compared to porcelain insulators including susceptibility to aging due to being constructed from organic materials, contamination performance over time, inability to test in an energized state and susceptibility to handling, storage and installation damage. Electric Power Research Institute (EPRI) has recommended to utilities that the specific model of polymer insulators used on this line be removed from service.

Drivers:

The Hook Rd – Elbridge #7 115kV circuit has experienced a number of momentary interruptions due to polymer insulator failures. Momentary outages on the Hook Rd – Elbridge #7 circuit have caused the International Wire Group's (IWG), Jordan, NY facilities operational issues. The IWG facility is supplied by NYSEG via a 34.5kV line from the NYSEG Hamilton Rd Substation which is a Loop-in/Loop-out on the Hook Rd – Elbridge #7 line. IWG have registered a complaint with the NY PSC.

Customer Benefit:

Replacing the polymer insulators on the Hook Road-Elbridge #7 line will address insulator-related momentary outages for IWG.

2014 to 2015 Variance:

This project was not in last year's Plan.

Table 2-33
Transmission – Hook Road-Elbridge Polymer Insulator Replacement
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | - | - | - | - | - | - | - |
| 2015 | - | 0.05 | 1.2 | - | - | - | 1.2 |

345kV Laminated Cross-Arm Replacement Program (C060365 - \$12.6m)

The New Scotland – Alps #2 345kV line has experienced two failures on tangent (D-1501) structures within the past three years. The root cause has been identified to be the ageing laminated cross arms used to support the suspension insulators.

2015 NY Capital Investment Plan

Drivers:

Several D1501 cross arm samples were obtained from structures on the New Scotland-Alps #2 line being replaced due to normal maintenance. These cross arms were destructively examined in the field by forcing a shear failure parallel to their lamination. Once split, the lamination was examined for glue adhesion quality. Concurrently, samples were sent to SUNY-ESF for laboratory analysis. SUNY-ESF performed mechanical testing on large length samples to measure their bending strengths and compare them to their original design specifications. The results were that the in-service cross arms were weaker than what was specified.

Customer Benefit:

This program promotes safety and reliability by assuring transmission lines meet the governing NESC under which they were built by replacing deteriorating laminated cross arms that no longer structurally or electrically conform to their design specifications.

2014 to 2015 Variance:

This project was not in last year's Plan.

Table 2-34
Transmission – Laminated Cross-Arm Replacement
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | - | - | - | - | - | - | - |
| 2015 | - | 0.1 | 3.5 | 3.0 | 3.0 | 3.0 | 12.6 |

New Edic Station Control House (C058129 - \$2.4m)

Drivers:

A new control house was anticipated for the relay replacement program due to the age and over-crowding of equipment in the existing building. Due to the number of Asset Management, Transmission Planning, and Customer Requirements projects that are currently ongoing, replacement of the control house has been advanced in the current Plan.

Customer Benefit:

This project will help support the future needs of customer requirements, possible expansions from transmission planning, and asset replacements where the internal equipment would have to be upgraded to meet new NPCC and FERC requirements.

2015 NY Capital Investment Plan

2014 to 2015 Variance:

This project was not in last year's Plan.

Table 2-35
Transmission – New Edic Station Control House
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | - | - | - | - | - | - | - |
| 2015 | - | 2.0 | 0.4 | - | - | - | 2.4 |

Turner Type D Switch Replacements (C052603 - \$2.3m)

This project will replace all Turner Electric Company (Turner) Type D sidebreak disconnect switches in the National Grid transmission line system. This switch model suffers from reliability problems due to incomplete closure of the switch blades during operation. The blades on this type of switch are difficult to properly latch within the switch jaw and improper closure cannot be seen from the ground. If not properly latched, over time, the blades of the switch can gradually work free from the jaw, resulting in poor contact and eventual failure.

Drivers:

The primary drivers of this strategy include both reliability and safety. The potential failure of switches during service is a risk to employees. It is not feasible to ensure that all phases of a switch are fully closed after each operation due to the variables of switch design, installation, and operation. Harsh weather, especially during winter months, poses the greatest concern for the safe operation of Turner D switches. High winds and icy conditions put strong mechanical forces on the switch arm. If the jaw is not correctly locked, a build-up of ice can push the blade out of the contact area, resulting in an arc failure.

Customer Benefit:

It has been determined that the Type D switch manufactured by Turner presents a potential safety and reliability risk due to its design and problems inherent in its operation.

2014 to 2015 Variance:

There is no variance projected between the two Plans, the project continues to move forward as planned.

2015 NY Capital Investment Plan

Table 2-36
Transmission – Turner Type D Switch Replacements
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | - | 0.1 | 0.8 | 0.7 | 0.7 | - | 2.3 |
| 2015 | - | 0.1 | 0.8 | 0.7 | 0.7 | - | 2.3 |

Problem Identification Worksheets (PIWs) (C031545)

The Company employs a process called "Problem Identification Worksheets" to document faults and defects with in-service substation and overhead line equipment that are identified either through normal maintenance activities (often called 'follow-up' work) or through inspection routines (often called 'trouble' work). Typically, the issues identified through the PIW process cannot be corrected immediately and require investigation, engineering analysis and solution design. These activities and the solutions proposed often lead to low cost capital projects to replace or refurbish items of equipment.

Drivers:

Historically, issues identified during inspection or maintenance were added to the capital plan in outer years to avoid reprioritizing other planned projects. In FY10 a budgetary line for PIWs was introduced to recognize that a number of high priority, low cost, capital projects will inevitably arise during the year and these should be undertaken to address found-on-inspection issues. PIWs typically require some degree of investigation and engineering to identify a solution. PIWs are also used to identify and correct transmission overhead line components that no longer meet minimum NESC requirements. This work is over-and-above that required during normal I&M.

Issues arising from PIWs are prioritized and engineering solutions for the highest priority are developed within year. Utilizing this approach, the Company can make progress on low cost capital investments that might otherwise be lost in the capital plan.

Customer Benefit:

The PIW approach followed by the Company benefits customers and the overall health of the system. PIWs identify important issues and work that are high priority, but the work does not usually fall into the scope of ongoing strategies, and are not yet damage / failures. PIWs help identify trends throughout the system and give the Company feedback on how better to manage the system as a whole.

2014 to 2015 Variance:

The investment levels in FY16 to FY20 have been held the same as the 2014 Plan. PIW driven projects are likely to increase over the Plan period as a result of other capital investment reductions.

2015 NY Capital Investment Plan

Table 2-37
Transmission – Problem Identification Worksheets
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|
| 2014 | 0.4 | 1.0 | 1.0 | 1.0 | 1.0 | - | 4.4 |
| 2015 | - | 0.4 | 1.0 | 1.0 | 1.0 | 1.0 | 4.4 |

2015 NY Capital Investment Plan

5. E. Non-Infrastructure

Non-Infrastructure capital expenditures are for items that are not part of the electric power system, but are required to run the power system such as tools, communications, and other general plant.

Transmission Substation Physical Security (C053136)

This program provides state-of-the-art security measures to deter and/or detect unauthorized access to substations.

Drivers:

This program is driven by the need for additional physical security measures at certain substations to mitigate break-ins and the increasing risk that unauthorized access may lead to potential injury or death of a trespasser who comes in contact with energized equipment. Reducing and detecting unauthorized access also reduces risk of vandalism and damage to electric system equipment.

This project provides physical security measures in compliance with NERC standards.

Customer Benefits:

Deterring and detecting unauthorized access to certain substations would result in:

- Avoided or reduced physical and personal injury to unauthorized third parties as well as Company personnel at the substations.
- Reduced potential for service interruptions or equipment damage/loss from vandalism or theft.
- Protection of transmission stations against physical attack.

2014 to 2015 Variance:

The variance is due to anticipated costs to comply with NERC's CIP-014-1 in FY17.

Table 2-38
Transmission Substation Security
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | - | 1.5 | 1.5 | 1.5 | 1.5 | - | 6.0 |
| 2015 | - | 1.5 | 3.0 | 3.0 | 3.0 | 3.0 | 13.5 |

Chapter 3. Sub-Transmission System

The sub-transmission system comprises approximately 4,237 miles of lines including: 290 miles of 69kV, 365 miles of 46kV, 2332 miles of 34.5kV, 1050 miles of 23kV and 200 miles of lines below 23kV. Over the five-year period covered by this Plan, the Company expects to invest approximately \$182 million on the sub-transmission system, as shown in Table 3-1 below. There is a slight overall decrease in Sub-transmission spend between the 2014 CIP and the 2015 CIP due to efforts to reduce negative reserves in the prior plan which were offset by larger project listings. As a result, a better defined portfolio of projects is being presented for Sub-transmission. This has also resulted in some larger variances in a few of the programs.

Table 3-1
Sub-Transmission System Capital Expenditure by Spending Rationale (\$millions)
 A complete list of all projects in the capital plan can be found in Exhibit 2.

| Spend Rationale | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|---------------------------------------|-------------|-------------|-------------|-------------|-------------|--------------|
| Customer Requests/Public Requirements | 1.6 | 1.5 | 2.3 | 3.7 | 3.2 | 12.3 |
| Damage/Failure | 3.4 | 3.5 | 3.5 | 3.6 | 3.0 | 16.9 |
| System Capacity & Performance | 3.3 | 3.6 | 1.2 | 2.0 | 2.9 | 12.9 |
| Asset Condition | 19.0 | 20.5 | 32.1 | 33.3 | 34.9 | 139.8 |
| Total | 27.3 | 29.0 | 39.1 | 42.5 | 44.0 | 181.9 |

2015 NY Capital Investment Plan

3. A. Customer Requests/Public Requirements

Customer Request/Public Requirements investment levels are based primarily on forecasted spending on known specific work and a review of historical blanket spending. These estimates reflect consideration given to inflation, estimates of materials, labor, indirect cost, market sector analysis, overall economic conditions and historical activity.

Variances in planned program spending between the 2014 and 2015 Plans are also discussed below.

Table 3-2
Customer Request/Public Requirements Variance Summary (\$millions)

| | CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|-------------------|------|------|------|------|------|------|------|-------|
| Specific Projects | 2014 | 2.4 | 1.7 | 1.6 | 2.9 | 1.4 | - | 9.9 |
| | 2015 | - | 1.2 | 1.1 | 1.9 | 2.7 | 3.2 | 10.1 |
| Blankets | 2014 | 0.4 | 0.4 | 0.4 | 0.4 | 0.4 | - | 2.1 |
| | 2015 | - | 0.4 | 0.4 | 0.4 | 0.5 | 0.5 | 2.2 |
| Total | 2014 | 2.8 | 2.1 | 2.0 | 3.3 | 1.8 | - | 12.0 |
| | 2015 | - | 1.6 | 1.5 | 2.3 | 3.2 | 3.7 | 12.3 |

Aside from blanket and program spending described in this section, there are two specific projects identified under this spending rationale that have forecasted spending in excess of \$1 million in any single fiscal year:

- Project C034722, DOTR NYS Route 28 White Lake - McKeever Substation (Moose River) Transmission Line: This project provides for the mandatory relocation of 6 miles of 46kV overhead sub-transmission facilities along Route 28 in the towns of Forestport and Webb to facilitate a NYSDOT project
- Project C054665, Extend LN 611 & 612 to Riverbend, provides for the extension of two circuits across a rail yard to the Riverbend Development.

2015 NY Capital Investment Plan

3. B. Damage/Failure

The Damage/Failure investment level for the sub-transmission system is primarily based on historical costs for such work. Where condition renders the asset unable to perform its intended electrical or mechanical function on the delivery system, the Company initiates the timely replacement of such asset under the Damage/Failure spending rationale.

2014 to 2015 Variance:

The variance between the 2014 and 2015 Plans is based on recent historical spending.

Table 3-3
Damage/Failure
Variance Summary (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 2.6 | 2.1 | 2.2 | 2.2 | 2.3 | - | 11.4 |
| 2015 | - | 3.4 | 3.5 | 3.5 | 3.6 | 3.0 | 16.9 |

2015 NY Capital Investment Plan

3. C. System Capacity and Performance

The projected investment for sub-transmission work in the system capacity and performance spending rationale over the Plan period is shown in the table below.

2014 to 2015 Variance:

The projected program investment is based on the specific projects discussed in the Load Relief, Reliability and Sub-transmission Automation programs portions of this chapter. As described below, there has been a shift from System Capacity projects towards Asset Condition rationale projects. The overall spend in sub-transmission between the 2014 CIP and 2015 CIP are nearly the same.

Table 3-4
System Capacity and Performance
Variance Summary (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 3.8 | 5.4 | 9.9 | 8.6 | 6.0 | - | 33.7 |
| 2015 | - | 3.3 | 3.6 | 1.2 | 2.0 | 2.9 | 12.9 |

There are no specific projects in this category not associated with any of the programs estimated to have spending in excess of \$1 million in any fiscal year.

Capacity Planning

Drivers:

An annual review of the sub-transmission system, including substation and circuit loading, is performed to review equipment utilization. The reviews take into account both normal equipment loading and Load at Risk following an N-1 contingency. Forecasted load additions are applied to historical data and the system is analyzed to determine where and when constraints are expected to develop. Recommendations for system reconfiguration or system infrastructure development are created as part of this annual review to ensure load can be served during peak demand periods and is documented in the Annual Capacity Plan.

The normal loading assessment identifies load relief plans for facilities that are projected to exceed 100 percent of normal capability (i.e., maximum peak loading allowed assuming no system contingencies). The projects from these reviews are intended to be in-service during the year the load limit is forecasted to occur. In general, load growth within the service area has averaged 0.7 percent over the past 10 years, and that modest growth rate is expected to continue at a similar level for the next 10 years. However, individual areas within the service area are forecasted to grow at varying rates.

In addition to the normal loading review, the Company has instituted planning criteria for Load at Risk following an N-1 contingency that sets MW and MWh interruption exposure thresholds (“MWh Violations”) for various supply and feeder contingencies for the purpose of setting a standard for minimum electrical system performance. These thresholds are applied in conjunction with other criteria—such as maintaining acceptable delivery voltage and observing equipment capacity ratings—to ensure the system operates in a reliable manner while managing risk of customer interruptions to an acceptable level. MWh thresholds have been identified for three specific contingencies. For loss of a single substation supply line, a maximum interruption load limit of 20MW and/or 240MWh is specified, assuming that the line can be returned to service within 12 hours. For loss of a single substation power transformer, a maximum interruption load limit of 10MW and/or 240MWh is specified, assuming that the transformer can either be replaced or a mobile unit installed within 24 hours. Analysis of the interruptions under this criteria assume that any and all practical means are used to return load to service including use of mobile transformers and field switching via other area supply lines and/or area feeder ties. MWh analysis recognizes the approximate times required to install mobile/back-up equipment as well as stepped field switching, i.e. moving load from the adjoining in-service station with feeder ties, that will be used to pick up customers experiencing an interruption, to a second adjoining station to increase the capability of the feeder ties.

Customer Benefits:

The benefit to customers of completing the work identified in capacity planning studies includes less exposure to service interruptions due to overloaded cables and transformers. In addition, the implementation of projects to mitigate MWh Violations will reduce the likelihood that an unacceptable number of customers will be without service for extended periods due to supply, substation equipment or feeder contingencies.

2015 NY Capital Investment Plan

The projects resulting from these studies are now typically classified as Load Relief or Reliability. Other program classifications are possible. Although a project is classified in one program or another, it may have multiple drivers.

2014 to 2015 Variance:

The projected investment in this program is shown below. The variation year on year is due to the scope and timing of specific projects. Several cable replacement projects with load relief drivers have been removed in favor of the sub-transmission cable replacement program. In addition, Station-related sub-transmission capacity improvements are discussed in Chapter 2 Transmission due to their FERC classification. Many of the projects in the Sub-transmission Asset Replacement and Overhead Line programs have multiple drivers and provide load relief and reliability improvements as well. Load Relief and Reliability programs are combined in the table below to provide a comparison between the 2014 and 2015 Plans.

Table 3-5
Capacity Planning
Program Variance (\$millions)

| | CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|----------------------|------|------|------|------|------|------|------|-------|
| Specific Projects | 2014 | 1.9 | 3.4 | 6.4 | 5.2 | 0.3 | - | 17.1 |
| | 2015 | - | 1.9 | 3.1 | 0.7 | 2.4 | 1.5 | 9.5 |
| Load Relief Blankets | 2014 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | - | 0.1 |
| | 2015 | - | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.1 |
| Total | 2014 | 1.9 | 3.4 | 6.4 | 5.2 | 0.3 | - | 17.2 |
| | 2015 | - | 2.0 | 3.1 | 0.7 | 2.4 | 1.5 | 9.6 |

The following specific projects are classified as Load Relief and are estimated to have spending in excess of \$1 million in any fiscal year:

- Project C028893, Buffalo 23kV Reconductor - Huntley 2. This project will replace cable 11H from Sawyer Station to Buffalo Station 52. This cable has exceeded summer normal ratings in the past and may exceed emergency ratings for the loss of one of the other three supply cables.

There are no specific projects classified as Reliability that are estimated to have spending in excess of \$1 million in any fiscal year. There are projects in other classifications that have reliability benefits.

2015 NY Capital Investment Plan

Sub-Transmission Automation

In a continuing effort to modernize the grid the Sub-Transmission Automation Strategy includes advanced distribution automation methodologies as well as SCADA for reclosers, fault locators, and switches; and the interface of distribution automation enabled line devices with substation feeder breakers. It also encompasses the communication of these devices with each other and to central operations centers and database warehouses. The Company often refers to such devices and communications technology as Advanced Grid Applications.

Drivers:

The Company recognizes the benefit of identifying projects where the installation of modernized switching schemes will provide increased reliability to the sub-transmission system. The number of Advanced Grid Application switches per circuit or installation will vary depending on the number of substations the circuit supplies, the desired segmentation of the line, and the configuration of the supply system. Many of the automation schemes are unique and are developed considering an analysis of expected costs and benefits.

Customer Benefits:

Distribution lines or substations not equipped with automated sectionalizing or throw over schemes may be subject to extended service interruptions as Operations personnel must travel to the field locations to perform switching. This program provides an opportunity to continue to modernize the grid for the benefit of customers by reducing the number of customer interruptions that result from a given contingency and the time required to reconfigure the system to restore service to as many customers as possible while a faulted section of the system is being repaired.

2014 to 2015 Variance:

The projected investment is shown in the table below. Approximately \$5.0M in additional projects have been identified, but funding projects have not yet been created and hence they are not yet placed into the plan. The prioritization of projects and the timing of their implementation will be based on the performance of the various individual circuits.

Table 3-6
Sub-Transmission Automation
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 1.1 | 0.6 | 1.2 | 2.1 | 2.0 | - | 7.0 |
| 2015 | - | 1.1 | 0.0 | 0.0 | 0.0 | 0.0 | 1.1 |

The following circuits have been identified for Sub-transmission Automation:

- Lowville-Boonville #22 Line
- Akwesasne-Fort Covington-Malone #26 Line

2015 NY Capital Investment Plan

- Akwesasne-Nicholville #23 Line
- Nicholville-Malone #21 Line
- Gasport-Telegraph Line 312
- Delavan-Machias- Line 801
- Homer Hill – Nile Line 811
- Sherman-Ashville Line 863

Funding projects have not yet been initiated for these lines. Potential spend on these projects is approximately \$5.0M.

2015 NY Capital Investment Plan

3. D. Asset Condition

Planned asset condition investment levels for the sub-transmission system are described below.

2014 to 2015 Variance:

It should be noted that the replacement of several deteriorated cable circuits are accounted for in the System Capacity and Performance spending rationale since the replacements also provide needed capacity increases.

**Table 3-7
Asset Condition
Variance Summary (\$millions)**

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 23.6 | 23.1 | 22.5 | 26.2 | 31.9 | - | 127.5 |
| 2015 | - | 19.0 | 20.5 | 32.1 | 33.3 | 34.9 | 139.8 |

The following specific Asset Replacement projects have forecasted spending that exceeds \$1 million in any fiscal year:

- Project C046707, Oakfield-Caledonia LN201 Reconductor. Reconductor approximately 11 miles between Churchville and Caledonia including pole replacements.
- Project C046779, Shaletton-Ridge 610, Station 207 tap provides for the refurbishment or replacement of deteriorated steel towers on the Station 207 tap.
- Project C046468, W. Portland-Sherman 867-34.5kV Refurbishment. Refurbish 34.5kV line including pole replacement as needed and replacement of deteriorated small copper conductors.
- Project C046469, Dake Hill-W Salamanca 816-34.5kV Refurbishment. Refurbish 34.5kV line including pole replacement as needed and replacement of deteriorated small copper conductors.
- Project C046465, Phillips-Barker 301-34.5kV Refurbishment. Refurbish 34.5kV line including pole replacement and replacement of deteriorated overhead conductor.
- Project C052209, Hartfield-S.Dow 859-34.5kV Relocation. Relocate 6 miles of 34.kV line due to access and tree trimming constraints. Scope removed from mainline refurbishment Project C033180

2015 NY Capital Investment Plan

Inspection and Maintenance

Under this program, the Company performs visual inspections on all overhead and underground distribution assets once every five years. Each inspection identifies and categorizes all necessary repairs, or asset replacements, against a standard and in terms of criticality to improve customer reliability in compliance with the Commission's Safety Order in Case 04-M-0159.¹

In addition, the following types of inspections are conducted by the Company:

- Aerial assessments of sub-transmission lines on an annual basis, and
- Infra-red inspection of sub-transmission lines on a three year schedule.

The Company also performs annual elevated voltage testing per the Commission's Safety Order on all facilities capable of conducting electricity that are publicly accessible.

This program has been moved from the Customer Requests/Public Requirements spending rationale to Asset Condition to better reflect its impact on the condition of the Company's electric facilities.

Drivers:

The Company implements the Inspection and Maintenance program in accordance with the Commission's directives in Case 04-M-0159. The Company's annual Asset Condition Report details the application of the Inspection and Maintenance program to sub-transmission assets.²

Customer Benefits:

This program is designed to ensure the Company fulfills its obligation to provide safe and adequate service by inspecting its facilities and repairing safety and reliability issues identified in a timely fashion.

2014 to 2015 Variance:

Current investment forecasts are based on actual expenditures incurred under the Inspection and Maintenance program and an expectation that the number of defects found in future year inspections will decrease as the inspection cycle repeats.

Table 3-8
Inspection and Maintenance
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 11.4 | 9.0 | 5.7 | 5.0 | 5.0 | - | 33.0 |
| 2015 | - | 6.3 | 6.3 | 6.2 | 6.1 | 6.1 | 31.0 |

¹ Case 04-M-0159, Proceeding on Motion of the Commission to Examine the Safety of Electric Transmission and Distribution Systems, Order Adopting Changes in the Electric Safety Standards (issued and effective Dec. 15, 2008) ("Safety Order").

² Report on the Condition of Physical Elements of Transmission and Distribution Systems, Case 12-E-0201, most recently filed on October 1, 2014.

2015 NY Capital Investment Plan

Overhead Line

Various projects are in place to refurbish or replace sub-transmission overhead assets to ensure the system continues to perform in a safe and reliable manner. This includes pole, tower, overhead ground wire and conductor replacement in addition to the work generated via the Inspection and Maintenance program discussed above.

Drivers:

Although spending is categorized by spending rationale, all drivers are considered in determining the optimum project solution. Reliability and condition are the main drivers for these projects. Historically, the number of reliability events that are initiated on the sub-transmission system is low; however these events can result in a significant number of customers being interrupted where the lines are radial.

Physical condition of the sub-transmission system is being assessed through the Inspection and Maintenance program, helicopter surveys and by local engineering reviews and 'walk downs'.

Customer Benefits:

Refurbishment and replacement of sub-transmission system components can have a significant impact on regional CAIDI/SAIFI and Customer Minutes Interrupted (CMI) since they typically supply distribution stations.

2014 to 2015 Variance:

The projected investment is shown in the table below. Existing identified work under this program will be continued. New projects are being identified on lines where work is needed due to significant deterioration.

**Table 3-9
Overhead Line
Program Variance (\$millions)**

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 6.5 | 8.5 | 11.4 | 14.0 | 19.5 | - | 63.3 |
| 2015 | - | 7.2 | 8.7 | 11.8 | 13.4 | 19.6 | 60.7 |

The following specific projects have forecasted spending that exceeds \$1 million in any fiscal year:

- Project C033180, Hartfield-South Dow 859 Refurbishment. Refurbish 34.5kV line including pole replacement as needed and replacement of deteriorated conductors.
- Project C033182, Amsterdam-Rotterdam 3/4 Relocation. Relocate ¾ mile of Double Circuit 69kV to avoid wetland.
- Project C046441, Lighthouse Hill-Mallory 22-34.5kV Refurbishment. Refurbish 34.5kV including pole replacements

2015 NY Capital Investment Plan

- Project C046472, Ballston-Mechanicville 6-34.5kV Refurbishment. Refurbish 34.5kV line including pole, tower, and overhead ground wire replacements.
- Project C046681, Mallory-Cicero 33-34.5kV Refurbishment. Refurbish 34.5kV line including pole replacements and a centerline relocations to correct unequal span lengths, reducing the number of structures.
- Project C052511, Barker-Lyndonville 301-34.5kV Refurbishment. Refurbish 34.5kV line including pole replacements as needed and replacement of deteriorated overhead conductor.
- Project C052512, Lyndonville-Medina 301-34.5kV Refurbishment. Refurbish 34.5kV line including pole replacements as needed and replacement of deteriorated overhead conductor.
- Project C046459, Deerfield-Whitesboro 26-46kV Refurbishment. Refurbish 46kV line including pole replacements as needed and deteriorated overhead ground wire.
- Project C050323, Mechanicville-Schuylerville 4-34.5kV Refurbishment. Refurbish 34.5kV line including pole replacements as needed.
- Project C046473, Woodard 29-34.5kV Refurbishment. Refurbish 34.5kV line including pole, tower and overhead conductor replacements.
- Project C050959, Elbridge-Jewitt 31-34.5kV Refurbishment. Refurbish 34.5kV line including pole and Aeromotor tower replacements.
- Project C046641, Callanan Tap – Rebuild Existing 34.5 Line provides for the refurbishment of the Callanan Tap 1 between Bethlehem-Voorheesville Line 1 and the customer.
- Project CD00898, West Milton Tap – 34.5kV new Line, provides of the installation of an approximately 3 mile new supply line to West Milton from Rock City Falls to allow the retirement of approximately 9 miles of line.

The following projects are accomplishing similar work to the Overhead Line projects but have a program code of Asset Replacement. The costs for these projects are not included in Table 3-9; project summaries are included below Table 3-7.

- Project C046468, W. Portland-Sherman 867-34.5kV Refurbishment
- Project C046469, Dake Hill-W Salamanca 816-34.5kV Refurbishment.
- Project C046465, Phillips-Barker 301-34.5kV Refurbishment
- Project C052209, Hartfield-S.Dow 859-34.5kV Relocation
- Project C046779, Shaleton-Ridge 601, Station 207 Tap-34.5kV Refurbishment

2015 NY Capital Investment Plan

Underground Cable

Various projects are completed each year to refurbish or replace sub-transmission underground assets to ensure the system continues to perform in a safe and reliable manner.

Buffalo

A major program has been initiated to replace 23kV cables in the city of Buffalo. The existing distribution system in the City of Buffalo was built starting in 1929 and is supplied by four terminal stations: Sawyer, Seneca, Kensington and Elm Street. The 23kV cable system represents about 433 miles of underground cables and supplies over forty 4.16kV distribution substations. Approximately 385 miles of the original 1-3/C-350kcmil CU PILC (paper in lead covered cable) installed in the late 1930s are still in service. As time progresses, the aging cables experience continued mechanical stress due to annual loading cycles and eventually fail, causing interruptions.

Through analysis of failure records, 83 miles of cables have been identified that are considered high risk. These are cables that have a high rate of failure and have a major impact to our distribution substations and customers in an event of cable failure.

Drivers:

Failures of individual sub-transmission cables do not typically impact customer reliability since the portions of the system where they are utilized are generally networked. However, because these systems are located below ground and are out of sight, failures of underground sub-transmission cables can be difficult to locate and time-consuming to repair leaving the system at risk.

There are approximately 1,100 miles of sub-transmission underground cable. Approximately one-half are more than 48 years old and one-third are more than 60 years old. The sub-transmission underground cable asset replacement program replaces cables that are in poor condition, have had a history of failure or of a type known to have performance issues.

Customer Benefits:

Cable replacement projects reduce the likelihood of in service cable failures, and resulting exposure to the risk of extended outages.

2014 to 2015 Variance:

The projected program investment is shown in the table below. The variation year on year is due to the scope and timing of specific projects.

Table 3-10
Underground Cable
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 1.4 | 5.2 | 4.4 | 3.7 | 6.2 | - | 20.8 |
| 2015 | - | 1.6 | 2.1 | 4.3 | 3.0 | 3.7 | 14.7 |

2015 NY Capital Investment Plan

The following specific projects have forecasted spending that exceeds \$1 million in any fiscal year:

Project C052483, Buffalo 23kV UG Cable replacement program provides for the replacement of high risk cables.

Project C036273, Partridge-Ave A#5 Cable Replacement provides for the replacement of approximately one-third of a mile of gas filled cable in the City of Albany.

Not represented in the investment forecasts in the table above is the cable replacement project C028893, Buffalo 23kV Reconductor - Huntley2. This planned project is included in the forecasts for spending in the System Capacity and Performance Spending Rationale, in the Capacity Planning program.

Chapter 4. Distribution System

The Company's distribution system consists of lines and substations typically operating at 15kV and below. There are nearly 36,000 circuit miles of overhead primary wire and nearly 7,500 circuit miles of underground primary cable on the system supplying approximately 400,000 overhead, padmount and underground distribution transformers. Additionally, there are 421 substations providing service to the Company's 1.6 million electric customers.¹ The current five-year plan for distribution is represented in Table 4-1.

Table 4-1
Distribution System Capital Expenditure by Spending Rationale (\$millions)

| Spend Rationale | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|---------------------------------------|--------------|--------------|--------------|--------------|--------------|---------------|
| Customer Requests/Public Requirements | 85.5 | 84.9 | 89.3 | 90.9 | 89.7 | 440.3 |
| Damage/Failure | 27.7 | 28.1 | 28.6 | 29.5 | 29.1 | 143.0 |
| System Capacity & Performance | 70.1 | 63.0 | 81.5 | 78.4 | 80.3 | 373.4 |
| Asset Condition | 67.3 | 72.9 | 82.6 | 93.2 | 86.3 | 402.2 |
| Non-Infrastructure | 3.0 | 3.0 | 3.0 | 3.1 | 3.0 | 15.1 |
| Total | 253.6 | 251.8 | 285.1 | 295.0 | 288.5 | 1374.0 |

¹ The distribution system data was taken January 24, 2015 from National Grid Asset Information Website located at <http://usinfo.net2/OurOrganization/NetworkStrategyUS/AssetManagement/Pages/AssetDetails.aspx>.

2015 NY Capital Investment Plan

4. A. Customer Requests/Public Requirements

Distribution Customer Requests/Public Requirements projects include capital expenditures for new business residential, new business commercial, outdoor lighting, and third party attachments, among other things. Customer Requests/Public Requirements investment levels are based primarily on review of historical blanket spending and forecasted spending on known specific work. These estimates reflect consideration given to inflation, estimates of materials, labor, indirect cost, market sector analysis, overall economic conditions and historical activity.

Little variance between the 2014 and 2015 Plans is forecasted for this category.

Table 4-2
Customer Requests/Public Requirements Spending Rationale
Variance Summary (\$millions)

| | CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|-------------------|------|------|------|------|------|------|------|-------|
| Blankets | 2014 | 67.7 | 69.4 | 70.9 | 72.7 | 74.5 | - | 355.3 |
| | 2015 | - | 68.7 | 69.3 | 71.2 | 73.8 | 72.6 | 355.6 |
| Specific Projects | 2014 | 17.8 | 16.4 | 16.4 | 16.6 | 16.7 | - | 83.9 |
| | 2015 | - | 16.8 | 15.6 | 18.2 | 17.1 | 17.1 | 84.7 |
| Total | 2014 | 85.5 | 85.8 | 87.3 | 89.2 | 91.2 | - | 439.1 |
| | 2015 | - | 85.5 | 84.9 | 89.3 | 90.9 | 89.7 | 440.3 |

Blankets

The distribution Customer Requests/Public Requirements blankets include items such as New Business Residential, New Business Commercial, Outdoor Lighting, Public Requirements, Transformer Purchase and Installation, Meter Purchase and Installation, Third Party Attachments, and Land Rights. Exhibit 3 shows the detailed investment for all blankets in this rationale. Blankets are described in more detail below:

New Business Residential

Installation of new overhead or underground services to residential customers, reconnections as well as miscellaneous equipment related to providing or upgrading services based on customer requests. Project spending can also include costs for the extension of distribution feeders directly related to providing service to a new residential customer or development; and actual spending is net of any contribution in aid of construction (CIAC).

New Business Commercial

Installation of new services to commercial customers, reconnections as well as miscellaneous equipment related to providing or upgrading services based on customer requests. Project spending can also include costs for the extension of distribution feeders directly related to providing service to a new commercial or industrial customer or development; and actual spending is net of any CIAC.

Transformer Purchase

Transformers are purchased and are shipped to locations within the Company where these items are put into stores.

Meter Purchase

Meters are purchased and shipped to locations within the Company where these items are put into stores.

Meter Installation

Meters are installed or replaced at customer metering points to maintain equipment compatibility and readout accuracy.

Public Outdoor Lighting

Street lighting or private area lighting and related equipment is installed or replaced.

Public Requirements

Overhead and underground facility relocations resulting from bridge or roadway rebuilds, expansions, or relocations; municipal requests to relocate overhead facilities underground; and other public authorities requesting or performing work that requires equipment or facilities to be relocated.

2015 NY Capital Investment Plan

4. B. Damage/Failure

Damage/Failure projects are required to replace equipment and restore the electric system to its original configuration and capability following equipment damage or failure. Damage may be caused by storms, vehicle accidents, vandalism or other unplanned events, among other causes. The Damage/Failure spending rationale is typically a mandatory spending rationale of work that is non-discretionary in terms of scope and timing.

The Damage/Failure investment level for the distribution system is primarily based on historical actual costs for such work. Where condition renders the asset unable to perform its intended electrical or mechanical function on the delivery system, the Company initiates the timely replacement of such asset under the Damage/Failure spending rationale.

2014 to 2015 Variance:

Spending in the damage failure category is forecasted to increase approximately 20 percent compared to last year's plan. The increase in future spend in this year's Plan compared to last year relates to an increase in actual spending that is projected into future years. Comparison of the distribution Damage/Failure investment levels from the 2014 and 2015 Plans is set forth below.

Table 4-3
Damage/Failure Spending Rationale
Variance Summary (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 22.5 | 23.1 | 23.5 | 23.9 | 23.7 | - | 116.7 |
| 2015 | - | 27.7 | 28.1 | 28.6 | 29.5 | 29.1 | 143.0 |

Aside from blanket and program related projects, there are no specific projects identified under this spending rationale that exceed \$1 million in any fiscal year.

2015 NY Capital Investment Plan

4. C. System Capacity and Performance

System Capacity and Performance projects are required to ensure the electric network has sufficient capacity, resiliency, or operability to meet the growing and/or shifting demands of the system and our customers. Projects in this spending rationale are intended to reduce degradation of equipment service lives due to thermal stress, to improve performance of facilities where design standards have changed over time, and to provide appropriate degrees of system configuration flexibility to limit adverse reliability impacts of contingencies. In addition to accommodating load growth, the expenditures in this rationale are used to install new equipment such as capacitor banks to maintain the requisite power quality required by customers and reclosers that limit the customer impact associated with an interruption. It also includes investment to improve performance of the network through the reconfiguration of feeders and the installation of feeder ties. The projected distribution investment in the system capacity and performance spending rationale over the Plan period is shown below.

2014 to 2015 Variance:

The forecasted investment levels represent the cash flow of specific projects. The variance between the 2014 and 2015 Plans is based on the scope and timing of the specific projects in this category as discussed following the table below.

Table 4-4
System Capacity and Performance Spending Rationale
Variance Summary (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 67.9 | 68.0 | 83.3 | 93.1 | 95.7 | - | 408.1 |
| 2015 | - | 70.1 | 63.0 | 81.5 | 78.4 | 80.3 | 373.4 |

Capacity Planning

Drivers:

An annual review of the distribution system, including substation and feeder loading, is performed to review equipment utilization. The reviews take into account both normal equipment loading and Load at Risk following an N-1 contingency. Forecasted load additions are applied to historical data and the system is analyzed to determine where and when constraints are expected to develop. Recommendations for system reconfiguration or system infrastructure development are created as part of this annual review to ensure load can be served during peak demand periods and is documented in the Annual Capacity Plan.

The normal loading assessment identifies load relief plans for facilities that are projected to exceed 100 percent of normal capability (i.e., maximum peak loading allowed assuming no system contingencies). The projects from these reviews are intended to be in-service during the year the load limit is forecasted to occur. In general, load growth within the service area has averaged 0.7 percent over the past 10 years, and this growth rate is expected to continue for the next 10 years. However, individual areas within the service area are forecasted to grow at varying rates.

In addition to the normal loading review, the Company has instituted planning criteria for Load at Risk following an N-1 contingency that sets MW and MWh interruption exposure thresholds ("MWh Violations") for various supply and feeder contingencies for the purpose of setting a standard for minimum electrical system performance. These thresholds are applied in conjunction with other criteria - such as maintaining acceptable delivery voltage and observing equipment capacity ratings - to ensure the system operates in a reliable manner while managing risk of customer interruptions to an acceptable level. MWh thresholds have been identified for three specific contingencies. For loss of a single substation supply line, a maximum interruption load limit of 20MW and/or 240MWh is specified, assuming that the line can be returned to service within 12 hours. For loss of a single substation power transformer, a maximum interruption load limit of 10MW and/or 240MWh is specified, assuming that the transformer can either be replaced or a mobile unit installed within 24 hours. Finally, for loss of any single distribution feeder element, a maximum interruption of 16MWh is specified. Analysis of the interruptions under this criteria assume that any and all practical means are used to return load to service including use of mobile transformers and field switching via other area supply lines and/or area feeder ties. MWh analysis recognizes the approximate times required to install mobile/back-up equipment as well as stepped field switching, i.e. moving load from the adjoining in-service station with feeder ties, that will be used to pick up customers experiencing an interruption, to a second adjoining station to increase the capability of the feeder ties.

The Annual Capacity plan reviews loading on over 2,000 feeders and more than 400 substations and results in numerous upgrade projects that range in scope from switching load between feeders and/or substations to new lines or substations.

2015 NY Capital Investment Plan

Customer Benefits:

The benefit to customers of completing the work identified in capacity planning studies includes less exposure to service interruptions due to overloaded cables and transformers. In addition, the implementation of projects to mitigate MWh Violations will reduce the likelihood that an unacceptable number of customers will be without service for extended periods due to supply, substation equipment or feeder contingencies.

The projects resulting from these studies are now typically classified as Load Relief or Reliability. Other program classifications are possible. Even though a project is classified in one program or another it may have multiple drivers.

2014 to 2015 Variance:

The projected investment is shown in the table below and variation year on year is due to the scope and timing of specific projects. Projects in this program in prior years have been reclassified to the Load Relief and Reliability programs. The table below consolidates those two programs for the 2015 CIP to provide for a comparison to the 2014 CIP. The variance in spend is due to an increase in identified load relief projects in later years compared to earlier years.

Table 4-5
Capacity Planning
Program Variance (\$millions)

| | CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|----------------------|------|------|------|------|------|------|------|-------|
| Specific Projects | 2014 | 28.5 | 30.3 | 49.7 | 59.8 | 55.4 | - | 223.7 |
| | 2015 | - | 49.9 | 44.1 | 54.8 | 57.7 | 57.4 | 263.9 |
| Load Relief Blankets | 2014 | 1.8 | 1.9 | 1.9 | 2.0 | 2.1 | - | 9.7 |
| | 2015 | - | 1.8 | 1.9 | 1.9 | 2.0 | 2.0 | 9.6 |
| Total | 2014 | 30.3 | 32.2 | 51.6 | 61.8 | 57.4 | - | 233.4 |
| | 2015 | - | 51.7 | 45.9 | 56.7 | 59.6 | 59.5 | 273.5 |

The following specific projects are classified as Load Relief and are forecasted with planned spending in excess of \$1 million in any fiscal year. Details on the planned spending profiles for these projects are included in Exhibit 3.

- Projects C046609 and C046643, Milton Ave Substation and feeders, respectively. These projects provide for the resolution of normal loading concerns and MWh Violations for contingency loss of the existing substation transformer.
- Projects C046475 and C046476, New Cicero Substation and feeders, respectively. These projects provide for the resolution of normal loading concerns and MWh Violations for contingency loss of an existing substation transformer at Pine Grove Substation.

2015 NY Capital Investment Plan

- Projects C046634 and C046635, New Haven Transformer Upgrade and Feeder, respectively. These projects upgrade the existing transformer at New Haven and extend a new feeder to relieve/retire Mexico Substation and provide a feeder tie to East Pulaski to address loading and contingency concerns.
- Project C032446, Harris 54 Relief with associated projects provides for the upgrade of the existing distribution feeder getaways and two new feeders to resolve loading above summer normal ratings and MWh criteria violations of the Harris Ave. Substation transformer as well as asset condition concerns at adjacent substations.
- Project C046511, Teall Substation Rebuild, provides for replacing the existing metalclad switchgear with higher rated switchgear and installing a second transformer to address loading and asset condition issues.
- Project CD00896, Randall Road New Substation. This portion of the project is for a new 15kV switchgear and capacitor bank at a new 115-13.2 kV station. This and associated projects will resolve loading above summer normal rating of the existing substation transformer, MWh criteria violations and distribution feeder loading issues.
- Project CD00897, Randall Road Distribution Getaways. This project provides for the distribution line work associated with Project CD00896 described above.
- Projects C046798 and C046796, Sodeman Road New Substation and Distribution Getaways, respectively. These projects provide for a new 15kV switchgear and capacitor bank at a new 115-13.2 kV station as well as distribution feeder getaways, feeder reconductoring and other feeder work. These projects will resolve loading above summer normal rating of the existing substation transformer, MWh criteria violations and distribution feeder loading issues.
- Project C046490, Van Dyke Station. This project installs a new 115-13.2kV station to address loading, asset condition and reliability concerns in and adjacent to the Town of Bethlehem.
- Projects C016087, C046487, C046488, C046495 and C052098 Van Dyke Feeders. These projects provide for distribution line work associated with Project C046490 described above.
- Projects C053137 Forbes Ave – New Substation and CD00893, DeLaet's Landing Feeders, respectively. These projects are for a new 115-13.2kV station and feeders to address loading concerns in the City of Rensselaer due to a new development.
- Project C046761, Grooms Rd 24557 provides for the rebuild and conversion of Saratoga Road from 4.8kV to 13.2kV to address loading concerns.
- Project C046790 and C046791, McCrea Substation and feeders, respectively. These projects provide for the resolution of normal loading concerns at Burgoyne and Butler as well as asset condition concerns at the existing McCrea substation.

2015 NY Capital Investment Plan

- Project CD00895, Queensbury, provides for connecting the new station metalclad switchgear to the existing feeders.
- Project C028929 – Frankhauser. This project provides for new distribution feeder construction to be supplied by the Frankhauser Substation to address distribution and sub transmission capacity issues.
- Project C036502, Buffalo Station 56 Upgrade Four Transformers. This project replaces four 23-4.16kV transformers with larger transformers to address loading above summer normal ratings.
- Project C035743, Wilson 93 Load Relief. This project provides for the replacement of the existing Wilson Transformer with a larger transformer to address station loading concerns.
- Project C046538, Eden Switch Structure. This and associated projects provide of the installation of a new 34.5-13.2kV station near the existing Eden Switch Structure as well as the construction of new feeders to address loading and reliability concerns in the area.
- Project CD01128, Buffalo Station 49 – UG Upgrades. This project provides for three (3) new feeders in a new conduit and manhole system to supply customers in the Buffalo Niagara Medical Corridor.
- Project C051585, Sonora Way 115-13.2v Substation. This and associated projects provide for the relief of normal loading concerns at area substations as well as address outage exposure concerns.

The following specific projects are classified as Reliability program and are forecasted with planned spending in excess of \$1 million in any fiscal year. Details on the planned spending profiles for these projects are included in Exhibit 3.

- Project C036188, East Malloy Substation Second Transformer Addition. This project provides for the resolution of MWh Violations for contingency loss of the existing substation transformer.
- Project C036189, Fly Road Transformer Addition and C046722 Fly Road Low Side Substation Equipment. These projects provide for the resolution of MWh violations for the contingency loss of the existing transformer and load relief for adjacent feeders.
- Project C046636, Whitaker Substation. This project provides for the resolution of MWh Violations for contingency loss of the existing substation transformer.
- Project C046627 and C046610, Watertown New 115/13.2kV Substation and feeders, respectively. These projects provide for a new 115-13.2kV substation and distribution feeders to address normal and contingency loading issues in the Watertown area.
- Project C054587, Malone Second Transformer. This and associated projects are to resolve MWh violations for contingency loss of the existing substation transformer.

2015 NY Capital Investment Plan

- Project C046613, Terminal Station relocation. This and associated projects provide for the replacement of the existing Terminal Station at a nearby location to address reliability issues.
- Project C049197 – NR 76462-CoRte28-Rebuild. This project constructs new three-phase and single-phase portion of the circuit to upgrade and/or replace existing.
- Project C049727, McGraw-Truxton Feeder Tie. This project creates a feeder tie to resolve the lack of feeder ties on Truxton 73 and provide operational flexibility to improve restoration times for our customers.
- Projects C029186 and C029187, Station 214 - Second Transformer Addition and new feeders respectively. These projects will resolve the existing loading above summer normal rating of the existing transformer and provide relief to existing stations and adjacent feeders.
- Project C036056, Military Road 210 - Second Transformer Addition. This project provides for the resolution of MWh Violations for contingency loss of the existing substation transformer.
- Project C036059, Shawnee Road 76 - Second Transformer Addition. This project provides for the resolution of MWh Violations for contingency loss of the existing substation transformer.
- Project C036639, Buffalo Station 139 - Replace Transformers. This project provides for the replacement of the two existing Buffalo Station 139 Substation transformers, which are overloaded on contingency loss of one transformer.
- Project CD01089 and CD01090, West Hamlin 82 - Install Transformer #2 and additional feeders respectively. These projects provide for the resolution of MWh Violations for contingency loss of the existing substation transformer.
- Project C046590 and C045589, Mumford – Install Transformer #2 and additional feeder respectively. These projects provide for the resolution of MWh Violations for contingency loss of the existing substation transformer.
- Project C046536, Delameter - Install Two 20/26/33 MVA Transformers. This project and associated projects provide for the resolution of MWh Violations for contingency loss of the existing substation transformer, asset condition issues with the existing transformer and loading issues with neighboring stations.
- Project C051266 and C051265, New Tonawanda Station and Line Work, respectively. These projects provide for the installation of a new 115-13.2kV substation and feeders to supply the Riverview Development in Tonawanda.
- Projects CD00977 and CD99964, Long Road #209 new TB#2 and additional feeder, respectively. These projects install a second transformer at Long Road and extend a new feeder to address contingency loading issues on Grand Island.
- Project C046593 and C046591, West Sweden New Station and Feeders, respectively. These projects provide for the installation of a new 115-13.2kV substation and feeders to address contingency loading concerns.

2015 NY Capital Investment Plan

- Project C036057, Lockport Road 216 Second Transformer. This and associated projects provide for the installation of a second transformer to address contingency overloads in the area.

Heavily Loaded Line Transformer

The distribution line transformer strategy endeavors to mitigate outage/failure risks due to overloading of distribution service transformers. Transformer loading is reviewed annually via reports generated from the customer use information within the Geographical Information System (GIS). Transformers with calculated demands exceeding load limits specified in the applicable Construction Standard are identified and investigated in the field.

Heavily loaded units are to be systematically removed from the system over the next fifteen years. Replacement levels may be adjusted based on changes to loading levels, the condition of the population and budget constraints.

Drivers:

There are approximately 200 transformer failures per year due to overloading which affect approximately 3,000 customers annually. Proactive management of equipment loading through annual review has prevented overloaded transformers from becoming a significant system performance problem.

Customer Benefits:

The main benefit of this strategy is that asset utilization will be maximized by maintaining units in service until such point that replacement is required as identified through recurring loading reviews or visual and operational inspection, recognizing that transformer life expectancy is predominantly affected by loading and environmental factors rather than age. Implementation of this strategy will ensure the sustainability of this asset class over time and maintain its relatively minor impact on overall system reliability and customer satisfaction.

2014 to 2015 Variance:

The planned spend for the Heavily Loaded Line Transformer program, has been reduced to accommodate higher priority projects for the next several years.

Table 4-6
Heavily Loaded Line Transformer
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 3.2 | 3.2 | 3.3 | 3.4 | 3.4 | - | 16.5 |
| 2015 | - | 0.8 | 0.8 | 0.8 | 0.8 | 0.8 | 3.8 |

Remote Terminal Unit (RTU)

This strategy covers the addition of Remote Terminal Units (RTUs) and related infrastructure at substations presently lacking remote monitoring and control capabilities. RTUs in substations communicate with the EMS (Energy Management System) and provide the means to leverage substation data that provides operational intelligence and significantly reduces response time to abnormal conditions through real time monitoring and control.

There is an additional investment to replace outdated RTUs based on their asset condition. That investment is documented in the Asset Condition spending rationale section.

Drivers:

RTUs will allow for remote operation and management of the system at stations providing benefits in contingency response and recovery and thus improving performance and reliability. In addition, RTUs are key components of automation and modernization of the Company's infrastructure.

Customer Benefits:

This strategy provides the means to leverage operational intelligence and significantly reduce response time to abnormal conditions through real time monitoring and control. The strategy also enables the distribution automation, sub-transmission automation, and future modernization strategies which will improve service to customers. When used to monitor and control the distribution feeder breakers and associated feeder equipment, RTUs and EMS facilitate the isolation of faulted equipment and the time required to reconfigure the distribution system to re-energize customers in non faulted segments of the distribution system.

2014 to 2015 Variance:

The projected investment is shown in the table below and the Company plans to spend a similar amount year after year.

Table 4-7
Remote Terminal Unit
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 2.5 | 1.4 | 1.0 | 1.5 | 2.2 | - | 8.6 |
| 2015 | - | 3.4 | 0.9 | 1.5 | 1.5 | 1.5 | 8.8 |

Engineering Reliability Review

An Engineering Reliability Review (ERR) can be completed for any feeder experiencing reliability problems or any localized pocket of poor performance. ERRs are often performed on those feeders defined as Worst Performing Feeders (“WPF”) as described in the Electric Service Reliability Report, filed annually in accordance with Case 90-E-1119. The scope of an ERR is typically a:

- Review of one-year and multi-year historical reliability data for current issues and trends.
- Review of recently completed and/or future planned work which is expected to impact reliability.
- Review the need for the installation of radial and/or loop scheme reclosers.
- Review for additional line fuses to improve the sectionalization of the feeder.
- Comprehensive review of the coordination of protective devices to ensure proper operation.
- Review for equipment in poor condition.
- Review of heavily loaded equipment.
- Review for other feeder improvements such as fault indicators, feeder ties, capacitor banks, load balancing, additional switches and reconductoring (overhead and/or underground).

Drivers:

The ERR recommendations are utilized as a basis to improve the reliability on the circuits experiencing recent poor reliability performance.

Customer Benefits:

The ERR program will improve customer reliability in areas in which performance has been substandard. The ERR work also helps to harden the feeder and make the feeder more resilient.

2014 to 2015 Variance:

Projects associated with the ERR program are reactionary and are identified as reliability concerns arise. As such, specific projects are only identified in the early years of the plan. A future spending plan is created and reviewed annually to target priority projects.

Table 4-8
Engineering Reliability Review
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 3.7 | 6.2 | 8.0 | 7.9 | 7.0 | - | 32.8 |
| 2015 | - | 1.5 | 2.6 | 11.5 | 6.4 | 8.8 | 30.7 |

2015 NY Capital Investment Plan

Minor Storm Hardening

The Minor Storm Hardening program proposes to increase the resilience of the distribution system in select areas of the service territory that have experienced repeated outages during adverse weather days in an effort to improve reliability performance and customer satisfaction for those customers experiencing multiple interruptions. Work in these projects includes: reconductoring with tree resistant conductors, review of pole size and class as well as the use of Grade B construction at critical poles (junction poles, switch poles and road/rail/water crossings), additional sectionalizing points as appropriate (reclosers, fuses and switches), enhanced lightning protection and enhanced vegetation management.

Drivers:

The Storm hardening recommendations are utilized as a basis to improve the reliability in targeted areas that have experienced recent poor performance during adverse weather events.

Customer Benefits:

The Minor Storm Hardening program will enhance distribution resiliency in targeted areas.

2014 to 2015 Variance:

The projected investment and the variation between the 2014 and 2015 Plans is shown in the table below. A portion of the variance for FY16, FY17 and FY18 is the classification of several projects as Reliability even with “Minor Storm” in the project title, which represents approximately \$1.8M total for those years. Additional variance is due to improved project scopes and estimates due to the analysis performed on the circuits identified for the program.

**Table 4-9
Storm Hardening
Program Variance (\$millions)**

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 3.8 | 3.1 | 3.2 | 3.3 | 3.4 | - | 16.8 |
| 2015 | - | 1.3 | 0.9 | 2.0 | 2.0 | 1.6 | 7.8 |

There are no specific projects in this category forecasted with planned spending in excess of \$1 million in any fiscal year.

2015 NY Capital Investment Plan

Overhead Distribution Fusing

Various projects are in place which will maintain customer reliability through the installation of fuses on overhead distribution lines. Fuses are installed to isolate permanent faults on the distribution system. Ideally, these fuses are installed at locations which limit the interruption to the fewest number of customers possible. Proper fuse application will limit the duration of the interruption by isolating the fault to a smaller area and reducing the time required to find the fault.

Drivers:

Fuses isolate the faulted area of a feeder and thereby interrupt the smallest practical number of customers.

Customer Benefits:

These projects will result in a reduction in the number of customer interruptions and will help the Company continue to meet its service quality metrics.

2014 to 2015 Variance:

The program consists of two distinct components: fuse identification and fuse installation. The identification of fuse locations will conclude in FY17, and installations are expected to continue into FY19.

Table 4-10
Overhead Distribution Fusing
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 2.4 | 2.4 | 2.4 | 1.2 | 0.0 | - | 8.4 |
| 2015 | - | 1.2 | 0.8 | 0.4 | 0.3 | 0.0 | 2.7 |

Arc Flash Mediation - 480 Volt Spot Networks

The installation of 480 volt spot network primary and secondary isolation equipment mitigates the arc flash hazard levels within 480 volt spot network systems.

Drivers:

The primary driver of this strategy is safety. National Grid adheres to the National Electrical Safety Code's Part 4: Work Rules for the Operation of Electric Supply and Communication Lines and Equipment. This strategy addresses the National Electrical Safety Code 2012 revision which requires an arc flash hazard analysis for work assignments within distribution secondary network systems. This strategy will mitigate the calculated incident energy levels by installing engineering controls.

2015 NY Capital Investment Plan

Customer Benefits:

Installation of primary and secondary isolation equipment will facilitate emergency and routine maintenance without interruption of service to the customer. The high side isolation switches will eliminate disruption to customers of the same voltage level by eliminating the need for them to switch to back up sources or take an outage in the event a 480 volt network transformer has an issue that requires it to be de-energized.

2014 to 2015 Variance:

Forecasted spending levels are shown below. Previous materials issues are being resolved and installations increasing. Additional experience with equipment installs also contributes to the increasing number of installations. The project is forecasted for FY19 completion.

Table 4-11
Arc Flash Mitigation - 480 Volt Spot Networks Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 4.0 | 4.0 | 4.0 | 2.1 | 0.0 | - | 14.1 |
| 2015 | - | 3.1 | 3.4 | 3.4 | 3.4 | 0.0 | 13.3 |

Substation Flood Mitigation

The substation flood mitigation program endeavors to mitigate outage/failure risks due to flooding of distribution substations. Substation flood risk was analyzed to determine which distribution substations were at a high risk. Further analysis was completed to determine mitigating actions for each of the high risk substations. Some actions may be to raise certain equipment or to install a barrier at a particular station. Relocating a station was used in limited applications.

Drivers:

The Substation flood mitigation recommendations are utilized to improve the reliability in targeted areas that have a high probability to experience flooding during extreme rain events.

Customer Benefits:

The Substation Flood Mitigation program will enhance distribution resiliency in targeted areas.

2014 to 2015 Variance:

This is a new program for 2015.

2015 NY Capital Investment Plan

Table 4-12
Substation Flood Mitigation Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | - | - | - | - | - | - | - |
| 2015 | - | 1.9 | 1.9 | 0.0 | 0.0 | 0.0 | 3.9 |

The following specific project is classified as Flood Mitigation program and is forecasted with planned spending in excess of \$1 million in any fiscal year:

- Project C053167, Union Falls – Flood Mitigation. This and associated projects provide for the construction a new substation and feeder getaways at a higher elevation to address the flood risk at the existing substation.

System Capacity and Performance – Other

Projects previously categorized as other in System Capacity and Performance have been re-categorized into the various programs.

2015 NY Capital Investment Plan

4. D. Asset Condition

Planned asset condition investment levels for the distribution system, and comparison to investment levels from last year's Plan, are shown below.

2014 to 2015 Variance:

The variance between the 2014 and 2015 Plans is based on the scope and timing of the specific projects in this category as discussed following the table below.

Table 4-13
Asset Condition Spending Rationale
Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 64.1 | 67.9 | 78.7 | 74.2 | 75.0 | - | 359.9 |
| 2015 | - | 67.3 | 72.9 | 82.6 | 93.2 | 86.3 | 402.2 |

Funding levels for the programs and projects included in the Asset Condition rationale are presented below.

The following specific projects are proposed under the Asset Condition and are not associated with any of the programs described later in this chapter and exceed \$1 million in any fiscal year:

- Project C046790 and C046791, McCrea Substation and feeders, respectively. These projects provide for the resolution of normal loading concerns at Burgoyne and Butler as well as asset condition concerns at the existing McCrea substation.
- Project C046606, MV-Poland 62258 Route 8 Reconductor. This project reconductors and refurbishes the existing distribution circuit including pole replacements.
- Projects C046854 and C046859, Buffalo Station 42 Rebuild – D Station and feeders respectively. These projects replace the existing outdoor Buffalo Station 42 to address the existing condition issues at the substation.
- Project CD00782, Buffalo Station 122 Rebuild – Substation. This project replaces the existing outdoor Buffalo Station 122 to address the existing asset condition issues at the substation.
- Project C050400, Ohio St – Buffalo River Tunnel/Bore. This project provides for a new casing and duct bank approximately 50 feet under the river to replace the existing flooded tunnel and to connect to two new 20-way duct banks from the Ohio Street rebuild project.

2015 NY Capital Investment Plan

Inspection and Maintenance

The Company performs visual inspections on all overhead and underground distribution line assets once every five years. Each inspection identifies and categorizes all necessary repairs, or asset replacements, against a standard and in terms of criticality to maintain customer safety and reliability in compliance with the Commission's Safety Order in Case 04-M-0159.² The Company also performs annual contact voltage testing per the Commission's Safety Order on all facilities that are capable of conducting electricity and are publicly accessible, such as street lights.

2014 to 2015 Variance:

Current investment forecasts are based on actual expenditures being incurred with the on-going Inspection and Maintenance program. The increase in future spend in this year's Plan compared to last year relates to an increase in actual spending that is projected into future years.

Table 4-14
Inspection and Maintenance
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 25.4 | 21.8 | 21.8 | 21.8 | 18.7 | - | 109.7 |
| 2015 | - | 34.2 | 36.8 | 31.8 | 31.0 | 31.4 | 165.1 |

Underground Cable

A strategy has been implemented to proactively replace underground cable on the sub-transmission, distribution primary and distribution secondary systems. Available information such as failure history, cable age, inspection program results and cable type were used to identify candidate cable replacements for further engineering evaluation. Sub-transmission and distribution cable replacement projects will be on a circuit basis, with each project justified, engineered, scoped and approved individually. A single program funding number in each Division will be used for secondary cable replacement. Distribution cable replacement opportunities are aligned with other projects such as Buffalo Substation rebuild projects and load relief projects.

² Case 04-M-0159, Proceeding on Motion of the Commission to Examine the Safety of Electric Transmission and Distribution Systems, Order Adopting Changes in the Electric Safety Standards (issued and effective Dec. 15, 2008) ("Safety Order").

2015 NY Capital Investment Plan

Drivers:

Recently, there have been a number of cable failures that resulted in manhole cover dislodgements and smoking manholes. These events heightened concerns regarding the safety and reliability of the aged underground systems. Although the consequence of a manhole event can be severe, the likelihood of an event remains low. This strategy is expected to further reduce the likelihood of manhole events by proactively replacing cable based on its condition and past performance.

Customer Benefits:

Cable systems are often designed with greater redundancy than overhead systems, and cable failure often has a limited impact on customer reliability statistics. However, if cable performance deteriorates significantly, the likelihood of concurrent failures increases. Cable failures can result in increased operation and loading on parallel equipment, further increasing the risk of failure on the rest of the system. The consequences of multiple secondary network failures or multiple sub-transmission failures would be significant. Proactive replacement of aged cable in these systems is expected to reduce the risk of concurrent failures and the potential for large scale customer outages in urban areas, including critical loads such as police, fire and hospitals.

2014 to 2015 Variance:

The projected investment is shown in the table below. On-going cable replacement projects will be completed in FY16. New expenditures for the secondary cable replacement program are projected as \$3.3M annually. Sub-transmission cable replacement expenditures as identified in the strategy are not shown. For FY18 through FY20 inclusive are \$6.0M in unidentified primary cable replacement projects. These will be replaced with specific projects as each project is justified, engineered, scoped and approved individually.

Table 4-15
Primary and Secondary Underground Cable
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 10.3 | 6.3 | 5.0 | 5.0 | 5.0 | - | 31.5 |
| 2015 | - | 3.5 | 3.4 | 10.6 | 12.2 | 9.3 | 39.0 |

2015 NY Capital Investment Plan

Buffalo Streetlight Cable Replacement

This program will re-establish safe and reliable underground street light service by replacing faulty street light cables and conduit, and removing temporary overhead conductors.

Drivers:

Fiscal year 2016 is the fourth year of a planned 10 year program to replace deteriorated street light cable in the Buffalo area to address repetitive incidents of elevated voltage (EV) as determined through periodic testing as defined under electric operating procedure NG-EOP G016. The underground street light cable system located in the Buffalo metropolitan area is comprised of a variety of electrical cable types and electrical wiring configurations that have been in service for more than 50 years. Recently, Elevated Voltage Testing has identified stray voltage incident rates that are from 2 to 20 times the rates measured in other areas in the Company's service territory.

Analyses have determined the primary driver for the elevated voltages in this area is the deteriorated physical condition of the street light cable. Spot repairs have only marginally remedied the incidence rates. Current incident rates in many of the 11 Company-defined test zones in Buffalo have experienced inconsistent EV results following each spot repair cycle since 2009. Testing of the new circuitry has resulted in a dramatic reduction of EV incidents associated with street light infrastructure.

Customer Benefits:

This work will provide more reliable street light service and reduce the incidence of elevated voltages in the Buffalo area.

2014 to 2015 Variance:

The Company expects to spend approximately \$2.5M annually under this program to replace an estimated 14% of the city's existing street light cable system over the 10 year program period. The projected investment is shown in the table below.

Table 4-17
Buffalo Streetlight Cable Replacement
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 2.4 | 2.4 | 2.4 | 2.4 | 2.5 | - | 12.3 |
| 2015 | - | 2.4 | 2.4 | 2.4 | 2.5 | 2.5 | 12.3 |

Substation Asset Condition Programs

Substation assets frequently have long lead times and require significant projects in terms of cost, complexity and project duration for replacement or refurbishment. Consequently, it is often more efficient as well as cost effective to review an entire substation. Further, where there are asset condition issues that indicate replacement as an option, the Company reviews planning and capacity requirements to ensure alternative solutions are evaluated such as system reconfiguration to retire a substation. Hence, the asset strategies coordinate with system planning to develop an integrated system plan.

Substation Power Transformers

Power transformers are large capital items with long lead times. Their performance can have a significant impact on reliability and system capacity. Condition data and condition assessment are the key drivers for identifying replacement candidates. Replacements are prioritized through a risk analysis which includes feedback from operations personnel. The distribution element covers transformers which are identified as replacement candidates through the test and assessment procedure. A 'Watch List' of candidate transformers has been identified and recorded in the Asset Condition Report.³

Drivers:

There are approximately 751 power transformers plus 21 spares with primary voltages 69kV and below. Each unit is given a condition code based on individual transformer test and assessment data, manufacture/design and available operating history. Higher codes relate to transformers which may have anomalous condition; units with a higher code are subject to more frequent monitoring and assessment, and are candidates for replacement on the Watch List.

Customer Benefits:

The impact of power transformer failure events on customers is historically substantial. By proactively replacing units in poor condition there will be direct benefits to customers in reduced impact of power transformers on performance.

2014 to 2015 Variance:

The projected program investment is shown below. Through on-going review of the distribution substation transformer fleet, new problems are identified. Replacement costs and related annual investment will vary based upon the size of the transformer to be replaced. In addition, rephasing of projects and their timelines has contributed to the variance.

³ Report on the Condition of Physical Elements of Transmission and Distribution Systems, Case 12-E-0201, filed most recently October 1, 2014.

2015 NY Capital Investment Plan

Table 4-18
Substation Power Transformers
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 3.7 | 4.8 | 6.3 | 2.9 | 2.8 | - | 20.4 |
| 2015 | - | 3.6 | 1.6 | 3.5 | 3.3 | 4.9 | 16.8 |

The capital investment plan in Exhibit 3 shows the current list of transformers expected to be replaced within the next five years. The following specific projects are expected to exceed \$1 million in any fiscal year:

- Project C051706, Grooms Road Substation Transformer Replacement. This project provides for the replacement of two transformers.
- Project C046670, Station 124 Transformer Replacement. This project provides for the replacement of two transformers.
- Project C046676, Liberty Street Substation Transformer Replacement. This project provides for the replacement of one transformer.

Indoor Substations

The purpose of this strategy is to replace, retrofit, or retire the twenty-four remaining indoor distribution substations. The indoor substations were built in the 1920s through the 1940s. These substations have inherent safety risks due to design and equipment condition. Sixteen of these indoor substations remain to be rebuilt in the City of Buffalo and five are in Niagara Falls. The remaining three substations are located in Syracuse, Gloversville and Troy. Details of the asset condition issues and key drivers are outlined in the asset condition report.

Drivers:

These indoor substations are obsolete. Their outmoded design does not meet currently accepted safety practices, equipment and protection schemes are becoming unreliable in their function of interrupting faults, and in general the condition of equipment shows signs of deterioration.

Customer Benefits:

Under normal conditions, failure of obsolete indoor substation equipment could result in sustained customer interruptions until some type of replacement is installed. Equipment outages can result in increased operation and loading on parallel equipment. Indoor substations typically supply urban environments, including critical loads such as police, fire and hospitals. This program mitigates the risk for a long-term, sustained, customer interruptions occurring in these urban areas.

2015 NY Capital Investment Plan

2014 to 2015 Variance:

The projected program investment is shown below. The spending has been modified based on a redistribution of projects and further development of the plan for each substation.

Table 4-19
Indoor Substations
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 8.4 | 5.7 | 14.5 | 10.9 | 11.1 | - | 50.6 |
| 2015 | - | 4.7 | 4.8 | 6.5 | 7.1 | 5.8 | 28.9 |

- In Buffalo, two indoor projects are in progress and have exceeded \$1 million: Buffalo Stations #27 and #29. Four indoor substation projects are expected to exceed \$1 million: Buffalo Stations #30, #37, #53 and #59. Additional Buffalo Indoor Stations will still be need rebuilding after the FY16-20 timeframe.
- In Niagara Falls, three indoor substation rebuilds are expected to exceed \$1 million: Eighth Street #80, Welch #83, and Stephenson #85.
- In Syracuse, expansion of the Rock Cut #286 substation which will be completed in FY16 will exceed \$1 million in total. The Rock Cut #286 substation expansion will allow the retirement of the Brighton Avenue #8 substation.

Metal-Clad Switchgear

Deteriorated metal-clad switchgear can be prone to water and animal ingress which leads to failures. Visual surveys will detect such degradation, but cannot identify surface tracking where hidden behind metal enclosures. Identification of these concerns is more likely with electro-acoustic detection techniques. By using sensors to detect anomalous sound (acoustic) waves or electric signals in the metal-clad switchgear, it is possible to identify equipment condition concerns before failure. An initial review using this technique identified a number of locations for further action as part of this strategy.

For each substation, an analysis will be conducted to determine if direct replacement is the best course of action or if an alternate means of supplying the load will be constructed.

Drivers:

Metal-clad switchgear installed prior to 1970 has several factors that can lead to component failure. Electrical insulation voids were more prevalent in earlier vintage switchgear. Higher temperatures due to poor ventilation systems can degrade lubrication in moving parts such as breaker mechanisms; and, gaskets and caulking deteriorate over time leading to ingress of moisture.

Customer Benefits:

The impact of each metal-clad switchgear event on local customers is usually substantial, with nearly 3,000 customers interrupted for over three hours per event. This program would reduce the risk of such events and provide significant benefit to the affected customers.

2014 to 2015 Variance:

The projected program investment is shown below. The capital forecast reflects new condition assessment data and analyses that helped identify and prioritize replacement candidates. Multiple stations are in progress with a program underway to prioritize additional stations. Lastly, the new Maple Ave Substation was not categorized under the Metal-clad Switchgear Program last year and adds significantly to the variance.

Table 4-20
Metal-Clad Switchgear
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|
| 2014 | 0.1 | 1.2 | 7.7 | 9.5 | 8.1 | - | 26.6 |
| 2015 | - | 2.3 | 6.2 | 12.5 | 14.6 | 12.4 | 48.0 |

The following specific projects are expected to exceed \$1 million in any fiscal year:

- Project C046747, Johnson Road Substation Replace Metal-Clad Switchgear. This project provides for the replacement of the existing metal-clad switchgear with new equipment.

2015 NY Capital Investment Plan

- Project C046741, Hopkins 253 Substation Replace Metal-Clad Switchgear. This project provides for the replacement of the existing metal-clad switchgear and transformers with new equipment.
- Project C052706, Station 61 Metal-Clad Switchgear. This project provides for the replacement of the existing metal-clad switchgear with new equipment...
- Project C051707, Station 162 Metal-Clad Switchgear. This project provides for the replacement of the existing metal-clad switchgear with new equipment.
- Project C056616, Station 140 Metal-clad Switchgear. This project provides for the replacement of the existing metal-clad switchgear with new equipment.
- Project C046478, New Maple Ave Substation. This project builds a new 115-13.2kV substation on a new site to replace the existing metal-clad Market Hill 69-4.16kV substation.
- Project C056611, Tuller Hill 246. This project provides for the replacement of the existing unit substation with new equipment.
- Project C036213, Chrisler Metal-clad Switchgear. This project provides for the replacement and conversion of the existing metal-clad switchgear and transformers with new equipment.
- Project C056609, Avenue A 291 Metal-clad Switchgear. This project provides for the replacement of two metal-clad switchgear and two transformers with new equipment.
- Project C056614, Pine Grove Metal-clad Switchgear. This project provides for the replacement of the existing metal-clad switchgear with new equipment.

2015 NY Capital Investment Plan

Substation Circuit Breakers and Reclosers

Certain types, or families, of breakers have been specifically identified for replacement in the next ten years. Breaker families are typically older, obsolete units that are less safe or less reliable. Certain breaker families that are targeted for replacement contain parts that must be custom machined or units that contain asbestos in the interrupting systems and require extra precautions during maintenance, refurbishment and overhaul.

Drivers:

The approach for breaker condition coding was based on engineering judgment and experience which was supported by discussion with local Operations personnel. The units are prioritized for replacement based on the condition coding; units in poorer condition are given a higher score. Many of these breakers are obsolete.

Aged units have been specifically identified for replacement because they are difficult to repair due to the lack of available spare parts. Likewise, unreliable units have been identified for replacement to reduce the number of customer interruptions.

Customer Benefits:

In addition to providing reliability benefits, several of the targeted breaker families present opportunities to reduce hazards associated with safety and the environment (i.e. oil and asbestos).

2014 to 2015 Variance:

The projected program investment is shown below. The overall spend has been modified based on lessons learned regarding scheduling, availability of resources, and a more accurate identification of breakers per station location.

Table 4-21
Circuit Breakers and Reclosers
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 1.6 | 2.2 | 2.2 | 1.4 | 1.4 | - | 8.8 |
| 2015 | - | 2.2 | 1.9 | 2.2 | 1.9 | 1.9 | 10.1 |

2015 NY Capital Investment Plan

Substation Batteries and Related

This program mirrors the Transmission Substation Batteries and Chargers program. Battery and charger systems are needed to ensure substation operational capability during both normal and abnormal system conditions. The intent of this program is to replace battery and charger systems that are 20 years old. The 20 year limit is based on industry best practice and experience in managing battery systems. This program work is coordinated with other asset replacement programs where appropriate.

Currently, there are over 200 substation batteries in service. To bring all battery systems to less than twenty years old within ten years would require a replacement rate of approximately nine per year.

Individual battery problems may be identified at any time during Visual and Operational inspections or periodic testing. Problems identified through these methods are addressed under the Damage/Failure spending rationale.

Drivers:

Failure of batteries and charger systems may result in substation protective relays and/or circuit breakers not operating as designed.

Customer Benefits:

Battery and charger system failures can result in additional customers being interrupted as back-up relay schemes at remote substations will have to isolate a fault. It may also result in equipment damage if a fault is not cleared in a timely fashion. Interruptions related to battery incidents are uncommon at this time as the replacement program is working as desired.

2014 to 2015 Variance:

The projected program investment is shown below. The budget has been adjusted to reflect the population of batteries approaching industry best practice replacement age over the next several years.

Table 4-22
Substation Battery and Related
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|
| 2014 | 0.9 | 0.9 | 0.9 | 0.9 | 0.9 | - | 4.5 |
| 2015 | - | 0.9 | 0.6 | 0.6 | 0.6 | 0.6 | 3.3 |

2015 NY Capital Investment Plan

Mobile Substation

Mobile substations are key elements for ensuring continued reliability and supporting the system during serious incidents.

Drivers:

To improve the management of the mobile substation fleet, the Company conducted a review which considered system requirements, the amount of mobile usage, and the uniqueness of individual units to better understand the condition of all members of the fleet and their associated risks. Highly utilized units may present a risk if they are not properly maintained or refurbished. Further, uniquely configured units or very highly utilized units in which there is only one available unit on the system, present some risk since they may not be available for an emergency due to utilization elsewhere. Based on the review, mobile substation protection upgrades, rewinds and replacement units were recommended.

Customer Benefits:

A mobile substation or transformer is the quickest method for restoring service to customers when an outage occurs in a substation, typically occurring within sixteen to twenty-four hours. By refurbishing, upgrading, replacing and purchasing new mobile substations, as necessary, via system reviews and condition assessments, the risk of extended customer outages will be significantly reduced. In addition, properly addressing the needs of the mobile fleet will allow us to schedule maintenance for substation transformers in a timely manner since they are one of the most valuable assets on the system. Lastly, having an adequate number of mobile substations on hand will promote the completion of new construction projects on-time and on-budget.

2014 to 2015 Variance:

The projected investment is shown below. Projects have been redistributed based upon changes in asset condition and the availability of the units so that upgrade work can be performed.

Table 4-23
Mobile Substation
Program Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 0.6 | 1.8 | 2.5 | 2.1 | 1.0 | - | 8.0 |
| 2015 | - | 1.3 | 0.6 | 0.6 | 2.3 | 2.7 | 7.4 |

2015 NY Capital Investment Plan

4. E. Non-Infrastructure

This spending rationale includes items that do not fit into the previous four categories but are necessary for the operation of the distribution system. They include capitalized tools such as micro-processor based relay test equipment and SF6 gas handling carts. In addition, radio system expansion and upgrade projects across the system are included in this spending rationale.

Drivers:

Specialized tools are required by Operations personnel to perform equipment maintenance and complete capital projects. Radio communication systems upgrades and replacements are necessary for real time communications while performing switching and for other operational needs.

Customer Benefits:

The proper tools allow Operations personnel to work safely and efficiently thus reducing overall costs. Radio communications promote personnel safety by allowing the control centers to direct Operations personnel during field switching. In addition, timely communications allow a coordinated response to interruptions thereby limiting customer interruption durations.

2014 to 2015 Variance:

The projected investment is shown below. The reduction results from a change in historical trend.


Table 4-27
Non-Infrastructure Spending Rationale
Variance (\$millions)

| CIP | FY15 | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|------|------|------|------|------|------|------|-------|
| 2014 | 3.2 | 3.3 | 3.3 | 3.3 | 3.4 | - | 16.5 |
| 2015 | - | 3.0 | 3.0 | 3.0 | 3.1 | 3.0 | 15.1 |

Chapter 5. Investment by Transmission Study Area

For regional analysis, the Company's service territory is divided into eight transmission study areas. The transmission study areas are shown in Figure 5-1. Within the eight transmission study areas, the sub-transmission and distribution networks are further subdivided into 43 distribution study areas.

Figure 5-1
Transmission Study Areas



Each of the transmission study areas is described separately below in the following format:

- Area Summary
- Area Description
- Major Project Table

5. A. Northeast Transmission Study Area

Area Summary

The principal driver for the transmission and distribution capacity projects in the Northeast transmission study area is load growth associated with Luther Forest industrial load, specifically Global Foundries, and the general area distribution load growth that is stimulated by the economic impact of the Luther Forest development during the period from 2012-2019. A new 230-115 kV Eastover substation is expected to be placed in service in March 2015. This new station will avoid 115kV line overloads, Rotterdam 230-115 kV transformer overloads, and support adequate system post-contingency voltage levels. New 115-13.2kV substations at Sodeman Road, Randall Road and McCrea are recommended to supply load growth in the area and correct some asset concerns.

Area Description

The Northeast transmission study area serves approximately 133,900 customers. The study area extends approximately 90 miles north along the western border of Vermont, from Cambridge in the south to Westport in the north, and extends approximately 45 miles to the west at its widest point to Indian Lake. The area incorporates the southeastern section of the Adirondack State Park. Much of the area load is concentrated in the southern portion of the study area, along Interstate I-87 and US Route 9, particularly in the Towns of Ballston Spa, Saratoga Springs and Glen Falls. Some of the areas offer summer recreation and see a spike in load during the summer months.

The 115kV system runs primarily in a north-south direction on both sides of Lake George. There is a single radial line, east of Lake George, which runs north from Whitehall substation, which extends to the NYSEG system and also continues north to the Port Henry substation. The western 115kV radial line extends from the Spier Falls substation to the North Creek substation in the Adirondack State Park. There is an extensive 34.5kV system in the study area supplying smaller towns along interstate I-87 and Route 28.

In the Northeast transmission study area there is one distribution study area, also called Northeast. The Northeast distribution study area has a total of 112 distribution feeders that supply customers in this area. There are eighty-eight 13.2kV feeders, with twenty-five being supplied from 34.5-13.2kV transformers, and the rest supplied by 115-13.2kV transformers; thirty-five 34.5kV sub-transmission lines that supply the distribution step down transformers in the area; ten 4.8kV feeders with six supplied by 34.5-4.8kV transformers; and fourteen 4.16kV feeders all supplied by 34.5-4.16kV transformers.

Major Project Table

The following table identifies major projects by spending rationale for this study area.

2015 NY Capital Investment Plan

**Table 5-1
Northeast Major Projects**

| Spending Rationale | Program | System | Distribution Study Area | Project Name | Funding Number |
|-------------------------------------|---------------------------------|-------------------------------------|-------------------------|-------------------------------------|----------------|
| | Asset Replacement | DIST | Northeast | McCrea Station - New station - Inst | C046790 |
| Asset Condition | Component Fatigue/Deterioration | TRAN | | Mohican - Replace Bank 1 and Relays | C053133 |
| | | | | Queensbury - replace OCBs | C049554 |
| | | | | Spier-Rotterdam 1 & 2 ACR | C060212 |
| | | | | Ticonderoga 2-3 T5810-T5830 ACR | C039521 |
| | | | | TICONDEROGA 2-3 T5810-T5830 SXR2 | C039487 |
| | | | | Whitehall - replace OCBs | C049564 |
| | | | | System Capacity & Performance | Load Relief |
| Sodeman Rd - New station - dist get | C046796 | | | | |
| Sodeman Rd Station - new station - | C046798 | | | | |
| TO Led System Studies | TRAN | Ballston Tap Sw. St - Line Taps | | | C060251 |
| | | Ballston Tap Switching Station | | | C060250 |
| | | McCrea Line | | | C053150 |
| | | Mulberry Tap Sw St - Line taps | | | C060253 |
| | | Mulberry Tap Switching Station | | | C060252 |
| | | Queensbury TB3 & TB4 upgrades (sub) | | | C036822 |
| | | Ticonderoga Cap Bank | | | C060254 |

5. B. Capital and Hudson Valley Transmission Study Area

Area Summary

Key drivers behind the transmission capacity related projects in this transmission study area include the following:

- Thermal issues observed on the Rotterdam 230-115 kV transformer banks drive the recommended new 230-115 kV Eastover substation in the Northeast Region, which also addresses issues in the Capital & Hudson Valley Region. This substation is expected to be in service in 2016.
- Projected load growth in the area over the next 5 to 10 years, and in the adjacent Northeast study area – particularly that associated with Luther Forest, will trigger future projects.

Key sub-transmission and distribution drivers include the following:

- DeLaet's Landing is a proposed Underground Commercial Development (UCD) in the City of Rensselaer. In response, construction of a new substation at Forbes Avenue will be used to supply the area. This new substation will also address flooding concerns at Rensselaer substation.
- Van Dyke Road Station is a new 115-13.2kV station that will be used to address load growth at Vista Tech Park and loading and asset concerns at adjacent stations.
- Maple Avenue is a new 115-13.2kV station that will be used to address asset condition issues at Market Hill substation and loading in the Amsterdam area.

Area Description

The Capital and Hudson Valley study area is connected to the Utica Rome study area in the west, the New England system in the east, the Central Hudson Gas and Electric (CHG&E) and Consolidated Edison (ConEd) systems in the south, and the Northeast study area in the north. The transmission system consists primarily of 115kV and 345kV transmission lines. There are also several 230kV lines emanating from Rotterdam Substation. The Capital and Hudson Valley study area is the east end of the Central-East interface, which is a power interface between central NY and eastern NY. Several transmission lines in the area are also important facilities to the UPNY-SENY interface between the eastern NY system and the downstate system.

National Grid has three 345-115kV transformers in the region; two at New Scotland and one at Reynolds Road. There are three existing 230-115kV transformers at Rotterdam. In addition, Con Ed has one 345-115kV transformer at Pleasant Valley and CHG&E has one 345-115kV transformer at Hurley Ave. Station, all of which have impacts on the National Grid system.

Within the Capital and Hudson Valley study area, there are six distribution study areas: Capital-Central, Capital-East, Capital-North, Mohawk, Schenectady and Schoharie.

The Capital-Central study area serves approximately 89,000 customers. The study area encompasses the greater Albany area, including a mixture of commercial customers heavily concentrated in downtown Albany, and industrial and residential customers spread across downtown to the suburban areas. The primary distribution system in Capital-Central is predominantly 13.2kV with pockets of 4.16kV primarily in the City of Albany and 4.8kV south of the City of Albany. Most 4kV distribution substations are supplied from the local 34.5kV sub-transmission system, whereas most 13.2kV distribution substations are supplied from the local 115kV transmission system.

The Capital-East study area serves approximately 84,100 customers. The study area is located east of the Hudson River, with the center approximately adjacent to Albany. This area extends approximately from Valley Falls in the north to Tivoli in the south. The larger load concentrations are in the cities of Rensselaer and Troy and in the towns along US Route 9. There is a 345kV source into the area at Reynolds Road substation and a 115kV corridor running in a north-south direction supplying approximately 90% of the distribution load in the area. There is also a 34.5kV sub-transmission system in the central area with the 115kV sources from Greenbush, North Troy, Hudson and Hoosick substations. In addition, there is scattered generation on the 34.5kV system in the area.

The Capital-North study area serves approximately 86,600 customers. The study area encompasses the suburban area north of the City of Albany, including a mixture of industrial, commercial and residential customers throughout Colonie, Cohoes, Watervliet, Clifton Park, Halfmoon, Waterford, Niskayuna, and Ballston. The primary distribution system in Capital-North is predominantly 13.2kV with a few pockets of 4.16kV in the Newtonville area and 4.8kV in the Town of Ballston. All 4kV distribution substations are supplied from the 34.5kV sub-transmission system, whereas most 13.2kV distribution substations are supplied from the 115kV transmission system. Maplewood and Patroon substations are the main sources for the 34.5kV sub-transmission system in this area, which is operated in loop configuration. Along with these facilities, a group of hydro and cogeneration power plants located along the Mohawk River (School St, Crescent, Vischer Ferry, Colonie Landfill, etc) form the backbone of the local 34.5kV sub-transmission system. In addition to supplying power to all 4kV and a few 13.2kV distribution substations, the 34.5kV sub-transmission system serves several industrial customers such as Mohawk Paper, Honeywell, Norlite, and Cascade Tissue. Major distribution customers in this area include the Albany International Airport, which is supplied by feeders from Forts Ferry, Sand Creek, Wolf Road and Inman Road substations.

The Mohawk study area serves approximately 61,200 customers. The study area includes the City of Amsterdam and the rural areas west of the city. This area is comprised of mostly residential customers and farms with some commercial and industrial customers located in areas such as the City of Amsterdam, Gloversville, Johnstown, Northville, and Canajoharie. The primary distribution system in Mohawk is predominantly 13.2kV with areas of 4.16kV (Gloversville and Johnstown areas) and 4.8kV (Canajoharie). Most 4kV distribution substations are supplied from the 23kV and 69kV sub-transmission system, whereas most 13.2kV distribution substations are supplied from the 115kV transmission system.

2015 NY Capital Investment Plan

The Schenectady study area serves approximately 57,900 customers. The study area is defined by the region that includes the City of Schenectady and the surrounding suburban areas. This area includes a mixture of industrial, commercial and residential customers spread across downtown to suburban areas such as Niskayuna, Glenville, and Rotterdam. The primary distribution system in Schenectady area is predominantly 13.2kV with a few pockets of 4.16kV (Schenectady, Scotia and Rotterdam areas). All 4kV distribution substations are supplied from the local 34.5kV sub-transmission system, whereas most 13.2kV distribution substations are supplied from the local 115kV transmission system. In addition, the downtown areas of Schenectady are served by a general network that is supplied by the Front Street Substation. Rotterdam, Woodlawn and Rosa Rd. are the main sources for the local 34.5kV sub-transmission system, which is operated in loop configuration.

The Schoharie study area serves approximately 20,600 customers. The study area is defined by the region west and south of Schenectady that include towns and villages along the I-88 and Route 20 corridors such as Delanson, Schoharie, Cobleskill, Schenevus, and Sharon Springs. This area is mostly rural comprised mainly of residential customers and farms with few commercial and industrial customers. The primary distribution system in Schoharie is predominantly 13.2kV with areas of 4.8kV (Cobleskill, Worcester, and Schenevus areas). Most distribution substations in this region are supplied from the local 23kV and 69kV sub-transmission system. Marshville and Rotterdam are the main sources for the local 69kV sub-transmission system which is operated in loop configuration. The 69kV sub-transmission system supplies power to both 4kV and 13.2kV distribution substations, besides a few industrial and commercial customers, such as Guilford Mills and SUNY Cobleskill. The existing 23kV sub-transmission system in Schoharie, which supplies power to East Worcester, Worcester, and Schenevus substations, is operated in radial configuration from Summit substation.

Major Project Table

The following table identifies major projects by spending rationale for this study area.

**Table 5-2
Capital and Hudson Valley Major Project**

| Spending Rationale | Program | System | Distribution Study Area | Project Name | Funding Number |
|--------------------|---------------------------------|--------|-------------------------|------------------------------------|----------------|
| Asset Condition | Component Fatigue/Deterioration | TRAN | None | Hoosick - Replace Bank 1 & relays | C053132 |
| | | | | Inghams Phase Shifting Transformer | C047864 |
| | | | | Inghams Station - Assoc Line work | C060240 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | System | Distribution Study Area | Project Name | Funding Number |
|--------------------|-------------------------------------|--------|-------------------------|--------------------------------------|----------------|
| | | | | Inghams Station Re-vitalization | C050917 |
| | | | | Leeds - Replace U Series Relays | C024663 |
| | | | | Menands Station Relay Replacement | C049601 |
| | | | | New Scotland - replace 345kV OCBs | C049553 |
| | | | | Rotterdam 115kV SubRebuild(AIS) | C034850 |
| | | | | Woodlawn Transformer Replacement | C051986 |
| | Sub T Overhead Line | SUBT | Mohawk | Amsterdam-Rotterdam3/4 Relocation | C033182 |
| | | | Capital-North | Mech-Schuylerville 4-34.5kV refurb | C050323 |
| | | | | W. Milton Tap-34.5kV new line | CD00898 |
| | | | Capital-Central | Callanan Tap - Rebuild exist 34.5In | C046641 |
| | | | | Riverside 28855 UG Cable Replacement | C036468 |
| | Sub T Underground Cable Replacement | DIST | Capital-Central | Partridge-Ave A # 5 Cable Replaceme | C036273 |
| | | SUBT | | | |
| | Substation Metal-clad Switchgear | DIST | Mohawk | Maple Ave Feeder Getaways | C046479 |
| | | | | New Maple Ave Substation | C046478 |
| | | | Capital-Central | Avenue A 291 Metalclad Replacement | C056609 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | System | Distribution Study Area | Project Name | Funding Number |
|---------------------------------------|------------------------------|--------|-------------------------|-------------------------------------|----------------|
| | | | Schnecetady | Chrisler Metal Clad Replacement | C036213 |
| | Substation Mobile | | None | Mobile Substation 2E - Replacement | C046666 |
| | Substation Power Transformer | | Capital-North | Grooms Rd Transformer Replacement | C051706 |
| | Substation Relay/Protection | | Capital-Central | Trinity Station Relay Replacement | C049625 |
| Customer Requests/Public Requirements | New Business | | Schnecetady | Mohawk Harbor Development Civil | C055843 |
| Damage/Failure | Damage/Failure | TRAN | None | Leeds SVC B TRF D/F | C057879 |
| System Capacity & Performance | ERR | DIST | Mohawk | *Stoner 52 - Stoner Trail Extension | C050437 |
| | Load Relief | | Capital-North | Grooms Rd 34557 - Saratoga Rd Conve | C046761 |
| | | | | Randall Rd - New station - Dist get | CD00897 |
| | | | | Randall Rd - New station - M/C S/G | CD00896 |
| | | | Capital-Central | Van Dyke - UG - Civil & Elec work | C052098 |
| | | | | Van Dyke Station - New 115/13.2kV s | C046490 |
| | | | | Van Dyke Station - New 56 Dist Feed | C046487 |
| | | | | Van Dyke Station-New 54 Dist Feed. | C046495 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | System | Distribution Study Area | Project Name | Funding Number |
|--------------------|---------------------------------------|--------|-------------------------|-------------------------------------|----------------|
| | | | | Van Dyke Subst- New 57 Dist Feeder | C046488 |
| | | | | Van Dyke Subst- new feeders | C016087 |
| | | | Capital-East | DeLaet's Landing DxD | CD00893 |
| | | | | Forbes Ave - New Substation | C053137 |
| | Secondary Network Arcflash Mitigation | | Capital-Central | Arc Flash NY East Div 480V Spot NW | C047464 |
| | TO Led System Studies | TRAN | None | Eastover - Add 2nd Bank | C060247 |
| | | | | Eastover Rd - New 230-115kV Station | C031326 |
| | | | | Eastover Rd- New Line Taps | C031419 |
| | | | | Ephratah Sub Rebuild - Line Portion | C053144 |
| | | | | Ephratah substation rebuild | C046486 |
| | | | | Hudson Valley Reinforcement | C053148 |
| | | | | Mohican Battenkill#15 Rebuild Recon | C034528 |
| | | | | New Scotland - Add Reactors LN19/20 | C060246 |
| | | | | Randall Rd Transmission Line | C043672 |
| | | | | Riverside-Reynolds Rd#4 Forbes Tap | C043592 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | System | Distribution Study Area | Project Name | Funding Number |
|--------------------|---------|--------|-------------------------|--------------------------------------|----------------|
| | | | | Rotterdam - Menands Recond 12 miles | C060243 |
| | | | | Rotterdam-TB6/7 Reconnect & R86 Bus | C060255 |
| | | | | Schoharie substation reconfiguration | C046494 |

5. C. Northern Transmission Study Area

Area Summary

Key drivers behind the transmission capacity related projects in this study area include the following:

- The interconnection of several wind generation projects.
- All overloads resulting from contingencies can be mitigated by reducing hydro generation, wind generation, or imports from Hydro Quebec.

Key sub-transmission and distribution drivers include the following:

- New 115-13.2kV substation in the south Watertown area to supply load growth in the area.

A potential major driver for the area is the possible North Country Power Authority (NCPA) takeover of the electrical system in portions of St. Lawrence and Franklin Counties. The Company is not aware of any activity regarding NCPA in the past year.

Area Description

The Northern transmission study area includes the 115kV transmission facilities in the Northern Region and the northeast portion of the Mohawk Valley Region.

The backbone of the 115kV Northern area system runs from National Grid ALCOA substation to Boonville substation. The major substations along the 115kV transmission corridor are Browns Falls, Colton, Dennison and Taylorville.

The Jefferson/Lewis county area is bounded by the #5 – #6 Lighthouse Hill-Black River lines to the west and the #5 – #6 Boonville-Taylorville lines to the east. The Ogdensburg-Gouverneur area is served by the #7 Colton-Battle Hill, #8 Colton-McIntyre and the #13 ALCOA-North Ogdensburg 115kV lines. The #1 – #2 Taylorville-Black River lines and the #3 Black River-Coffeen support the load in the Watertown area. The Thousand Island region is served by the #4 Coffeen-Thousand Island 115kV radial line. The Colton-Malone #3, Malone-Lake Colby #5, and Willis-Malone #1 (NYPA) 115kV lines serves the Tri Lakes region. The Akwesasne #21 115kV Tap served from the Reynolds/GM #1 (NYPA) 115kV line supplies part of the Nicholville-Malone area.

Within the Northern study area, there are four distribution study areas: Nicholville-Malone, St. Lawrence, Tri-Lakes and WLOF (Watertown and Lowville). The Nicholville-Malone study area serves approximately 16,100 customers. There are total of twenty seven feeders (twenty 4.8kV and seven 13.2kV feeders) in the study area. The distribution substations are primarily supplied from the 34.5kV system with exception of Malone 13.2kV and Akwesasne 4.8kV substations that are served by the 115kV system. The main supplies for the 34.5kV sub-transmission system are Akwesasne, Malone, and Nicholville substations. It is operated as a radial system due to loading issues although the system is constructed as a loop

2015 NY Capital Investment Plan

design. There are also two hydroelectric facilities connected to the system (Macomb and Chasm substations).

The St. Lawrence area serves approximately 39,600 customers. There are twenty-six 4.8kV feeders and thirty 13.2kV feeders in the study area. The distribution substations are supplied from 23kV and 34.5kV sub-transmission lines with exception of four substations, Corning, Higley, North Gouverneur and Ogdensburg substations that are served from the 115kV system. The main supplies for the 23kV sub-transmission system are Balmat, Little River, McIntyre, Mine Rd. and Norfolk substations. Browns Falls substation is the main supply for the 34.5kV sub-transmission system.

The Tri-Lakes area serves approximately 8,800 customers. There are twenty nine 4.8kV, two 2.4kV feeders and six 13.2kV feeders in the study area. Most of the distribution substations are supplied from the 46kV sub-transmission system with the exception of Lake Colby and Ray Brook substations that are served from the 115kV system. The supply for 46kV sub-transmission system in the area is Lake Colby substation. There are two municipal electric companies supplied via the 46kV sub-transmission in the Tri-Lakes area, Lake Placid and Tupper Lake.

The WLOF area serves approximately 70,100 customers. There are nine 23-4.8kV substations supplying twenty-seven 4.8kV feeders; and ten 115-13.2kV substations supplying thirty-eight 13.2kV feeders. The 23kV sub-transmission system is supplied from the Boonville, Black River, Coffeen, Indian River, North Carthage and Taylorville substations.

Major Project Table

The following table identifies major projects by spending rationale for this study area.

**Table 5-3
Northern Major Projects**

| Spending Rationale | Program | System | Distribution Study Area | Project Name | Funding Number |
|--------------------|---------------------------------|--------|-------------------------|---------------------------------|----------------|
| Asset Condition | Asset Replacement | DIST | St. Lawrence | State St Feeder Conversion | C050697 |
| | | SUBT | Nicholville-Malone | Fort Covington-Malone 26-34.5kV | C050197 |
| | Component Fatigue/Deterioration | TRAN | None | Br F-Taylorville 3-4 ACR | C024359 |
| | | | | Colton-BF 1-2 T3140-T3150 ACR | C036164 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | System | Distribution Study Area | Project Name | Funding Number |
|-----------------------------|------------------------------|--------|-------------------------------------|-------------------------------------|----------------|
| | | | | Colton-Replace CBs and Disconnects | C029844 |
| | | | | Mohican - Replace Bank 1 and Relays | C053133 |
| | | | | Taylorville-B 5-6 T3320-T3330 ACR | C027437 |
| | Substation Power Transformer | DIST | WLOF | Sewalls Island #2 TRF Replacement | C058406 |
| ERR | Nicholville-Malone | | NR-85251-NYS Hwy 30-FdrTie | C049760 | |
| | St. Lawrence | | NR-Brady 95757-CoRt27-FdrTie | C046861 | |
| Reliability | Nicholville-Malone | | Malone Second 115/13.2kV Bank | C054587 | |
| | WLOF | | *NR_76462-CoRte28-Rebuild | C049197 | |
| | | | Watertown New 115/13.2 kV Substatio | C046610 | |
| | | | | C046627 | |
| Substation Flood Mitigation | Tri-Lakes | | Union Falls - Flood mitigation | C053167 | |

5. D. Syracuse Oswego Cortland Transmission Area

Area Summary

The drivers behind the transmission capacity related projects in the Syracuse Oswego Cortland (SOC) study area are:

- Area load has, over time, reached levels that result in potential post-contingency overloading of one of the Clay 345-115kV autotransformers, as well as three 115kV circuits in the Syracuse area.
- Recommended projects to address post-contingency overloading include the replacement of the Clay 345-115kV TB1 autotransformer with an existing spare and the replacement of that spare, and the reconductoring of the Clay-DeWitt #3 and Clay-Teall #10 lines.
- The Clay-G.E. #14 line was shown to be overloaded for certain criteria contingencies when the Syracuse Energy facility was no longer in-service and will be reconductored.
- Fault current levels have been identified in excess of the interrupting capability of breakers at four different substations in the area.

Key sub-transmission and distribution drivers include the following:

- Load growth in the Syracuse University and the North Syracuse areas are major drivers of distribution capacity work.
- The addition of second transformers and new feeders at several substations are major drivers of reliability work.

Area Description

The SOC study area includes the 345kV and 115kV transmission facilities in the Central Region and all of the 115kV and above transmission facilities around the Oswego Complex area, including the 345kV Scriba and Volney stations.

The SOC area is bordered by Elbridge substation in the West, Cortland substation in the South, Oneida substation in the East, and Clay substation in the North. The major substations in the area include Clay, South Oswego, Dewitt, and Geres Lock. This area also includes some of the assets stretching between Mortimer and Elbridge.

Within the SOC study area, there are eight distribution study areas: Cazenovia, Cortland, East Syracuse, Manilus-Fayetteville, North Syracuse, Syracuse, Volney and West Syracuse.

The Cazenovia study area serves approximately 5,100 customers. The study area is a very rural region, with the Village of Cazenovia and the Cazenovia Industrial Park being the only

large loads. The distribution system consists of one 34.5-13.2kV, three 34.5kV-4.8kV substations and one 34.5-4.16V substation. The only physical constraint is Cazenovia Lake and the residential load which is spread around Cazenovia Lake.

The Cortland study area serves approximately 26,200 customers. The study area is defined by the region that includes the City of Cortland and the surrounding towns and villages. It is located in central New York between Syracuse and Binghamton. The primary distribution system voltages in Cortland are 13.2kV and 4.8kV. Most of the area is fed from a 34.5kV sub-transmission system supplied out of the Cortland and Labrador substations.

The East Syracuse study area serves approximately 13,000 customers. The study area is an industrial suburb of the City of Syracuse. The distribution system consists of one 115-34.5kV, three 115-13.2kV and three 34.5-4.8kV substations. The transmission supply is adequate and the only physical barriers are Interstate 690 and Interstate 481 going through the area. Customers are served via fifteen 13.2kV feeders and eleven 4.8kV feeders.

The Manlius Fayetteville study area serves approximately 24,300 customers. The study area is a residential suburb of Syracuse. The distribution system consists of one 115-34.5kV, four 115-13.2kV and one 34.5-4.8kV substation. Most new load additions to the area are residential developments.

The North Syracuse study area serves approximately 71,800 customers. The study area is the northern suburb of the City of Syracuse. It has experienced the majority of the new housing which has been built in the Syracuse metropolitan area. The distribution system consists of one 115-34.5kV, nine 115-13.2kV and five 34.5-4.8kV stations. The physical barriers in the North Syracuse area are the two interstates highways, I-81 and I-90.

The Syracuse study area serves approximately 61,400 customers. The study area is made up of the City of Syracuse in central New York as well as the Village of Skaneateles about 20 miles southwest of the city. The primary distribution system voltages in Syracuse are 13.2kV and 4.16kV. There is also a 12kV network fed out of Ash St. substation. Most of the area is fed from a 34.5kV sub transmission system supplied by Ash St, Elbridge, Solvay, Teall Ave., and Tilden substations. There is also some 13.2kV fed directly from the 115kV transmission system.

The Volney study area serves approximately 55,300 customers. The study area includes the cities of Oswego and Fulton. The distribution system consists of four 115-34.5kV, seven 115-13.2kV, five 34.5-13.2kV, eight 34.5-4.8kV and one 34.5-4.16kV substations. A physical barrier in this area is the Oswego River, which is also a canal.

The West Syracuse study area serves approximately 22,700 customers. The study area is a suburb west of the City of Syracuse. The distribution system consists of one 115-34.5kV, two 115-13.2kV, and four 34.5-4.16kV substations.

2015 NY Capital Investment Plan

Major Project Table

The following table identifies major projects by spending rationale for this study area.

**Table 5-4
Syracuse Oswego Cortland Major Projects**

| Spending Rationale | Program | System | Distribution Study Area | Project Name | Funding Number |
|--------------------|-------------------------------------|--------|-------------------------|-------------------------------------|----------------|
| Asset Condition | Asset Replacement | SUBT | West Syracuse | Solvay 26 | C046438 |
| | Component Fatigue/Deterioration | TRAN | None | Battle Hill - replace 3 OCBs | C049543 |
| | | | | Curtis Relay /Breaker Replacement | C049584 |
| | | | | GE-Geres Lock 8 T2240 ACR | C047835 |
| | | | | Oswego - 115kV & 34.5kV - Asset Sep | C043426 |
| | | | | Teal Ave. Transformer Replacement | C047865 |
| | | | | Tilden - replace OCBs | C049556 |
| | | | | Re-furbish Teall 25/Woodard 24-34.5 | C046446 |
| | Sub T Overhead Line | SUBT | North Syracuse | Mallory-Cicero L33-34.5 kV line Ref | C046681 |
| | | | Volney | Woodard 29-34.5kv | C046473 |
| | | | | Bristol Hill-Phoenix 23-34.5kv | C046474 |
| | | | | LHH-Mallory 22-34.5kv | C046441 |
| | | | West Syracuse | Elbridge-Jewitt 31-34.5kV refurb | C050959 |
| | | | | Elbridge-Marcellus 30 Refurbishment | C054927 |
| | Sub T Underground Cable Replacement | | Syracuse | Solvay Ash 27 Cable Repl SubT | C032147 |
| | | | | Solvay-Ash #28 34.5kV Replace Cable | C045629 |
| | Substation Metal-clad Switchgear | DIST | Cortland | Tuller Hill 246 Unit Metalclad Repl | C056611 |
| | | | North Syracuse | Hopkins 253 - Replace Metalclad Gea | C046741 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | System | Distribution Study Area | Project Name | Funding Number |
|---------------------------------------|---------------------------------------|--------|-------------------------|-------------------------------------|----------------|
| | | | | Pine Grove Metalclad Replacement | C056614 |
| Customer Requests/Public Requirements | Customer Interconnections | TRAN | None | Green Pwr Wind Loop in/out | C058101 |
| Damage/Failure | Damage Failure Other | SUBT | Syracuse | NY_CD_38kV_FPC/EEI-Swgr-Part 1 | C058959 |
| System Capacity & Performance | Generator Retirements | TRAN | None | Clay - GE 14 Reconductoring | C045253 |
| | | | | Reconductor #5 Elbridge - State St | C047297 |
| | Load Relief | DIST | North Syracuse | New Cicero Substation Dline | C046476 |
| | | | | New Cicero Substation DSub | C046475 |
| | | | Syracuse | Teal Substation Rebuild-Swgr | C046511 |
| | | | | Fairdale Dsub | C046640 |
| | | | Volney | New Haven xfmr upgrade-Buswork | C046634 |
| | | | | New Haven xfmr upgrade-Dline | C046635 |
| | | | | | |
| | | | West Syracuse | Harris 54 Relief | C032446 |
| | | | | Milton Ave 2nd Switchgear | C046609 |
| | | | | Milton Ave DLine | C046643 |
| | | SUBT | Syracuse | Mallory-Cicero 33-34.5kV-relocation | C054507 |
| | Reliability | DIST | Cortland | *CR - McGraw-Truxton feeder tie | C049727 |
| | | | Syracuse | East Molloy Second Transformer | C036188 |
| | | | | Fly Rd Feeder Work | C046594 |
| | | | | Fly Rd. Transformer Addition | C036189 |
| | | | | Temple Sub Central Breaker Upgrades | C059519 |
| | | | Volney | Whitaker Dsub | C046636 |
| | Secondary Network Arcflash Mitigation | | Syracuse | Arc Flash Mediation - 480V spot net | CD01278 |
| | TO Led System Studies | TRAN | None | Central Breaker Upgrades - Ash | C043424 |
| | | | | Clay Substation Reconfiguration | C047275 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | System | Distribution Study Area | Project Name | Funding Number |
|--------------------|---------|--------|-------------------------|-------------------------------------|----------------|
| | | | | Clay-Teall#10, Clay-Dewitt#3 Recond | C043995 |

5. E. Utica Rome Transmission Study Area

Area Summary

The drivers behind the transmission capacity related projects in this study area are:

- The need to address thermal and voltage issues drive projects that will rebuild the Porter, Rome, and Inghams substations. This will include replacement of the Inghams phase shifting transformer with a new one that will have a larger range of variation in angle.
- Other issues found in this area are addressed by operational solutions, given current NERC TPL Planning Criteria and the current BES definition.
- Upon adoption of new NERC TPL Planning Criteria and the new BES definition (≥ 100 kV), further study will determine permanent fixes for certain issues for which operational solutions are currently acceptable.

Key sub-transmission and distribution drivers include the following:

- Rebuilding of the Poland 62258 feeder along NYS Route 8 to improved reliability and loading profile.
- Refurbishment of several 46kV sub-transmission circuits to address asset condition concerns.
- Relocation of Terminal Substation to address asset condition, reliability and environmental concerns.

Area Description

The Utica Rome transmission study area includes the 115kV and above transmission system with the northern boundaries at Boonville and Lighthouse Hill substations, west at Oneida, and east at Inghams substation. Within the Utica Rome study area, there are four distribution study areas: Oneida, Rome, Utica and WLOF-MV (Old Forge area).

The Oneida study area serves approximately 18,500 customers. The study area includes the City of Oneida and the Village of Canastota. In the City of Oneida the Oneida Hospital has dual distribution supplies. Across the street from the hospital is the H.P.Hood Dairy Products Inc. facility which represents 4MVA of the load and also has dual distribution supplies. The Village of Canastota which is located in western section of the Oneida area has several large commercial and industrial customers including Canastota Industrial Park, Owl Wire and Cable, Inc and Die Molding Inc. A geographic constraint is the distance to other substations and the lack of feeder ties. There have been improvements to feeder ties between the Oneida and Peterboro substations. Developing these ties was challenging due to the New York State Thruway which has stringent road crossing regulations, which is located between the two substations.

2015 NY Capital Investment Plan

The Rome area serves approximately 26,400 customers. There are thirty 4.8kV feeders and seventeen 13.2kV feeders in the study area. All distribution substations are supplied from the 115kV system. As a result there are no sub-transmission lines in the area.

The Utica study area serves approximately 81,500 customers. The study area includes the City of Utica. The distribution system consists of four 115-46kV, ten 115-13.2kV, four 46-13.2kV and seven 46-5kV substations.

The WLOF-MV study area serves approximately 7,900 customers in Old Forge. There are five 46-4.16kV substations supplying nine 4.8kV feeders and one 13.2kV substation supplied out of Alder Creek substation. The 46kV sub-transmission system is supplied out of the Boonville substation.

Major Project Table

The following table identifies major projects by spending rationale for this study area.

**Table 5-5
Utica Rome Major Projects**

| Spending Rationale | Program | System | Distribution Study Area | Project Name | Funding Number |
|--------------------|---------------------------------|--------|-------------------------|-------------------------------------|----------------|
| Asset Condition | Asset Replacement | DIST | Utica | MV- Poland 62258 Route 8 Reconducto | C046606 |
| | Component Fatigue/Deterioration | TRAN | None | Boonville-Rome 3-4 T4060-T4040 ACR | C047795 |
| | | | | Boonvill-Portr 1-2 T4020-T4030 ACR | C047818 |
| | | | | Edic - New Control House | C058129 |
| | | | | LightHH 115kV Yard Repl & cntrl hs. | C031662 |
| | | | | Porter-Rotterdam 31 T4210 ACR | C030890 |
| | | | | Schuyler - replace OCBs | C049562 |
| | | | | Terminal-Schuyler 7 T4260 ACR | C047833 |
| | Sub T Overhead Line | SUBT | Utica | Deerfield-Schuyler 22-46kV | C050288 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | System | Distribution Study Area | Project Name | Funding Number |
|---------------------------------------|-----------------------|--------|-------------------------|-------------------------------------|----------------|
| | | | | Deerfield-Whitesboro 26-46kv | C046459 |
| | | | | Yahundasis-Clinton 24 - 46kv | C046449 |
| Customer Requests/Public Requirements | Other | TRAN | None | Edic-LN 1-7 & 24-40,Rpl Cbs-TOTS | C058063 |
| | Public Requirements | SUBT | WLOF-MV | DOTR NYSRt28 White Lk-McKeever SubT | C034722 |
| | | TRAN | None | NYPA's Marcy So Series Compensator | C059802 |
| System Capacity & Performance | NERC/NPCC Standards | | | Porter 230kV-Upgrade Brks/Disc/PT's | C036866 |
| | Reliability | DIST | Utica | Terminal Station Sub Relocation | C046613 |
| | TO Led System Studies | TRAN | None | New bay at Edic 345kv substation | C044674 |
| | | | | Porter #3 / #7 Install Reactors | C060241 |
| | | | | Terminal Station Relocation TLine | C059672 |

5. F. Genesee Transmission Study Area

Area Summary

Key transmission projects in the Genesee study area have the following drivers:

- Low post-contingency voltages in the area in general and at Golah in particular, especially for bus faults at Lockport or Mortimer that affect the entire 115kV bus.
- Low post-contingency voltages developing in the 2016 to 2026 time frame in the Batavia and Brockport areas as a result of load growth.
- Heavy post-contingency conductor loadings in the Batavia Station (existing loads), on the Lockport-Batavia #107 line, and the Mortimer-Golah #110 line.
- In addition to the addition of tie breakers at Lockport and Mortimer, other recommended projects include construction of a four breaker ring splitting the National Grid #119 circuit and the RG&E #906 circuit.

Key sub-transmission and distribution drivers include the following:

- Reliability issues are being addressed with the addition of second transformers and new distribution feeders supplied from West Hamlin and Mumford Stations.
- Capacity concerns in the area are being address by a transformer upgrade at Attica and a new distribution substation adjacent to North Lakeville Station.

Area Description

The Genesee transmission study area includes National Grid assets within NYISO Zone B. The area includes assets as far west as Lockport and as far east as Mortimer. The system consists of several 115kV circuits between Lockport and Mortimer stations. Three circuits go directly from Lockport to Mortimer, three circuits go from Lockport to Batavia and several circuits in series connect Batavia and Golah. Today one 115kV line and one 69kV line travel between Mortimer and Golah.

Two 345kV circuits owned by NYPA travel parallel to this area from Niagara to Rochester. At Rochester Station 80, RG&E has four 345-115kV transformers with 115kV connections to Rochester Station 82. Station 82 is the RG&E 115kV station adjacent to National Grid's Mortimer Station.

At Lockport, one circuit connects the station to the NYSEG Hinman Rd. Station. Hinman Rd. is connected by a single circuit to Delphi, a load and generator, and Delphi is connected by a single line to Robinson Rd. Station. At Robinson Rd., a 230-115kV transformer is connected to the Niagara – Robinson #64 and Robinson – Stolle #65 230kV circuits.

This area also includes some of the assets stretching between Mortimer in the Western Region and Elbridge in the Central Region.

2015 NY Capital Investment Plan

Within the Genesee study area, there are three distribution study areas: Genesee North, Genesee South and Livingston.

The Genesee North study area serves approximately 41,200 customers. There are a total of 51 distribution feeders that supply customers in this area. There are twenty 13.2kV feeders, with four being supplied from 34.5-13.2kV transformers, and the rest are fed from 115-13.2kV transformers. The thirty-one 4.8kV feeders are all fed from 34.5-4.8kV transformers. There are ten 34.5kV sub-transmission lines that supply the distribution step down transformers in the area.

The Genesee South study serves approximately 32,300 customers. The study area is defined by the region that includes the City of Batavia and the surrounding towns and villages. It is located east of Buffalo and southwest of the City of Rochester. The primary distribution system voltages in Genesee South are 13.2kV and 4.8kV. Most of the 13.2kV system is fed from the area 115kV transmission system. The rest of the 13.2kV system, as well as the 4.8kV system, are fed from a 34.5kV sub-transmission system supplied out of the North Akron, Batavia, North Leroy, and Oakfield substations. There are several customers supplied directly from the sub-transmission system.

The Livingston study area serves approximately 28,700 customers. The study area is made up of Livingston County which is south of Rochester and east of Batavia. The primary distribution system voltages in Livingston are 13.2kV and 4.8kV. Half of the load is supplied from the 115-13.2kV East Golah substation. The remainder is supplied from 69kV and 34.5kV sub-transmission system supplied out of the Golah and North Lakeville substations. Two customers are supplied directly from 115kV.

Major Project Table

The following table identifies major projects by spending rationale for this study area.

**Table 5-6
Genesee Major Projects**

| Spending Rationale | Program | System | Distribution Study Area | Project Name | Funding Number |
|------------------------|--|--------|-------------------------|-------------------------------------|----------------|
| Asset Condition | Asset Replacement | SUBT | Genesee North | Phillips-Barker 301-34.5kv | C046465 |
| | | | Genesee South | Oakfield - Caledonia LN201 reconduc | C046707 |
| | | | Livingston | N.Lakeville - Ridge LN 218 Refurbis | C046766 |
| | Component Fatigue/Deterioration | TRAN | None | Alabama-Telegraph 115 T1040 ACR. | C033014 |
| | | | | Batavia-Golah 119 ACR | C060217 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | System | Distribution Study Area | Project Name | Funding Number |
|-------------------------------|---------------------|--------|-------------------------|-------------------------------------|----------------|
| | | | | Brockport Tap Refurbishment | C055531 |
| | | | | Hook Rd-Elbridge Polymer Insulators | C056626 |
| | | | | Lockport 103-104 T1620-T1060 STR | C027432 |
| | | | | Lockport-Batavia 112 T1510 ACR | C003422 |
| | | | | Mortmr-Pannll 24-25 T1590-T1600 ACR | C047816 |
| | | | | Pannell-Geneva 4-4A T1860 ACR | C030889 |
| | | | | Rochester UG Pumping Plant | C015988 |
| | Sub T Overhead Line | SUBT | Genesee North | Barker-Lyndonville 301-34.5kV | C052511 |
| | | | | Lyndonville-Medina 301-34.5kV | C052512 |
| Damage/Failure | Damage/Failure | TRAN | None | North LeRoy TRF #1 Replacement | C056083 |
| System Capacity & Performance | Load Relief | DIST | Livingston | S.Livingston relief: F5 work | C051692 |
| | | | | S.Livingston relief: Fd4 work | C051691 |
| | | | | S.Livingston relief: Dist Fder Work | C051694 |
| | | | | Sonora Way 115 – 13.2kV Substation | C051585 |
| | | | | South Livingston relief - DLine Fd2 | C046552 |
| | Reliability | | Genesee North | West Hamlin #82 - Install Transform | CD01089 |
| | | | | West Hamlin #82 - New TB2 - Install | CD01090 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | System | Distribution Study Area | Project Name | Funding Number |
|--------------------|-----------------------|--------|-------------------------|--------------------------------------|----------------|
| | | | | West Sweden - Install New Station | C046593 |
| | | | | West Sweden -New Sta - Install Fdrs | C046591 |
| | | | Genesee South | Mumford #50 - TB2 - Install New Fdr | C046589 |
| | | | | Mumford #50 - Install Transformer #2 | C046590 |
| | TO Led System Studies | TRAN | None | TP West Golah Substation | C050695 |

5. G. Frontier Transmission Study Area

Area Summary

The principal drivers for transmission projects in this area are:

- Low post-contingency voltages at Huntley and Gardenville.
- Fault current levels that result in overdutied breakers at Gardenville.
- High post-contingency autotransformer loadings on the 230-115kV banks at Gardenville.
- High post-contingency 115kV line loadings on lines extending south and east from Niagara, Packard, and Gardenville.
- Recommended major projects that address capacity issues include reconfiguring or reconductoring of the #181, #54, and #195 lines, the addition of a 115 kV capacitor bank and bus tie breaker at Huntley, and some reconfiguration and upgrading of limiting elements at Lockport and Mountain stations.
- The proposed rebuild of Old Gardenville Station to address station configuration issues as well as asset condition issues will also partially address capacity needs.

Key sub-transmission and distribution drivers include the following:

- Load growth in the Tonawanda area. A new 115-13.2kV substation will be used to supply the new commerce/industrial parks.
- Planned development in the City of Buffalo in the outer harbor and Buffalo River areas will require an upgraded substation to supply that area.
- Load growth by at the Buffalo Niagara Medical Campus as well as across downtown will be served by Elm Street substation.
- Area loading requiring the upgrade of multiple Buffalo area substations, including Buffalo Station 56, 59, 122, 214.
- Indoor substations are an asset condition issue and there are several replacement projects in progress in Buffalo.
- The condition of Harper 115-12kV station and several indoor substations in Niagara Falls are driving a new 115-13.2kV substation and other new projects in Niagara Falls.

Area Description

The Frontier transmission study area includes assets within NYISO Zone A. The area includes assets as far east as Lockport, the Niagara and Buffalo areas and the system stretching south to Gardenville. The system consists primarily of 115kV and 230kV double

2015 NY Capital Investment Plan

circuit transmission lines. The major substations are Packard (230 and 115kV), Huntley (230 and 115kV), and Lockport (115kV). There is a joint National Grid and NYSEG substation at Gardenville (230 and 115kV). National Grid has three 230/115kV transformers at Gardenville and two at Packard. NYSEG and NYPA also have their own substations in the area.

Within the Frontier study area there are ten distribution study areas: Amherst, Cheektowaga, Elm, Grand Island, Kensington, Niagara, Niagara Falls, Sawyer, Seneca and Tonawanda.

The Amherst study area serves approximately 65,100 customers. The study area is located east of Tonawanda and Niagara, and north of the City of Buffalo and encompasses the towns of Amherst, Pendleton, Wheatfield, Wilson and Lewiston. The Erie Canal divides the study area and may present challenges in creating new feeder ties and recommended supply expansion. The primary distribution system in Amherst is 13.2kV and 4.16kV, with a few small pockets of 4.8kV. The area substations are supplied by the 115kV transmission system with the exception of Buffalo Station 58 and Buffalo Station 124, which are supplied by 34.5kV sub-transmission lines originating from Youngman Terminal Station and Buffalo Station 67, which is supplied by the 34.5kV sub-transmission lines originating from Walden substation.

The Cheektowaga study area serves approximately 7,900 customers. The area is located east of the City of Buffalo. There are several stations in this area that are supplied by 115kV transmission lines. Walden is the largest and has two transformers that serve the 34.5kV sub-transmission system. Dale Rd. substation is 115-13.2kV, while Buffalo substations 61 and 154 are 115 - 4.16kV. The remaining substations in the area are 34.5-4.16kV. Buffalo Substation 146 has a 34.5-4.8kV and a 34.5-13.2kV transformer.

The Elm study area serves approximately 3,300 customers and is part of the City of Buffalo. It contains the downtown area as well as surrounding urban areas with a mix of residential, commercial and industrial loads. Elm Street Substation is a 230-23kV station that supplies the Buffalo network as well as the sub-transmission supply to several distribution stations. The Buffalo network has approximately 120MW of load. Most of the load is served by a low voltage AC general network which is supplied by multiple paralleled transformers with multiple 23kV supply cables thus providing very high reliability.

The Grand Island study area serves approximately 8,700 customers. The study area is made up of Grand Island which is between the City of Buffalo and Niagara Falls. It is primarily suburban and rural residential with areas of commercial and industrial parks. There are two National Grid substations supplied from 115kV lines with distribution feeders at 13.2kV.

The Kensington study area serves approximately 35,600 customers. There are eighty 4.16kV feeders; all fed from thirty-eight 23-4.16kV transformers and nineteen 23kV sub-transmission lines. The Kensington Substation has four 115-23kV transformers, and provides the supply to the 23kV sub-transmission system. This substation is located in the City of Buffalo and the study area contains significant amounts of underground distribution mainlines and overhead laterals. The Kenmore Terminal Station supplies several smaller commercial customers and the South Campus of the SUNY at Buffalo.

The Niagara study area serves approximately 12,800 customers. The study area

encompasses the towns of Lewiston, Porter, and Wilson. The study area is bordered to the west by Niagara River, to the North by Lake Ontario, and to the south by Power Reservoir. Area distribution is served primarily at 4.8kV and supplied by a 34.5kV sub-transmission network. The 34.5kV sub-transmission network operates in a loop system that is supplied by both Mountain and Sanborn 115-34.5kV substations. Swann Road supplies a significant portion of this area and is 115-13.2kV.

The Niagara Falls study area serves approximately 38,700 customers. The study area is bordered to the north, south, and west by the Niagara River. The Power Reservoir also borders the area to the north, east of the Niagara River. Interstate 190 runs from the north to the south along the eastern section of the study area. The CSX Railroad runs from the east to the west along the northern section of the area. The Niagara Falls International Airport lies east of the city. These boundaries limit feeder ties and distribution supply expansion in the area. The area is supplied primarily by the 115kV transmission system, however, a 12kV sub-transmission system is supplied by Harper and Gibson substations. Distribution load is served by 13.2kV, 4.8kV, and 4.16kV circuits.

The Sawyer study area serves approximately 63,700 customers. The study area contains portions of the City of Buffalo and the Town of Tonawanda. There are 154 4.16kV feeders supplying the area which are supplied by 23kV supply cables and multiple, paralleled transformers.

The Seneca study area serves approximately 44,100 customers. The study area is the southeast section of Buffalo. It is served primarily from the Seneca Terminal Station which has four 115-23kV transformers and serves 25 supply lines at 23kV. Most of the distribution substations are served by four supply cables and have four 23-4.16kV transformers. As throughout the City of Buffalo, almost all distribution load is served at 4.16kV.

The Tonawanda study area serves approximately 27,400 customers. The study area encompasses the City of North Tonawanda as well as a portion of the City and Town of Tonawanda. Bordering the western section of the area is the Niagara River. Ellicott Creek flows parallel to Tonawanda Creek in the northern part of the town of Tonawanda, with a confluence just east of the Niagara River. These creeks flow through the central part of the area from east to west. The eastern section of the area is bordered by the Town of Amherst and forming the southern border is the Village of Kenmore and the City of Buffalo. The area is served primarily by the 115kV transmission system and the 23kV sub-transmission system. Distribution voltage is served primarily by 4.16kV feeders.

2015 NY Capital Investment Plan

Major Project Table

The following table identifies major projects by spending rationale for this study area.

**Table 5-7
Frontier Major Projects**

| Spending Rationale | Program | System | Distribution Study Area | Project Name | Funding Number |
|--------------------|--|--------|-------------------------|-------------------------------------|----------------|
| Asset Condition | Asset Replacement | DIST | Niagara Falls | New Harper Substation D Line | C046417 |
| | | | Seneca | Buffalo Station 42 Rebuild - D Line | C046859 |
| | | | | Buffalo Station 42 Rebuild - D Stat | C046854 |
| | | | Tonawanda | Buffalo Station 122 Rebuild - Sub | CD00782 |
| | | SUBT | Cheektowaga | Galleria Mall - Switchgear Replmnts | C058985 |
| | Buffalo Street Light Cable Replacement | DIST | None | Buffalo Street Light Cable Replacem | CD00851 |
| | Component Fatigue/Deterioration | TRAN | | Gard-Dun 141-142 T1260-T1270 ACR | C003389 |
| | | | | Gardenville 180-182 T1660-T1780 ACR | C027436 |
| | | | | Gardenville Rebuild | C005156 |
| | | | | Gardenville-Rebuild Line Relocation | C030084 |
| | | | | LockportSubstationRebuildCo36TxT | C035464 |
| | | | | Packard Relays line 191 to 195 | C051423 |
| | | | | Rebuild Huntley Station | C049902 |
| | | | | Seneca Terminal Transformer Replace | C049744 |
| | Sub T Underground Cable Replacement | SUBT | | Buffalo 23kV UG Cable replacement | C052483 |
| | Substation Indoor | DIST | Kensington | Buffalo Station 53 Rebuild - Line | C046929 |
| | | | | Buffalo Station 53 Rebuild - Sub | C046945 |
| | | | Niagara Falls | Eighth St 80 - Indoor Substation Re | C046585 |
| | | | | Stephenson 85 - Indoor Substation R | C046580 |
| | | | | | C046581 |
| | | | | Welch 83 - Indoor Substation Refurb | C046584 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | System | Distribution Study Area | Project Name | Funding Number | |
|-------------------------------|---------------------------------------|-----------------------------------|-------------------------|-------------------------------------|-------------------------------------|---------|
| | | | | Welch 83 Indoor Substation Refurbis | C046583 | |
| | | | Sawyer | Buffalo Station 37 Rebuild - Sub | C033474 | |
| | | | Seneca | Buffalo Station 59 Rebuild - Sub | C033475 | |
| | Substation Metal-clad Switchgear | | Amherst | Station 140 Metalclad Replacement | C056616 | |
| | | | Cheektowaga | Station 61 - Metalclad Replacement | C051707 | |
| | | | Kensington | Station 162 Metalclad Replacement | C052706 | |
| | Substation Power Transformer | | Amherst | Station 124 - Almeda Ave Transforme | C046670 | |
| | Frankhauser New Station - Line Work | C028929 | | | | |
| System Capacity & Performance | Load Relief | | Elm | Buffalo Station 49 - UG Upgrades | CD01128 | |
| | | | Niagara | Wilson 93 Load Relief - Replace TB1 | C035743 | |
| | | | Sawyer | Buffalo Sta 56- upgrade 4 Xfmrs | C036502 | |
| | | | | Buffalo 23kV Reconductor - Huntley2 | C028893 | |
| | | SUBT | DIST | Grand Island | Long Rd 209 - New F20955 | CD00964 |
| | | Long Road 209 - Install TB2 | | | CD00977 | |
| | Niagara | Shawnee Road 76 | | C036059 | | |
| | Niagara Falls | Lockport Road 216 - Install TB#2 | | C036057 | | |
| | | Military Road 210 - Install TB#2 | | C036056 | | |
| | Tonawanda | New Dist Sub - Tonawanda NYW DSub | | C051266 | | |
| | | New Dist Sub -Tonawanda NYW DLine | | C051265 | | |
| | | Station 214 - Install TB2 | | C029186 | | |
| | | Station 214 - New F21467 | | C029187 | | |
| | Secondary Network Arcflash Mitigation | Elm | | NY West Div Arc Flash 480V Spot NW | C047461 | |
| | TO Led System Studies | TRAN | | None | Elm St Relief_Add 4th Xfer | C049594 |
| | | | | | Grdvll-Bffl Rvr146 2nd Tap Ohio Sta | C054713 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | System | Distribution Study Area | Project Name | Funding Number |
|--------------------|---------|--------|-------------------------|-------------------------------------|----------------|
| | | | | Mountain upgrade 115 - 34.5kV trans | C044359 |
| | | | | New Harper Substation - TxT Sub | C044874 |
| | | | | Sanborn upgrade 115 - 34.5kV transf | C044361 |
| | | | | Sawyer Fourth 230-23kV Bank | C053147 |
| | | | | TP Reconductor line #181 | C050744 |

5. H. Southwest Transmission Study Area

Area Summary

The primary drivers of the transmission capacity related projects in the Southwest study area are:

- A wide range of contingencies that can result in voltages well below criteria at various locations in this study area. The vulnerability of the area to these voltage issues is significantly amplified if certain key generators are not operating.
- Projects to address capacity problems in this area, including the new Five-Mile Road 345/115kV station north of Homer Hill, the addition of a second capacitor bank at Homer Hill, the closing of a normally open breaker at Andover, and the addition of a second bus tie breaker in the Dunkirk substation.
- Projects to address the longer-term reliability considerations, including two 33.3 MVAR capacitor banks at Dunkirk, a second 75 MVAR capacitor bank at the Huntley 115 kV switchyard and reconductoring of two 115kV lines between Five Mile Rd and Homer Hill.

Key sub-transmission and distribution drivers include the following:

- The 34.5kV sub-transmission system, which consists of several very long loops that traverse rugged territory.
- Load growth and reliability concerns in the South Chautauqua portion of the area are driving new station projects.
- Load growth and asset condition issues at Stations in the Eden/Evans area that are being addressed by a new substation and expansion/upgrade of Delameter Road Substation.
- Load growth in the Buffalo Outer Harbor area will require an expansion/upgrade of Buffalo Station 42.

Area Description

The Southwest transmission study area includes the system as far north as Gardenville station, east into Wellsville and the system stretching south into Pennsylvania. The transmission system consists primarily of 115kV and 230kV double circuit transmission lines. The major stations are Gardenville (230 and 115kV), a joint National Grid and NYSEG station, Dunkirk (230 and 115kV), Falconer (115kV) and Homer Hill (115kV). National Grid has 230-115kV transformers at Gardenville (3) and Dunkirk (2). NYSEG also has two 230-115kV transformers at Gardenville.

Within the Southwest study area, there are six distribution study areas: Cattaraugus – North, Chautauqua North, Chautauqua South, Erie South, Olean and Wellsville.

The North Cattaraugus study area serves approximately 15,200 customers. There are seven 13.2kV feeders, five of which are fed via two 115-13.2kV transformers at the Valley substation. The remaining two 13.2kV feeders are fed from 34.5-13.2kV transformers at the

Price Corners and Reservoir substations. There are also twenty 4.8kV feeders, all supplied by 34.5-4.8kV transformers at various area substations. There are seven 34.5kV sub-transmission lines that provide supply for the 34.5-4.8kV transformers and a minimal number of industrial customers that are supplied directly from the 34.5kV system. There are several NYSEG substations and municipal electric departments supplied from the 34.5kV system.

The North Chautauqua study area serves approximately 22,900 customers. There are ten 4.8kV feeders, which are all fed from 34.5-4.8kV transformers. There are also twenty 13.2kV distribution feeders with all but one fed by 115-13.2kV transformers at various substations in the area. One 13.2kV feeder is supplied by a 34.5-13.2kV transformer at the West Portland substation. There are also eight 34.5kV sub-transmission lines which provide the supply to the 34.5-4.8kV step-down transformers in the area.

The Chautauqua South study area serves approximately 17,900. Customers are supplied by twenty 4.8kV delta feeders, which are all fed from 34.5-4.8kV transformers. There are four 13.2kV feeders with three fed by the Baker Street 115-13.2kV transformer and one fed by the French Creek 34.5-13.2kV transformer. There are five 34.5kV sub-transmission lines that are supplied from Hartsfield and South Dow 115kV substations.

The Erie South study area serves approximately 34,100 customers. The study area includes the Buffalo outer harbor area and those areas south of the City of Buffalo with approximately half the feeders served at 13.2kV. The 115kV system supplies the 13.2kV stations. The rest of the feeders operate at 4.8kV or 4.16kV.

The Olean study area serves approximately 18,500 customers. There are twenty distribution feeders that provide service to area customers. There are eight 4.8kV feeders supplied by 34.5-4.8kV transformers at various stations. Eleven of the area's twelve 13.2kV feeders are fed from 115-13.2kV transformers. The remaining single feeder is served from a 34.5-13.2kV transformer at the Vandalia substation.

The Wellsville study area serves approximately 4,400 customers. This study area is a small rural region located near the Pennsylvania border and is supplied by the 115-34.5kV Andover and Nile substations. There are two 34.5kV supply lines in the area. Load is served by five substations serving nine 4.8kV feeders.

2015 NY Capital Investment Plan

Major Project Table

The following table identifies major projects by spending rationale for this study area.

**Table 5-8
Southwest Major Projects**

| Spending Rationale | Program | System | Distribution Study Area | Project Name | Funding Number |
|---------------------------------------|---------------------------------|--------|-------------------------|--------------------------------------|----------------|
| Asset Condition | Asset Replacement | DIST | Erie South | Ohio St - Buffalo River Tunnel/Bore | C050400 |
| | | SUBT | Cattaraugus North | Dake Hill-W. Salamanca 816-34.5kv | C046469 |
| | | | Chautauqua South | W. Portland-Sherman 867-34.5kv | C046468 |
| | | | Erie South | Shaleton-Ridge 610, Station 207 Tap | C046779 |
| | | | Chautauqua North | Hartfield-S. Dow 859-Relocate Part | C052209 |
| | Component Fatigue/Deterioration | TRAN | None | Dunkrk-Falc 161-162 T1090-T1100 ACR | C047831 |
| | | | | Homer Hill-Bennett 157 T1340 ACR | C027429 |
| | Sub T Overhead Line | SUBT | Chautauqua South | Relocate S. Dow-Poland 865-34.5kV | C050177 |
| | | | | West Portland-Sherman 867 Relocatio | C055118 |
| | | | Chautauqua North | Hartfield-S. Dow 859 Refurbish | C033180 |
| Customer Requests/Public Requirements | New Business | | Erie South | Extend LN 611 & 612 to Riverbend | C054665 |
| System Capacity & Performance | Generator Retirements | TRAN | None | Five Mile to Homer Hill reconduct | C047319 |
| | Load Relief | DIST | Erie South | Eden switch structure - install 2-10 | C046538 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | System | Distribution Study Area | Project Name | Funding Number |
|--------------------|-----------------------|--------|-------------------------|-------------------------------------|----------------|
| | | | | Eden Switch Structure-New Fdr 1 | C048015 |
| | | | | Eden Switch Structure-New fdr# 2 | C048016 |
| | | SUBT | | Ohio St station - SubT lines | C055304 |
| | Reliability | DIST | | Bflo Sta 139 - Replace Transformers | C036639 |
| | | | | Delameter Install two 20/26/33MVA | C046536 |
| | | | | Delameter F9356-express& rebuild | C047877 |
| | TO Led System Studies | TRAN | None | Airco-Bffl Rvr147 Adv Metal Tap | C054711 |
| | | | | Construct Five Mile Station | C024015 |
| | | | | Ohio Street new 115 - 34.5kV sub | C055263 |
| | | | | W. Ashville substation TxT | C043833 |

Exhibit 1 - Transmission Capital Investment Plan

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|---------------------------------|-------------------------------------|-----------|------------|-----------|------------|-----------|-----------|-------------|
| Asset Condition | Asset Condition I&M | NY Inspection Repairs - Capital | C026923 | 11,309,200 | 4,279,229 | 3,011,547 | 3,011,820 | 1,150,000 | 22,761,796 |
| | Asset Condition I&M Total | | | 11,309,200 | 4,279,229 | 3,011,547 | 3,011,820 | 1,150,000 | 22,761,796 |
| | Component Fatigue/Deterioration | 345kV Laminated cross-arm program | C060365 | 100,000 | 3,500,000 | 3,000,000 | 3,000,000 | 3,000,000 | 12,600,000 |
| | | Alabama-Telegraph 115 T1040 ACR. | C033014 | 500,000 | 4,100,000 | 500,000 | 0 | 0 | 5,100,000 |
| | | Alps relay replacement | C049296 | 0 | 140,650 | 0 | 0 | 0 | 140,650 |
| | | AMT PIW - NIMO | C031545 | 415,000 | 1,000,000 | 1,000,000 | 1,000,000 | 1,000,000 | 4,415,000 |
| | | ASH ST_22325_22329-REACTORS | C054430 | 20,000 | 0 | 0 | 0 | 0 | 20,000 |
| | | Batavia Station Relay Replacement | C043506 | 34,300 | 0 | 0 | 0 | 0 | 34,300 |
| | | Batavia-Golah 119 ACR | C060217 | 0 | 0 | 0 | 300,000 | 1,000,000 | 1,300,000 |
| | | BatteryRplStrategyCo36TxT | C033847 | 219,453 | 199,999 | 159,996 | 684,000 | 250,000 | 1,513,448 |
| | | Battle Hill - replace 3 OCBs | C049543 | 2,000 | 1,000,000 | 0 | 0 | 0 | 1,002,000 |
| | | Bethlehem Relay Replacem't Strategy | C049583 | 0 | 20,000 | 120,019 | 0 | 0 | 140,019 |
| | | Boonville Rebuild | C049903 | 0 | 0 | 0 | 50,000 | 100,000 | 150,000 |
| | | Boonville-Rome 3-4 T4060-T4040 ACR | C047795 | 100,000 | 200,000 | 200,000 | 8,000,000 | 394,000 | 8,894,000 |
| | | Boonvill-Portr 1-2 T4020-T4030 ACR | C047818 | 50,000 | 100,000 | 170,000 | 170,000 | 4,687,000 | 5,177,000 |
| | | Br F-Taylorville 3-4 ACR | C024359 | 310,400 | 5,840,000 | 2,920,000 | 0 | 0 | 9,070,400 |
| | | Breaker T Repl Program 4-69kV NYC. | C049258 | 105,000 | 739,000 | 600,000 | 600,000 | 600,000 | 2,644,000 |
| | | Breaker T Repl Program 4-69kV NYE | C049257 | 105,000 | 931,000 | 600,000 | 600,000 | 600,000 | 2,836,000 |
| | | Breaker T Repl Program 4-69kV NYW | C049260 | 165,000 | 1,271,000 | 600,000 | 600,000 | 600,000 | 3,236,000 |
| | | Brockport Tap Refurbishment | C055531 | 100,000 | 1,020,000 | 85,000 | 0 | 0 | 1,205,000 |
| | | Browns Falls - OCB replacements | C043043 | 39,990 | 0 | 0 | 0 | 0 | 39,990 |
| | | Capital Reserve - Asset Condition | CNYX31AC | -5,570,113 | -834,896 | -5,982,383 | -105,454 | -805,605 | -13,298,451 |
| | | Carr St./E.Syracuse CO-Gen Relays | C049739 | 0 | 50,000 | 426,800 | 0 | 0 | 476,800 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|---------|--------------------------------------|-----------|-----------|------------|------------|------------|------------|------------|
| | | CIRCUIT BREAKER RECLOS RPL NYC TXD | C035142 | 9,000 | 0 | 0 | 0 | 0 | 9,000 |
| | | Colton-BF 1-2 T3140-T3150 ACR | C036164 | 20,000 | 350,000 | 2,000,000 | 6,000,000 | 2,329,000 | 10,699,000 |
| | | Colton-Replace CBs and Disconnects | C029844 | 1,544,900 | 135,170 | 0 | 0 | 0 | 1,680,070 |
| | | Curtis Relay /Breaker Replacement | C049584 | 50,000 | 688,750 | 349,000 | 0 | 0 | 1,087,750 |
| | | Dunkirk Rebuild | C005155 | 0 | 0 | 0 | 0 | 250,000 | 250,000 |
| | | Dunkirk-Falconer 161/162 Shield Wir | C054226 | 44,000 | 0 | 0 | 0 | 0 | 44,000 |
| | | Dunkirk-Falc 161-162 T1090-T1100 ACR | C047831 | 0 | 0 | 0 | 0 | 1,000,000 | 1,000,000 |
| | | East Syracuse Co-Gen Disconnects | C056726 | 25,000 | 0 | 0 | 0 | 0 | 25,000 |
| | | Edic - New Control House | C058129 | 2,000,000 | 400,000 | 0 | 0 | 0 | 2,400,000 |
| | | Edic/N Scotland-NG Assoc work-TOTS | C058064 | 500,000 | 0 | 0 | 0 | 0 | 500,000 |
| | | Elm St. Replace 67L Relays | CD00728 | 6,800 | 0 | 0 | 0 | 0 | 6,800 |
| | | Feura Bush Relay Replacement | C049585 | 0 | 90,000 | 720,115 | 0 | 0 | 810,115 |
| | | Frontier Lines 180 181 ACR | C060215 | 0 | 0 | 0 | 0 | 300,000 | 300,000 |
| | | Gard-Dun 141-142 T1260-T1270 ACR | C003389 | 100,000 | 1,000,000 | 5,000,000 | 25,000,000 | 25,000,000 | 56,100,000 |
| | | Gardenville 180-182 T1660-T1780 ACR | C027436 | 0 | 0 | 50,000 | 50,000 | 1,000,000 | 1,100,000 |
| | | Gardenville Rebuild | C005156 | 4,273,920 | 14,550,000 | 15,272,000 | 4,209,800 | 0 | 38,305,720 |
| | | Gardenville-Depew 54 ACR | C060213 | 0 | 0 | 0 | 0 | 300,000 | 300,000 |
| | | Gardenville-Rebuild Line Relocation | C030084 | 1,800,000 | 4,851,800 | 4,035,980 | 100,000 | 0 | 10,787,780 |
| | | Gard-HH 151-152 T1950-T1280 S ACR | C027425 | 0 | 0 | 0 | 0 | 200,000 | 200,000 |
| | | GE Butyl Rubber VT Replacement | C049002 | 528,000 | 224,000 | 320,000 | 0 | 0 | 1,072,000 |
| | | GE-Geres Lock 8 T2240 ACR | C047835 | 400,000 | 4,000,000 | 10,000,000 | 500,000 | 0 | 14,900,000 |
| | | GERES LOCK - RPLC R815 OCB | C049138 | 200,000 | 0 | 0 | 0 | 0 | 200,000 |
| | | Geres Lock-Solvay 2 ACR | C060206 | 0 | 0 | 0 | 0 | 100,000 | 100,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|---------|-------------------------------------|-----------|-----------|-----------|------------|------------|------------|------------|
| | | Gibson Substation Retirement | C046579 | 0 | 0 | 77,350 | 0 | 0 | 77,350 |
| | | Golah Relay & Breaker Strategy Repl | C050920 | 0 | 25,000 | 165,026 | 0 | 0 | 190,026 |
| | | Greenbush Relay Replacement | C049587 | 0 | 50,000 | 330,053 | 0 | 0 | 380,053 |
| | | Greenbush-Stephentown #993 ACR | C060208 | 0 | 0 | 0 | 0 | 300,000 | 300,000 |
| | | Headson - OCB Replacements | C043044 | 7,000 | 0 | 0 | 0 | 0 | 7,000 |
| | | Homer Hill - West Olean 156 ACR | C060218 | 0 | 0 | 0 | 0 | 200,000 | 200,000 |
| | | Homer Hill Switch Relay Replacement | C043505 | 45,000 | 0 | 0 | 0 | 0 | 45,000 |
| | | Homer Hill-Bennett 157 T1340 ACR | C027429 | 560,000 | 6,499,500 | 100,000 | 0 | 0 | 7,159,500 |
| | | Hook Rd-Elbridge Polymer Insulators | C056626 | 50,000 | 1,200,000 | 0 | 0 | 0 | 1,250,000 |
| | | Hoosick - Replace Bank 1 & relays | C053132 | 25,000 | 700,000 | 3,400,000 | 0 | 0 | 4,125,000 |
| | | Hudson Station 087- Animal Fence | C059640 | 50,000 | 0 | 0 | 0 | 0 | 50,000 |
| | | Huntley Sub-Rem TB130 & 140 cables | C028089 | 27,000 | 0 | 0 | 0 | 0 | 27,000 |
| | | Independence Station relay Replace | C049598 | 0 | 80,000 | 523,800 | 0 | 0 | 603,800 |
| | | Inghams Phase Shifting Transformer | C047864 | 2,240,000 | 750,000 | 0 | 0 | 0 | 2,990,000 |
| | | Inghams Station - Assoc Line work | C060240 | 0 | 0 | 0 | 0 | 1,000,000 | 1,000,000 |
| | | Inghams Station Re-vitalization | C050917 | 0 | 110,000 | 113,000 | 500,000 | 5,000,000 | 5,723,000 |
| | | Inghams-E. Springfield #7 ACR | C060209 | 0 | 0 | 0 | 0 | 300,000 | 300,000 |
| | | Leeds - Replace U Series Relays | C024663 | 2,164,448 | 0 | 0 | 0 | 0 | 2,164,448 |
| | | Leeds Station Service | C049900 | 956,920 | 24,000 | 0 | 0 | 0 | 980,920 |
| | | LightHH 115kV Yard Repl & cntrl hs. | C031662 | 20,000 | 300,000 | 1,500,000 | 5,000,000 | 15,000,000 | 21,820,000 |
| | | Lockport 103-104 T1620-T1060 STR | C027432 | 0 | 50,000 | 100,000 | 200,000 | 1,300,000 | 1,650,000 |
| | | Lockport-Batavia 108 T1500 STR | C027431 | 42,500 | 0 | 0 | 0 | 0 | 42,500 |
| | | Lockport-Batavia 112 T1510 ACR | C003422 | 100,000 | 1,000,000 | 17,000,200 | 25,600,000 | 17,000,000 | 60,700,200 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|-----------------------|---------|-------------------------------------|-----------|-----------|-----------|-----------|-----------|------------|------------|
| | | Lockport Substation Rebuild Co36TxT | C035464 | 0 | 50,000 | 498,271 | 1,500,240 | 10,000,000 | 12,048,511 |
| | | Long Lane Relay Replacement | C049600 | 0 | 100,000 | 660,106 | 0 | 0 | 760,106 |
| | | Maplewood-Norton-Replace Pilot Wire | C036006 | 265,050 | 0 | 0 | 0 | 0 | 265,050 |
| | | Marshville - replace R11 OCB | C049547 | 35,000 | 315,050 | 0 | 0 | 0 | 350,050 |
| | | McIntyre Relay Replacement | C047860 | 226,000 | 34,920 | 0 | 0 | 0 | 260,920 |
| | | Menands Station Relay Replacement | C049601 | 300,000 | 4,484,740 | 498,200 | 0 | 0 | 5,282,940 |
| | | Mohican - Replace Bank 1 and Relays | C053133 | 0 | 0 | 996,400 | 2,989,200 | 0 | 3,985,600 |
| | | Mortimer-Golah #110 ACR | C060220 | 0 | 0 | 0 | 0 | 300,000 | 300,000 |
| | | Mortmr-Pannll 24-25 T1590-T1600 ACR | C047816 | 25,000 | 0 | 100,000 | 200,000 | 5,000,000 | 5,325,000 |
| | | Mountain Station Relay Replacement | C049603 | 0 | 47,000 | 481,280 | 0 | 0 | 528,280 |
| | | New Scotland - replace 345kV OCBs | C049553 | 1,067,840 | 8,800 | 0 | 0 | 0 | 1,076,640 |
| | | New Scotland Relay Replacement | C047861 | 15,000 | 634,729 | 0 | 0 | 0 | 649,729 |
| | | Niagara-Lockport 101 & 102 ACR | C060216 | 0 | 0 | 0 | 0 | 300,000 | 300,000 |
| | | North Ogdensburg Relay Replacement | C047862 | 30,070 | 134,830 | 0 | 0 | 0 | 164,900 |
| | | North Troy Relay Replacement | C049605 | 0 | 25,000 | 165,026 | 0 | 0 | 190,026 |
| | | NS-Leeds 93-94 T5480-T5490 SXR | C007918 | 0 | 0 | 0 | 0 | 50,000 | 50,000 |
| | | NY Oil Circuit Breaker Replacements | C037882 | 0 | 0 | 0 | 1,600,256 | 2,000,000 | 3,600,256 |
| | | Oneida Substation Rebuild | C034443 | 0 | 0 | 0 | 0 | 250,000 | 250,000 |
| | | Oswego - 115kV & 34.5kV - Asset Sep | C043426 | 1,315,579 | 5,000,000 | 3,000,000 | 0 | 0 | 9,315,579 |
| | | Packard Relays line 191 to 195 | C051423 | 646,990 | 657,660 | 0 | 0 | 0 | 1,304,650 |
| | | Packard-Walck Road 129 ACR | C060214 | 0 | 0 | 0 | 0 | 300,000 | 300,000 |
| | | Pannell-Geneva 4-4A T1860 ACR | C030889 | 25,000 | 100,000 | 200,000 | 5,000,000 | 500,000 | 5,825,000 |
| | | Porter-Rotterdam 31 T4210 ACR | C030890 | 1,771,000 | 70,000 | 300,000 | 2,000,000 | 10,000,000 | 14,141,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|---------|-------------------------------------|-----------|---------|-----------|-----------|-----------|------------|------------|
| | | Porter-Schuyler 13 Removal | C048649 | 0 | 21,150 | 0 | 0 | 0 | 21,150 |
| | | Porter-Watkins Rd 5 ACR | C060207 | 0 | 0 | 0 | 0 | 300,000 | 300,000 |
| | | Praxair Station Rebuild | C054227 | 100,000 | 0 | 0 | 0 | 0 | 100,000 |
| | | Purchase Spare Transformers | C053135 | 0 | 0 | 3,000,000 | 0 | 0 | 3,000,000 |
| | | Pyrites New Battery House | C051704 | 800 | 0 | 0 | 0 | 0 | 800 |
| | | Quaker-Sleight Road #13 ACR | C060219 | 0 | 0 | 0 | 0 | 300,000 | 300,000 |
| | | Queensbury - replace OCBs | C049554 | 50,000 | 1,000,160 | 0 | 0 | 0 | 1,050,160 |
| | | Rebuild Huntley Station | C049902 | 25,000 | 350,000 | 2,500,400 | 5,100,000 | 10,300,000 | 18,275,400 |
| | | Relay Replacement Program NY-T | C034690 | 0 | 0 | 0 | 2,000,000 | 4,000,000 | 6,000,000 |
| | | Repl Pilot Wire-Central Ave-Patroom | C036031 | 2,550 | 0 | 0 | 0 | 0 | 2,550 |
| | | Ridge Substation - 34.5kV System Re | C046693 | 287,914 | 0 | 0 | 0 | 0 | 287,914 |
| | | Rochester UG Pumping Plant | C015988 | 101,000 | 700,000 | 298,900 | 0 | 0 | 1,099,900 |
| | | Rotterdam 115kV SubRebuild(AIS) | C034850 | 0 | 50,000 | 300,000 | 6,750,000 | 20,000,000 | 27,100,000 |
| | | Rotterdam-Bear Swamp E205 T5630 ACR | C047832 | 0 | 0 | 0 | 200,000 | 200,000 | 400,000 |
| | | Schuyler - replace OCBs | C049562 | 100,000 | 1,000,000 | 0 | 0 | 0 | 1,100,000 |
| | | Schuyler Rd Repl 918 928 CirSws | C050799 | 217,000 | 0 | 0 | 0 | 0 | 217,000 |
| | | Scriba Relay Replacement | C049611 | 38,800 | 780,850 | 56,260 | 0 | 0 | 875,910 |
| | | Seneca Term Relay Replacement | C049613 | 0 | 70,000 | 470,075 | 0 | 0 | 540,075 |
| | | Seneca Terminal Transformer Replace | C049744 | 350,000 | 1,700,000 | 0 | 0 | 0 | 2,050,000 |
| | | Shield Wire: Gardenville-Depew 54 | C028706 | 246,000 | 0 | 0 | 0 | 0 | 246,000 |
| | | Spier-Queensbury #17 ACR | C060211 | 0 | 0 | 0 | 0 | 300,000 | 300,000 |
| | | Spier-Queensbury #5 115kV ACR | C060210 | 0 | 0 | 0 | 0 | 300,000 | 300,000 |
| | | Spier-Rotterdam 1 & 2 ACR | C060212 | 0 | 0 | 0 | 300,000 | 1,000,000 | 1,300,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|---------------------------------------|-------------------------------------|-----------|------------|------------|------------|-------------|-------------|-------------|
| | | System Spare TRF eastern NY | C057026 | 490,000 | 0 | 0 | 0 | 0 | 490,000 |
| | | Taylorville-B 5-6 T3320-T3330 ACR | C027437 | 7,434,180 | 1,592,000 | 0 | 0 | 0 | 9,026,180 |
| | | Teal Ave. Transformer Replacement | C047865 | 2,029,600 | 2,679,000 | 350,000 | 0 | 0 | 5,058,600 |
| | | Terminal-Schuyler 7 T4260 ACR | C047833 | 0 | 50,000 | 85,000 | 170,000 | 1,045,000 | 1,350,000 |
| | | Ticonderoga - replace R4 OCB | C049552 | 50,000 | 300,000 | 0 | 0 | 0 | 350,000 |
| | | Ticonderoga 2-3 T5810-T5830 ACR | C039521 | 125,000 | 1,000,000 | 5,000,000 | 14,000,000 | 28,000,000 | 48,125,000 |
| | | TICONDEROGA 2-3 T5810-T5830 SXR2 | C039487 | 2,992,000 | 0 | 0 | 0 | 0 | 2,992,000 |
| | | Ticonderoga-Sanford T6410R Removal | C032309 | 25,000 | 0 | 742,500 | 0 | 0 | 767,500 |
| | | Tilden - replace OCBs | C049556 | 0 | 50,000 | 1,000,000 | 0 | 0 | 1,050,000 |
| | | Turner D Switch Replacements (36) | C052603 | 100,000 | 800,000 | 688,000 | 688,000 | 0 | 2,276,000 |
| | | Volney station Relay Replacement | C049626 | 50,000 | 650,870 | 0 | 0 | 0 | 700,870 |
| | | Walck RD Relay Replacement | C049628 | 0 | 25,000 | 165,026 | 0 | 0 | 190,026 |
| | | Whitehall - replace OCBs | C049564 | 75,000 | 975,156 | 0 | 0 | 0 | 1,050,156 |
| | | Wood Pole Mgmt Prgm (Osmose) | C011640 | 1,030,560 | 2,553,600 | 1,621,840 | 1,500,000 | 1,500,000 | 8,206,000 |
| | | Woodard Relay Replacement | C047863 | 100,000 | 269,660 | 0 | 0 | 0 | 369,660 |
| | | Woodlawn Transformer Replacement | C051986 | 1,350,000 | 1,800,000 | 450,000 | 0 | 0 | 3,600,000 |
| | | Yahnundasis Relay replacement | C049629 | 0 | 0 | 370,059 | 0 | 0 | 370,059 |
| | Component Fatigue/Deterioration Total | | | 37,578,451 | 86,435,149 | 89,453,300 | 126,056,042 | 177,949,395 | 517,472,337 |
| | Failure Trend | Central Div Sta - Shielded Cable | C058003 | 34,920 | 176,400 | 26,460 | 308,700 | 0 | 546,480 |
| | | Higley-Repl Fuses w/Ckt Switcher | C034664 | 652,735 | 0 | 0 | 0 | 0 | 652,735 |
| | | New Scotland- Relay Cable Shielding | C056244 | 133,000 | 0 | 0 | 0 | 0 | 133,000 |
| | | Osprey Mitigation Sleight-Auburn #3 | C049288 | 43,000 | 0 | 0 | 0 | 0 | 43,000 |
| | | West Div - Shielded Cables | C058130 | 79,000 | 0 | 79,000 | 0 | 0 | 158,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|---------------------------------------|---------------------------|--|-----------|------------|-------------|-------------|-------------|-------------|-------------|
| | Failure Trend Total | | | 942,655 | 176,400 | 105,460 | 308,700 | 0 | 1,533,215 |
| | NERC/NPCC Standards | Br. Falls-Taylorville 4 T3090 CCR | C048221 | 450,000 | 0 | 0 | 0 | 0 | 450,000 |
| | | Browns Falls-Taylorville 3 T3080CCR | C048218 | 600,000 | 0 | 0 | 0 | 0 | 600,000 |
| | | Conductor Clearance - NY Program | C048678 | 9,254,520 | 10,704,280 | 10,704,280 | 10,000,000 | 10,000,000 | 50,663,080 |
| | | NERC CIP - NMPC | C049085 | 1,150,000 | 50,000 | 0 | 0 | 0 | 1,200,000 |
| | NERC/NPCC Standards Total | | | 11,454,520 | 10,754,280 | 10,704,280 | 10,000,000 | 10,000,000 | 52,913,080 |
| Asset Condition Total | | | | 61,284,826 | 101,645,058 | 103,274,588 | 139,376,562 | 189,099,395 | 594,680,428 |
| Customer Requests/Public Requirements | Customer Interconnections | Byrne Dairy Load Expansion | C052843 | 283,000 | 200,000 | 0 | 0 | 0 | 483,000 |
| | | Byrne Dairy Load Expansion-Reimb | C052843R | -283,000 | -200,000 | 0 | 0 | 0 | -483,000 |
| | | Everpower Allegany IA-Tap/Switches | C047385 | 100,000 | 910,000 | 0 | 0 | 0 | 1,010,000 |
| | | Everpower Allegany IA-Tap/Switches Reimb | C047385R | -100,000 | -910,000 | 0 | 0 | 0 | -1,010,000 |
| | | Everpower Wind IA- SUF & AF Work | C047387 | 100,000 | 1,420,000 | 0 | 0 | 0 | 1,520,000 |
| | | Everpower Wind IA- SUF & AF Work Reimb | C047387R | -100,000 | -1,420,000 | 0 | 0 | 0 | -1,520,000 |
| | | Green Power Wind Project | C058099 | 758,000 | 0 | 0 | 0 | 0 | 758,000 |
| | | Green Power Wind Project-Reimb | C058099R | -758,000 | 0 | 0 | 0 | 0 | -758,000 |
| | | Green Pwr Wind Loop in/out | C058101 | 1,057,000 | 0 | 0 | 0 | 0 | 1,057,000 |
| | | Green Pwr Wind Loop in/out Reimb | C058101R | -1,057,000 | 0 | 0 | 0 | 0 | -1,057,000 |
| | | Line #46 115kV Replace w/ CNP | C053121 | 158,000 | 0 | 0 | 0 | 0 | 158,000 |
| | | NYSEG-LF Interct.115/34.5kV Sta. | C052588 | 632,000 | 0 | 0 | 0 | 0 | 632,000 |
| | | NYSEG-LF Interct.115/34.5kV Sta. Reimb | C052588R | -531,000 | 0 | 0 | 0 | 0 | -531,000 |
| | | ReEnergy/Fort Drum Interconnect | C058403 | 155,000 | 0 | 0 | 0 | 0 | 155,000 |
| | | ReEnergy/Fort Drum Interconnect Reimb | C058403R | -155,000 | 0 | 0 | 0 | 0 | -155,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|---------------------------------|---|-----------|------------|------------|------|------|------|------------|
| | | Roaring Brook Wind-Line #5 Loop T | C055663 | 620,000 | 1,455,000 | 0 | 0 | 0 | 2,075,000 |
| | | Roaring Brook Wind-Line #5 Loop T Reimb | C055663R | -620,000 | -1,455,000 | 0 | 0 | 0 | -2,075,000 |
| | | RoaringBrookUpgrade Martinsburg SUB | C055408 | 250,000 | 353,000 | 0 | 0 | 0 | 603,000 |
| | | RoaringBrookUpgrade Martinsburg SUB Reimb | C055408R | -250,000 | -353,000 | 0 | 0 | 0 | -603,000 |
| | | Watervliet Arsenal Request Dbl Tap | C053377 | 50,000 | 0 | 0 | 0 | 0 | 50,000 |
| | | Watervliet Arsenal Request Dbl Tap Reimb | C053377R | -50,000 | 0 | 0 | 0 | 0 | -50,000 |
| | Customer Interconnections Total | | | 259,000 | 0 | 0 | 0 | 0 | 259,000 |
| | Other | Edic-LN 1-7 & 24-40,Rpl Cbs-TOTS | C058063 | 1,445,000 | 85,000 | 0 | 0 | 0 | 1,530,000 |
| | | Edic-LN 1-7 & 24-40,Rpl Cbs-TOTS Reimb | C058063R | -1,445,000 | -85,000 | 0 | 0 | 0 | -1,530,000 |
| | | New Scotland - LN1 & 18 Rly - TOTS | C058060 | 306,000 | 18,000 | 0 | 0 | 0 | 324,000 |
| | | New Scotland - LN1 & 18 Rly - TOTS Reimb | C058060R | -306,000 | -18,000 | 0 | 0 | 0 | -324,000 |
| | | RG&E--Mortimer Sub 251 Upgrade | C056410 | 107,241 | 0 | 0 | 0 | 0 | 107,241 |
| | | RG&E--Mortimer Sub 251 Upgrade Reimb | C056410R | -107,241 | 0 | 0 | 0 | 0 | -107,241 |
| | | Scriba - LN 10 Rly - TOTS | C058061 | 306,000 | 18,000 | 0 | 0 | 0 | 324,000 |
| | | Scriba - LN 10 Rly - TOTS Reimb | C058061R | -306,000 | -18,000 | 0 | 0 | 0 | -324,000 |
| | | Volney - LN 19 RLY - TOTS | C058062 | 153,000 | 9,000 | 0 | 0 | 0 | 162,000 |
| | | Volney - LN 19 RLY - TOTS Reimb | C058062R | -153,000 | -9,000 | 0 | 0 | 0 | -162,000 |
| | Other Total | | | 0 | 0 | 0 | 0 | 0 | 0 |
| | Public Requirements | FAA Obstruction Lighting - West | C027954 | 270,000 | 0 | 0 | 0 | 0 | 270,000 |
| | | NYPA's Marcy So Series Compensator | C059802 | 2,500,000 | 3,000,000 | 0 | 0 | 0 | 5,500,000 |
| | | NYPA's Marcy So Series Compensator Reimb | C059802R | -2,500,000 | -3,000,000 | 0 | 0 | 0 | -5,500,000 |
| | | TP Relocate Lafarge-Pleasant Villy#8 | C050745 | 10,000 | 0 | 0 | 0 | 0 | 10,000 |
| | Public Requirements Total | | | 280,000 | 0 | 0 | 0 | 0 | 280,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|---|-----------------------------|-------------------------------------|-----------|-----------|-----------|-----------|-----------|-----------|------------|
| | TO Led System Studies | Solar Cty Tap off 145/146 | C053152 | 200,000 | 358,000 | 20,000 | 0 | 0 | 578,000 |
| | | Solar Cty Tap off 145/146-Reimb | C053152R | -200,000 | -358,000 | -20,000 | 0 | 0 | -578,000 |
| | TO Led System Studies Total | | | 0 | 0 | 0 | 0 | 0 | 0 |
| Customer Requests/Public Requirements Total | | | | 539,000 | 0 | 0 | 0 | 0 | 539,000 |
| Damage/Failure | Damage/Failure | #4 Porter-Valley/Valley-Fairfie | C060139 | 600,000 | 0 | 0 | 0 | 0 | 600,000 |
| | | DENNISON-COLTN 4 T3180 SW X4-1 D-F | C047698 | 2,100 | 0 | 0 | 0 | 0 | 2,100 |
| | | DENNISON-COLTN 4 T3180 SW X4-3 D-F | C052317 | 2,100 | 0 | 0 | 0 | 0 | 2,100 |
| | | EAST CONKLIN LN17 COMM EQUIPMENT | C054843 | 110,000 | 0 | 0 | 0 | 0 | 110,000 |
| | | Elm St. Station #4 TRF D/F | C051039 | 3,400 | 0 | 0 | 0 | 0 | 3,400 |
| | | G-HH 151-52 T1950-T1280 Str265 D-F | C042184 | 79,800 | 0 | 0 | 0 | 0 | 79,800 |
| | | Leeds SVC B TRF D/F | C057879 | 1,400,000 | 0 | 0 | 0 | 0 | 1,400,000 |
| | | MCINTYRE CAP BANK RELAY UPGRADE | C055226 | 182,400 | 0 | 0 | 0 | 0 | 182,400 |
| | | N Troy-Hoosick #5 Sw 511 & 522 Repl | C058680 | 438,480 | 0 | 0 | 0 | 0 | 438,480 |
| | | NEW SCOTLAND | C039722 | 2,000 | 0 | 0 | 0 | 0 | 2,000 |
| | | North LeRoy TRF #1 Replacement | C056083 | 423,808 | 1,844,869 | 61,569 | 0 | 0 | 2,330,246 |
| | | OHL D-F Disconnect Switch Spares | C048159 | 450,000 | 1,000,000 | 0 | 0 | 0 | 1,450,000 |
| | | PACKARD-GARDV 182 T1780 D-F | C042364 | 10,000 | 0 | 0 | 0 | 0 | 10,000 |
| | | Seneca D/F #4 TRF Replacement | C058119 | 896,760 | 0 | 0 | 0 | 0 | 896,760 |
| | | Stoner-Rotterdam #12 Sw 1222 Replac | C058236 | 234,880 | 0 | 0 | 0 | 0 | 234,880 |
| | | Storm Budgetary Reserve - NMPC | C003481 | 500,000 | 500,000 | 500,000 | 500,000 | 500,000 | 2,500,000 |
| | | Taylorville OCB R240 D/F | C057500 | 45,000 | 0 | 0 | 0 | 0 | 45,000 |
| | | Trans Station Failure Budget Reserv | C003792 | 3,000,000 | 4,750,000 | 5,000,000 | 5,000,000 | 5,000,000 | 22,750,000 |
| | | TransLine Damage-Failure Budget Res | C003278 | 450,000 | 450,000 | 450,000 | 450,000 | 450,000 | 2,250,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|-------------------------------|--|--|-----------|------------|------------|------------|------------|-----------|------------|
| | | Yahnudasis T4160-T4300 D-F Struc | C038162 | 161,000 | 0 | 0 | 0 | 0 | 161,000 |
| | | Damage/Failure Total | | 8,991,728 | 8,544,869 | 6,011,569 | 5,950,000 | 5,950,000 | 35,448,166 |
| | | Damage/Failure Total | | 8,991,728 | 8,544,869 | 6,011,569 | 5,950,000 | 5,950,000 | 35,448,166 |
| Non-Infrastructure | Station Control and Monitoring Systems | EDIC SECURITY UPGRADES | C051894 | 15,000 | 0 | 0 | 0 | 0 | 15,000 |
| | | IntrMeterInvestmentPrgmCo 36 | C035267 | 156,170 | 0 | 0 | 0 | 0 | 156,170 |
| | | PORTER SECURITY UPGRADES | C051895 | 15,000 | 0 | 0 | 0 | 0 | 15,000 |
| | | Program-Remote Terminal Unit (RTU) | C003772 | 901,518 | 194,000 | 0 | 0 | 0 | 1,095,518 |
| | | Substation Security Program | C053136 | 1,500,000 | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 | 13,500,000 |
| | Station Control and Monitoring Systems Total | | | 2,587,688 | 3,194,000 | 3,000,000 | 3,000,000 | 3,000,000 | 14,781,688 |
| | Non-Infrastructure Total | | | 2,587,688 | 3,194,000 | 3,000,000 | 3,000,000 | 3,000,000 | 14,781,688 |
| System Capacity & Performance | Generator Retirements | Clay - GE 14 Reconductoring | C045253 | 5,054,700 | 0 | 0 | 0 | 0 | 5,054,700 |
| | | Five Mile to Homer Hill reduct | C047319 | 8,655,610 | 0 | 0 | 0 | 0 | 8,655,610 |
| | | New Elbridge - State St Line | C047298 | 8,904,000 | 0 | 0 | 0 | 0 | 8,904,000 |
| | | New Elbridge - State St Line Reimb | C047298R | -8,904,000 | 0 | 0 | 0 | 0 | -8,904,000 |
| | | Reconductor #5 Elbridge - State St | C047297 | 0 | 1,000,000 | 2,600,000 | 0 | 0 | 3,600,000 |
| | | Reconductor #5 Elbridge - State St Reimb | C047297R | 0 | -1,000,000 | -2,600,000 | 0 | 0 | -3,600,000 |
| | | Reconfigure Elbridge Sub | C047299 | 3,096,000 | 0 | 0 | 0 | 0 | 3,096,000 |
| | | Reconfigure Elbridge Sub Reimb | C047299R | -3,096,000 | 0 | 0 | 0 | 0 | -3,096,000 |
| | Generator Retirements Total | | | 13,710,310 | 0 | 0 | 0 | 0 | 13,710,310 |
| | NERC/NPCC Standards | CIP v5-C&I (NMPC-Low) | C058315 | 0 | 610,000 | 0 | 0 | 0 | 610,000 |
| | | CIP v5-US CNI (NMPC-High) | C058313 | 1,925,000 | 0 | 0 | 0 | 0 | 1,925,000 |
| | | Porter 115 kV Rebuild | C028686 | 100,050 | 0 | 0 | 0 | 0 | 100,050 |
| | | Porter 230kV-Upgrade Brks/Disc/PT's | C036866 | 25,000 | 250,000 | 1,000,160 | 15,000,000 | 0 | 16,275,160 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|---------------------------|---|-----------|------------|------------|------------|------------|-----------|-------------|
| | NERC/NPCC Standards Total | | | 2,050,050 | 860,000 | 1,000,160 | 15,000,000 | 0 | 18,910,210 |
| | Performance | Mohican St. add Station Service TRF | C055988 | 146,000 | 0 | 0 | 0 | 0 | 146,000 |
| | Performance Total | | | 146,000 | 0 | 0 | 0 | 0 | 146,000 |
| | TO Led System Studies | Add Brkr to Mortimer-Elbridge #2 | C053139 | 0 | 0 | 50,000 | 200,000 | 0 | 250,000 |
| | | Airco-Bfll Rvr147 Adv Metal Tap | C054711 | 160,000 | 1,200,000 | 200,000 | 0 | 0 | 1,560,000 |
| | | Ballston Tap Sw. St - Line Taps | C060251 | 10,000 | 100,000 | 800,000 | 200,000 | 0 | 1,110,000 |
| | | Ballston Tap Switching Station | C060250 | 200,000 | 1,500,000 | 7,000,000 | 500,000 | 0 | 9,200,000 |
| | | BETHLEHEM L10, L14 RELAY UPGRADE | C045624 | 5,100 | 0 | 0 | 0 | 0 | 5,100 |
| | | Bethlehem sub relay upgrade line #6 | C054267 | 131,750 | 63,750 | 0 | 0 | 0 | 195,500 |
| | | Capital Reserve - System Capacity & Performance | CNYX31SCP | -8,818,751 | -551,143 | -4,767,843 | -43,194 | -69,712 | -14,250,643 |
| | | Central Breaker Upgrades - Ash | C043424 | 1,501,440 | 0 | 0 | 0 | 0 | 1,501,440 |
| | | CENTRAL BREAKER UPGRADES - TEALL | C043427 | 247,000 | 0 | 0 | 0 | 0 | 247,000 |
| | | Clay Substation Reconfiguration | C047275 | 7,852,000 | 0 | 0 | 0 | 0 | 7,852,000 |
| | | Clay-Teall#10,Clay-Dewitt#3 Recond | C043995 | 5,390,000 | 11,060,000 | 19,140,000 | 1,710,000 | 0 | 37,300,000 |
| | | Clay-Woodard #17 replace 2.66 miles | C060242 | 50,000 | 800,000 | 0 | 0 | 0 | 850,000 |
| | | Construct Five Mile Station | C024015 | 14,100,000 | 2,649,000 | 0 | 0 | 0 | 16,749,000 |
| | | Construct Five Mile Station - Line | C024016 | 797,500 | 0 | 0 | 0 | 0 | 797,500 |
| | | Eastover - Add 2nd Bank | C060247 | 300,000 | 4,500,000 | 700,000 | 0 | 0 | 5,500,000 |
| | | Eastover Rd - New 230-115kV Station | C031326 | 3,250,000 | 0 | 0 | 0 | 0 | 3,250,000 |
| | | Eastover Rd-New Line Taps | C031419 | 1,235,000 | 0 | 0 | 0 | 0 | 1,235,000 |
| | | Elm St Relief_Add 4th Xfer | C049594 | 4,257,000 | 2,299,000 | 1,995,000 | 47,500 | 0 | 8,598,500 |
| | | Ephratah Sub Rebuild - Line Portion | C053144 | 0 | 0 | 50,000 | 749,700 | 749,700 | 1,549,400 |
| | | Ephratah substation rebuild | C046486 | 0 | 0 | 50,000 | 1,200,192 | 1,300,208 | 2,550,400 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|---------|-------------------------------------|-----------|------------|-----------|-----------|-----------|---------|------------|
| | | Golah Sub rebuild | C051831 | 0 | 0 | 0 | 55,000 | 489,600 | 544,600 |
| | | GrdVII-Bfll Rvr146 2nd Tap Ohio Sta | C054713 | 300,000 | 2,600,000 | 200,000 | 0 | 0 | 3,100,000 |
| | | Greenbush-Schodack 13&15 Tline | C052324 | 916,080 | 0 | 0 | 0 | 0 | 916,080 |
| | | Greenbush-Schodack/Hudson Sub | C052319 | 498,000 | 0 | 0 | 0 | 0 | 498,000 |
| | | Harper sub new 115 kV line taps | C044594 | 28,200 | 504,900 | 257,450 | 0 | 0 | 790,550 |
| | | Homer Hill Sub115kV Bus Upgrade | C059300 | 191,800 | 5,880 | 0 | 0 | 0 | 197,680 |
| | | Hudson Valley Reinforcement | C053148 | 0 | 100,000 | 400,000 | 8,001,000 | 0 | 8,501,000 |
| | | Line 116 tap to new N.Lakeville Sub | C052024 | 170,000 | 300,000 | 0 | 0 | 0 | 470,000 |
| | | Lowville Automated 115 kV Switches | C032259 | 4,200 | 0 | 0 | 0 | 0 | 4,200 |
| | | Luther Forest/Malta Diff. Scheme | C047897 | 800 | 0 | 0 | 0 | 0 | 800 |
| | | Malone 2nd Bank_Tline | C059673 | 0 | 40,000 | 240,000 | 120,000 | 0 | 400,000 |
| | | McCrea Line | C053150 | 0 | 0 | 425,000 | 1,300,000 | 0 | 1,725,000 |
| | | Mohican Battenkill#15 Rebuild Recon | C034528 | 26,789,400 | 5,979,600 | 0 | 0 | 0 | 32,769,000 |
| | | Mortimer line Re-Arrangement | C060248 | 0 | 0 | 0 | 0 | 500,000 | 500,000 |
| | | Mountain Station line relocation | C054944 | 157,402 | 0 | 0 | 0 | 0 | 157,402 |
| | | Mountain upgrade 115 - 34.5kV trans | C044359 | 3,800,000 | 45,535 | 0 | 0 | 0 | 3,845,535 |
| | | Mulberry Tap Sw St - Line taps | C060253 | 10,000 | 100,000 | 800,000 | 200,000 | 0 | 1,110,000 |
| | | Mulberry Tap Switching Station | C060252 | 200,000 | 1,500,000 | 7,000,000 | 500,000 | 0 | 9,200,000 |
| | | N.Lakeville - Add 34.5kV LN226 bker | C051826 | 0 | 0 | 0 | 32,000 | 485,000 | 517,000 |
| | | New bay at Edic 345kv substation | C044674 | 2,548,000 | 550,000 | 0 | 0 | 0 | 3,098,000 |
| | | New Harper Substation - TxT Sub | C044874 | 1,179,900 | 5,622,320 | 1,796,440 | 0 | 0 | 8,598,660 |
| | | New Scotland - Add Reactors LN19/20 | C060246 | 800,000 | 800,000 | 0 | 0 | 0 | 1,600,000 |
| | | New Tonawanda Station - Line Taps | C053156 | 50,000 | 200,000 | 260,000 | 50,000 | 0 | 560,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|---------|-------------------------------------|-----------|-----------|-----------|-----------|---------|-----------|------------|
| | | New Watertown 115-13.2kV T - Line | C053155 | 0 | 84,000 | 112,000 | 100,000 | 0 | 296,000 |
| | | New West Sweden Station - Line Work | C053159 | 0 | 0 | 0 | 25,000 | 475,000 | 500,000 |
| | | Ohio St Station-access rd easement | C060190 | 100,000 | 0 | 0 | 0 | 0 | 100,000 |
| | | Ohio Street new 115 - 34.5kV sub | C055263 | 500,000 | 6,000,000 | 4,156,000 | 0 | 0 | 10,656,000 |
| | | Patroon sub relay upgrade line #6 | C054269 | 131,750 | 63,750 | 0 | 0 | 0 | 195,500 |
| | | Porter #3 / #7 Install Reactors | C060241 | 400,000 | 800,000 | 0 | 0 | 0 | 1,200,000 |
| | | Queensbury TB3 & TB4 upgrades (sub) | C036822 | 1,000,000 | 0 | 0 | 0 | 0 | 1,000,000 |
| | | Randall Rd Transmission Line | C043672 | 148,500 | 716,830 | 712,500 | 0 | 0 | 1,577,830 |
| | | Reactive Comp prog in NE Reg NRRP | C035773 | 0 | 0 | 0 | 0 | 200,000 | 200,000 |
| | | Reactor at Unionville Sub for #7	 | C056065 | 801,500 | 0 | 0 | 0 | 0 | 801,500 |
| | | Recond 1/2 Mile of Dewitt-Tilden 19 | C053143 | 0 | 0 | 100,000 | 826,000 | 0 | 926,000 |
| | | Recond Cortland Clarks Corners | C053141 | 0 | 0 | 25,000 | 394,400 | 0 | 419,400 |
| | | Re-route New Scotland #7	 Lines | C053223 | 393,000 | 0 | 0 | 0 | 0 | 393,000 |
| | | Riverside-Reynolds Rd#4 Forbes Tap | C043592 | 74,250 | 1,527,570 | 990,000 | 0 | 0 | 2,591,820 |
| | | Rotterdam - Menands Recond 12 miles | C060243 | 0 | 0 | 0 | 150,000 | 1,000,000 | 1,150,000 |
| | | Rotterdam-TB6/7 Reconnect & R86 Bus | C060255 | 50,000 | 1,600,000 | 450,000 | 0 | 0 | 2,100,000 |
| | | Sanborn upgrade 115 - 34.5kV transf | C044361 | 2,000,000 | 44,279 | 0 | 0 | 0 | 2,044,279 |
| | | Sawyer Fourth 230-23kV Bank | C053147 | 0 | 110,000 | 732,260 | 750,120 | 732,260 | 2,324,640 |
| | | Schoharie substation reconfiguratio | C046494 | 0 | 0 | 0 | 914,747 | 938,550 | 1,853,296 |
| | | SECOND 115 KV BUS TIE AT LOCKPORT | C031482 | 60,000 | 0 | 0 | 0 | 0 | 60,000 |
| | | Sodeman Rd Install New taps | C043755 | 0 | 147,000 | 490,000 | 0 | 0 | 637,000 |
| | | Spier Rotterdam NEW Line | C031418 | 770,000 | 0 | 0 | 0 | 0 | 770,000 |
| | | Spier-2nd bus tie brkr/upgr #5 bus | C060244 | 80,000 | 275,000 | 0 | 0 | 0 | 355,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|-------------------------------------|---------|-------------------------------------|-----------|-------------|-------------|-------------|-------------|-------------|-------------|
| | | Taps to 115 kV new Cicero Sub | C050939 | 24,000 | 24,000 | 426,000 | 120,000 | 0 | 594,000 |
| | | Terminal Station Relocation TLine | C059672 | 0 | 200,000 | 1,200,000 | 600,000 | 0 | 2,000,000 |
| | | Ticonderoga Cap Bank | C060254 | 50,000 | 1,600,000 | 200,000 | 0 | 0 | 1,850,000 |
| | | TP Mortimer Second Bus tie | C050696 | 563,022 | 150,400 | 0 | 0 | 0 | 713,422 |
| | | TP Reconductor line #181 | C050744 | 100,000 | 1,000,000 | 23,000,000 | 20,000,000 | 5,000,000 | 49,100,000 |
| | | TP West Golah Substation | C050695 | 250,000 | 800,000 | 5,730,000 | 500,000 | 0 | 7,280,000 |
| | | Trans Study Budgetary Reserve NY | C008376 | 150,000 | 150,000 | 150,000 | 150,000 | 150,000 | 750,000 |
| | | Upgrade Niagara - Packard #195 | C029945 | 210,000 | 0 | 0 | 0 | 0 | 210,000 |
| | | Van Dyke 115-13.2 Sub Taps | C044173 | 623,000 | 0 | 0 | 0 | 0 | 623,000 |
| | | W. Ashville sub 115kV In 160 tap | C043832 | 7,823 | 1,914 | 1,076 | 206,098 | 0 | 216,910 |
| | | W. Ashville substation TxT | C043833 | 641,732 | 354,089 | 562,000 | 3,099,875 | 0 | 4,657,696 |
| | | West Hamlin 82 TXT Line | C048901 | 85,000 | 88,000 | 0 | 0 | 0 | 173,000 |
| | | Youngs St Sta 214 -115kV tap- Tline | C054963 | 0 | 50,400 | 80,800 | 15,000 | 0 | 146,200 |
| TO Led System Studies Total | | | | 77,525,398 | 57,756,074 | 75,713,683 | 42,673,438 | 11,950,605 | 265,619,198 |
| System Capacity & Performance Total | | | | 93,431,758 | 58,616,074 | 76,713,843 | 57,673,438 | 11,950,605 | 298,385,718 |
| Grand Total | | | | 166,835,000 | 172,000,000 | 189,000,000 | 206,000,000 | 210,000,000 | 943,835,000 |

Exhibit 2 - Sub-Transmission Capital Investment Plan

2015 NY Capital Investment Plan

| pending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|-------------------|-------------------|-------------------------------------|-----------|---------|---------|-----------|-----------|-----------|-----------|
| Asset Condition | Asset Replacement | 69kV supply to Market Hill retireme | C046368 | 0 | 0 | 0 | 0 | 1,000 | 1,000 |
| | | Amsterdam 69 KV reconfig and LB SWs | C049299 | 200,000 | 0 | 0 | 0 | 0 | 200,000 |
| | | Beck - Harper L106 Removal | C036196 | 1,000 | 0 | 0 | 0 | 0 | 1,000 |
| | | Buffalo Station 122 Rebuild - 23kV | CD00780 | 15,000 | 12,000 | 139,000 | 83,000 | 11,000 | 260,000 |
| | | Buffalo Station 42 Rebuild - SubT L | C046853 | 0 | 30,000 | 500,000 | 0 | 0 | 530,000 |
| | | Cuyler#24 SubT tap-Sub Replacement | C060019 | 20,000 | 100,000 | 0 | 0 | 0 | 120,000 |
| | | Dake Hill-W. Salamanca 816-34.5kv | C046469 | 0 | 0 | 520,000 | 2,400,000 | 480,000 | 3,400,000 |
| | | Fort Covington-Malone 26-34.5kV | C050197 | 0 | 0 | 0 | 565,000 | 565,000 | 1,130,000 |
| | | Galleria Mall - Switchgear Replmnts | C058985 | 600,000 | 600,000 | 600,000 | 0 | 0 | 1,800,000 |
| | | Hartfield-S. Dow 859-Relocate Part | C052209 | 100,000 | 0 | 830,000 | 1,245,000 | 0 | 2,175,000 |
| | | Homer Hill-Ceres 809-34.5kv retire | CD00825 | 1,000 | 0 | 0 | 0 | 0 | 1,000 |
| | | L226 - Extend line to N Lville Sta | C015766 | 0 | 0 | 0 | 35,000 | 623,000 | 658,000 |
| | | LN404 Moutain - Sanborn reconductor | CD01276 | 0 | 0 | 581,000 | 0 | 0 | 581,000 |
| | | Lockport - Maple Rd L92E&W Removal | C036200 | 1,000 | 0 | 0 | 0 | 0 | 1,000 |
| | | M&T bank Tap 701-34.5kv | C046462 | 895,000 | 0 | 0 | 0 | 0 | 895,000 |
| | | N. Ashford-Nuclear Fuel Services 81 | C046467 | 201,000 | 0 | 0 | 0 | 0 | 201,000 |
| | | N.Lakeville - Ridge LN 218 Refurbis | C046766 | 0 | 0 | 60,000 | 572,000 | 531,000 | 1,163,000 |
| | | Nassau-Hudson 9, 34.5kV CIVIL ACR | C060106 | 450,000 | 0 | 0 | 0 | 0 | 450,000 |
| | | Oakfield - Caledonia LN201 reconduc | C046707 | 0 | 0 | 0 | 50,000 | 2,316,000 | 2,366,000 |
| | | Ohio-Ridge 613-34.5kv | C046453 | 0 | 27,000 | 850,000 | 9,000 | 0 | 886,000 |
| | | Phillips-Barker 301-34.5kv | C046465 | 0 | 70,000 | 1,286,000 | 2,340,000 | 0 | 3,696,000 |
| | | Phillips-Telegraph 304-34.5kv | C046466 | 0 | 0 | 0 | 0 | 83,000 | 83,000 |
| | | Rankine - Adams - 25 Cycle Line Ret | C046620 | 0 | 0 | 5,000 | 5,000 | 0 | 10,000 |

2015 NY Capital Investment Plan

| pending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|-------------------|----------------------------------|-------------------------------------|-----------|-----------|-----------|-----------|-----------|-----------|------------|
| | | Refurbish H-Lns 27h,28h,33h pt 1 | C046470 | 550,000 | 0 | 0 | 0 | 0 | 550,000 |
| | | Shaleton-Ridge 610, Station 207 Tap | C046779 | 0 | 0 | 76,000 | 1,200,000 | 0 | 1,276,000 |
| | | Solvay 26 | C046438 | 0 | 0 | 119,000 | 551,000 | 627,000 | 1,297,000 |
| | | Sta 122 taps 622/623-23kv | C046461 | 0 | 26,000 | 481,000 | 9,000 | 0 | 516,000 |
| | | Station 126 taps 33h/34h-23kv | C046450 | 0 | 0 | 0 | 0 | 26,000 | 26,000 |
| | | W. Portland-Sherman 867-34.5kv | C046468 | 0 | 1,813,000 | 2,907,000 | 25,000 | 0 | 4,745,000 |
| | Asset Replacement Total | | | 3,034,000 | 2,678,000 | 8,954,000 | 9,089,000 | 5,263,000 | 29,018,000 |
| | Blanket | CNY Sub Trans-Line Asset Replace | CNC0075 | 203,000 | 206,000 | 209,000 | 212,000 | 215,000 | 1,045,000 |
| | | ENY Sub Trans-Line Asset Replace | CNE0075 | 213,000 | 216,000 | 219,000 | 222,000 | 225,000 | 1,095,000 |
| | | WNY Sub Trans-Line Asset Replace | CNW0075 | 315,000 | 320,000 | 325,000 | 330,000 | 335,000 | 1,625,000 |
| | Blanket Total | | | 731,000 | 742,000 | 753,000 | 764,000 | 775,000 | 3,765,000 |
| | Denergized T Line Strategy | Lisbon-Heuvelton #25 Removal | C025079 | 0 | 1,000 | 0 | 0 | 0 | 1,000 |
| | | Mortimer-Solvay 5-69kV - remove | C049335 | 1,000 | 1,000 | 0 | 0 | 0 | 2,000 |
| | | S Niagara Falls Sub-T Line Remove | C053426 | 0 | 1,000 | 1,000 | 1,000 | 1,000 | 4,000 |
| | Denergized T Line Strategy Total | | | 1,000 | 3,000 | 1,000 | 1,000 | 1,000 | 7,000 |
| | Sub T Overhead Line | Amsterdam-Rotterdam3/4 Relocation | C033182 | 720,000 | 2,223,000 | 0 | 0 | 0 | 2,943,000 |
| | | Bagdad-Dake Hill 815-34.5kV refurb. | C050292 | 0 | 0 | 0 | 50,000 | 765,000 | 815,000 |
| | | Ballston-Mechanicville 6-34.5kv | C046472 | 167,000 | 1,632,000 | 1,206,000 | 0 | 0 | 3,005,000 |
| | | Ballston-Shore Rd-Rosa Rd 5 and 8-3 | C046457 | 0 | 0 | 0 | 97,000 | 553,000 | 650,000 |
| | | Barker-Lyndonville 301-34.5kV | C052511 | 0 | 0 | 43,000 | 808,000 | 2,040,000 | 2,891,000 |
| | | Bethlehem-Selkirk 5-34.5kV | C048817 | 390,000 | 0 | 0 | 0 | 0 | 390,000 |
| | | Bristol Hill-Phoenix 23-34.5kv | C046474 | 0 | 0 | 77,000 | 620,000 | 484,000 | 1,181,000 |
| | | Burnett-Headson 34-34.5kV | C050199 | 0 | 0 | 26,000 | 151,000 | 449,000 | 626,000 |

2015 NY Capital Investment Plan

| pending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|-------------------|---------|-------------------------------------|-----------|-----------|---------|-----------|-----------|-----------|-----------|
| | | Callanan Tap - Rebuild exist 34.5ln | C046641 | 236,000 | 236,000 | 2,000,000 | 0 | 0 | 2,472,000 |
| | | Carthage-N. Carthage-Deferiet 23kv | C046435 | 0 | 0 | 0 | 0 | 45,000 | 45,000 |
| | | Carthage-Taylorville 21/22/26-23kv | C046436 | 0 | 0 | 0 | 0 | 55,000 | 55,000 |
| | | Cottrell Paper Tap 11-34.5kv | C046443 | 0 | 394,000 | 0 | 0 | 0 | 394,000 |
| | | Deerfield-Schuyler 22-46kV | C050288 | 350,000 | 826,000 | 0 | 0 | 0 | 1,176,000 |
| | | Deerfield-whitesboro 26-46kv | C046459 | 0 | 0 | 151,097 | 1,900,000 | 0 | 2,051,097 |
| | | Elbridge-Jewitt 31-34.5kV refurb | C050959 | 0 | 0 | 0 | 129,000 | 1,097,000 | 1,226,000 |
| | | Elbridge-Marcellus 30 Refurbishment | C054927 | 0 | 0 | 75,000 | 400,000 | 575,000 | 1,050,000 |
| | | Epratah-Caroga 2-23kv | C046456 | 0 | 0 | 0 | 33,000 | 682,000 | 715,000 |
| | | Hartfield-S. Dow 859 Refurbish | C033180 | 2,096,000 | 0 | 0 | 0 | 0 | 2,096,000 |
| | | Homer Hill-Nile 811-34.5kV | C050326 | 0 | 0 | 47,000 | 839,000 | 14,000 | 900,000 |
| | | Homer Hill-Nile 811-34.5kv ION | CD01216 | 174,000 | 0 | 0 | 0 | 0 | 174,000 |
| | | LHH-Mallory 22-34.5kv | C046441 | 0 | 0 | 0 | 54,000 | 1,234,000 | 1,288,000 |
| | | Lyndonville-Medina 301-34.5kV | C052512 | 0 | 0 | 0 | 68,000 | 2,635,000 | 2,703,000 |
| | | Mallory-Cicero L33-34.5 kV line Ref | C046681 | 0 | 25,000 | 1,662,000 | 1,600,000 | 0 | 3,287,000 |
| | | Maplewood-Latham#9 Mohawk View taps | CD00832 | 150,000 | 0 | 0 | 0 | 0 | 150,000 |
| | | Maplewood-Menands 17/18 d/c-34.5kv | C046432 | 0 | 0 | 0 | 56,000 | 511,000 | 567,000 |
| | | Mech-Schuylerville 4-34.5kV refurb | C050323 | 0 | 0 | 0 | 129,000 | 2,580,000 | 2,709,000 |
| | | Menands-Liberty 9 Relocation | C033172 | 402,000 | 151,000 | 0 | 0 | 0 | 553,000 |
| | | MV-Trenton-Deerfield 21/27-46kv | C046464 | 789,000 | 0 | 0 | 0 | 0 | 789,000 |
| | | N. Angola-Bagdad 857-34.5kV Catt. | C050289 | 0 | 0 | 0 | 23,000 | 558,000 | 581,000 |
| | | Nassau-Hudson #9, 34.5kV Refurb | C058581 | 0 | 50,000 | 850,000 | 0 | 0 | 900,000 |
| | | Nile-S. Wellsville 812- | C051765 | 0 | 0 | 0 | 0 | 50,000 | 50,000 |

2015 NY Capital Investment Plan

| pending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|-------------------|---------|-------------------------------------|-----------|---------|---------|---------|---------|---------|-----------|
| | | 34.5kV refur | | | | | | | |
| | | Queensbury-Henry Street 14-34.5kv | C046442 | 0 | 0 | 0 | 28,000 | 398,000 | 426,000 |
| | | Refurbish H lines 26H, 33H, 34H | C048911 | 0 | 0 | 0 | 0 | 28,000 | 28,000 |
| | | Refurbish H Lns 26H, 34H | C048910 | 28,000 | 0 | 850,000 | 9,000 | 0 | 887,000 |
| | | Refurbish H-Lns 27h,25h,33h,36h | C048909 | 28,000 | 542,000 | 7,000 | 0 | 0 | 577,000 |
| | | Re-furbish Teall 25/Woodard 24-34.5 | C046446 | 50,000 | 50,000 | 623,000 | 496,000 | 0 | 1,219,000 |
| | | Relocate S. Dow-Poland 865-34.5kV | C050177 | 200,000 | 0 | 856,625 | 856,625 | 0 | 1,913,250 |
| | | Remove Woodard 24/Teall 25 partial | C052065 | 0 | 0 | 1,000 | 0 | 0 | 1,000 |
| | | Rotterdam-Scotia-Rosa Road 32/6 - | C046455 | 0 | 65,000 | 554,000 | 9,000 | 0 | 628,000 |
| | | S2830 Lewiston-Mountain 405, 34.5kV | C056427 | 0 | 0 | 50,000 | 100,000 | 0 | 150,000 |
| | | Scotia-Rosa Rd 6, 34.5kV Refurb | C055164 | 0 | 50,000 | 425,000 | 150,000 | 0 | 625,000 |
| | | Solvay 35, 34.5kV Refurb | C056385 | 0 | 0 | 50,000 | 300,000 | 0 | 350,000 |
| | | Solvay/Woodard-Ash st 27&27&28- 34. | C046439 | 0 | 0 | 0 | 73,000 | 538,000 | 611,000 |
| | | Tap to H&V Greenwich-34.5kv | C046477 | 0 | 10,000 | 610,000 | 0 | 0 | 620,000 |
| | | Taylorville-Effley 24-23kv | C046437 | 0 | 0 | 36,708 | 222,804 | 0 | 259,512 |
| | | Teall-Headson L31-L29-34.5 kV line | C046686 | 0 | 0 | 0 | 850,000 | 0 | 850,000 |
| | | Tonawanda Lines 601-604-23kv | C046451 | 0 | 0 | 38,000 | 350,000 | 10,000 | 398,000 |
| | | Tonawanda Lines 622-624-23kv | C046452 | 0 | 0 | 24,000 | 121,000 | 350,000 | 495,000 |
| | | Trenton-Prospect 23-46kv | C046448 | 0 | 0 | 36,708 | 457,559 | 0 | 494,267 |
| | | Trenton-Whitesboro 25, 34.5kV | C058579 | 50,000 | 875,000 | 0 | 0 | 0 | 925,000 |
| | | Union-Ausable Forks 36-46kV ref | C050320 | 0 | 0 | 0 | 0 | 97,000 | 97,000 |
| | | Union-Franklin 34-46kV refurb. | C052510 | 300,000 | 0 | 0 | 0 | 0 | 300,000 |
| | | Union-Lake Clear 35-46kV refurb | C050324 | 0 | 0 | 0 | 0 | 129,000 | 129,000 |

2015 NY Capital Investment Plan

| pending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|-------------------|-------------------------------------|-------------------------------------|-----------|-----------|-----------|------------|------------|------------|------------|
| | | Varick-Bristol Hill 202-34.5kv | C046460 | 0 | 0 | 0 | 52,000 | 748,000 | 800,000 |
| | | W. Milton Tap-34.5kv new line | CD00898 | 713,000 | 1,236,000 | 466,000 | 0 | 0 | 2,415,000 |
| | | W. Salamanca-Homer Hill 805-34.5kv | C050293 | 0 | 0 | 0 | 0 | 47,000 | 47,000 |
| | | Waterport tap 301-34.5kv | C052515 | 0 | 0 | 0 | 0 | 68,000 | 68,000 |
| | | West Portland-Sherman 867 Relocatio | C055118 | 100,000 | 0 | 906,000 | 250,000 | 0 | 1,256,000 |
| | | Woodard 24/Teall 25 Refurb N. -190 | c060445 | 0 | 50,000 | 0 | 0 | 500,000 | 550,000 |
| | | Woodard 24/Teall 25-34.5kv | C046447 | 100,000 | 0 | 0 | 0 | 0 | 100,000 |
| | | Woodard 28-34.5kv | C046440 | 0 | 0 | 48,659 | 448,169 | 13,658 | 510,486 |
| | | Woodard 29-34.5kv | C046473 | 150,000 | 0 | 75,000 | 751,000 | 1,425,000 | 2,401,000 |
| | | Woodard-Teall 32-34.5kv refurbish | C050322 | 0 | 0 | 0 | 0 | 129,000 | 129,000 |
| | | Yahnundasis-Clinton 24 - 46kv | C046449 | 40,000 | 250,000 | 0 | 374,000 | 618,000 | 1,282,000 |
| | | Yahnundasis-Clinton 27, 46kV | C055143 | 0 | 0 | 50,000 | 500,000 | 150,000 | 700,000 |
| | | Sub T Overhead Line Total | | 7,233,000 | 8,665,000 | 11,844,797 | 13,355,157 | 19,575,658 | 60,673,612 |
| | Substation Indoor | Buffalo Station 29 Rebuild - 23 kV | C006724 | 40,000 | 0 | 0 | 0 | 0 | 40,000 |
| | | Buffalo Station 30 - Rebuild - 23kV | C015755 | 0 | 0 | 0 | 0 | 10,000 | 10,000 |
| | | Buffalo Station 37 Rebuild - 23 kV | C033471 | 0 | 2,000 | 81,000 | 54,000 | 0 | 137,000 |
| | | Buffalo Station 53 Rebuild - 23 kV | C046928 | 0 | 0 | 0 | 30,000 | 150,000 | 180,000 |
| | | Buffalo Station 59 Rebuild - 23 kV | C033472 | 0 | 0 | 10,000 | 93,000 | 62,000 | 165,000 |
| | Substation Indoor Total | | | 40,000 | 2,000 | 91,000 | 177,000 | 222,000 | 532,000 |
| | Sub T Underground Cable Replacement | 701 Line - Kensington Expwy UG | C053243 | 255,000 | 0 | 0 | 0 | 0 | 255,000 |
| | | Buffalo 23kV UG Cable replacement | C052483 | 0 | 150,000 | 3,000,000 | 3,000,000 | 3,000,000 | 9,150,000 |
| | | Partridge-Ave A # 5 Cable Replaceme | C036273 | 1,324,000 | 452,000 | 0 | 0 | 0 | 1,776,000 |
| | | Solvay Ash 27 Cable Repl SubT | C032147 | 0 | 657,000 | 617,000 | 733,000 | 0 | 2,007,000 |

2015 NY Capital Investment Plan

| pending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|---------------------------------------|---|-------------------------------------|------------|------------|------------|------------|------------|-------------|------------|
| | | Solvay-Ash #28 34.5kV Replace Cable | C045629 | 0 | 830,000 | 639,000 | 0 | 0 | 1,469,000 |
| | Sub T Underground Cable Replacement Total | | | 1,579,000 | 2,089,000 | 4,256,000 | 3,733,000 | 3,000,000 | 14,657,000 |
| | De-energized T-Line Strategy | Balstn-Randall-W. Milton 34.5kV rem | C048968 | 0 | 0 | 0 | 1,000 | 0 | 1,000 |
| | | Bennett Bridge-Solvay 6-69kV-remove | C048824 | 0 | 30,000 | 30,000 | 0 | 0 | 60,000 |
| | | Castleton Greenbush Line 5 | C036365 | 1,000 | 0 | 0 | 0 | 0 | 1,000 |
| | | Harper-Sta 104 32-12kv | C046615 | 1,000 | 0 | 0 | 0 | 0 | 1,000 |
| | | Jeliff Tap 34.5kV -remove | C049097 | 1,000 | 0 | 0 | 0 | 0 | 1,000 |
| | | New Gardenville Substation-SubT Lin | CD00636 | 30,000 | 0 | 0 | 0 | 0 | 30,000 |
| | | Rankine-Harper 16/17 and Adams -Har | C046514 | 1,000 | 0 | 0 | 0 | 0 | 1,000 |
| | | Remove Atlantic Ref Tap 23-34.5kV | C049338 | 1,000 | 0 | 0 | 0 | 0 | 1,000 |
| | | Remove School St. - Watervliet 3/4 | C046512 | 1,000 | 0 | 0 | 0 | 0 | 1,000 |
| | | Station 150 Tap 701-34.5kV remove | C049499 | 1,000 | 0 | 0 | 0 | 0 | 1,000 |
| | | Terminal Sta B - R48, R46, R25 Rem. | C036204 | 0 | 2,000 | 2,000 | 0 | 0 | 4,000 |
| | | Terminal Sta C - C12 & C14 Removal | C036203 | 3,000 | 0 | 0 | 0 | 0 | 3,000 |
| | | Terminal-Cornelia 43 13.2kV-remove | C049037 | 1,000 | 0 | 0 | 0 | 0 | 1,000 |
| | De-energized T-Line Strategy Total | | | 41,000 | 32,000 | 32,000 | 1,000 | 0 | 106,000 |
| | Inspection & Maintenance | I&M - NC Sub-T Line Work From Insp | C026166 | 2,323,821 | 2,300,583 | 2,277,577 | 2,254,801 | 2,232,253 | 11,389,035 |
| | | I&M - NE Sub-T Line Work From Insp | C026165 | 1,632,377 | 1,616,053 | 1,599,893 | 1,583,894 | 1,568,055 | 8,000,272 |
| | | I&M - NW Sub-T Line Work From Insp | C026167 | 2,375,265 | 2,351,512 | 2,327,997 | 2,304,717 | 2,281,670 | 11,641,161 |
| | Inspection & Maintenance Total | | | 6,331,463 | 6,268,148 | 6,205,467 | 6,143,412 | 6,081,978 | 31,030,468 |
| Asset Condition Total | | | 18,990,463 | 20,479,148 | 32,137,264 | 33,263,569 | 34,918,636 | 139,789,080 | |
| Customer Requests/Public Requirements | Blanket | CNY Sub Trans-Line New Business | CNC0071 | 51,000 | 52,000 | 53,000 | 54,000 | 55,000 | 265,000 |
| | | CNY Sub Trans-Line Public Require | CNC0072 | 76,000 | 77,000 | 78,000 | 79,000 | 80,000 | 390,000 |

2015 NY Capital Investment Plan

| pending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|---|-----------------------------------|-------------------------------------|-----------|-----------|-----------|-----------|-----------|-----------|------------|
| | | ENY Sub Trans-Line New Business | CNE0071 | 82,000 | 84,000 | 86,000 | 88,000 | 90,000 | 430,000 |
| | | ENY Sub Trans-Line Public Require | CNE0072 | 10,000 | 10,000 | 10,000 | 10,000 | 10,000 | 50,000 |
| | | NY Central Sub T Line Third Party | CNC0078 | 51,000 | 52,000 | 53,000 | 54,000 | 55,000 | 265,000 |
| | | NY East Sub T Line Third Party | CNE0078 | 15,000 | 15,000 | 15,000 | 15,000 | 15,000 | 75,000 |
| | | NY West Sub T Line Third Party | CNW0078 | 10,000 | 10,000 | 10,000 | 10,000 | 10,000 | 50,000 |
| | | WNY Sub Trans-Line New Business | CNW0071 | 63,000 | 66,000 | 69,000 | 72,000 | 75,000 | 345,000 |
| | | WNY Sub Trans-Line Public Require | CNW0072 | 63,000 | 66,000 | 69,000 | 72,000 | 75,000 | 345,000 |
| | Blanket Total | | | 421,000 | 432,000 | 443,000 | 454,000 | 465,000 | 2,215,000 |
| | New Business | 34.5kV tap to Intergrow Greenhouse | C052513 | 10,000 | 0 | 0 | 0 | 0 | 10,000 |
| | | East - West Medical Corridor Cable | CD00823 | 15,000 | 0 | 0 | 0 | 0 | 15,000 |
| | | Extend LN 611 & 612 to Riverbend | C054665 | 0 | 21,000 | 85,000 | 2,027,000 | 0 | 2,133,000 |
| | | Samaritan Hospital Sub-T Service | C053783 | 1,000 | 0 | 0 | 0 | 0 | 1,000 |
| | | TxD RESERVE for New Business Commer | C046913 | 1,049,055 | 1,049,055 | 1,099,010 | 1,149,450 | 1,149,450 | 5,496,020 |
| | New Business Total | | | 1,075,055 | 1,070,055 | 1,184,010 | 3,176,450 | 1,149,450 | 7,655,020 |
| | Public Requirements | Cortland 20,34.5kV Suite-Kote Reloc | C057780 | 1,000 | 0 | 0 | 0 | 0 | 1,000 |
| | | DOTR NYSRt28 White Lk-McKeever SubT | C034722 | 0 | 0 | 0 | 50,000 | 1,598,000 | 1,648,000 |
| | | UG 404 Line Cable Replacement | C053704 | 0 | 0 | 680,000 | 0 | 0 | 680,000 |
| | Public Requirements Total | | | 1,000 | 0 | 680,000 | 50,000 | 1,598,000 | 2,329,000 |
| | T_Customer Interconnections | Skaneateles 34.5kV Tap frm NYSEG508 | C058559 | 100,000 | 0 | 0 | 0 | 0 | 100,000 |
| | T_Customer Interconnections Total | | | 100,000 | 0 | 0 | 0 | 0 | 100,000 |
| Customer Requests/Public Requirements Total | | | | 1,597,055 | 1,502,055 | 2,307,010 | 3,680,450 | 3,212,450 | 12,299,020 |
| Damage/Failure | Blanket | CNY Sub Trans-Line Damage Failure | CNC0073 | 406,000 | 412,000 | 418,000 | 424,000 | 430,000 | 2,090,000 |
| | | ENY Sub Trans-Line | CNE0073 | 386,000 | 392,000 | 398,000 | 404,000 | 410,000 | 1,990,000 |

2015 NY Capital Investment Plan

| pending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|-------------------------------|----------------------------|--------------------------------------|-----------|-----------|-----------|-----------|-----------|-----------|------------|
| | | Damage Failure | | | | | | | |
| | | WNY Sub Trans-Line Damage Failure | CNW0073 | 2,030,000 | 2,060,000 | 2,091,000 | 2,122,000 | 2,154,000 | 10,457,000 |
| | Blanket Total | | | 2,822,000 | 2,864,000 | 2,907,000 | 2,950,000 | 2,994,000 | 14,537,000 |
| | Damage Failure Other | NY_CD_38kV_FPC/EEI-Swgr-Part 1 | C058959 | 600,000 | 600,000 | 600,000 | 600,000 | 0 | 2,400,000 |
| | Damage Failure Other Total | | | 600,000 | 600,000 | 600,000 | 600,000 | 0 | 2,400,000 |
| Damage/Failure Total | | | | 3,422,000 | 3,464,000 | 3,507,000 | 3,550,000 | 2,994,000 | 16,937,000 |
| System Capacity & Performance | Blanket | CNY Sub Trans-Line Load Relief | CNC0077 | 10,000 | 10,000 | 10,000 | 10,000 | 10,000 | 50,000 |
| | | CNY Sub Trans-Line Reliability | CNC0076 | 102,000 | 104,000 | 106,000 | 108,000 | 110,000 | 530,000 |
| | | ENY Sub Trans-Line Load Relief | CNE0077 | 1,000 | 1,000 | 1,000 | 1,000 | 1,000 | 5,000 |
| | | ENY Sub Trans-Line Reliability | CNE0076 | 51,000 | 52,000 | 53,000 | 54,000 | 55,000 | 265,000 |
| | | WNY Sub Trans-Line Load Relief | CNW0077 | 10,000 | 10,000 | 10,000 | 10,000 | 10,000 | 50,000 |
| | | WNY Sub Trans-Line Reliability | CNW0076 | 100,000 | 310,000 | 315,000 | 320,000 | 325,000 | 1,370,000 |
| | Blanket Total | | | 274,000 | 487,000 | 495,000 | 503,000 | 511,000 | 2,270,000 |
| | Load Relief | Buffalo 23kV Rec.-Sen. 1,2,3,19,31S | C048826 | 918,000 | 0 | 0 | 0 | 0 | 918,000 |
| | | Buffalo 23kV Reconductor - Huntley2 | C028893 | 59,000 | 1,247,000 | 0 | 0 | 0 | 1,306,000 |
| | | Eden Switch Structure - SubT | C052023 | 15,000 | 75,000 | 300,000 | 60,000 | 0 | 450,000 |
| | | Extend of line 612 to STA42 | C055350 | 341,000 | 0 | 0 | 0 | 0 | 341,000 |
| | | Golah Avon 217 line reconductoring | C036054 | 0 | 0 | 50,000 | 676,000 | 187,000 | 913,000 |
| | | Install parallel cable of Newark- Ma | CD01121 | 0 | 0 | 0 | 64,000 | 800,000 | 864,000 |
| | | Mallory-Cicero 33-34.5kV-relocation | C054507 | 150,000 | 850,000 | 0 | 0 | 0 | 1,000,000 |
| | | Ohio St station - SubT lines | C055304 | 85,000 | 856,000 | 270,000 | 0 | 0 | 1,211,000 |
| | | Station 74 23kV supply to MITS | C055269 | 12,000 | 33,000 | 0 | 0 | 0 | 45,000 |
| | | Two Mile Creek Rd Sta-SubT | C052509 | 192,000 | 0 | 0 | 0 | 0 | 192,000 |

2015 NY Capital Investment Plan

| pending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|-------------------------------------|-------------------|-------------------------------------|------------|------------|------------|------------|------------|-------------|-----------|
| | | TxD RESERVE for Load Relief Unident | C046912 | 0 | 0 | 0 | 0 | 745,000 | 745,000 |
| | | Van Dyke Station - Beth-Delmar #6 I | C046482 | 0 | 0 | 0 | 10,000 | 0 | 10,000 |
| | | Van Dyke-DelmarBypass exten rebuilt | C053683 | 162,000 | 0 | 0 | 0 | 0 | 162,000 |
| | Load Relief Total | | | 1,934,000 | 3,061,000 | 620,000 | 810,000 | 1,732,000 | 8,157,000 |
| | Reliability | Beck - Harper L105 Removal | C036195 | 1,000 | 0 | 0 | 0 | 0 | 1,000 |
| | | Gardenville-Blasdell L131/L132 Rem. | C036201 | 1,000 | 0 | 0 | 0 | 0 | 1,000 |
| | | Kenmore-Winspear 630/631-ref | C050318 | 0 | 0 | 37,000 | 350,000 | 0 | 387,000 |
| | | Line 216 Reconductoring | C051583 | 0 | 0 | 0 | 0 | 50,000 | 50,000 |
| | | LN863 Findley Lake - French Creek e | C046510 | 0 | 0 | 0 | 291,000 | 582,000 | 873,000 |
| | | W.Ashville substation TxD LN863 tap | C048152 | 0 | 19,000 | 0 | 50,000 | 0 | 69,000 |
| | | Reliability Total | | | 2,000 | 19,000 | 37,000 | 691,000 | 632,000 |
| | Sub T Automation | 223 Line Replace Sectionalizer | C054077 | 63,000 | 0 | 0 | 0 | 0 | 63,000 |
| | | 227 Line Replace Sectionalizer | C054078 | 63,000 | 0 | 0 | 0 | 0 | 63,000 |
| | | 312 Line Replace Sectionalizer | C054081 | 63,000 | 0 | 0 | 0 | 0 | 63,000 |
| | | 811 Line Replace Sectionalizer | C054083 | 63,000 | 0 | 0 | 0 | 0 | 63,000 |
| | | 857 Line Replace Sectionalizers | C054082 | 133,000 | 0 | 0 | 0 | 0 | 133,000 |
| | | MV- Trenton-Whitesboro 25 Switch | C058309 | 125,000 | 0 | 0 | 0 | 0 | 125,000 |
| | | Nassau-Hudson #9 - Reclosers | C057881 | 150,000 | 0 | 0 | 0 | 0 | 150,000 |
| | | WD - Install ScadaMates on the 301 | CD00474 | 124,000 | 0 | 0 | 0 | 0 | 124,000 |
| | | WD - Install ScadaMates on the 803 | CD00514 | 289,000 | 0 | 0 | 0 | 0 | 289,000 |
| | | Sub T Automation Total | | | 1,073,000 | 0 | 0 | 0 | 0 |
| System Capacity & Performance Total | | | 3,283,000 | 3,567,000 | 1,152,000 | 2,004,000 | 2,875,000 | 12,881,000 | |
| Grand Total | | | 27,292,518 | 29,012,203 | 39,103,274 | 42,498,019 | 44,000,086 | 181,906,100 | |

Exhibit 3 – Distribution Capital Investment Plan

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|-------------------|--------------------------------------|-----------|---------|---------|-----------|-----------|---------|-----------|
| Asset Condition | Asset Replacement | *NR-81452-Jolly Island Grp-Upgrade | C049780 | 240,000 | 0 | 0 | 0 | 0 | 240,000 |
| | | *NR-81452-Lake of the Isles-Upgrade | C049782 | 0 | 0 | 0 | 400,000 | 0 | 400,000 |
| | | *NR-N Gouverneur 98352-Lead Mine Rd | C049635 | 170,000 | 0 | 0 | 0 | 0 | 170,000 |
| | | *NR-Westville 88561-Donovan Rd | C010695 | 255,000 | 0 | 0 | 0 | 0 | 255,000 |
| | | Blue Stores 30351 - Pleasant Vale | C051985 | 0 | 0 | 0 | 85,000 | 0 | 85,000 |
| | | Broadway Network Retirement | C046712 | 0 | 8,000 | 120,000 | 0 | 0 | 128,000 |
| | | Buffalo Station 17 - 25 Cycle Feeder | C046617 | 3,000 | 0 | 0 | 0 | 0 | 3,000 |
| | | Buffalo Station 12 - 25 Cycle Retir | CD00969 | 0 | 15,000 | 0 | 0 | 0 | 15,000 |
| | | Buffalo Station 122 Rebuild - Line | CD00779 | 0 | 39,000 | 470,000 | 278,000 | 39,000 | 826,000 |
| | | Buffalo Station 122 Rebuild - Sub | CD00782 | 904,000 | 64,000 | 454,000 | 3,265,000 | 824,000 | 5,511,000 |
| | | Buffalo Station 14 - 25 Cycle Feede | C046616 | 3,000 | 0 | 0 | 0 | 0 | 3,000 |
| | | Buffalo Station 14 - 25 Cycle Retir | CD00974 | 0 | 2,000 | 0 | 0 | 0 | 2,000 |
| | | Buffalo Station 20 - 25 Cycle Feede | C046618 | 0 | 0 | 1,000 | 1,000 | 0 | 2,000 |
| | | Buffalo Station 42 Rebuild - D Line | C046859 | 0 | 50,000 | 1,112,000 | 427,000 | 0 | 1,589,000 |
| | | Buffalo Station 42 Rebuild - D Stat | C046854 | 20,000 | 676,000 | 6,000,000 | 0 | 0 | 6,696,000 |
| | | Buffalo Station 72 - 25 Cycle Feede | C046619 | 3,000 | 0 | 0 | 0 | 0 | 3,000 |
| | | Burgoyne 51 - Rebuild Durkeetown Rd | CD00222 | 0 | 0 | 240,000 | 0 | 0 | 240,000 |
| | | Caledonia sub 44 - Line Relay Rep | C052444 | 0 | 32,495 | 56,988 | 0 | 0 | 89,483 |
| | | Canajoharie 03122 - Rebuild Rt 162 | C000329 | 0 | 0 | 4,000 | 451,000 | 0 | 455,000 |
| | | Church St 53 - West Line Rd Relocat | C054923 | 0 | 0 | 10,000 | 140,000 | 0 | 150,000 |
| | | CR_Syracuse_West St MH 2-5 U_051_Co | CD00489 | 0 | 80,000 | 0 | 0 | 0 | 80,000 |
| | | Crown Pt. 51 - Creek Rd Gap Closing | C048906 | 0 | 0 | 85,000 | 0 | 0 | 85,000 |
| | | Cuyler DLine - pole | C055354 | 290,000 | 122,000 | 0 | 0 | 0 | 412,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|-----------------------|---------|--|-----------|---------|---------|---------|-----------|-----------|-----------|
| | | mounted equip | | | | | | | |
| | | Delanson 51 - Route 7 Rebuild/Conve | C046424 | 723,000 | 0 | 0 | 0 | 0 | 723,000 |
| | | Delevan F1162 Steel Wire PIW | C056734 | 10,000 | 0 | 186,000 | 0 | 0 | 196,000 |
| | | F2761 Steel Wire PIW | C056621 | 10,000 | 0 | 300,000 | 0 | 0 | 310,000 |
| | | Grand St. 51 - Route 7 Gap Closing | CD00374 | 0 | 0 | 136,000 | 0 | 0 | 136,000 |
| | | Henry St 36 - River Crossing | C029432 | 0 | 0 | 421,000 | 0 | 0 | 421,000 |
| | | Karner - Patroon Reconducting 477 | C052303 | 0 | 0 | 24,000 | 119,000 | 132,000 | 275,000 |
| | | Karner - Patroon UG Getaways | C052307 | 0 | 0 | 24,000 | 292,000 | 381,000 | 697,000 |
| | | Karner - Ruth RD UG getaways | C052305 | 0 | 0 | 24,000 | 298,000 | 384,000 | 706,000 |
| | | Karner - Sand Creek Reconducting477 | C052304 | 0 | 0 | 24,000 | 204,000 | 242,000 | 470,000 |
| | | Karner - Sand Creek UG Getaways | C052306 | 0 | 0 | 24,000 | 111,000 | 150,000 | 285,000 |
| | | Karner 31707 Feeder Conversion | C049958 | 0 | 0 | 24,000 | 81,000 | 97,000 | 202,000 |
| | | Karner 31715 Feeder Conversion | C049964 | 0 | 0 | 24,000 | 122,000 | 130,000 | 276,000 |
| | | Karner 31716 Feeder Conversion | C049979 | 0 | 0 | 24,000 | 113,000 | 146,000 | 283,000 |
| | | Karner 31717 Feeder Conversion | C049980 | 0 | 0 | 24,000 | 117,000 | 120,000 | 261,000 |
| | | Karner 31718 Feeder Conversion | C049984 | 0 | 0 | 24,000 | 105,000 | 130,000 | 259,000 |
| | | Karner 31719 Feeder Conversion | C049982 | 0 | 0 | 24,000 | 81,000 | 97,000 | 202,000 |
| | | Karner- Ruth RD Reconducting 477 | C049989 | 0 | 0 | 24,000 | 235,000 | 304,000 | 563,000 |
| | | Karner-Pinebush Conversion | C052308 | 0 | 0 | 24,000 | 120,000 | 117,000 | 261,000 |
| | | Little River 4.8kV Sub Retirement | CD01311 | 1,000 | 0 | 0 | 0 | 0 | 1,000 |
| | | Machias F1362 Replace Steel Wire | C056619 | 10,000 | 150,000 | 0 | 0 | 0 | 160,000 |
| | | McCrea Station - New station - Geta | C046791 | 0 | 0 | 0 | 221,972 | 391,716 | 613,688 |
| | | McCrea Station - New station - Inst | C046790 | 0 | 55,000 | 409,000 | 1,921,000 | 2,282,000 | 4,667,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|---------|-------------------------------------|-----------|---------|-----------|------------|------------|-----------|-------------|
| | | Middleburgh 51 - Route 145 Extend/C | CD01010 | 0 | 0 | 756,000 | 0 | 0 | 756,000 |
| | | Minoa Upgrade Station Regulator | C046806 | 73,000 | 0 | 0 | 0 | 0 | 73,000 |
| | | MOD Switch "Whip Design" ARP | C051948 | 137,000 | 0 | 0 | 0 | 0 | 137,000 |
| | | MV- Poland 62258 Route 8 Reconducto | C046606 | 0 | 43,000 | 1,429,000 | 659,000 | 0 | 2,131,000 |
| | | | CD00883 | 19,000 | 0 | 0 | 0 | 0 | 19,000 |
| | | MV-Poland 62258 Route 8 Reconducto | CD00885 | 661,000 | 0 | 0 | 0 | 0 | 661,000 |
| | | MV-Poland 62258 Route 8 Reconductor | C046605 | 0 | 990,000 | 0 | 0 | 0 | 990,000 |
| | | MV-Rome 76254-HWY 49 Reconductor | C050005 | 0 | 0 | 400,000 | 0 | 0 | 400,000 |
| | | New Harper Substation D Line | C046417 | 0 | 0 | 108,000 | 544,000 | 584,000 | 1,236,000 |
| | | Niagara Falls Network Retirement | C046502 | 0 | 0 | 8,000 | 120,000 | 0 | 128,000 |
| | | Norton Street UG Civil Rebuild | C050138 | 0 | 451,000 | 0 | 0 | 0 | 451,000 |
| | | NR-E Watertown 81758-Spring ValleyD | CD01300 | 0 | 0 | 0 | 457,000 | 0 | 457,000 |
| | | NR-Fine 97866-NYS Hwy 3-Relocation | C049754 | 0 | 0 | 0 | 170,000 | 0 | 170,000 |
| | | NR-T.I.81452-County Route 100-Overl | CD01132 | 0 | 70,000 | 0 | 0 | 0 | 70,000 |
| | | NY GE Butyl Rubber PT Replacement | C051745 | 100,000 | 100,000 | 100,000 | 100,000 | 100,000 | 500,000 |
| | | Ohio St - Buffalo River Tunnel/Bore | C050400 | 50,000 | 2,150,000 | 0 | 0 | 0 | 2,200,000 |
| | | Reserve for Asset Replacement Unide | C046917 | 0 | 0 | -1,833,000 | 0 | 6,440,000 | 4,607,000 |
| | | | C046947 | 0 | 0 | -8,231,000 | -7,890,000 | 0 | -16,121,000 |
| | | Shore Rd 28185 - Saratoga Rd Conver | C054836 | 0 | 0 | 20,000 | 574,000 | 0 | 594,000 |
| | | State St Feeder Convension | C050697 | 0 | 50,000 | 525,000 | 625,000 | 0 | 1,200,000 |
| | | Station 01 - Remove 25 Cycle Feeder | C046624 | 1,800 | 340 | 0 | 0 | 0 | 2,140 |
| | | Station 05 - 25 Cycle Feeder 0528 R | C046623 | 1,800 | 290 | 0 | 0 | 0 | 2,090 |
| | | Station 06 - 25 Cycle Feeder Remova | C046622 | 1,800 | 230 | 0 | 0 | 0 | 2,030 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|-----------------------------------|-------------------------------------|-----------|-----------|-----------|-----------|-----------|------------|------------|
| | | Station 08 - 25 Cycle Feeder Remova | C046625 | 0 | 0 | 1,000 | 1,000 | 0 | 2,000 |
| | | Station 36 Voltage Reduction Replac | C049677 | 4,000 | 0 | 0 | 0 | 0 | 4,000 |
| | | Station 66 (Union Rd) Rebuild - DLi | CD00685 | 10,000 | 80,000 | 0 | 0 | 0 | 90,000 |
| | | Tonawanda - F7128 Removal | C036206 | 0 | 0 | 3,000 | 3,000 | 0 | 6,000 |
| | | Unionville Reactors - Fiber Install | C058519 | 250,000 | 0 | 0 | 0 | 0 | 250,000 |
| | | Western New York - Metering Upgrade | C046515 | 0 | 9,000 | 109,000 | 109,000 | 0 | 227,000 |
| | Asset Replacement Total | | | 3,951,400 | 5,237,355 | 3,711,988 | 4,659,972 | 13,090,716 | 30,651,431 |
| | Blanket | Cent NY-Dist-Asset Replace Blanket | CNC0017 | 2,030,000 | 2,060,000 | 2,091,000 | 2,122,000 | 2,154,000 | 10,457,000 |
| | | East NY-Dist-Asset Replace Blanket | CNE0017 | 2,132,000 | 2,164,000 | 2,196,000 | 2,229,000 | 2,262,000 | 10,983,000 |
| | | West NY-Dist-Asset Replace Blanket | CNW0017 | 2,842,000 | 2,885,000 | 2,928,000 | 2,972,000 | 3,017,000 | 14,644,000 |
| | | Blanket Total | | 7,004,000 | 7,109,000 | 7,215,000 | 7,323,000 | 7,433,000 | 36,084,000 |
| | Sub T Overhead Line | Dist Transfers-Ln#859 Hartfield-Dow | C047977 | 214,000 | 0 | 0 | 0 | 0 | 214,000 |
| | | L867 Underbuilt distribution | C057047 | 0 | 117,250 | 117,250 | 0 | 0 | 234,500 |
| | | M&T L701 - Transfer Dist Underbuilt | C054366 | 105,000 | 0 | 0 | 0 | 0 | 105,000 |
| | | Oakfield-Caledonia LN201 Dist Under | C047684 | 0 | 0 | 0 | 0 | 20,000 | 20,000 |
| | | Olean FDR 0461 Underbuilt Sub-T | C053382 | 50,000 | 0 | 0 | 0 | 0 | 50,000 |
| | Sub T Overhead Line Total | | | 369,000 | 117,250 | 117,250 | 0 | 20,000 | 623,500 |
| | Substation Circuit Switcher | Circuit Switcher Strategy Co:36 | C051845 | 60,000 | 0 | 0 | 0 | 0 | 60,000 |
| | Substation Circuit Switcher Total | | | 60,000 | 0 | 0 | 0 | 0 | 60,000 |
| | Substation Indoor | Beech St 81 - Indoor Substation Ref | C046577 | 0 | 0 | 0 | 0 | 55,000 | 55,000 |
| | | Buffalo Indoor Sub. #29 Refurb. | C006722 | 622,000 | 0 | 0 | 0 | 0 | 622,000 |
| | | Buffalo Station 27 Rebuild - Sta | C033473 | 213,000 | 0 | 0 | 0 | 0 | 213,000 |
| | | Buffalo Station 29 Rebuild - Fdrs | C006723 | 36,000 | 0 | 0 | 0 | 0 | 36,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|----------------------------------|-------------------------------------|-----------|-----------|-----------|-----------|-----------|-----------|------------|
| | | Buffalo Station 30 - Rebuild - Fdrs | C015754 | 0 | 0 | 0 | 86,000 | 600,000 | 686,000 |
| | | Buffalo Station 30 Rebuild - Sta | C046519 | 0 | 0 | 0 | 0 | 93,000 | 93,000 |
| | | Buffalo Station 34 Rebuild - Line | C046932 | 0 | 0 | 0 | 0 | 86,000 | 86,000 |
| | | Buffalo Station 37 Rebuild - Line | C033477 | 0 | 0 | 600,000 | 220,000 | 0 | 820,000 |
| | | Buffalo Station 37 Rebuild - Sub | C033474 | 2,397,000 | 2,426,000 | 817,000 | 0 | 0 | 5,640,000 |
| | | Buffalo Station 53 Rebuild - Line | C046929 | 0 | 0 | 86,000 | 600,000 | 600,000 | 1,286,000 |
| | | Buffalo Station 53 Rebuild - Sub | C046945 | 0 | 0 | 0 | 93,000 | 1,754,000 | 1,847,000 |
| | | Buffalo Station 59 Rebuild - Line | C033478 | 0 | 0 | 86,000 | 112,000 | 8,000 | 206,000 |
| | | Buffalo Station 59 Rebuild - Sub | C033475 | 0 | 0 | 61,000 | 1,754,000 | 3,880,000 | 5,695,000 |
| | | Eighth St 80 - Indoor Substation Re | C046585 | 29,000 | 250,000 | 810,000 | 750,000 | 0 | 1,839,000 |
| | | | C046586 | 16,000 | 275,000 | 441,000 | 220,000 | 0 | 952,000 |
| | | Eleventh St 82 - Indoor Substation | C046582 | 0 | 0 | 0 | 0 | 65,000 | 65,000 |
| | | Removal of Brighton Ave 4 kV Sub | CD00886 | 1,000 | 0 | 0 | 0 | 0 | 1,000 |
| | | Rock Cut #286 2nd Tranf and Metalc | CD00882 | 970,000 | 0 | 0 | 0 | 0 | 970,000 |
| | | Stephenson 85 - Indoor Substation R | C046580 | 95,000 | 650,000 | 720,000 | 0 | 0 | 1,465,000 |
| | | | C046581 | 265,000 | 1,172,000 | 1,187,000 | 0 | 0 | 2,624,000 |
| | | Welch 83 - Indoor Substation Refurb | C046584 | 0 | 68,000 | 410,000 | 594,000 | 0 | 1,072,000 |
| | | Welch 83 Indoor Substation Refurbis | C046583 | 54,000 | 0 | 1,239,660 | 1,326,960 | 0 | 2,620,620 |
| | | Substation Indoor Total | | 4,698,000 | 4,841,000 | 6,457,660 | 5,755,960 | 7,141,000 | 28,893,620 |
| | Substation Metal-clad Switchgear | Avenue A 291 Metalclad Replacement | C056609 | 0 | 0 | 490,000 | 1,600,000 | 2,725,000 | 4,815,000 |
| | | Chrisler Metal Clad Replacement | C036213 | 500,000 | 1,020,000 | 2,425,000 | 297,000 | 0 | 4,242,000 |
| | | Delmar Distribution Removal | C050241 | 0 | 0 | 0 | 3,000 | 0 | 3,000 |
| | | Delmar Station Retirement | C049692 | 0 | 0 | 1,000 | 0 | 0 | 1,000 |
| | | Emmet St - Repl TB1 and mclad | C017952 | 0 | 0 | 0 | 2,000 | 0 | 2,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|------------------------------|--|-----------|-----------|-----------|------------|------------|------------|------------|
| | | Hopkins 253 - Replace Metalclad Gea | C046741 | 1,178,000 | 2,790,000 | 788,000 | 0 | 0 | 4,756,000 |
| | | Hopkins Rd Metalclad Replacement | C054383 | 10,000 | 160,000 | 178,000 | 0 | 0 | 348,000 |
| | | Johnson Rd - Replace Metalclad Gear | C046747 | 0 | 0 | 0 | 0 | 327,000 | 327,000 |
| | | Maple Ave Feeder Getaways | C046479 | 0 | 0 | 25,000 | 1,215,000 | 3,145,000 | 4,385,000 |
| | | Market Hill substation retirement | C046367 | 0 | 0 | 0 | 0 | 1,000 | 1,000 |
| | | New Maple Ave Substation | C046478 | 250,000 | 714,000 | 1,559,000 | 1,245,000 | 0 | 3,768,000 |
| | | NY Metalclad Switchgear Replacement | C051713 | 0 | 0 | 1,000,000 | 4,000,000 | 5,500,000 | 10,500,000 |
| | | Pine Grove Metalclad Replacement | C056614 | 0 | 150,000 | 2,380,000 | 128,000 | 0 | 2,658,000 |
| | | Station 140 Metalclad Replacement | C056616 | 0 | 240,000 | 2,800,000 | 1,316,000 | 0 | 4,356,000 |
| | | Station 162 Metalclad Replacement | C052706 | 0 | 0 | 0 | 233,000 | 2,716,000 | 2,949,000 |
| | | Station 61 - Metalclad Replacement | C051707 | 0 | 0 | 150,000 | 2,380,000 | 150,000 | 2,680,000 |
| | | Tuller Hill 246 Unit Metalclad Repl | C056611 | 375,000 | 1,135,000 | 672,000 | 0 | 0 | 2,182,000 |
| | | Whitesboro 632 - Retirement | C046742 | 0 | 0 | 0 | 0 | 10,000 | 10,000 |
| | | Substation Metal-clad Switchgear Total | | 2,313,000 | 6,209,000 | 12,468,000 | 12,419,000 | 14,574,000 | 47,983,000 |
| | Substation Mobile | Mobile 8C Upgrade | C051743 | 233,000 | 0 | 0 | 0 | 0 | 233,000 |
| | | Mobile Substation 2E - Replacement | C046666 | 0 | 0 | 10,000 | 695,000 | 669,000 | 1,374,000 |
| | | Mobile Substation 4E - Refurbish an | C046667 | 0 | 0 | 0 | 448,000 | 0 | 448,000 |
| | | Mobile Substation 6E - Rewind | C046668 | 1,020,000 | 200,000 | 0 | 0 | 0 | 1,220,000 |
| | | Mobile Substation 7C - Refurbish an | C046673 | 0 | 400,000 | 0 | 0 | 0 | 400,000 |
| | | NY Mobile Substation Program | C051744 | 0 | 0 | 560,000 | 1,600,000 | 1,600,000 | 3,760,000 |
| | Substation Mobile Total | | | 1,253,000 | 600,000 | 570,000 | 2,743,000 | 2,269,000 | 7,435,000 |
| | Substation Power Transformer | Collins Station - Replace Transform | C046602 | 493,000 | 0 | 0 | 0 | 0 | 493,000 |
| | | Cuyler#24 DSub Station Removal | C036102 | 0 | 100,000 | 0 | 0 | 0 | 100,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|---|--------------------------------------|-----------|-----------|-----------|-----------|-----------|-----------|------------|
| | | French Mountain Transformer Replac | C059139 | 250,000 | 0 | 0 | 0 | 0 | 250,000 |
| | | Galeville 71,72&73 fdrs conversion | C050749 | 0 | 0 | 0 | 63,000 | 902,000 | 965,000 |
| | | Galeville Station Rebuild | C050746 | 0 | 0 | 50,000 | 357,000 | 510,000 | 917,000 |
| | | Grooms Rd Transformer Replacement | C051706 | 397,000 | 864,000 | 850,000 | 0 | 0 | 2,111,000 |
| | | Hancock 13773 and 13772 Conversion | C050606 | 0 | 10,000 | 560,000 | 0 | 0 | 570,000 |
| | | IE - NY ARP Transformers | C025801 | 0 | 0 | 600,000 | 900,000 | 900,000 | 2,400,000 |
| | | Liberty Street Station 94- Replace T | C046676 | 455,000 | 0 | 0 | 0 | 0 | 455,000 |
| | | NY ARP Spare Substation Transformer | C026055 | 600,000 | 600,000 | 600,000 | 600,000 | 600,000 | 3,000,000 |
| | | Rock City Station 623 - Transformer | C046671 | 0 | 0 | 330,000 | 360,000 | 0 | 690,000 |
| | | Sewalls Island #2 TRF Replacement | C058406 | 1,450,000 | 0 | 0 | 0 | 0 | 1,450,000 |
| | | State St 954 Station Retirement | C050640 | 0 | 0 | 0 | 1,000 | 4,000 | 5,000 |
| | | Station 124 - Almeda Ave Transforme | C046670 | 0 | 0 | 464,000 | 2,583,000 | 354,000 | 3,401,000 |
| | | Substation Power Transformer Total | | 3,645,000 | 1,574,000 | 3,454,000 | 4,864,000 | 3,270,000 | 16,807,000 |
| | Sub T Underground Cable Replacement | Ballston 53 - Colonial Hills Cable | C055486 | 165,000 | 0 | 0 | 0 | 0 | 165,000 |
| | | Primary Dist Cable Replacements NY | C058308 | 0 | 0 | 6,000,000 | 6,000,000 | 6,000,000 | 18,000,000 |
| | | Riverside 28855 UG Cable Replacemen | C036468 | 0 | 9,000 | 1,203,000 | 2,297,000 | 0 | 3,509,000 |
| | Sub T Underground Cable Replacement Total | | | 165,000 | 9,000 | 7,203,000 | 8,297,000 | 6,000,000 | 21,674,000 |
| | Primary Underground Cable Replacement | Hague Rd 53 - Submarine Cable. | C050522 | 0 | 0 | 50,000 | 600,000 | 0 | 650,000 |
| | | Schroon 51 - Submarine Cable Repair | C050333 | 0 | 0 | 72,000 | 0 | 0 | 72,000 |
| | Primary Underground Cable Replacement Total | | | 0 | 0 | 122,000 | 600,000 | 0 | 722,000 |
| | Network Secondary Underground Cable Replacement | Network Secondary Cable Replacement | C052903 | 1,500,000 | 1,500,000 | 1,500,000 | 1,500,000 | 1,500,000 | 7,500,000 |
| | | | C052923 | 400,000 | 400,000 | 400,000 | 400,000 | 400,000 | 2,000,000 |
| | | | C052924 | 1,400,000 | 1,400,000 | 1,400,000 | 1,400,000 | 1,400,000 | 7,000,000 |
| | | Troy LVAC Network - William St | CD00628 | 0 | 112,000 | 0 | 0 | 0 | 112,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|---|-------------------------------------|-----------|-----------|-----------|-----------|-----------|-----------|------------|
| | Network Secondary Underground Cable Replacement Total | | | 3,300,000 | 3,412,000 | 3,300,000 | 3,300,000 | 3,300,000 | 16,612,000 |
| | Substation Battery and Related | Batts/Charg- NY Central | C032013 | 300,000 | 200,000 | 200,000 | 200,000 | 200,000 | 1,100,000 |
| | | Batts/Charg- NY West | C032014 | 300,000 | 200,000 | 200,000 | 200,000 | 200,000 | 1,100,000 |
| | | Batts/Charg--NY East | C032012 | 300,000 | 200,000 | 200,000 | 200,000 | 200,000 | 1,100,000 |
| | Substation Battery and Related Total | | | 900,000 | 600,000 | 600,000 | 600,000 | 600,000 | 3,300,000 |
| | Pilot Wire | Partridge St.-Riverside-Repl PW | C036007 | 3,000 | 0 | 0 | 0 | 0 | 3,000 |
| | | Weaver St. - Emmet -Repl Pilot Wire | C036009 | 4,000 | 0 | 0 | 0 | 0 | 4,000 |
| | Pilot Wire Total | | | 7,000 | 0 | 0 | 0 | 0 | 7,000 |
| | Substation Breaker | NC ARP Breakers & Reclosers | C032253 | 865,000 | 612,000 | 624,000 | 636,000 | 648,000 | 3,385,000 |
| | | NE ARP Breakers & Reclosers | C032252 | 737,000 | 612,000 | 624,000 | 636,000 | 648,000 | 3,257,000 |
| | | NW ARP Breakers & Reclosers | C032261 | 600,000 | 612,000 | 624,000 | 636,000 | 648,000 | 3,120,000 |
| | | Peat St - replace R825 OCB | C049550 | 0 | 35,000 | 314,000 | 0 | 0 | 349,000 |
| | Substation Breaker Total | | | 2,202,000 | 1,871,000 | 2,186,000 | 1,908,000 | 1,944,000 | 10,111,000 |
| | Substation Relay/Protection | Altamont Relay Replacement Strategy | C049581 | 0 | 51,000 | 51,000 | 0 | 0 | 102,000 |
| | | Grooms Rd. Relay Replacement | C049597 | 1,000 | 51,000 | 51,000 | 0 | 0 | 103,000 |
| | | Riverside Relay Replacement | C049606 | 60,000 | 412,000 | 286,000 | 0 | 0 | 758,000 |
| | | Temple Relay repl for Ash St line | C055184 | 400,000 | 0 | 0 | 0 | 0 | 400,000 |
| | | Temple Station Relay Replacement | C049616 | 0 | 80,000 | 595,000 | 0 | 0 | 675,000 |
| | | Trinity Station Relay Replacement | C049625 | 194,000 | 1,465,000 | 0 | 0 | 0 | 1,659,000 |
| | Substation Relay/Protection Total | | | 655,000 | 2,059,000 | 983,000 | 0 | 0 | 3,697,000 |
| | Outdoor Lighting - Discretionary | Woodcrest Blvd | C057494 | | | | | | |
| | | | | 150,000 | 0 | 0 | 0 | 0 | 150,000 |
| | Outdoor Lighting - Discretionary Total | | | 150,000 | 0 | 0 | 0 | 0 | 150,000 |
| | Buffalo Street Light Cable Replacement | Buffalo Street Light Cable Replacem | CD00851 | 2,434,000 | 2,434,000 | 2,434,000 | 2,494,000 | 2,494,000 | 12,290,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|---------------------------------------|--|-------------------------------------|------------|------------|------------|------------|------------|-------------|-------------|
| | Buffalo Street Light Cable Replacement Total | | | 2,434,000 | 2,434,000 | 2,434,000 | 2,494,000 | 2,494,000 | 12,290,000 |
| | Inspection & Maintenance | I&M - NC D-Line OH Work From Insp | C026160 | 7,000,000 | 9,901,269 | 5,066,909 | 5,016,240 | 4,966,078 | 31,950,496 |
| | | I&M - NC D-Line UG Work From Insp | C026163 | 159,142 | 157,551 | 155,975 | 154,415 | 152,871 | 779,954 |
| | | I&M - NE D-Line OH Work From Insp | C026159 | 14,571,279 | 14,425,566 | 14,281,311 | 14,138,497 | 13,997,112 | 71,413,765 |
| | | I&M - NE D-Line UG Work From Insp | C026162 | 494,572 | 489,626 | 484,730 | 479,883 | 475,084 | 2,423,895 |
| | | I&M - NW D-Line OH Work From Insp | C026161 | 11,374,779 | 11,261,031 | 11,148,421 | 11,036,937 | 10,926,567 | 55,747,735 |
| | | I&M - NW D-Line UG Work From Insp | C026164 | 550,986 | 545,476 | 540,021 | 534,621 | 529,275 | 2,700,379 |
| | | Otten 41213- Crusher Hill Rd | C053629 | 0 | 0 | 85,000 | 0 | 0 | 85,000 |
| | Inspection & Maintenance Total | | | 34,150,758 | 36,780,519 | 31,762,367 | 31,360,593 | 31,046,987 | 165,101,224 |
| Asset Condition Total | | | 67,257,158 | 72,853,124 | 82,584,265 | 86,324,525 | 93,182,703 | 402,201,775 | |
| Customer Requests/Public Requirements | Blanket | Cent NY-Dist-3rd Party Atch Blankt | CNC0022 | 294,000 | 298,000 | 302,000 | 307,000 | 312,000 | 1,513,000 |
| | | Cent NY-Dist-Land/Rights Blanket | CNC0009 | 1,218,000 | 1,236,000 | 1,255,000 | 1,274,000 | 1,293,000 | 6,276,000 |
| | | Cent NY-Dist-Meter Blanket | CNC0004 | 812,000 | 824,000 | 836,000 | 849,000 | 862,000 | 4,183,000 |
| | | Cent NY-Dist-New Bus-Comm Blanket | CNC0011 | 4,060,000 | 4,121,000 | 4,183,000 | 4,246,000 | 4,310,000 | 20,920,000 |
| | | Cent NY-Dist-New Bus-Resid Blanket | CNC0010 | 6,598,000 | 6,697,000 | 6,797,000 | 6,899,000 | 7,002,000 | 33,993,000 |
| | | Cent NY-Dist-Public Require Blanket | CNC0013 | 1,218,000 | 1,236,000 | 1,255,000 | 1,274,000 | 1,293,000 | 6,276,000 |
| | | Cent NY-Dist-St Light Blanket | CNC0012 | 2,436,000 | 2,473,000 | 2,510,000 | 2,548,000 | 2,586,000 | 12,553,000 |
| | | East NY-Dist-3rd Party Atch Blankt | CNE0022 | 81,000 | 82,000 | 83,000 | 84,000 | 85,000 | 415,000 |
| | | East NY-Dist-Land/Rights Blanket | CNE0009 | 1,000 | 1,000 | 1,000 | 1,000 | 1,000 | 5,000 |
| | | East NY-Dist-Meter Blanket | CNE0004 | 820,000 | 841,000 | 862,000 | 884,000 | 906,000 | 4,313,000 |
| | | East NY-Dist-New Bus-Comm Blanket | CNE0011 | 3,756,000 | 3,812,000 | 3,869,000 | 3,927,000 | 3,986,000 | 19,350,000 |
| | | East NY-Dist-New Bus-Resid Blanket | CNE0010 | 6,598,000 | 6,697,000 | 6,797,000 | 6,899,000 | 7,002,000 | 33,993,000 |
| | | East NY-Dist-Public Require Blanket | CNE0013 | 1,128,000 | 1,156,000 | 1,185,000 | 1,215,000 | 1,245,000 | 5,929,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|------------------------------|-------------------------------------|-----------|------------|------------|------------|------------|------------|-------------|
| | | East NY-Dist-St Light Blanket | CNE0012 | 1,320,000 | 1,340,000 | 1,360,000 | 1,380,000 | 1,401,000 | 6,801,000 |
| | | NiMo Meter Purchases | CN03604 | 3,655,000 | 3,662,000 | 3,670,000 | 3,763,600 | 3,763,600 | 18,514,200 |
| | | NiMo Transformer Purchases | CN03620 | 21,950,000 | 21,900,000 | 22,950,000 | 23,550,000 | 23,950,000 | 114,300,000 |
| | | West NY-Dist-3rd Party Atch Blankt | CNW0022 | 242,000 | 246,000 | 250,000 | 254,000 | 258,000 | 1,250,000 |
| | | West NY-Dist-Land/Rights Blanket | CNW0009 | 579,000 | 588,000 | 597,000 | 606,000 | 615,000 | 2,985,000 |
| | | West NY-Dist-Meter Blanket | CNW0004 | 836,000 | 874,000 | 913,000 | 954,000 | 997,000 | 4,574,000 |
| | | West NY-Dist-New Bus-Comm Blanket | CNW0011 | 3,162,000 | 3,225,000 | 3,290,000 | 3,356,000 | 3,423,000 | 16,456,000 |
| | | West NY-Dist-New Bus-Resid Blanket | CNW0010 | 3,774,000 | 3,849,000 | 3,926,000 | 4,005,000 | 4,085,000 | 19,639,000 |
| | | West NY-Dist-Public Require Blanket | CNW0013 | 871,000 | 893,000 | 915,000 | 938,000 | 961,000 | 4,578,000 |
| | | West NY-Dist-St Light Blanket | CNW0012 | 3,248,000 | 3,297,000 | 3,346,000 | 3,396,000 | 3,447,000 | 16,734,000 |
| | Blanket Total | | | 68,657,000 | 69,348,000 | 71,152,000 | 72,609,600 | 73,783,600 | 355,550,200 |
| | Distributed Generation | NO_State St 95462 Convert to 3Ph | C048519 | 13,000 | 0 | 0 | 0 | 0 | 13,000 |
| | | Tuly Cntr 27852 convert New Hope DG | C056651 | 85,000 | 0 | 0 | 0 | 0 | 85,000 |
| | Distributed Generation Total | | | 98,000 | 0 | 0 | 0 | 0 | 98,000 |
| | New Business | 250 Delaware Ave - New Spot Network | C058128 | 400,000 | 0 | 0 | 0 | 0 | 400,000 |
| | | 3ph Upgd-79 Lakewood Rd,Williamstwn | C049759 | 0 | 10,000 | 670,000 | 0 | 0 | 680,000 |
| | | 520 Seneca St, Utica | C057406 | 85,000 | 0 | 0 | 0 | 0 | 85,000 |
| | | Birch Ave 51 - Route 9N Conversion | C053127 | 0 | 0 | 94,000 | 0 | 0 | 94,000 |
| | | Brookside Crossing Phase 1, Oneida | C052928 | 43,000 | 0 | 0 | 0 | 0 | 43,000 |
| | | BUTTERVILLE FARMS, Adams NY | C055346 | 153,000 | 0 | 0 | 0 | 0 | 153,000 |
| | | Camillus Apartments URD, Camillus | C055165 | 68,000 | 0 | 0 | 0 | 0 | 68,000 |
| | | CR-Ash Street-13.2kV Feeder 22352 | CD01217 | 264,000 | 0 | 0 | 0 | 0 | 264,000 |
| | | East Batavia Substation - DLine Upg | CD00587 | 0 | 0 | 199,000 | 0 | 0 | 199,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|---------------------|--------------------------------------|-----------|-----------|-----------|------------|-----------|-----------|------------|
| | | F5961 Extend to 500 Seneca St | C055398 | 308,000 | 0 | 0 | 0 | 0 | 308,000 |
| | | Gen County Econ Dev Corp | C057505 | 150,000 | 0 | 0 | 0 | 0 | 150,000 |
| | | Inner Harbor Project, Syracuse NY | C057287 | 85,000 | 0 | 0 | 0 | 0 | 85,000 |
| | | Maxon Alco - Mix use Devlpmnt | C052327 | 500,000 | 0 | 0 | 0 | 0 | 500,000 |
| | | Minoa Farms Part 2 Phs 5, Minoa NY | C050159 | 55,000 | 0 | 0 | 0 | 0 | 55,000 |
| | | Mohawk Harbor Development Civil | C055843 | 1,352,000 | 0 | 0 | 0 | 0 | 1,352,000 |
| | | MOOSE RIVER COMMONS URD, Old Forge | C056407 | 43,000 | 0 | 0 | 0 | 0 | 43,000 |
| | | Partridge Road Complex, Malone, NY | C054863 | 43,000 | 0 | 0 | 0 | 0 | 43,000 |
| | | Reserve for New Business Commercial | C046920 | 2,000,000 | 3,000,000 | 3,148,740 | 3,198,720 | 3,198,720 | 14,546,180 |
| | | Reserve for New Business Residentia | C046921 | 3,006,000 | 5,820,000 | 6,227,280 | 6,277,500 | 6,277,500 | 27,608,280 |
| | | South Meadows Phase 1 - CAZENOVIA NY | C053485 | 43,000 | 0 | 0 | 0 | 0 | 43,000 |
| | | Sports field, Judd Rd, Whitesboro | C057408 | 85,000 | 0 | 0 | 0 | 0 | 85,000 |
| | | Sta 59 - 13.2kV Ratio Banks | C056986 | 420,000 | 0 | 0 | 0 | 0 | 420,000 |
| | | The Common at Flemings Farm URD | C055416 | 234,000 | 0 | 0 | 0 | 0 | 234,000 |
| | | The Preserves at Clifton Park URD | C050113 | 0 | 0 | 85,000 | 0 | 0 | 85,000 |
| | | UCD-Park South - Myrtle Ave, Albany | C053091 | 200,000 | 0 | 0 | 0 | 0 | 200,000 |
| | | New Business Total | | 9,537,000 | 8,830,000 | 10,424,020 | 9,476,220 | 9,476,220 | 47,743,460 |
| | Public Requirements | 3806.28 Rt 49 @ Depot Rd (Site E) | C054585 | 68,000 | 0 | 0 | 0 | 0 | 68,000 |
| | | DESTINY USA HOTEL, Syracuse NY | C054463 | 0 | 255,000 | 0 | 0 | 0 | 255,000 |
| | | DOT - 3028.11 Rt 281 Cortland | C053128 | 510,000 | 0 | 0 | 0 | 0 | 510,000 |
| | | DOT City of Watertown Harrison St | C054703 | 85,000 | 0 | 0 | 0 | 0 | 85,000 |
| | | DOT Cleveland Dr Bridge | C048677 | 1,000 | 0 | 0 | 0 | 0 | 1,000 |
| | | DOT Factory St | C051963 | 128,000 | 0 | 0 | 0 | 0 | 128,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|---|--|-------------------------------------|-----------|------------|------------|------------|------------|------------|-------------|
| | | Watertown NY | | | | | | | |
| | | DOT Jefferson Co DPW CR69 | C052123 | 102,000 | 0 | 0 | 0 | 0 | 102,000 |
| | | Island Rd, Ausable Forks | C054790 | 70,000 | 0 | 0 | 0 | 0 | 70,000 |
| | | MV-DOT Herkimer Co. Newport Rd. DOT | C054926 | 140,000 | 0 | 0 | 0 | 0 | 140,000 |
| | | Nestle Substation Demo | CD01051 | 1,000 | 0 | 0 | 0 | 0 | 1,000 |
| | | Oswego - Trolley Light Pole Replace | CD00810 | 464,000 | 0 | 0 | 0 | 0 | 464,000 |
| | | PIN 1085.42 Rt 146 / Mohawk | C057859 | 213,000 | 0 | 0 | 0 | 0 | 213,000 |
| | | PIN 1085.42 RT 146 over Mohawk R | C055355 | 168,000 | 0 | 0 | 0 | 0 | 168,000 |
| | | PIN 1460.32 Rt 32 over Mohawk River | C054068 | 0 | 518,000 | 0 | 0 | 0 | 518,000 |
| | | PIN 2056.79 | C055418 | 98,000 | 0 | 0 | 0 | 0 | 98,000 |
| | | PIN 5757.18 Kenmore Ave | C054523 | 140,000 | 0 | 0 | 0 | 0 | 140,000 |
| | | Reserve for Public Requirements Uni | C046922 | 4,180,000 | 5,947,000 | 7,600,000 | 7,600,000 | 7,600,000 | 32,927,000 |
| | | Rotterdam 13852 & 13853 Relocation | C046422 | 400,000 | 0 | 0 | 0 | 0 | 400,000 |
| | | Village of Clayton Downtown - OH-UG | C053443 | 85,000 | 0 | 0 | 0 | 0 | 85,000 |
| | | Wilbur Road Relocation | C048178 | 0 | 0 | 170,000 | 0 | 0 | 170,000 |
| | Public Requirements Total | | | 6,853,000 | 6,720,000 | 7,770,000 | 7,600,000 | 7,600,000 | 36,543,000 |
| | Outdoor Lighting - Discretionary | WoodstreamFarms-UG-Lighting | C055111 | 343,000 | 0 | 0 | 0 | 0 | 343,000 |
| | Outdoor Lighting - Discretionary Total | | | 343,000 | 0 | 0 | 0 | 0 | 343,000 |
| Customer Requests/Public Requirements Total | | | | 85,488,000 | 84,898,000 | 89,346,020 | 89,685,820 | 90,859,820 | 440,277,660 |
| Damage/Failure | Blanket | Cent NY-Dist-Damage/Failure Blanket | CNC0014 | 7,511,000 | 7,624,000 | 7,738,000 | 7,854,000 | 7,972,000 | 38,699,000 |
| | | Cent NY-Dist-Subs Blanket | CNC0002 | 508,000 | 516,000 | 524,000 | 532,000 | 540,000 | 2,620,000 |
| | | East NY-Dist-Damage/Failure Blanket | CNE0014 | 7,105,000 | 7,212,000 | 7,320,000 | 7,430,000 | 7,541,000 | 36,608,000 |
| | | East NY-Dist-Subs Blanket | CNE0002 | 711,000 | 722,000 | 733,000 | 744,000 | 755,000 | 3,665,000 |
| | | West NY-Dist-Damage/Failure Blanket | CNW0014 | 6,293,000 | 6,387,000 | 6,483,000 | 6,580,000 | 6,679,000 | 32,422,000 |
| | | | | | | | | | |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|-------------------------------|----------------------------|-------------------------------------|-----------|------------|------------|------------|------------|------------|-------------|
| | | West NY-Dist-Subs Blanket | CNW0002 | 711,000 | 722,000 | 733,000 | 744,000 | 755,000 | 3,665,000 |
| | Blanket Total | | | 22,839,000 | 23,183,000 | 23,531,000 | 23,884,000 | 24,242,000 | 117,679,000 |
| | Damage Failure Other | Delta Lake Estates Primary Cable Re | C056449 | 128,000 | 0 | 0 | 0 | 0 | 128,000 |
| | | Genesee Substation Retirement | C051871 | 0 | 0 | 0 | 1,000 | 0 | 1,000 |
| | | Reserve for Damage/Failure Unidenti | C046918 | 2,014,800 | 2,115,540 | 2,216,280 | 2,317,020 | 2,317,020 | 10,980,660 |
| | | | C046948 | 2,756,754 | 2,802,800 | 2,852,850 | 2,902,900 | 2,902,900 | 14,218,204 |
| | Damage Failure Other Total | | | 4,899,554 | 4,918,340 | 5,069,130 | 5,220,920 | 5,219,920 | 25,327,864 |
| Damage/Failure Total | | | | 27,738,554 | 28,101,340 | 28,600,130 | 29,104,920 | 29,461,920 | 143,006,864 |
| Non-Infrastructure | Blanket | Cent NY-Dist-Telecomm Blanket | CNC0021 | 1,000 | 1,000 | 1,000 | 1,000 | 1,000 | 5,000 |
| | | Cent NY-General-Genl Equip Blanket | CNC0070 | 639,000 | 649,000 | 659,000 | 669,000 | 679,000 | 3,295,000 |
| | | East NY-Dist-Telecomm Blanket | CNE0021 | 1,000 | 1,000 | 1,000 | 1,000 | 1,000 | 5,000 |
| | | East NY-Genl Equip Budgetary Reserv | CNE0070 | 609,000 | 618,000 | 627,000 | 636,000 | 646,000 | 3,136,000 |
| | | West NY-Dist-Telecomm Blanket | CNW0021 | 1,000 | 1,000 | 1,000 | 1,000 | 1,000 | 5,000 |
| | | West NY-General-Genl Equip Blanket | CNW0070 | 711,000 | 722,000 | 733,000 | 744,000 | 755,000 | 3,665,000 |
| | Blanket Total | | | 1,962,000 | 1,992,000 | 2,022,000 | 2,052,000 | 2,083,000 | 10,111,000 |
| | Telcom | Telecom and Radio Equipment | C004157 | 995,000 | 995,000 | 995,000 | 995,000 | 995,000 | 4,975,000 |
| | Telcom Total | | | 995,000 | 995,000 | 995,000 | 995,000 | 995,000 | 4,975,000 |
| Non-Infrastructure Total | | | | 2,957,000 | 2,987,000 | 3,017,000 | 3,047,000 | 3,078,000 | 15,086,000 |
| System Capacity & Performance | Blanket | Cent NY-Dist-Load Relief Blanket | CNC0016 | 558,000 | 566,000 | 574,000 | 583,000 | 592,000 | 2,873,000 |
| | | Cent NY-Dist-Reliability Blanket | CNC0015 | 1,218,000 | 1,236,000 | 1,255,000 | 1,274,000 | 1,293,000 | 6,276,000 |
| | | East NY-Dist-Load Relief Blanket | CNE0016 | 615,000 | 630,000 | 646,000 | 662,000 | 679,000 | 3,232,000 |
| | | East NY-Dist-Reliability Blanket | CNE0015 | 1,218,000 | 1,236,000 | 1,255,000 | 1,274,000 | 1,293,000 | 6,276,000 |
| | | West NY-Dist-Load Relief Blanket | CNW0016 | 637,000 | 666,000 | 696,000 | 727,000 | 760,000 | 3,486,000 |
| | | West NY-Dist-Reliability Blanket | CNW0015 | 2,030,000 | 2,060,000 | 2,091,000 | 2,122,000 | 2,154,000 | 10,457,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|---------------|-------------------------------------|-----------|-----------|-----------|-----------|-----------|-----------|------------|
| | Blanket Total | | | 6,276,000 | 6,394,000 | 6,517,000 | 6,642,000 | 6,771,000 | 32,600,000 |
| | Load Relief | *Cedar 51 - Buttermilk Falls Rd | C049764 | 0 | 0 | 251,000 | 0 | 0 | 251,000 |
| | | *Firehouse 44953 - Dunsbach Rd Conv | C049864 | 0 | 0 | 106,000 | 0 | 0 | 106,000 |
| | | *Firehouse Rd Station - New Feeder | C050081 | 0 | 0 | 467,000 | 0 | 0 | 467,000 |
| | | *Hague Rd 52 - Convert Route 22 | C050717 | 0 | 0 | 10,000 | 0 | 787,000 | 797,000 |
| | | *Hudson Falls 51 - Convert Broadway | C050023 | 0 | 10,000 | 201,650 | 0 | 0 | 211,650 |
| | | *Pawling Ave Conv (29252/37253) | C050103 | 0 | 0 | 210,000 | 280,000 | 0 | 490,000 |
| | | *Vail Mills 51 - County Hwy 107 | C049793 | 0 | 0 | 0 | 354,000 | 0 | 354,000 |
| | | *Wilton 52 - Rt 32 3 Phase Ext. | C019570 | 0 | 10,000 | 593,000 | 0 | 0 | 603,000 |
| | | *N Syracuse Sub Getaways | C030506 | 488,000 | 0 | 0 | 0 | 0 | 488,000 |
| | | 37062 Route 3 Hammond - Rebuild | C052312 | 0 | 0 | 0 | 159,000 | 0 | 159,000 |
| | | 73353 County RTE 125 - Rebuild | C052216 | 0 | 0 | 10,000 | 0 | 713,000 | 723,000 |
| | | 73353 State HWY 12E - Rebuild | C052208 | 0 | 0 | 0 | 286,000 | 0 | 286,000 |
| | | 81452 Westminster Park Rd - Rebuild | C052344 | 0 | 0 | 340,000 | 0 | 0 | 340,000 |
| | | 81456 Route 15 - Rebuild | C052343 | 0 | 0 | 0 | 468,000 | 0 | 468,000 |
| | | 81458 Kring Point Road - Rebuild | C052335 | 0 | 0 | 0 | 255,000 | 0 | 255,000 |
| | | 81653 Alexandria Street - Rebuild | C052334 | 0 | 0 | 0 | 340,000 | 0 | 340,000 |
| | | 81757 RTE 156 - Rebuild | C052205 | 0 | 0 | 340,000 | 0 | 0 | 340,000 |
| | | 87553 Green Settlement Rd - Rebuild | C052323 | 0 | 0 | 0 | 465,000 | 0 | 465,000 |
| | | 87554 County RTE 189 & 95 - Rebuild | C052367 | 0 | 10,000 | 500,000 | 204,000 | 0 | 714,000 |
| | | 89552 Crooks Road - Rebuild | C052443 | 0 | 0 | 280,000 | 213,000 | 0 | 493,000 |
| | | 8th St Conversion Niagara Falls | C046841 | 37,000 | 0 | 0 | 0 | 0 | 37,000 |
| | | 93854 Jefferson Ave - Rebuild | C052186 | 0 | 0 | 255,000 | 0 | 0 | 255,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|---------|-------------------------------------|-----------|-----------|-----------|---------|---------|---------|-----------|
| | | 95554 HWY 11 - Rebuild | C052371 | 0 | 0 | 0 | 10,000 | 415,000 | 425,000 |
| | | 95556 Miner Street - Rebuild | C052372 | 0 | 0 | 0 | 10,000 | 415,000 | 425,000 |
| | | 95756 HWY 37 - Rebuild | C052347 | 0 | 0 | 315,000 | 0 | 0 | 315,000 |
| | | 95756 Linden Street - Rebuild | C052369 | 0 | 0 | 531,000 | 0 | 0 | 531,000 |
| | | 97654 Skinnerville Road - Rebuild | C052370 | 0 | 0 | 0 | 10,000 | 371,000 | 381,000 |
| | | 98455 Degrasse-Russell rd - Rebuild | C052103 | 0 | 0 | 0 | 595,000 | 0 | 595,000 |
| | | Attica Station transformer upgrade | C046611 | 570,000 | 0 | 0 | 0 | 0 | 570,000 |
| | | Battenkill 57-North Rd Ratio Relief | C057410 | 0 | 208,000 | 0 | 0 | 0 | 208,000 |
| | | Beech Ave Conversion Niagara Falls | C032751 | 0 | 431,000 | 0 | 0 | 0 | 431,000 |
| | | Brook Road 55 - Barney Rd. Rebuild | C047978 | 0 | 0 | 128,000 | 0 | 0 | 128,000 |
| | | Buffalo Sta 56- upgrade 4 Xfmrs | C036502 | 1,668,200 | 1,181,800 | 0 | 0 | 0 | 2,850,000 |
| | | Buffalo Station 129 - F12974 Recond | C046558 | 0 | 434,000 | 0 | 0 | 0 | 434,000 |
| | | Buffalo Station 49 - UG Upgrades | CD01128 | 1,107,000 | 0 | 0 | 0 | 0 | 1,107,000 |
| | | Buffalo Station 56 - New F5664 | C046530 | 0 | 57,000 | 815,000 | 0 | 0 | 872,000 |
| | | Burdeck 26552 - Burnett St Conversi | C046632 | 0 | 0 | 0 | 592,000 | 0 | 592,000 |
| | | Butler 53 - Add breaker for 53 ckt | C047481 | 3,000 | 0 | 0 | 0 | 0 | 3,000 |
| | | Butler 53 - Build 36253 feeder - OH | C047455 | 224,000 | 0 | 0 | 0 | 0 | 224,000 |
| | | Butler 53 - Build 36253 feeder - UG | C028878 | 676,000 | 0 | 0 | 0 | 0 | 676,000 |
| | | Center St 52 - Route 5 Rebuild/Conv | C048833 | 0 | 0 | 0 | 440,000 | 0 | 440,000 |
| | | Clinton 54 - E Main St Conversion | C055366 | 0 | 0 | 0 | 168,000 | 0 | 168,000 |
| | | Coffeen 76053 Holcomb St - Rebuild | C052188 | 0 | 0 | 0 | 213,000 | 0 | 213,000 |
| | | Coffeen 76056 White Rd - Rebuild | C052203 | 0 | 0 | 10,000 | 0 | 466,000 | 476,000 |
| | | CR Brewton Retire | C010751 | 0 | 0 | 0 | 0 | 3,000 | 3,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|---------|--------------------------------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| | | CR- Convert 26554 Brooklea Dr | C052226 | 0 | 412,000 | 0 | 0 | 0 | 412,000 |
| | | CR- Convert 29351 north of station | C049397 | 0 | 510,000 | 0 | 0 | 0 | 510,000 |
| | | CR- Paloma 55 convert NYS 48 | C051832 | 0 | 10,000 | 476,000 | 0 | 0 | 486,000 |
| | | CR- Pebble Hill Burke Rd Ratio | C051710 | 0 | 179,000 | 0 | 0 | 0 | 179,000 |
| | | CR- Pine Grove 56 NYS Hwy 31 conver | CD00608 | 300,000 | 0 | 0 | 0 | 0 | 300,000 |
| | | Curry Rd 36552 UG Getaway Replace | C056406 | 0 | 160,000 | 0 | 0 | 0 | 160,000 |
| | | Dekalb 98455 Town Line rd - Rebuild | C052106 | 0 | 0 | 0 | 595,000 | 0 | 595,000 |
| | | DeLaet's Landing DxD | CD00893 | 61,000 | 458,000 | 1,608,000 | 0 | 0 | 2,127,000 |
| | | Eden switch structure - install 2-10 | C046538 | 200,000 | 800,000 | 1,210,000 | 1,600,000 | 0 | 3,810,000 |
| | | Eden Switch Structure- New Fdr 1 | C048015 | 590,000 | 590,000 | 0 | 0 | 0 | 1,180,000 |
| | | Eden Switch Structure- New fdr# 2 | C048016 | 0 | 642,000 | 643,000 | 0 | 0 | 1,285,000 |
| | | F21555 Replace 4/0 PLAC Getaways | C057293 | 10,000 | 140,000 | 0 | 0 | 0 | 150,000 |
| | | Fairdale DLine | C046633 | 0 | 0 | 198,000 | 474,000 | 119,000 | 791,000 |
| | | Fairdale Dsub | C046640 | 0 | 53,000 | 843,000 | 523,000 | 0 | 1,419,000 |
| | | Forbes Ave - New Substation | C053137 | 143,000 | 1,000,000 | 3,488,000 | 500,000 | 0 | 5,131,000 |
| | | Frankhauser New Station - Line Work | C028929 | 6,290,000 | 0 | 0 | 0 | 0 | 6,290,000 |
| | | Gilbert Mills Xfmr Upgrade-Xfmr | C046563 | 369,000 | 0 | 0 | 0 | 0 | 369,000 |
| | | Grooms Rd 34557 - Saratoga Rd Conve | C046761 | 0 | 0 | 0 | 0 | 1,040,000 | 1,040,000 |
| | | Harris 54 Relief | C032446 | 1,000,000 | 907,000 | 907,000 | 0 | 0 | 2,814,000 |
| | | Juniper Distribution Removal Work | C050245 | 0 | 0 | 0 | 4,000 | 0 | 4,000 |
| | | Lakeville substation retirement | C046588 | 0 | 0 | 0 | 8,000 | 39,000 | 47,000 |
| | | Lyme 73353 RTE 59 - Rebuild | C052206 | 0 | 0 | 298,000 | 298,000 | 0 | 596,000 |
| | | Malone new 89554 feeder (Line work | C046626 | 0 | 0 | 638,000 | 0 | 0 | 638,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|-----------------------|---------|-------------------------------------|-----------|-----------|-----------|-----------|-----------|-----------|------------|
| | | Mayfield 51 - Paradise Point Rd | C050069 | 0 | 0 | 0 | 0 | 287,000 | 287,000 |
| | | Mexico Substation Demo | C046629 | 0 | 0 | 13,000 | 0 | 0 | 13,000 |
| | | Military Rd New F21052 - N Falls | C054046 | 0 | 760,000 | 133,000 | 0 | 0 | 893,000 |
| | | Milton Ave 2nd Switchgear | C046609 | 3,529,000 | 1,805,000 | 0 | 0 | 0 | 5,334,000 |
| | | Milton Ave DLine | C046643 | 1,000,000 | 100,000 | 2,900,000 | 6,000,000 | 0 | 10,000,000 |
| | | N.Gouverneur 98352 HWY58 - Rebuild | C052108 | 0 | 0 | 0 | 425,000 | 0 | 425,000 |
| | | New Cicero Substation Dline | C046476 | 50,000 | 156,000 | 1,000,000 | 41,000 | 0 | 1,247,000 |
| | | New Cicero Substation DSub | C046475 | 500,000 | 1,000,000 | 3,900,000 | 1,832,000 | 0 | 7,232,000 |
| | | New Haven xfmr upgrade-Buswork | C046634 | 0 | 0 | 0 | 400,000 | 2,180,000 | 2,580,000 |
| | | New Haven xfmr upgrade-Dline | C046635 | 0 | 0 | 200,000 | 2,800,000 | 0 | 3,000,000 |
| | | New Krumkill 42153 - UG Getaway Rep | C046648 | 0 | 170,000 | 0 | 0 | 0 | 170,000 |
| | | NR_Port Leyden 75563-Moose River Rd | CD01197 | 0 | 0 | 0 | 550,000 | 0 | 550,000 |
| | | OAK RUN ESTATES URD F10551 CONVSN | C055125 | 269,000 | 0 | 0 | 0 | 0 | 269,000 |
| | | Ogdensburg 93852 HWY 37 - Rebuild | C052143 | 0 | 0 | 0 | 153,000 | 0 | 153,000 |
| | | Ohio Street - North | C050405 | 5,000 | 0 | 0 | 0 | 0 | 5,000 |
| | | Ohio Street Conduit Bank - South | C050404 | 5,000 | 0 | 0 | 0 | 0 | 5,000 |
| | | Paloma Feeder Getaway | C032498 | 200,000 | 0 | 0 | 0 | 0 | 200,000 |
| | | Paloma new switchgear | CD01190 | 744,000 | 0 | 0 | 0 | 0 | 744,000 |
| | | Paloma Second Transformer | C032495 | 240,000 | 0 | 0 | 0 | 0 | 240,000 |
| | | Panama Rebuild | C046509 | 0 | 0 | 6,000 | 196,000 | 133,000 | 335,000 |
| | | Queensbury DLine Re-route Getaways | CD00895 | 3,000,000 | 200,000 | 0 | 0 | 0 | 3,200,000 |
| | | Randall Rd - New station - Dist get | CD00897 | 75,000 | 405,000 | 1,004,000 | 5,000 | 0 | 1,489,000 |
| | | Randall Rd - New station - M/C S/G | CD00896 | 250,000 | 750,000 | 2,000,000 | 1,700,000 | 0 | 4,700,000 |
| | | Raquette Lake Transformer Upgrade | CD01139 | 0 | 300,000 | 400,000 | 0 | 0 | 700,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|---------|-------------------------------------|-----------|-----------|-----------|------------|------------|-----------|-------------|
| | | Reserve for Load Relief Unidentifie | C046919 | 0 | 0 | -1,833,000 | 0 | 8,934,000 | 7,101,000 |
| | | | C046949 | 0 | 0 | -8,231,000 | -7,890,000 | 0 | -16,121,000 |
| | | Retirement of Juniper sub #500 | C049685 | 0 | 0 | 1,000 | 0 | 0 | 1,000 |
| | | RR-Menands 10157-Getaway Replacemen | C053966 | 0 | 10,000 | 377,000 | 0 | 0 | 387,000 |
| | | S.Livingston relief: F5 work | C051692 | 1,100,000 | 0 | 0 | 0 | 0 | 1,100,000 |
| | | S.Livingston relief: Fd3 work | C051690 | 0 | 0 | 0 | 0 | 50,000 | 50,000 |
| | | S.Livingston relief: Fd4 work | C051691 | 60,000 | 640,000 | 640,000 | 0 | 0 | 1,340,000 |
| | | S.Livingston rSlief: Dist Fder Work | C051694 | 0 | 60,000 | 310,000 | 468,000 | 361,000 | 1,199,000 |
| | | S.Philadelphia Transformer Upgrade | CD01293 | 350,000 | 373,000 | 0 | 0 | 0 | 723,000 |
| | | Sodeman Rd - New station - dist get | C046796 | 100,000 | 405,000 | 1,215,000 | 0 | 0 | 1,720,000 |
| | | Sodeman Rd Station - new station - | C046798 | 750,000 | 1,000,000 | 3,150,000 | 500,000 | 0 | 5,400,000 |
| | | Sonora Way 115 – 13.2kV Substation | C051585 | 1,100,000 | 2,000,000 | 1,332,000 | 0 | 0 | 4,432,000 |
| | | South Livingston relief - DLine Fd1 | C046759 | 140,000 | 0 | 0 | 0 | 0 | 140,000 |
| | | South Livingston relief - DLine Fd2 | C046552 | 0 | 0 | 50,000 | 890,000 | 550,000 | 1,490,000 |
| | | Spragueville Road - Rebuild | C051891 | 0 | 0 | 757,000 | 0 | 0 | 757,000 |
| | | Sta 129 Repl Cable Exits-Summ Prep | C056448 | 267,000 | 0 | 0 | 0 | 0 | 267,000 |
| | | Station 42 34.5-13.2kV Dline Work | C055352 | 750,000 | 30,000 | 0 | 0 | 0 | 780,000 |
| | | Station 42 rebuild: 34.5-13.2kV TB1 | C055353 | 750,000 | 30,000 | 0 | 0 | 0 | 780,000 |
| | | Station 56 New Feeders Getaway | C057826 | 150,000 | 150,000 | 0 | 0 | 0 | 300,000 |
| | | Station 74 23-4.16kV MITS | C055267 | 40,000 | 0 | 0 | 0 | 0 | 40,000 |
| | | Stoner 52 - Mohawk Dr Conversion | C050421 | 0 | 428,000 | 0 | 0 | 0 | 428,000 |
| | | Swiss Road - Rebuild | C052076 | 0 | 0 | 638,000 | 0 | 0 | 638,000 |
| | | Teal Substation Rebuild-Feeders | C046505 | 0 | 0 | 0 | 20,000 | 748,000 | 768,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|-------------|-------------------------------------|-----------|------------|------------|------------|------------|------------|-------------|
| | | Teal Substation Rebuild-Swgr | C046511 | 0 | 0 | 271,000 | 2,831,000 | 1,554,000 | 4,656,000 |
| | | Tibbets 29254 - 15th Ave Conversion | C046425 | 0 | 0 | 212,000 | 0 | 0 | 212,000 |
| | | Two Mile Creek Rd - Dline | C052028 | 436,000 | 0 | 0 | 0 | 0 | 436,000 |
| | | Union St 52 - County Hwy 59 | C056632 | 0 | 0 | 0 | 25,000 | 800,000 | 825,000 |
| | | Union St 54- Turnpike Rd Conversion | C055735 | 0 | 20,000 | 537,000 | 0 | 0 | 557,000 |
| | | Van Dyke - UG - Civil & Elec work | C052098 | 0 | 3,659,000 | 0 | 0 | 0 | 3,659,000 |
| | | Van Dyke Station - New 115/13.2kV s | C046490 | 4,868,000 | 0 | 0 | 0 | 0 | 4,868,000 |
| | | Van Dyke Station - New 53 Dist Feed | C046493 | 485,000 | 0 | 0 | 0 | 0 | 485,000 |
| | | Van Dyke Station - New 55 Dist Feed | C046489 | 164,000 | 0 | 0 | 0 | 0 | 164,000 |
| | | Van Dyke Station - New 56 Dist Feed | C046487 | 10,000 | 1,823,000 | 0 | 0 | 0 | 1,833,000 |
| | | Van Dyke Station-New 54 Dist Feed. | C046495 | 0 | 1,490,000 | 1,224,000 | 0 | 0 | 2,714,000 |
| | | Van Dyke Subst- New 57 Dist Feeder | C046488 | 1,354,000 | 969,000 | 0 | 0 | 0 | 2,323,000 |
| | | Van Dyke Subst- new feeders | C016087 | 0 | 1,068,000 | 0 | 0 | 0 | 1,068,000 |
| | | W.Chautauqua Dline work | C055265 | 0 | 0 | 6,000 | 230,000 | 200,000 | 436,000 |
| | | W.Chautauqua new 34.5-4.8kV sub | C055264 | 0 | 0 | 5,000 | 366,000 | 0 | 371,000 |
| | | Warrensburg 51 - County Home Bridge | CD01133 | 0 | 0 | 94,000 | 0 | 0 | 94,000 |
| | | Wilson 93 Load Relief - Replace TB1 | C035743 | 1,516,000 | 0 | 0 | 0 | 0 | 1,516,000 |
| | | Load Relief Total | | 37,993,200 | 28,003,800 | 27,982,650 | 20,606,000 | 20,165,000 | 134,750,650 |
| | Reliability | *Bethlehem 02155 Glenmont Rd Conv | C049990 | 0 | 0 | 201,000 | 0 | 0 | 201,000 |
| | | *Blue Stores 30352 - Conversion | C050107 | 0 | 0 | 428,000 | 0 | 0 | 428,000 |
| | | *Byron F1863 - Rebuild /Reconductor | C049762 | 0 | 0 | 0 | 555,000 | 0 | 555,000 |
| | | *CR - McGraw-Truxton feeder tie | C049727 | 0 | 0 | 0 | 1,000,000 | 0 | 1,000,000 |
| | | *Create Full Tie F15351 to F15352 | C049720 | 0 | 0 | 0 | 15,000 | 525,000 | 540,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|---------|--------------------------------------|-----------|---------|---------|---------|-----------|---------|-----------|
| | | *Create Full tie F18251 to F18254 | C049882 | 0 | 0 | 16,000 | 400,000 | 0 | 416,000 |
| | | *Create Full Tie F9354 to F9353 | C049783 | 0 | 0 | 380,000 | 0 | 0 | 380,000 |
| | | *E.Golah 5157 Tie w/Lakeville 19752 | C049880 | 10,000 | 568,000 | 0 | 0 | 0 | 578,000 |
| | | *Eagle Harbor F9263 Tie with F7951 | C049688 | 0 | 0 | 0 | 204,800 | 0 | 204,800 |
| | | *Hoosick 31451 - Conversion | C050082 | 0 | 0 | 237,000 | 0 | 0 | 237,000 |
| | | *Hoosick 31452 Conversion- High St. | C050083 | 0 | 0 | 400,000 | 0 | 0 | 400,000 |
| | | *Hudson 08753 - Rte 9G Conversion | C050108 | 0 | 0 | 296,000 | 0 | 0 | 296,000 |
| | | *Menands 10151 / 52 Relocations | C049998 | 411,000 | 0 | 0 | 0 | 0 | 411,000 |
| | | *Middleport F7765 Tie w/Shelby 7656 | C049711 | 0 | 0 | 16,000 | 426,000 | 0 | 442,000 |
| | | *NR_76462-CoRte28-Rebuild | C049197 | 0 | 0 | 0 | 1,200,000 | 0 | 1,200,000 |
| | | *NR-Hammond 37061-Calaboga Rd | C010688 | 0 | 0 | 400,000 | 300,000 | 0 | 700,000 |
| | | *Rbld/Conv F15352 to full tie F6353 | C049878 | 0 | 0 | 550,000 | 0 | 0 | 550,000 |
| | | *Rbld/Conv to Create tie F7652-7651 | C049802 | 0 | 16,000 | 309,000 | 0 | 0 | 325,000 |
| | | *Rebuild Darien F1662 Limited Tie | C049634 | 0 | 20,000 | 0 | 375,000 | 0 | 395,000 |
| | | *Rebuild portion of E.Otto F2861 | C049718 | 0 | 0 | 16,000 | 224,000 | 0 | 240,000 |
| | | *Rebuild portions of Catt. F1562 | C049686 | 5,000 | 365,000 | 0 | 0 | 0 | 370,000 |
| | | *Selkirk 14951 - Thatcher/River Conv | C049985 | 0 | 10,000 | 505,000 | 0 | 0 | 515,000 |
| | | *Selkirk 52/ Beth 58-Creble Rd Conv | C050001 | 0 | 0 | 243,000 | 0 | 0 | 243,000 |
| | | *Trinity 16458 - McCarty Ave Conv | C050000 | 0 | 10,000 | 314,000 | 0 | 0 | 324,000 |
| | | *Trinity 52- Delaware/Park Ave Conv | C049999 | 0 | 0 | 162,000 | 0 | 0 | 162,000 |
| | | *Weibel 56 - Wall Street Rebuild | C051325 | 0 | 0 | 0 | 10,000 | 840,000 | 850,000 |
| | | 81453-Ellis Road Rebuild&Relocation | C054930 | 0 | 0 | 120,000 | 0 | 0 | 120,000 |
| | | 81458 Dingman Point | C054533 | 0 | 0 | 0 | 96,000 | 0 | 96,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|---------|-------------------------------------|-----------|---------|---------|-----------|---------|-----------|-----------|
| | | Road Rebuild_RR | | | | | | | |
| | | 84661-Tower Road Relocation | C055344 | 0 | 0 | 229,000 | 0 | 0 | 229,000 |
| | | 91453 Rte 11 Relocation | C057007 | 0 | 0 | 0 | 240,000 | 0 | 240,000 |
| | | 92451 Sterling Pond Road Relocation | C056730 | 0 | 0 | 0 | 240,000 | 0 | 240,000 |
| | | 93663 Adams Road Relocation | C053286 | 0 | 0 | 0 | 85,000 | 0 | 85,000 |
| | | 97655 Raquette River Crossing | C057487 | 150,000 | 0 | 0 | 0 | 0 | 150,000 |
| | | BaileySettlement-Gore Rd_Rebuild | C054583 | 0 | 0 | 0 | 480,000 | 0 | 480,000 |
| | | Battenkill 57 - Sullivan Rd | C056323 | 0 | 0 | 60,000 | 0 | 0 | 60,000 |
| | | Battenkill 58 - Cambridge Rd | C053182 | 0 | 0 | 118,000 | 0 | 0 | 118,000 |
| | | Bflo Sta 139 - Replace Transformers | C036639 | 0 | 0 | 1,104,000 | 472,000 | 1,288,000 | 2,864,000 |
| | | Bolton 51 - Trout Lake Rd 3 Phase | C049560 | 315,000 | 0 | 0 | 0 | 0 | 315,000 |
| | | Brook Road 55 - Corinth 51 Tie | C050690 | 416,000 | 0 | 0 | 0 | 0 | 416,000 |
| | | Brook Road 55 - Lake Desolation Rd | C050691 | 0 | 0 | 10,000 | 411,000 | 0 | 421,000 |
| | | Caledonia Sub 44 - Add a 34.5 Bker | C052446 | 0 | 0 | 268,000 | 269,000 | 0 | 537,000 |
| | | Camillus Dsub | C046637 | 0 | 0 | 0 | 13,000 | 0 | 13,000 |
| | | Church St 56 - Convert Vrooman Ave | C048241 | 0 | 91,000 | 0 | 0 | 0 | 91,000 |
| | | Clinton 53 - Baum & Burrell Roads | C050684 | 0 | 0 | 0 | 194,000 | 0 | 194,000 |
| | | Cortland_LVAC Network_Disassemble | C054442 | 0 | 0 | 0 | 640,000 | 0 | 640,000 |
| | | CR- 23553 Cedarvale ratio relief | C051803 | 0 | 310,000 | 0 | 0 | 0 | 310,000 |
| | | CR- LHH 44 2012 NYS PSC Action item | CD00953 | 0 | 240,000 | 0 | 0 | 0 | 240,000 |
| | | CR- LHH44-N Osceola Rd | C055443 | 0 | 0 | 240,000 | 0 | 0 | 240,000 |
| | | CR- Lords Hill 66 Reconductoring | C054563 | 0 | 0 | 280,000 | 0 | 0 | 280,000 |
| | | CR- Niles 51 Dolphin Point QRS | C053106 | 255,000 | 0 | 0 | 0 | 0 | 255,000 |
| | | CR- Reconductor 12861 | C048591 | 92,000 | 0 | 0 | 0 | 0 | 92,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|---------|-------------------------------------|-----------|---------|---------|-----------|-----------|---------|-----------|
| | | CR- Sandy Creek 51 rebuild CR 17 | C050681 | 0 | 10,000 | 0 | 500,000 | 0 | 510,000 |
| | | CR- Sandy Creek 51 Wart Rd rebuild | C050679 | 0 | 10,000 | 177,000 | 0 | 0 | 187,000 |
| | | CR- Teall-Hpkins Tie | C052064 | 0 | 298,000 | 0 | 0 | 0 | 298,000 |
| | | CR- Wine Creek 53 tie | C055690 | 0 | 0 | 102,000 | 0 | 0 | 102,000 |
| | | Delameter - 115kV circuit switchers | C051492 | 0 | 0 | 0 | 90,000 | 180,000 | 270,000 |
| | | Delameter Install two 20/26/33MVA | C046536 | 0 | 50,000 | 1,830,000 | 2,680,000 | 890,000 | 5,450,000 |
| | | Delameter F9352 reconfigured layout | C047886 | 0 | 0 | 0 | 1,100 | 420,000 | 421,100 |
| | | Delameter F9356-express& rebuild | C047877 | 0 | 0 | 0 | 992,000 | 184,000 | 1,176,000 |
| | | Delameter new F9355 - express | C047885 | 0 | 0 | 680,000 | 300,000 | 0 | 980,000 |
| | | DLine -To expand Rock Cut Sub Retir | CD00881 | 490,000 | 0 | 0 | 0 | 0 | 490,000 |
| | | East Malloy- feeders and getaways | CD01279 | 0 | 0 | 380,000 | 380,000 | 0 | 760,000 |
| | | East Molloy Second Transformer | C036188 | 0 | 0 | 0 | 1,502,000 | 383,000 | 1,885,000 |
| | | F0153 - Walker Rd PIW | C048179 | 0 | 0 | 105,000 | 0 | 0 | 105,000 |
| | | F0456/0457 Build feeder tie | C049540 | 0 | 0 | 360,000 | 0 | 0 | 360,000 |
| | | F22652 Knapp Rd - Storm Hardening | C052066 | 0 | 553,000 | 0 | 0 | 0 | 553,000 |
| | | F4361 PIW - Littleville Road | C047870 | 0 | 0 | 106,000 | 0 | 0 | 106,000 |
| | | F7863 Carmen Rd PIW | C048146 | 0 | 0 | 113,000 | 0 | 0 | 113,000 |
| | | F9263 - Phipps Road PIW | C049079 | 0 | 0 | 296,000 | 0 | 0 | 296,000 |
| | | F9263 - Route 31 PIW | C049084 | 0 | 0 | 172,000 | 0 | 0 | 172,000 |
| | | F9354 new tie | C056867 | 0 | 10,000 | 100,000 | 0 | 0 | 110,000 |
| | | Fly Rd Feeder Work | C046594 | 0 | 0 | 340,000 | 700,000 | 0 | 1,040,000 |
| | | Fly Rd Low side substation equipmen | C046722 | 0 | 814,000 | 0 | 0 | 0 | 814,000 |
| | | Fly Rd. Transformer Addition | C036189 | 0 | 140,000 | 1,000,000 | 121,000 | 0 | 1,261,000 |
| | | Fort Gage 54 - Route 9L Rebuild | C050680 | 0 | 0 | 0 | 587,000 | 0 | 587,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|-----------------------|---------|--------------------------------------|-----------|-----------|---------|---------|-----------|-----------|-----------|
| | | Hanson Aggregate Regulators | C046508 | 9,000 | 0 | 0 | 0 | 0 | 9,000 |
| | | Harris Road Substation Expansion | CD01088 | 500,000 | 0 | 0 | 0 | 0 | 500,000 |
| | | Hinsdale Dsub | C046638 | 0 | 0 | 0 | 13,000 | 0 | 13,000 |
| | | Knapp Rd 22651 Feeder Tie | C028716 | 0 | 663,000 | 0 | 0 | 0 | 663,000 |
| | | Little River new 95555 feeder | C050922 | 0 | 50,000 | 450,000 | 0 | 0 | 500,000 |
| | | Lockport Road 216 - Install TB#2 | C036057 | 0 | 0 | 0 | 700,000 | 5,000,000 | 5,700,000 |
| | | Lockport Road 216 - Install TB#2 - | CD01252 | 0 | 0 | 0 | 100,000 | 162,000 | 262,000 |
| | | Long Rd 209 - New F20955 | CD00964 | 0 | 0 | 50,000 | 1,382,000 | 0 | 1,432,000 |
| | | Long Road 209 - Install TB2 | CD00977 | 0 | 0 | 500,000 | 3,600,000 | 0 | 4,100,000 |
| | | Malone Second 115/13.2kV Bank | C054587 | 0 | 0 | 135,000 | 2,620,000 | 2,410,000 | 5,165,000 |
| | | Middleburgh 51/Schoharie 51 LS | C050764 | 0 | 10,000 | 126,000 | 0 | 0 | 136,000 |
| | | Midler Station Retirement | C046702 | 0 | 0 | 242,000 | 0 | 0 | 242,000 |
| | | Military Rd New Feeder 21055 | C036566 | 0 | 175,000 | 123,000 | 0 | 0 | 298,000 |
| | | Military Road 210 - Install TB#2 | C036056 | 1,700,000 | 500,000 | 0 | 0 | 0 | 2,200,000 |
| | | Mill St_LVAC_2014 Upgrades-N-2 | C053903 | 0 | 0 | 510,000 | 0 | 0 | 510,000 |
| | | Mill ST_LVAC_2014 Upgrades-Newell | C054438 | 0 | 0 | 0 | 160,000 | 0 | 160,000 |
| | | Mill St_LVAC_2014 Upgrades -N-1 | C054385 | 200,000 | 0 | 0 | 0 | 0 | 200,000 |
| | | Minor Storm Hardening - 32451 | C056486 | 100,000 | 435,000 | 0 | 0 | 0 | 535,000 |
| | | Mumford #50 - TB2 - Install New Fdr | C046589 | 0 | 0 | 0 | 843,000 | 2,961,000 | 3,804,000 |
| | | Mumford #50 - Install Transformer #2 | C046590 | 0 | 0 | 0 | 468,000 | 2,137,000 | 2,605,000 |
| | | MV-89552 Dyke Road - Rebuild | C052447 | 0 | 0 | 0 | 298,000 | 0 | 298,000 |
| | | MV-Lehigh 51 & 54 Tie Creation | C050004 | 0 | 10,000 | 0 | 440,000 | 0 | 450,000 |
| | | MV-Lehigh 66954 | C050003 | 0 | 500,000 | 0 | 0 | 0 | 500,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|---------|-------------------------------------|-----------|---------|-----------|-----------|---------|---------|-----------|
| | | Reconductoring | | | | | | | |
| | | MV-Minor Storm Hardening-33351 | C056560 | 0 | 195,000 | 0 | 0 | 0 | 195,000 |
| | | MV-Minor Storm Hardening-38361 | C056728 | 0 | 0 | 450,000 | 0 | 0 | 450,000 |
| | | MV-Minor Storm Hardening-70152 | C056733 | 65,000 | 0 | 0 | 0 | 0 | 65,000 |
| | | MV-Rome 54 -Hogsback Rd Reconductor | C050097 | 0 | 0 | 0 | 192,000 | 0 | 192,000 |
| | | MV-Rome 54-Lauther Rd - Reconductor | C050086 | 0 | 0 | 320,000 | 0 | 0 | 320,000 |
| | | MV-Salisbury 57/Middleville 71 Tie | C049966 | 0 | 10,000 | 0 | 940,000 | 0 | 950,000 |
| | | MV-Turin 65355 & 56 Tie creation | C050002 | 0 | 0 | 0 | 160,000 | 0 | 160,000 |
| | | MV-Whitesboro64 Feeder Tie | C058226 | 0 | 85,000 | 0 | 0 | 0 | 85,000 |
| | | N Leroy F0455 - Linwood Road PIW | C056629 | 0 | 0 | 50,000 | 800,000 | 0 | 850,000 |
| | | New Dist Sub - Tonawanda NYW DSub | C051266 | 750,000 | 1,906,000 | 3,470,000 | 241,000 | 0 | 6,367,000 |
| | | New Dist Sub -Tonawanda NYW DLine | C051265 | 75,000 | 532,530 | 855,000 | 27,200 | 0 | 1,489,730 |
| | | North Bangor Conversion (D-Line) | C046418 | 0 | 10,000 | 670,000 | 0 | 0 | 680,000 |
| | | North Bangor new 34.5/13.2kV Statio | C046423 | 0 | 0 | 0 | 60,000 | 424,000 | 484,000 |
| | | North Creek 52 - Edwards Hill Road | C050688 | 0 | 58,000 | 0 | 0 | 0 | 58,000 |
| | | North Creek 52 - Peaceful Valley Rd | C049622 | 0 | 430,000 | 0 | 0 | 0 | 430,000 |
| | | North Troy 12353 - MSH - Relocation | C058224 | 200,000 | 0 | 0 | 0 | 0 | 200,000 |
| | | NR-81452-Head Island Rd-Upgrade | C053190 | 0 | 0 | 0 | 0 | 204,000 | 204,000 |
| | | NR-Lowville-SW528 Replacement | CD00959 | 34,000 | 0 | 0 | 0 | 0 | 34,000 |
| | | NR-Riverview 84762-French Rd-Rbld | C050183 | 0 | 0 | 0 | 136,000 | 0 | 136,000 |
| | | NY - East_1 ph cutout mounted Rclrs | C053928 | 51,000 | 127,000 | 127,000 | 102,000 | 102,000 | 509,000 |
| | | NY_Central_1ph_Cutout_Mnt Reclosers | C059620 | 51,000 | 127,000 | 127,000 | 102,000 | 102,000 | 509,000 |
| | | NY_West_1 PH Cutout Mnted Reclosers | C059607 | 51,000 | 128,000 | 128,000 | 102,000 | 102,000 | 511,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|-----------------------|---------|---|-----------|-----------|---------|------------|------------|-----------|-------------|
| | | OgdenBrook 51-Convert Aviation Road | C053381 | 0 | 361,000 | 0 | 0 | 0 | 361,000 |
| | | Old Hawkeye Road Relocation-84561 | C055464 | 0 | 0 | 119,000 | 0 | 0 | 119,000 |
| | | OswegatchieRiverCrossin g Relocation | C057008 | 0 | 0 | 0 | 240,000 | 0 | 240,000 |
| | | Pine Grove 5956/Bartell 32555 Feede | CD00475 | 0 | 0 | 0 | 263,000 | 0 | 263,000 |
| | | Port Henry 52 - Dalton Hill Rd | C054284 | 0 | 0 | 81,000 | 0 | 0 | 81,000 |
| | | Pottersville 51 - East Shore Dr | C050682 | 0 | 0 | 10,000 | 250,000 | 0 | 260,000 |
| | | Queensbury 57 - Dream Lake Rd | C055592 | 0 | 0 | 56,000 | 0 | 0 | 56,000 |
| | | Reconductor 5552 tie to 5262 | C048837 | 0 | 0 | 325,000 | 0 | 0 | 325,000 |
| | | Reserve for Reliability Unidentifie | C046923 | 0 | 0 | -1,833,000 | 0 | 8,934,000 | 7,101,000 |
| | | | C046950 | 0 | 0 | -6,891,000 | -7,888,000 | 0 | -14,779,000 |
| | | Reynolds Rd 33455 - 3- Phase Line Ex | C046646 | 0 | 0 | 196,000 | 0 | 0 | 196,000 |
| | | Schuylerville 11 - Casey Rd Rebuild | C048066 | 0 | 0 | 110,000 | 0 | 0 | 110,000 |
| | | Shawnee Road 76 | C036059 | 3,000,000 | 0 | 0 | 0 | 0 | 3,000,000 |
| | | Shawnee Road 76 (DLine) | CD00967 | 5,000 | 215,000 | 0 | 0 | 0 | 220,000 |
| | | Starr Rd Second Xfrm- 13kv Bus Exten | C032368 | 8,000 | 0 | 0 | 0 | 0 | 8,000 |
| | | Starr Rd. Second Xfrm | C032503 | 8,000 | 0 | 0 | 0 | 0 | 8,000 |
| | | Starr Road Feeder Work | C046363 | 3,000 | 0 | 0 | 0 | 0 | 3,000 |
| | | Station 214 - Install TB2 | C029186 | 0 | 180,000 | 2,059,000 | 155,000 | 0 | 2,394,000 |
| | | Station 214 - New F21467 | C029187 | 0 | 0 | 605,000 | 900,000 | 0 | 1,505,000 |
| | | Temple Sub Central Breaker Upgrades | C059519 | 305,000 | 915,000 | 0 | 0 | 0 | 1,220,000 |
| | | Terminal Station Sub Relocation | C046613 | 0 | 0 | 800,000 | 4,004,000 | 2,548,000 | 7,352,000 |
| | | Union St 52 - Greene/King Rd Conver | C056649 | 0 | 0 | 0 | 0 | 20,000 | 20,000 |
| | | Union St 53 - Kenyon Hill Road | C050779 | 0 | 72,000 | 0 | 0 | 0 | 72,000 |
| | | Union St. 53 - County Hwy 67 | C050777 | 0 | 0 | 250,000 | 0 | 0 | 250,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|-------------------|-------------------------------------|-----------|------------|------------|------------|------------|------------|-------------|
| | | Vail Mills 51 - Noonan Rd Convert | C051412 | 0 | 0 | 158,000 | 0 | 0 | 158,000 |
| | | VO_Herkimer_Net_UG Primary Upgrade | C054844 | 0 | 0 | 0 | 0 | 400,000 | 400,000 |
| | | Watertown New 115/13.2 kV Substatio | C046610 | 0 | 402,000 | 4,845,000 | 719,000 | 0 | 5,966,000 |
| | | | C046627 | 0 | 385,000 | 2,718,000 | 3,345,000 | 0 | 6,448,000 |
| | | West Hamlin #82 - Install Transform | CD01089 | 2,273,000 | 2,427,000 | 0 | 0 | 0 | 4,700,000 |
| | | West Hamlin #82 - New TB2 - Install | CD01090 | 400,000 | 1,530,000 | 1,401,000 | 0 | 0 | 3,331,000 |
| | | West Sweden - Install New Station | C046593 | 0 | 0 | 600,000 | 3,200,000 | 3,200,000 | 7,000,000 |
| | | West Sweden -New Sta - Install Fdrs | C046591 | 0 | 0 | 120,000 | 1,550,000 | 1,457,000 | 3,127,000 |
| | | Whitaker Dsub | C046636 | 0 | 0 | 100,000 | 916,000 | 2,198,000 | 3,214,000 |
| | | Whitesboro 64, 65 and 66 Retirement | C050878 | 0 | 0 | 0 | 0 | 420,000 | 420,000 |
| | | Whitesville F10161 move to road | C056851 | 10,000 | 120,000 | 0 | 0 | 0 | 130,000 |
| | Reliability Total | | | 11,942,000 | 16,073,530 | 26,825,000 | 36,843,100 | 37,491,000 | 129,174,630 |
| | Storm Hardening | 42951-Blue Ridge Rd Storm Hardening | C052248 | 411,000 | 0 | 0 | 0 | 0 | 411,000 |
| | | 42951-Hoffman Road Storm Hardening | C052252 | 220,000 | 0 | 0 | 0 | 0 | 220,000 |
| | | Battenkill 57-FY17 Storm Hardening | C057386 | 20,000 | 252,000 | 0 | 0 | 0 | 272,000 |
| | | Chestertown 51-FY16 Storm Hardening | C057306 | 196,000 | 0 | 0 | 0 | 0 | 196,000 |
| | | Chestertown 52-FY17 Storm Hardening | C057366 | 20,000 | 178,000 | 0 | 0 | 0 | 198,000 |
| | | Columbian Road Rebuild | C052072 | 0 | 64,000 | 0 | 0 | 0 | 64,000 |
| | | F10451 Storm Hardening Part 1 | C057431 | 10,000 | 0 | 0 | 180,000 | 0 | 190,000 |
| | | F10451 Storm Hardening Part 2 | C057432 | 10,000 | 0 | 0 | 180,000 | 0 | 190,000 |
| | | F2861 East Otto Storm Hardening | C052044 | 0 | 300,000 | 0 | 0 | 0 | 300,000 |
| | | F2862 Storm Hardening | C057428 | 10,000 | 0 | 466,000 | 0 | 0 | 476,000 |
| | | North Shore Road - Rebuild | C052073 | 0 | 64,000 | 0 | 0 | 0 | 64,000 |
| | | Scofield 53 - FY16 Storm Hardening | C057289 | 240,000 | 0 | 0 | 0 | 0 | 240,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|-----------------------------------|-------------------------------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| | | Sheppard Rd 2951 - Storm Hardening | C057429 | 7,000 | 0 | 210,000 | 210,000 | 0 | 427,000 |
| | | Storm Hardening - Lowville 77354 fe | C046396 | 150,000 | 0 | 0 | 0 | 0 | 150,000 |
| | | Storm Hardening - Placeholder for N | C046390 | 0 | 0 | 500,000 | 500,000 | 500,000 | 1,500,000 |
| | | | C046391 | 0 | 0 | 500,000 | 500,000 | 500,000 | 1,500,000 |
| | | | C046392 | 0 | 0 | 0 | 0 | 1,000,000 | 1,000,000 |
| | | Wethersfield 2361 - Storm Hardening | C057411 | 7,000 | 0 | 361,000 | 0 | 0 | 368,000 |
| | Storm Hardening Total | | | 1,301,000 | 858,000 | 2,037,000 | 1,570,000 | 2,000,000 | 7,766,000 |
| | Substation Flood Mitigation | Front Street - Flood Mitigation | C053165 | 382,000 | 0 | 0 | 0 | 0 | 382,000 |
| | | Indian Creek Rd Substation | C056566 | 910,000 | 0 | 0 | 0 | 0 | 910,000 |
| | | St Johnsville - Flood mitigation | C053166 | 6,000 | 0 | 0 | 0 | 0 | 6,000 |
| | | Union Falls - Flood mitigation | C053167 | 350,000 | 1,926,000 | 0 | 0 | 0 | 2,276,000 |
| | | Whitesboro Flood Mitigation | C053164 | 283,000 | 0 | 0 | 0 | 0 | 283,000 |
| | Substation Flood Mitigation Total | | | 1,931,000 | 1,926,000 | 0 | 0 | 0 | 3,857,000 |
| | Substation Mobile | NY New Mobile Substation 23 kV - 13 | C046402 | 0 | 623,000 | 714,000 | 0 | 0 | 1,337,000 |
| | | NY New Mobile Substation 34.5 kV - | C046410 | 719,000 | 690,000 | 0 | 0 | 0 | 1,409,000 |
| | Substation Mobile Total | | | 719,000 | 1,313,000 | 714,000 | 0 | 0 | 2,746,000 |
| | Substation RTU | Bremen - EMS Expansion/RTU Installa | CD01301 | 185,000 | 0 | 0 | 0 | 0 | 185,000 |
| | | Buckley Corners #454 - EMS Expansio | C053047 | 157,000 | 0 | 0 | 0 | 0 | 157,000 |
| | | Corinth Station 285 - EMS Expansion | C053084 | 258,000 | 0 | 0 | 0 | 0 | 258,000 |
| | | Nassau Station #113 - EMS Expansion | C053046 | 230,000 | 0 | 0 | 0 | 0 | 230,000 |
| | | Port Henry #385 - EMS Expansion | C053048 | 258,000 | 0 | 0 | 0 | 0 | 258,000 |
| | | REP - Dist Subs Without RTUs | C019851 | 900,000 | 900,000 | 1,500,000 | 1,500,000 | 1,500,000 | 6,300,000 |
| | | Station 126 - EMS Expansion/RTU Ins | CD01299 | 77,000 | 0 | 0 | 0 | 0 | 77,000 |
| | | Station 129 Brompton Rd - EMS Expan | C053086 | 372,000 | 0 | 0 | 0 | 0 | 372,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|----------------------|-------------------------------------|-----------|-----------|---------|-----------|-----------|-----------|-----------|
| | | Station 139 Martin Rd - EMS Expan | C053088 | 295,000 | 0 | 0 | 0 | 0 | 295,000 |
| | | Station 154 George Urban-EMS Expans | C053085 | 225,000 | 0 | 0 | 0 | 0 | 225,000 |
| | | Station 63 - EMS Expansion/RTU Inst | CD01303 | 10,000 | 0 | 0 | 0 | 0 | 10,000 |
| | | Station 74 - EMS Expansion/RTU Inst | CD01294 | 180,000 | 0 | 0 | 0 | 0 | 180,000 |
| | | Wilton Station 329 - EMS Expansion | C053083 | 260,000 | 0 | 0 | 0 | 0 | 260,000 |
| | Substation RTU Total | | | 3,407,000 | 900,000 | 1,500,000 | 1,500,000 | 1,500,000 | 8,807,000 |
| | ERR | *Ashley 51 - Baldwin Corners Rd Ph4 | C056711 | 0 | 0 | 400,000 | 0 | 0 | 400,000 |
| | | *Brook Rd 52 - Lewis Rd Conversion | C049761 | 0 | 0 | 273,000 | 0 | 0 | 273,000 |
| | | *Burdeck 53 - Ratio & Recloser Repl | C057067 | 0 | 77,000 | 0 | 0 | 0 | 77,000 |
| | | *Burgoyne 51 - County Hwy 41 | C049790 | 0 | 0 | 95,000 | 0 | 0 | 95,000 |
| | | *Church St 53 - Cnty Hwy 132 Convrt | C049652 | 0 | 0 | 0 | 653,000 | 0 | 653,000 |
| | | *Crown Pt. 51 - Breed Hill Rd | C049750 | 96,000 | 0 | 0 | 0 | 0 | 96,000 |
| | | *Farnan Rd 51 - Bluebird Road | C029431 | 0 | 0 | 238,000 | 0 | 0 | 238,000 |
| | | *Florida-Stoner Feeder Tie | C050438 | 0 | 0 | 20,000 | 650,400 | 0 | 670,400 |
| | | *Grooms Rd 34556 - Rte 146 Reconduc | C050105 | 0 | 0 | 0 | 0 | 190,000 | 190,000 |
| | | *McClellan 51 - Union ST Conversion | C050085 | 0 | 800,000 | 0 | 0 | 0 | 800,000 |
| | | *Mumford 5052 - Reconductor/Convert | C049885 | 0 | 0 | 399,000 | 0 | 0 | 399,000 |
| | | *NR_Hammond 37061_Pleasant Val Rd | C049725 | 0 | 10,000 | 590,000 | 0 | 0 | 600,000 |
| | | *NR_Hammond 37061-Oak Point Rd | C049723 | 0 | 0 | 480,000 | 0 | 0 | 480,000 |
| | | *NR-Bremen 81556-Beech Hill Rd | C049789 | 0 | 10,000 | 590,000 | 0 | 0 | 600,000 |
| | | *NR-Chasm Falls 85251-Duane Rd-Tie | C049757 | 0 | 10,000 | 590,000 | 280,000 | 0 | 880,000 |
| | | *NR-Chasm Falls 85251-Pond Rd-Rbld | C049777 | 0 | 10,000 | 550,000 | 0 | 0 | 560,000 |
| | | *NR-Higley 92451-Joe Indian Area | C049745 | 0 | 0 | 400,000 | 0 | 0 | 400,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|---------|-------------------------------------|-----------|---------|---------|---------|---------|-----------|-----------|
| | | *NR-Higley 92451-NYS Hwy 56-FdrTie | C046864 | 0 | 680,000 | 0 | 0 | 0 | 680,000 |
| | | *NR-Higley 92451-NYSHwy56 Number9 | C046865 | 170,000 | 0 | 0 | 0 | 0 | 170,000 |
| | | *NR-Parishville 93961-Relocate Fdr | C049751 | 0 | 0 | 0 | 128,000 | 0 | 128,000 |
| | | *Rosa Rd 57-Balltown Rd Conversion | C050084 | 0 | 0 | 0 | 600,000 | 0 | 600,000 |
| | | *Sharon 52 - State Route 145 | C049792 | 0 | 0 | 10,000 | 160,000 | 0 | 170,000 |
| | | *St Johnsville 51-Bellinger Rd | C050381 | 0 | 0 | 0 | 255,000 | 0 | 255,000 |
| | | *Stoner 52 - Stoner Trail Extension | C050437 | 0 | 0 | 0 | 20,000 | 1,000,000 | 1,020,000 |
| | | *Union St 54-Lincoln Hill Rd Ph 2 | C056627 | 0 | 0 | 10,000 | 250,000 | 0 | 260,000 |
| | | *Union St. 53/54 - Route 22 Tie | C056620 | 15,000 | 0 | 170,000 | 0 | 0 | 185,000 |
| | | *Vail Mills 52/53 - Fish House Rd | C019351 | 0 | 0 | 0 | 0 | 51,000 | 51,000 |
| | | *Vail Mills 53 - Union Mills Rd. | C019352 | 0 | 0 | 0 | 0 | 708,000 | 708,000 |
| | | Amsterdam 51/53 Widow Susan area | C028835 | 0 | 0 | 114,000 | 0 | 0 | 114,000 |
| | | Ashley 51 - Baldwin Corners Rd Ph3 | CD01117 | 0 | 0 | 90,000 | 0 | 0 | 90,000 |
| | | Blue Stores 30353 - MSH-Bells Pond | C058019 | 200,000 | 0 | 0 | 0 | 0 | 200,000 |
| | | Bolton 51/Warrensburg 51 Feeder Tie | CD00606 | 0 | 10,000 | 540,000 | 0 | 0 | 550,000 |
| | | Bolton 52 Reconfiguration | C046782 | 65,000 | 0 | 0 | 0 | 0 | 65,000 |
| | | Boyntonvil 33351-John Snyder Rd Ext | C051268 | 0 | 0 | 320,000 | 0 | 0 | 320,000 |
| | | Brook Rd 54 - Route 50 Conversion | C048584 | 0 | 416,000 | 0 | 0 | 0 | 416,000 |
| | | Burdeck 26552 - Westcott / Curry Rd | CD01226 | 0 | 104,000 | 0 | 0 | 0 | 104,000 |
| | | Burdeck 54 - Duanesburg Rd Convert | C056558 | 0 | 0 | 20,000 | 320,000 | 0 | 340,000 |
| | | Burgoyne 51 - Close Gaps on County | CD00208 | 57,000 | 0 | 0 | 0 | 0 | 57,000 |
| | | Center St 52 - Hickory Hill Rd Conv | C056808 | 0 | 0 | 193,000 | 0 | 0 | 193,000 |
| | | Center St 54 - Hyney Hill Road Rebu | CD00357 | 0 | 0 | 154,000 | 0 | 0 | 154,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|-----------------------|---------|-------------------------------------|-----------|---------|---------|-----------|-----------|-----------|-----------|
| | | Chrisler Ave 25735 Conversion | C057133 | 0 | 0 | 20,000 | 0 | 0 | 20,000 |
| | | Chrisler Ave 25737 Conversion | C057132 | 0 | 0 | 20,000 | 0 | 0 | 20,000 |
| | | Clinton 36653-54 Conversion Tie | C053628 | 0 | 0 | 298,000 | 0 | 0 | 298,000 |
| | | CR- 6651, Relocte Ballou Rd | C049353 | 0 | 0 | 200,000 | 0 | 0 | 200,000 |
| | | Curry Rd 52 - Altamont 55 Tie | C057249 | 0 | 53,000 | 0 | 0 | 0 | 53,000 |
| | | Ephratah 31 - Mud Rd Relocation | C056866 | 0 | 125,000 | 0 | 0 | 0 | 125,000 |
| | | ERR Program Placeholder | C046684 | 0 | 0 | 2,000,000 | 2,000,000 | 2,000,000 | 6,000,000 |
| | | Florida 51 - Fort Hunter Road | C050693 | 0 | 0 | 0 | 133,000 | 0 | 133,000 |
| | | Florida 51 - Mead Road | C050692 | 0 | 0 | 0 | 120,000 | 0 | 120,000 |
| | | Front St 52 - Schermerhorn St Recon | C056746 | 20,000 | 0 | 290,000 | 0 | 0 | 310,000 |
| | | Inghams 51-Salisbury 56 Convrt/Tie | C056606 | 0 | 0 | 0 | 0 | 30,000 | 30,000 |
| | | Lynn 55 - Weaver St 51 Tie Convrt | C055708 | 0 | 0 | 238,000 | 0 | 0 | 238,000 |
| | | McClellan 52 - Strong Street Conver | C057130 | 0 | 0 | 20,000 | 0 | 0 | 20,000 |
| | | Middleburg 51 - Schoharie Creek Rem | C056970 | 0 | 0 | 0 | 46,000 | 0 | 46,000 |
| | | Middleburgh 51 - Spur Rd Relocate | C056987 | 0 | 0 | 53,000 | 0 | 0 | 53,000 |
| | | NR_Lyme 73351_T.I. 81455-NYSHwy12E | CD01295 | 0 | 0 | 0 | 320,000 | 0 | 320,000 |
| | | NR_N Carthage_81652_NYSHwy3_Interna | C046835 | 0 | 0 | 0 | 510,000 | 480,000 | 990,000 |
| | | NR-85251-NYS Hwy 30-FdrTie | C049760 | 0 | 0 | 577,000 | 577,000 | 577,000 | 1,731,000 |
| | | NR-92759-Mt Pisgah Rd-Relocation | C050201 | 0 | 0 | 0 | 0 | 141,000 | 141,000 |
| | | NR-98454-95554-Co Rt 25-FdrTie | C050518 | 300,000 | 0 | 0 | 0 | 0 | 300,000 |
| | | NR-Brady 95757-CoRt27-FdrTie | C046861 | 0 | 0 | 0 | 595,000 | 560,000 | 1,155,000 |
| | | NR-Brady 95757-Riverside Dr-FdrTie | CD01191 | 0 | 0 | 0 | 458,000 | 0 | 458,000 |
| | | NR-Lowville 77354-Pine | C046866 | 300,000 | 300,000 | 0 | 0 | 0 | 600,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|---|-------------------------------------|-----------|-----------|-----------|------------|-----------|-----------|------------|
| | | Grove Road-F | | | | | | | |
| | | NR-Sunday Creek 87651-StillwaterRd- | CD01084 | 240,000 | 0 | 0 | 0 | 0 | 240,000 |
| | | NR-T.I.81452-Grandview Park Rd-Rebu | CD01188 | 0 | 0 | 0 | 238,000 | 0 | 238,000 |
| | | NR-T.I.81458-County Route 1-FdrTie | CD01187 | 0 | 0 | 0 | 230,000 | 0 | 230,000 |
| | | Ogdenbrook 51 - Cottage Hill Rd | C054983 | 0 | 0 | 100,000 | 0 | 0 | 100,000 |
| | | Port Henry 51 - Rebuild Route 9N fr | CD00326 | 0 | 0 | 117,000 | 0 | 0 | 117,000 |
| | | Port Henry 52 - Moriah Road | C019070 | 0 | 0 | 235,000 | 0 | 0 | 235,000 |
| | | Reynolds Rd 33455 Conversion | C046683 | 0 | 0 | 0 | 134,000 | 0 | 134,000 |
| | | Schoharie 52 - State Route 443 Rebu | CD00424 | 0 | 0 | 298,000 | 0 | 0 | 298,000 |
| | | St Johnsville - Sanders Road (ERR) | C029439 | 0 | 0 | 95,000 | 0 | 0 | 95,000 |
| | | St. Johnsville 51 - Paris Rd ERR | C055323 | 0 | 0 | 0 | 63,000 | 0 | 63,000 |
| | | Union St 52 - Brownell Rd. Rebuild | C056657 | 0 | 0 | 80,000 | 0 | 0 | 80,000 |
| | | Union St 52 - Content Farm Rd. | C056710 | 0 | 0 | 105,000 | 0 | 0 | 105,000 |
| | | Union St 54 - Lincoln Hill Rd Ph 1 | C056625 | 0 | 0 | 106,000 | 0 | 0 | 106,000 |
| | | Vail Mills 52 - County Hwy 16 Convt | C055530 | 0 | 0 | 0 | 20,000 | 301,000 | 321,000 |
| | | Vail Mills 52 - Honeywell Corners | C055707 | 0 | 0 | 0 | 0 | 351,000 | 351,000 |
| | | Weaver 51 - Crane & Francis Convers | C057129 | 0 | 0 | 20,000 | 0 | 0 | 20,000 |
| | | Weaver 51 - Pleasant St Conversion | C057110 | 0 | 20,000 | 335,000 | 0 | 0 | 355,000 |
| | ERR Total | | | 1,463,000 | 2,625,000 | 11,453,000 | 8,760,400 | 6,389,000 | 30,690,400 |
| | Secondary Network Arcflash Mitigation | Arc Flash Mediation - 480V spot net | CD01278 | 1,122,000 | 1,333,000 | 1,333,000 | 1,333,000 | 1,333,000 | 6,454,000 |
| | | Arc Flash NY East Div 480V Spot NW | C047464 | 765,000 | 774,000 | 774,000 | 774,000 | 774,000 | 3,861,000 |
| | | NY West Div Arc Flash 480V Spot NW | C047461 | 1,244,000 | 1,244,000 | 1,244,000 | 1,244,000 | 1,244,000 | 6,220,000 |
| | Secondary Network Arcflash Mitigation Total | | | 3,131,000 | 3,351,000 | 3,351,000 | 3,351,000 | 3,351,000 | 16,535,000 |

2015 NY Capital Investment Plan

| Spending Rationale | Program | Project Name | Project # | FY16 | FY17 | FY18 | FY19 | FY20 | Total |
|--------------------|--|-----------------------------------|-------------|-------------|-------------|-------------|-------------|---------------|-------------|
| | Side Tap Fusing | IE - NC Side Tap Fusing | C015511 | 400,000 | 400,000 | 400,000 | 75,000 | 0 | 1,275,000 |
| | | IE - NE Side Tap Fusing | C015510 | 400,000 | 0 | 0 | 0 | 0 | 400,000 |
| | | IE - NW Side Tap Fusing | C015509 | 400,000 | 400,000 | 0 | 0 | 0 | 800,000 |
| | | Weaver 51 - Guilderland Ave Recon | C057032 | 0 | 0 | 20,000 | 242,000 | 0 | 262,000 |
| | Side Tap Fusing Total | | | 1,200,000 | 800,000 | 420,000 | 317,000 | 0 | 2,737,000 |
| | Distribution Transformer Replacement | IE - NC Dist Transformer Upgrades | C014846 | 250,000 | 250,000 | 250,000 | 250,000 | 250,000 | 1,250,000 |
| | | IE - NE Dist Transformer Upgrades | C015828 | 250,000 | 250,000 | 250,000 | 250,000 | 250,000 | 1,250,000 |
| | | IE - NW Dist Transformer Upgrades | C010967 | 250,000 | 250,000 | 250,000 | 250,000 | 250,000 | 1,250,000 |
| | Distribution Transformer Replacement Total | | | 750,000 | 750,000 | 750,000 | 750,000 | 750,000 | 3,750,000 |
| | System Capacity & Performance Total | | | 70,113,200 | 62,994,330 | 81,549,650 | 80,339,500 | 78,417,000 | 373,413,680 |
| Grand Total | | | 253,553,912 | 251,833,794 | 285,097,065 | 288,501,765 | 294,999,443 | 1,373,985,979 | |

Exhibit 4 – Revenue Requirement and Rate Impact

2015 NY Capital Investment Plan

Exhibit 4

NIAGARA MOHAWK POWER CORPORATION
Summary of Bill Impact Associated with FY15 - FY18 T & D Capex Only
For Fiscal Years 2016, 2017 & 2018
(\$000's)

| | FY 2016 | FY 2017 | FY 2018 |
|--|----------------|----------------|----------------|
| Depreciation Expense | 8,823 | 16,361 | 24,287 |
| <u>Rate Base:</u> | | | |
| Net Utility Plant | 587,957 | 1,055,922 | 1,557,040 |
| Accumulated Deferred Taxes | -51,543 | -93,513 | -145,025 |
| Total Rate Base | 536,414 | 962,409 | 1,412,016 |
| ROR | 9.79% | 9.79% | 9.79% |
| Return on Rate Base | 52,515 | 94,220 | 138,236 |
| Total Revenue Requirement Impact of FY15 - FY18 Capex Only | 61,338 | 110,581 | 162,523 |
| Rate Base Impact of Depreciation on 3/31/14 Embedded Plant | -85,236 | -255,709 | -426,182 |
| ROR | 9.79% | 9.79% | 9.79% |

2015 NY Capital Investment Plan

| | | | |
|--|------------------|------------------|------------------|
| Total Revenue Requirement Impact of 3/31/14 Embedded Plant | -8,345 | -25,034 | -41,723 |
| Total Revenue Requirement Impact of Capex less impact of Embedded Plant | \$52,993 | \$85,547 | \$120,800 |
| Allocation of Revenue Requirement to SC1 Residential Customers | 31,372 | 50,644 | 71,515 |
| SC1 Residential Customers Cumulative Bill Impact per kWh | \$0.00271 | \$0.00433 | \$0.00607 |

Assumptions:

- 1) FY15 per Company 8&4 forecast, FY16 - FY18 capex per the 1/31/2015 CIP filing (Transmission, Distribution & Sub-Transmission only)
- 2) NYS PSC Staff's Depreciation Rates per - Case 12-E-0201
- 3) ROR based on 9.3% ROE per file Joint Proposal - Case 12-E-0201, utilized FY16 ROR for all years.
- 4) Embedded historic plant generates depreciation expense that will reduce rate base (increase to depreciation reserve). Reduced the revenue requirement to include the inherent reduction to ratebase from depreciating embedded plant determined as follows:

| | |
|--|----|
| March 31, 2014 Electric Depreciable Plant | ## |
| Composite Electric Depreciation Rate | ## |
| Total Annual Electric Depreciation based on embedded plant | ## |

 Ratebase impact determined by using a half year average of annual depreciation per year
- 5) Accumulated Deferred Taxes were calculated incorporating the new tangible property regulations Reg. §1.263(a)-3(g).
- 6) Allocated revenue requirement to SC1 customers based on FY2016 T&D Revenue at Proposed Rates per Appendix 2, Schedule 3, page 3 filed in the Joint Proposal in Case No. 12-E-0201. Used FY2016 allocation for FY2017 and FY2018.
- 7) Determined bill impact based on FY2016 through FY2018 sales forecast in Company's current business plan.

Exhibit 5: Non-Wires Alternatives Update

National Grid has guidelines for the review and consideration of non-wires-alternatives (“NWAs”) in its planning processes. The guidelines outline two stages of review: one to identify potential areas of need in which NWAs may be feasible, and one to determine NWA feasibility and design, if applicable, for each area of need. The first stage is completed by transmission and distribution planners as they review potential capital investment needs and the second is completed by project managers in the Customer organization.

Initial NWA Feasibility Review

The initial review for projects with NWA potential takes place after the Company’s transmission and distribution planning groups conduct their annual capital needs assessment. This review is used to screen projects in those plans against specific criteria to identify any that have potential for a feasible NWA. The specific criteria are:

1. Cost. The traditional infrastructure solution, based on engineering judgment, must be estimated to cost more than \$1Million.
2. Load Reduction Needed. The necessary load reduction must be less than twenty percent of the total load in the area of the defined need.
3. Timing. The start of construction on the traditional infrastructure solution must be at least thirty-six months in the future.
4. Asset Condition. The investment need must not be based on asset condition.

These factors are important in determining appropriate compensation levels for NWA solutions and the time within which NWAs must be implemented to address the identified system needs. Projects that satisfy the initial criteria progress to the secondary NWA review.

Secondary NWA Review

The secondary NWA review determines whether a viable NWA solution exists. Typically, this review involves compiling historical electric load data for the area of the defined need and customer information, including usage, for all affected accounts. The information is used to estimate the time of year and time of day of peak loads, as well as the drivers of those loads. To the extent they are available, energy efficiency measure installations, distributed energy resources, regional appliance saturation survey data, town assessment data and other applicable studies or databases are considered.

Once the circumstances and load drivers are determined, options for real-time load reduction, load shifting and conservation are considered as best fits each situation. The

2015 NY Capital Investment Plan

Company considers energy efficiency products, distributed generation, demand response and other direct and indirect load control and conservation measures in developing components for an NWA project. To be viable, an NWA must be cost competitive with the wires alternative counterpart.

Projects Reviewed

To date the Company has considered over 1,600 capital projects for potential NWA solutions. Many of the projects considered did not pass the initial NWA screen because they were driven by asset condition issues, had need dates that were too immediate, had cost estimates that did not meet the criteria, or were unrelated to electric load (e.g., involved equipment retirements or non-infrastructure projects). Several projects passed the initial feasibility screen, but did not clear the secondary review because a viable NWA solution could not be identified. Additionally, one project that did pass the secondary NWA review—the West Sweden/Brockport load relief project—was being actively developed, however, during development, loads in the West Sweden/Brockport area increased faster than originally anticipated such that the need date and necessary load relief made an NWA project no longer feasible.

The Company continues to seek NWA opportunities, and has identified a potential project in a load-stressed area north of Buffalo. The Kenmore area is undergoing the secondary NWA review to determine the potential for customers to provide the load relief. If viable, the area also would become a primary candidate to demonstrate demand-side resource capability in response to the Commission's order on Dynamic Load Management in the REV proceeding (Case 14-M-0101).

In addition to work the Company is doing regarding potential micro-grids in the Potsdam/Clarkson University and Buffalo/Buffalo Niagara Medical Campus areas, the Company identified and submitted to NYSERDA nine areas in upstate NY to be evaluated and considered for distributed generation/micro-grid projects in connection with NYSERDA's NY Prize competition. These areas were initially chosen based on outage exposure criteria. Further evaluation would be needed to assess the feasibility and viability of distributed generation/micro-grid projects in these areas. In addition to potential distributed generation/micro-grid projects, other non-traditional solutions, such as DER, direct load control, energy storage (batteries, flywheels, compressed air energy storage and thermal storage), targeted energy efficiency and demand response, and other measures, will also be evaluated.

The Company is currently reviewing its NWA criteria in light of the experience gained since 2011 in an effort to improve its NWA guidelines, criteria and processes.

Exhibit 6: Overhead Line Refurbishment Projects

Alabama-Telegraph (C033014 - \$5.1m)

The overhead line details:

Total length: Approximately 4 miles
Conductor: 4/0 ACSR 6/1 "Penguin"
Number of steel structure units: 0
Number of wood structure units: 44 H-Frame
Typical Installation date: 1940s (some Q-sheets indicate line may be as early as 1931)

Conductor test results were marginal and the Step 0 team concluded the conductor should be replaced due to falling Zinc levels which means ductility will further decrease over time. It is estimated that 5-10 years of conductor life expectancy remains. Revised conceptual engineering was completed in April 2014.

Project scope is to reconductor with 477 kcmil ACSR 26/7 Hawk, install shieldwire on entire length of line and replace all structures with H-Frame or 3-pole dead-end pulloff structures on concrete foundations.

Boonville-Rome 3 & 4 (C047795 - \$8.9M)

This project involves the Boonville-Rome 3 T4060 and the Boonville-Rome 4 T4040-T4040 115 kV transmission circuits. These are doubled circuited.

The overhead line details:

Total length: Approximately 26 miles (main line only)
Conductor: 4/0 Copper and 336.4 ACSR
Number of steel structure units: 233
Number of wood structure units: 27
Steel: 206 (steel lattice type structures)
Typical Installation date: 1930s

The project scope is a life extension project involving the targeted replacement of deteriorated structures, insulators and fittings, replacement of conductor splices, replacement of shield wire, tower painting, and footer repairs.

2015 NY Capital Investment Plan

Brockport Tap (C055531 - \$1.2m)

This project involves a 3 mile portion of the 7.5 mile tap between Sweden – Brockport Stations, a taps off the Lockport-Mortimer 111 and 113 lines.

The overhead line details:

Total length: Approximately 7.5 miles
Conductor: 795 kcmil, 4/0 and 336.4 ACSR
Number of steel structure units: 1 (steel lattice switch structure)
Number of wood structure units: 39
Typical Installation Date: 1940s for the #111 tap, 1955 for the #113 tap

The project scope is a life extension project involving the targeted replacement of deteriorated structures, damaged insulators and fittings, replacement of conductor splices, and add shield wire. The conductor was installed in 1983 and not being replaced at this time.

Browns Falls-Taylorville 3 & 4 (C024359 - \$9.1m)

This project involves the double circuit Browns Falls-Taylorville 3 T3080 and the Browns-Taylorville 4 T3090 lines.

The overhead line details:

Total length: Approximately 27 miles
Conductor: 4/0 Copper
Total number of structures: 227
Number of wood structure units: 5
Number of steel structure units: 222
Type(s) of structures: Flex towers, lattice towers, and wood pole
Typical Installation date: 1920s

The project scope involves the replacement of approximately 20% of the structures, shield wire, insulators and hardware, guys, and grounding improvements which are deteriorated. The project is in preliminary engineering.

Colton-Browns Falls 1 & 2 (C036164 - \$10.7m)

This project involves the Colton-Browns Falls 1 & 2 T3140 and T3150 115 kV transmission lines. These are doubled circuited.

The overhead line details:

Total length: Approximately 30.5 miles

2015 NY Capital Investment Plan

Conductor: 336.4 ACSR Linnet
Number of steel structure units: 273
Number of wood structure units: 13
Typical Installation date: 1920s

The scope is a life extension project involving the targeted replacement of deteriorated structures, cross-arm hangers and conductor attachment plates on reused suspension flex towers. Replace original conductor hardware, nonstandard shieldwire, guys and anchors in poor condition. Improve structure grounding and install signage.

Gardenville-Dunkirk 141 & 142 (C003389 - \$56.1m)

This project involves the Gardenville-Dunkirk 141 (T1260) and the Gardenville-Dunkirk 142 (T1270) 115 kV transmission circuits.

The overhead line details:

Total length: Approximately 45 miles (main line, including the Seneca Nation)
Conductor : Varies – 250 kcm CU, 400 CU, 4/0 CU, 336 kcm ACSR, and 636 kcm AAC, and 795 ACSR.
Total number of structures: 586 structures
Number of wood structures: 39 structures
Number of steel structures: 547 structures (of which are 310 Ritter-Conley Flexible Towers with Z cross members)
Types of structures: Double circuit, primarily steel (Z type flex), structures
Typical Installation date: 1930s vintage

After climbing steel towers to perform conductor clearance work in advance of the line refurbishment, it was revealed that many towers were in worse condition than originally thought. Further climbing inspections and aerial photography were ordered and the results drove a decision to change the scope from a life extension project involving the targeted replacement of deteriorated structures, insulators and fittings, conductor splices, shield wire, tower painting, and footer repairs to a full line rebuild.

Gardenville 180 & 182 (C027436 - \$1.1m)

This covers the Packard-Gardenville 182 T1780 (in its entirety) and the Niagara-Gardenville 180 T1660 (from Packard to Ellicott Junction, Tonawanda).

The overhead line details:

Total length: Packard to Gardenville (Lines 180/182, 182/62, 182/54), approx. 29 miles
Conductor :
Packard-Tonawanda 180/182; varies - 795 ACSR "Drake", 795 ACSR "Coot", and 500 CU

2015 NY Capital Investment Plan

Packard-Tonawanda 180/105; 795 ACSR "Coot"

Packard-Tonawanda 182/92; 500 CU

Tonawanda-Urban 182/92; varies - 636 ACSR "Kingbird", 795 ACSR "Coot", and 400 CU

Urban-Gardenville 182/54; varies - 636 ACSR "Kingbird", 795 ACSR "Coot", and 400 CU

Total number of structures: 417 (count includes 180 section north of Packard in CNAS118, about 10% of the line on a mileage basis)

Number of wood structures: 20

Number of steel pole/structures: 397

Types of structures: Lattice towers, flex towers, wood poles, and steel poles.

Typical Installation date: 1930s

The project scope is a life extension involving the targeted replacement of deteriorated structures (estimated around 5-10%), insulators and fittings, replacement of conductor splices, replacement of shield wire, and coordination of tower painting and footer repairs. This project is currently in conceptual engineering. The final scope will be based upon an engineering field assessment, input from Transmission Planning, conductor testing, and shield wire testing.

Homer Hill-Bennett 157 (C027429 - \$7.2m)

This project involves the Homer Hill-Bennett Road 157 T1340 115 kV transmission line.

The overhead line details:

Total length: 52.5 miles (includes taps)

Conductor: Varies – 4/0 CU, 4/0 ACSR, 336 kcm ACSR, 795 kcm ACSR, 1192 kcm ACSR

Total number of structures: 471

Number of wood structure units: 463

Number of steel structure units: 7

Types of structures: Single circuit, primarily wood structures

Typical Installation date: 1950s (taps are 1970s vintage)

This project is in Step 0 (conceptual engineering) and undergoing scope development based upon an engineering field assessment, input from Transmission Planning, conductor testing, and shield wire testing. The project scope is the targeted replacement of deteriorated structures, insulators and fittings, and conductor splices and will be bundled with Level 3 wood pole replacements identified in the NY Capital Inspection & Maintenance program to gain construction efficiencies.

Lockport-Batavia 112 (C003422 - \$60.7m)

This project involves the Lockport-Mortimer 112 T1510 115 kV transmission circuit.

2015 NY Capital Investment Plan

The overhead line details:

Total length: Approximately 34 miles
Conductor: Varies - 250 Copper 19-Strand, 795 ACSR "Coot" 36/1, 336.4 ACSR "Linnet" 26/7, 428 AAC 19-Strand, and 636 AAC "Orchid"
Total number of structures: 369
Number of wood structure units: 156
Number of steel structure units: 213
Types of structures: Steel towers (178 of which are tri-leg towers) and wood pole structures (111 of which are single pole with davit arms).
Typical Installation date: 1930-1940s

About 3.5 miles of the Lockport-Batavia 112 shares a double circuit with the Lockport-Batavia 108. In addition, for roughly the first third of these lines, both lines run parallel with and share the Lockport-Mortimer 111 right-of-way. Combining the 112 and 108 lines to the same structures where possible is being considered to relieve congestion in the corridor and open up access to it.

This project is in Step 0 (conceptual engineering) and undergoing scope development based upon an engineering field assessment, input from Transmission Planning, conductor testing, and shield wire testing. The project scope is a life extension involving the targeted replacement of deteriorated structures, insulators and fittings, replacement of conductor splices, replacement of shield wire, tower painting, and footer repairs.

Mortimer – Pannell 24 25 (C047816 - \$5.3m)

This project involves the Mortimer-Pannell 24 25 T1600 T1590 115kV Transmission lines.

The overhead line details:

Total length: Approximately 16 miles
Conductor: 795 ACSR "Coot", 336.4 ACSR "Oriole", 336.4 AL "Tulip" and 336.4 ACSR Merlin
Total number of structures: 175 structures
Number of wood structure units: 7
Number of steel structure units: 168
Typical Installation date: parts originally built in 1920s, upgraded to current 115kV in 1948

Life extension project involving the targeted replacement of deteriorated structures, insulators and fittings, conductor splices and shield wire. Tower painting and footer repairs. Conductor testing has been initiated, project in conceptual engineering.

Pannell – Geneva 4 4A (C030889 - \$5.8m)

This project involves the Pannell-Geneva 4-4A T1860 115kV transmission line.

2015 NY Capital Investment Plan

The overhead line details:

Total length: Approximately 25 miles
Conductor: 795 ACSR "Coot" and 336.4 ACSR "Oriole"
Total number of structures: 269 structures
Number of wood structure units: 3
Number of steel structure units: 266 (including 1 steel pole)
Types of structures: predominantly the original 1906 Aermoter towers except at angle points which were replaced with dead-end towers
Typical Installation date: parts originally built in 1906, upgraded to current 115kV in 1948

A conceptual engineering report (CER) was completed in November 2009 which studied four options. Since it is five years old, the CER will be freshened. Life extension project involving the targeted replacement of deteriorated structures, insulators and fittings, conductor splices and shield wire. Tower painting and footer repairs. Conductor testing has been initiated, project in conceptual engineering.

Porter-Rotterdam 31 (C030890 - \$14.1m)

This project involves the Porter-Rotterdam 31 T4210 230 kV transmission line.

The overhead line details:

Total length: 72 miles, Steel structures (dual circuit with NYPA) 12 miles, wood structures (single circuit) 60 miles
Conductor: 1,431 kcm ACSR and 795 kcm ACSR
Total number of structures: 698 structures
Number of wood structure units: 610
Number of steel structure units: 88
Types of structures: Steel pole (double circuit) and wood H-frame (single circuit)
Typical Installation date: 1940s – 1950

The project scope is the targeted replacement of extremely deteriorated wood structures. The scope of this project may be affected by the Energy Highway Project selection.

Taylorville-Boonville 5 & 6 (C027437 - \$9.0m)

This project involves the Taylorville-Boonville 5 T3320 and the Taylorville-Boonville 6 T3330 115 kV transmission circuit.

The overhead line details:

Total length: Approx. 31 miles (main line)
Taps Included In Stats: No
Conductor: 4/0 copper

2015 NY Capital Investment Plan

Total number of structures: 310
Number of wood structure units: 181
Number of steel structure units: 129
Types of structures: Primarily steel lattice towers (127) and double circuit wood pole structures (174 2-pole structures).
Typical Installation date (mainline): Late 1920s to early 1930s; most of the wood structures from the 1990s.

The project scope is life extension with the targeted replacement of deteriorated structures, insulators and fittings replacements on the older steel structures, replacement of shield wire, tower painting, and footer repairs. Project in preliminary engineering and expected to be in service by FY17.

Ticonderoga 2 & 3 (C039521 - \$48.1m)

This project targets the Ticonderoga-Republic 2 T5810 and the Ticonderoga-Whitehall 3 T5830 115 kV transmission circuits.

The overhead line details:

Total length: Approximately 46 miles total with about 23 miles on the T5810 and 23 miles on the T5830
Conductor: Ticonderoga-Republic 2 - 336.4 kcmil ACSR 30/7 "Oriole" and 4/0 Copper conductors. Ticonderoga-Whitehall 3 - 336.4 kcmil ACSR 30/7 "Oriole" conductor.
Total number of structures: 350
Number of wood structure units: 343
Number of steel structure units: 7
Types of structures: Single circuit, primarily consisting of wood pole H-frame structures and steel lattice towers
Typical Installation date: 1920-1930s

The project scope is the targeted replacement of deteriorated structures (not previously replaced during the safety refurbishment project C039487 in this Plan which is being done in advance of this project), insulator and fittings replacement, replacement of shield wire and conductor splices. This project is about to enter Step 0 (conceptual engineering) and undergo scope development based upon the engineering field assessment performed, input from Transmission Planning, conductor testing, and shield wire testing.