

BEFORE THE
STATE OF NEW YORK
BOARD ON ELECTRIC GENERATION
SITING AND THE ENVIRONMENT

In the Matter of

Eight Point Wind LLC

Case 16-F-00062

January 22, 2018

Prepared Testimony of:

Miguel Moreno-Caballero
Utility Engineering Specialist 3
(Acoustics)
Office of Electric, Gas, and
Water

State of New York
Department of Public Service
One Empire State Plaza
Albany, New York 12223-1350

1 Q. Will you please state your name, employer, and
2 business address?

3 A. My name is Miguel Moreno-Caballero and I am
4 employed by the New York State Department of
5 Public Service (DPS or the Department), located
6 at Three Empire State Plaza, Albany, New York,
7 12223.

8 Q. Mr. Moreno what is your position at the
9 Department?

10 A. I am a Utility Engineering Specialist 3
11 (Acoustics) in the Environmental Certification
12 and Compliance section of the Office of
13 Electric, Gas and Water (Staff).

14 Q. Please summarize your educational background and
15 professional experience.

16 A. I attended the Pontifical Xaverian University in
17 Bogota, Colombia and received a Bachelor of
18 Science degree in Civil Engineering in 1986.
19 Thereafter, I continued my education at
20 Universidad del Norte in Barranquilla, Colombia
21 and graduated with a Master in Business
22 Administration in 1992. I have accumulated more

1 than 20 years of experience in the field of
2 acoustics and noise control. I owned and
3 operated my own business in Colombia, South
4 America for about 13 years, where I worked as an
5 acoustical consultant and acoustical contractor.
6 I designed and built noise abatement solutions
7 for emergency generators, industrial machinery,
8 HVAC equipment, and interior acoustical designs
9 for indoor spaces. I obtained extensive
10 experience in noise control including noise
11 surveys and computer simulations of aircraft
12 noise for two international airports.
13 After my arrival to the United States, I was
14 employed as a Senior Acoustical Consultant by an
15 acoustical consultant firm in Washington D.C.,
16 from October 2005 until May 2008. There, I
17 analyzed sound surveys and performed computer
18 noise modeling for roadways and highways and
19 designed mitigation measures such as barriers
20 and selected building envelope specifications
21 for environmental noise control. I also
22 designed noise control solutions for mechanical

1 equipment and interior acoustics for indoor
2 spaces for a variety of projects. From May 2008
3 to June 2009, I was employed by an acoustical
4 consultant company in Manhattan and worked for
5 several acoustical and noise control projects
6 including data centers and corporate projects.
7 I joined the Department in November 2013. My
8 duties include reviewing Public Service Law
9 (PSL) Article VII and Article 10 pre-
10 applications, applications, environmental noise
11 assessments, noise surveys and mitigation
12 measures. I also review sound collection
13 protocols and witness sound measurements to
14 ensure compliance with Certificate Conditions.
15 I am a full-member of the Institute of Noise
16 Control Engineering and an Associate member of
17 the Acoustical Society of America.

18 Q. Mr. Moreno, which projects have you reviewed
19 under PSL Article 10 and Article VII
20 regulations?

21 A. Under Article VII regulations, I have reviewed
22 the applications for the following certified

1 cases: New York Power Authority, Case 13-T-0515;
2 DMP New York, Inc., Williams Field Services
3 Company LLC, Cases 13-T-0538 and 13-T-0350; PSEG
4 Power New York, Inc. Case 15-F-0040; and
5 Consolidated Edison Company of New York, Inc.,
6 Case 13-T-0586. Although currently pending or
7 uncertified, I also reviewed environmental noise
8 assessments for the following Article VII
9 projects: West Point Partners LLC, Case 13-T-
10 0292; Poseidon Transmission, LLC, Case 13-T-
11 0391; In the Matter of Alternating Current
12 Transmission Upgrades - Comparative Proceeding,
13 Case 13-E-0488; Vermont Green Line Devco, LLCI,
14 Case 16-T-0260; and Niagara Mohawk Power
15 Corporation, Case 15-T-0305. I am currently
16 working on numerous PSL Article 10 proceedings
17 (and some potentially affiliated Article VII
18 filings) regarding wind generating facilities at
19 various stages including the following projects:
20 Cassadaga Wind, LLC, Case 14-F-0490 already
21 certified by the New York State Board on
22 Generation siting and the Environment (Siting

1 Board); Lighthouse Wind, LLC, Case 14-F-0485;
2 Baron Winds, LLC, Case 15-F-0122; Galloo Island,
3 Case 15-F-0327; Bull Run Energy, LLC, Case 15-F-
4 0377; Eight Point Wind, LLC, Case 16-F-0062;
5 Atlantic Wind, LLC -Deer River-, Case 15-F-0267;
6 Canisteo Wind Energy, LLC, Case 16-F-0205; Case
7 16-F-0267;; Number Three Wind LLC, Case 16-F-
8 0328;; Heritage Wind LLC, Case 16-F-0546;
9 Bluestone Wind, LLC, Case 16-F-0559; Alle-Catt
10 Wind Energy, LLC, 17-F-0282 and Atlantic Wind,
11 LLC, -Mad River-, Case 16-F-0713. I am also
12 assigned on multiple PSL Article 10 proceedings
13 (and some potentially affiliated Article VII
14 filings) regarding solar generating facilities
15 at various stages including the following
16 projects: Mohawk Solar, LLC, Case 17-F-0182;
17 Hecate Energy Albany 1, LLC and Hecate Energy
18 Albany 2, LLC, Case 17-F-0617; and Hecate Energy
19 Greene County 1, LLC, Hecate Energy Greene 2,
20 LLC, and Hecate Energy Greene County 3, LLC,
21 Case 17-F-0619.

22 Q. Are you sponsoring or relying upon any other

1 exhibits?

2 A. Yes. I am sponsoring Exhibit__(MMC-1); through
3 Exhibit__(MMC-13).

4 Q. Please briefly described those exhibits.

5 A. Exhibit__(MMC-1) contains the document entitled
6 "Guidelines for Community Noise," World Health
7 Organization, 1999 (WHO 1999) which I will refer
8 to as "WHO-1999",
9 Exhibit__(MMC-2) contains a link to download the
10 document entitled "Guidelines and
11 Recommendations" which I will refer to as WHO-
12 2009.

13 Exhibit (MMC-3) contains and executive summary
14 of the most recent guidelines from the World
15 Health Organization (WHO) regional office for
16 Europe entitled "Environmental Noise Guidelines
17 for the European Region" published in October
18 2018 which I will refer to as "WHO-2018-ES".
19 Exhibit (MMC-4) contains the most recent
20 guidelines from the World Health Organization
21 (WHO) regional office for Europe entitled
22 "Environmental Noise Guidelines for the European

1 Region" published in October 2018 which I will
2 refer to as as "WHO-2018".
3 Exhibit_(MMC-5), contains a study entitled
4 "Massachusetts Study on Wind Turbine Acoustics.
5 Prepared for: Massachusetts Clean Energy Center
6 and Department of Environmental Protection.
7 Submitted by RSG Inc. Report 2.18.2016," which I
8 will refer to as MA-STUDY-2016 in my testimony.
9 Exhibit (MMC-6) contains my notes on Figure 26,
10 Page 69 of the MA-STUDY-2016.
11 Exhibit (MMC-7) contains the proposed
12 certificate Conditions on noise and vibration
13 that I am recommending for this Project.
14 Exhibit__(MMC-8) contains a Sound Testing
15 Compliance Protocol that I have developed and am
16 proposing for this project which I will refer to
17 as DPS-Protocol.
18 Exhibit__(MMC-9) contains Table 2 of a reference
19 called "Percentiles of Normal Hearing-Threshold
20 Distribution Under Free-Field Listening
21 Conditions in Numerical Form". Kenji Kurakata,
22 Tazu Mizunami, and Kuzama Matsushita. Acoust.

1 Sci. & Tech. 26, 5 (2005), which I will refer to
2 as KURAKATA-2005
3 Exhibit__(MMC-10) contains a drawing showing the
4 turbines proposed for this project and the
5 locations of non-participating residences
6 differentiated to indicate the short-term noise
7 levels reported in the Application.
8 Exhibit (MMC-11) contains an alternative to the
9 certificate conditions that I am presenting for
10 consideration including both a red-line and a
11 clean version.
12 Exhibit (MMC-12) contains a red line comparison
13 between certificate conditions proposed by the
14 Applicant and my proposed Certificate
15 Conditions.
16 Exhibit (MMC-13) contains my preliminary
17 comments and edits on the protocols presented in
18 the Application.
19 Q. Mr. Moreno, what is your role under PSL Article
20 10 regulation review?
21 A. Under Article 10, my duties include the review
22 of preliminary scoping statements, stipulations

1 and applications as they relate to the noise
2 assessments and avoidance or minimization of
3 environmental noise impacts from major electric
4 generation facilities. My role regarding wind
5 generating projects consists of the review of
6 sections of the Application related to noise
7 impact assessments from construction and
8 operation of the facilities which includes pre-
9 construction ambient noise surveys, analysis of
10 existing or potential future prominent tones,
11 noise modeling parameters, assumptions and
12 results, amplitude modulation, low-frequency
13 noise, infrasound, potential for hearing damage,
14 indoor and outdoor speech interference,
15 interference with the use of outdoor public
16 facilities and public areas, community complaint
17 potential or annoyance, and the potential for
18 interference with technological, industrial or
19 medical activities that are sensitive to
20 vibration or infrasound. In addition, my role
21 also includes the review of applicable noise
22 standards and guidelines, local regulations on

1 noise, design goals for the facilities, noise
2 abatement measures, complaint and resolution
3 plans for noise from construction and operation
4 of the facility, and proposed post-construction
5 noise evaluations and compliance for conformance
6 with certificate conditions.

7 Q. Why is the noise expected to be generated from
8 the Eight Point Wind LLC Project (Project) an
9 important issue for the Siting Board to consider
10 in this proceeding?

11 A. Public Service Law §164 and the implementing
12 regulations, 16 NYCRR 1001.19, require an
13 applicant for a Certificate of Environmental
14 Compatibility and Public Need (Certificate), to
15 provide certain information concerning the noise
16 and vibration impacts of the construction and
17 operation of a facility. In addition, the
18 various noise levels expected from a major
19 electric generating facility, including a wind
20 generating facility like this Project, are
21 important factors in determining the nature of
22 the probable environmental impacts of the

1 construction and operation of the proposed
2 facility and whether it avoids or minimizes
3 environmental impacts to the maximum extent
4 practicable.

5 Q. Can you please describe the different labels
6 such as L_{eq} , and the L_{90} , often used to describe
7 noise levels?

8 A. Noise levels frequently fluctuate over a wide
9 range and over time, so different sound
10 descriptors have been developed to describe
11 sound pressure levels over a period of time.
12 The " L_{eq} " is the equivalent-continuous sound
13 pressure level of a noise source. It is the
14 single sound pressure level that, if constant
15 over a specified time period, would contain the
16 same sound energy as the actual monitored sound
17 that varies in level over the measurement
18 period. Guidelines for noise are sometimes
19 expressed in terms of maximum noise levels
20 specifying the period of time over which the
21 measurements are taken. For example, 45 dBA L_{eq}
22 (8 hours) means that the noise levels evaluated

1 during 8 hours have an energy average equivalent
2 to a constant level of 45 dBA.

3 Q. What is a percentile level?

4 A. The L_n is the percentile level, where n is any
5 number between 0 and 100. The number designated
6 by n corresponds to the percentage of the
7 measurement time period by which the stated
8 sound level has been exceeded. (See, James P.
9 Cowan, Handbook of Environmental Acoustics, J.
10 Wiley [1994], p. 41). For instance, the L_{90} is
11 the sound level that is exceeded 90 percent of
12 the time, usually regarded as the "residual
13 level" or the background noise without the
14 source in question or discrete sound events
15 (Cowan, p. 41).

16 Q. What does the designation "dBA" mean?

17 A. "dB" is a designation for "decibel" which is
18 equivalent to a tenth of a "Bell" (a unit named
19 after Alexander Graham Bell). A Bell is too
20 large to describe the acoustic environment and
21 for that reason was broken into tenths or
22 "decibels." (Cowan, p. 41). The "A" letter after

1 the "dB" designation denotes one of the most
2 common weighting networks in acoustics and noise
3 control. The human ear does not sense all
4 frequencies in the same manner, and the human
5 ear does not hear sounds at different
6 frequencies the same way a typical microphone in
7 a sound level meter does. (Cowan p. 36). For
8 that reason, the "A-weighted" scale was
9 developed and is comprised of a series of
10 corrections applied to the sound levels measured
11 by a sound level meter at all frequencies of the
12 human audible spectra to resemble human hearing.
13 (Cowan p. 31). Although the normal hearing range
14 in humans goes from 20 Hertz up to 20,000 Hertz,
15 humans are more sensitive to sound with
16 frequencies between 200 Hertz and 10,000 Hertz
17 (Cowan p. 36) and for that reason the greatest
18 corrections are applied to the low frequencies.
19 (e.g. minus 57 dB at 16 Hertz). In addition, we
20 hear the sound levels between 500 Hertz and
21 4,000 Hertz similar to the way it is perceived
22 by a sound level meter microphone and for that

1 reason the corrections are lower ranging from
2 minus 3.2 dB at 500 Hertz up to 1.0 dB at 4,000
3 Hertz. After all corrections are applied to each
4 frequency sound level, the individual
5 contributions to the dBA level are added up and
6 the result is noted as "overall," "broadband,"
7 "dBA" or "dBA-weighted" noise level.

8 Q. Does the proposed Project avoid or minimize the
9 adverse environmental noise impacts to the
10 maximum extent practicable?

11 A. No. While the Project as proposed does provide
12 for some mitigation and avoidance of impacts, I
13 believe that potential adverse environmental
14 noise impacts from operation of the facility
15 have not been avoided or minimized to the
16 maximum extent practicable.

17 Q. Please explain your general impressions of the
18 Content of the Application for this project and
19 a summary of your findings.

20 A. I find that the design of the Project as
21 originally proposed will most likely comply with
22 the most relevant thresholds and criteria at

1 most receptors, but not all. I also note that
2 the computer noise modeling did not use Noise
3 Reduction Operations (NROs) to demonstrate
4 conformance with design goals at most receptors
5 which I think is not only a good approach during
6 the design phase but should be maintained during
7 the Siting process. However, this does not mean
8 that I agree with all the content of the
9 Application. In fact, I disagree with some of
10 the assumptions in the Application such as
11 interpreting computer sound results with the ISO
12 9613-2 Standard as the maximum hourly levels of
13 the project, the introduction of corrections to
14 the CONCAWE calculations to match the results
15 with the ISO 9613-2, the evaluation of sound
16 levels at 1.5 meters exclusively which may be
17 appropriate only for one-story residences but
18 not for residences with two or more stories,
19 among others. In addition, the World Health
20 Organization released new guidelines in October
21 of 2018, after the Application was filed, with
22 specific recommendations to address wind turbine

1 noise and with potential implications that I
2 consider important to be considered by the
3 Siting Board.

4 Q. What are the most important findings from your
5 review of WHO-2018 as related to this project?

6 A. One of the most important findings is that WHO-
7 2018 withdrew the outdoor short-term
8 recommendation of not exceeding 45 dBA-Leq-8-
9 hour during the nighttime that it had
10 recommended in 1999. WHO-1999 was the basis for
11 recommending the Siting Board that this short-
12 term limit be applied to Cassadaga Wind LLC in
13 Case 14-F-0490. In addition, WHO-2018 (p. 9)
14 recommends a lower outdoor-to-indoor noise
15 reduction provided by the residential buildings
16 than the one that was assumed in 1999 for
17 transportation noise sources, as well as
18 maintaining the indoor noise levels as
19 recommended in 1999. Furthermore, the new
20 recommendation from WHO-2018 is protective not
21 only of the nighttime period but of the daytime
22 and evening time periods as well and more

1 importantly it may require a lower long-term
2 nighttime noise limit than as recommended in
3 2009 which was also the basis for recommending
4 the Siting Board adopting a long-term goal for
5 Cassadaga Wind. After analyzing the
6 recommendations of WHO-1999, WHO-2009, and the
7 WHO-2018 independently, I recommend that the
8 short term 45 dBA-Leq-8-h is not the most
9 protective among all the three guidelines and
10 that a shorter limit, on the order of 42-dBA
11 should be adopted so that all three WHO
12 guidelines and recommendations are met and that
13 the potential adverse effects from the facility
14 are minimized.

15 Further I have identified a few turbines that
16 should be either re-located or eliminated from
17 consideration so that the adverse effects are
18 reduced on the most impacted receptors.

19 In addition, I do not find the post-construction
20 compliance monitoring protocol presented in the
21 Application as appropriate to demonstrate that
22 the adverse effects from the facility were in

1 fact avoided or minimized to the most extent
2 practicable and for that reason I am
3 recommending a different protocol for
4 consideration. Details of my findings are
5 presented in this testimony.

6 Q. What are your general impressions of the
7 Certificate Conditions proposed by the
8 Applicant.

9 A. The Proposed Certificate Conditions presented by
10 Eight Point Wind are similar to those applied by
11 the Siting Board in Case 14-F-0490, Cassadaga
12 Wind. I will be explaining the changes that I
13 consider important and some recommendations for
14 simplification of the Certificate Conditions,
15 and post-construction noise testing.

16 Q. Please explain the first recommendation about
17 the Certificate Conditions proposed by the
18 Applicant for Eight Point Wind?

19 A. I note an insertion of a provision in
20 Certificate Condition 65 (d) specifying that
21 "[r]evised sound modeling shall not incorporate
22 more than 3 dBA of the available NROs." As I

1 will discuss in my testimony, NROs should not be
2 used in a compliance filing to demonstrate
3 conformance with relevant criteria and
4 conditions that the Siting Board may impose on
5 Eight Point Wind, but rather as a contingency
6 mitigation option to be used after construction.
7 For that reason, this provision should be
8 replaced by one specifying that NROs shall not
9 be used for demonstrating conformance with the
10 Order in compliance filings.

11 Q. Do you disagree with any other proposed
12 Certificate Conditions?

13 A. Yes. Certificate Condition 77 states: "The
14 Certificate Holder shall evaluate in a
15 Compliance Filing which of the four alternate
16 turbine locations, if any, are necessary to be
17 employed in the following order of preference,
18 Alternate Turbine 1, Alternate Turbine 4,
19 Alternate Turbine 2, and Alternate Turbine 3. If
20 an alternate turbine location is deemed
21 necessary, the Certificate Holder will select
22 Alternate Turbine locations 1 and/or 4, then

1 2...." This condition should be modified
2 consistent with my recommendations that the
3 Applicant 1) eliminates Turbine #10 and use
4 ALT1 instead, which will reduce the impacts on
5 receptors 327 and 329; 2) eliminates Turbine #5
6 and use ALT2, which will reduce the impacts on
7 receptors 692 and 325; 3) eliminates ALT3 from
8 consideration, as its use would burden
9 receptors 456 and 454; and 4) eliminates Turbine
10 #20 and use adjacent turbine ALT4, which will
11 reduce the impacts on receptors 771 and 522. All
12 these recommendations are proposed to decrease
13 the noise levels on the most impacted receptors,
14 with short-term sound levels predicted between
15 43 and 44 dBA which are depicted in red and
16 orange colors in the Figure included in Exh MMC-
17 10. I will be explaining further in my testimony
18 why the sound levels at these receptors should
19 be reduced.

20 Q. Do you have any other comments on the proposed
21 certificate conditions?

22 A. Yes, all the changes that I am proposing on the

1 certificate conditions proposed by the Applicant
2 can be seen in exhibit MMC-12 but I will be
3 discussing most of them at the end of my
4 testimony. However, I would like to start with a
5 discussion regarding the short-term noise limits
6 included in Certificate Condition 74 (a)
7 proposed by the Applicant in light of the most
8 recent recommendations by the World Health
9 Organization. The most recent guideline, WHO-
10 2018, states: "[t]he current environmental noise
11 guidelines for the European Region supersede the
12 [WHO Guidelines for Community Noise] (CNG) from
13 1999 (p. 28). Nevertheless, the [Guideline
14 Development Group] GDG recommends that all CNG
15 indoor guideline values and any values not
16 covered by the current guidelines (such as
17 industrial noise and shopping areas) should
18 remain valid."
19 What this means is that the 45 dBA-Leq-8-h
20 outdoor from WHO-1999 was replaced with a new
21 recommendation that is potentially more
22 protective than the previous WHO-1999 guideline

1 for the nighttime and that the WHO-1999 indoor
2 recommendation of 30 dBA-Leq-8-h nighttime was
3 retained. I note that in 1999 the 45 dBA-Leq-8-
4 h outdoor recommendation was based on the
5 addition of an assumed 15-dBA outdoor-to-indoor
6 noise reduction to the 30-dBA-Leq-8-h nighttime
7 indoor recommendation ($30+15=40$). The outdoor-
8 to-indoor noise reduction is provided by the
9 exterior building components (e.g. exterior
10 walls, windows and roofs).

11 Q. Why is that a concern?

12 A. The concern is whether residences could provide
13 a 15-dBA noise reduction against wind turbine
14 noise so that they can be exposed to a maximum
15 outdoor noise level of 45-dBA-Leq-8-h and still
16 comply with a 30-dBA-Leq-8-h indoor
17 recommendation from WHO-1999. While good
18 quality construction may provide more than 15-
19 dBA reduction with the windows closed, it may
20 not be able to provide such reduction with the
21 windows open or partially open. The rule-of-
22 thumb is that a light-weight residence may

1 provide about 10 dBA outdoor-to-indoor reduction
2 with the windows open.

3 Q. What are the implications for this case?

4 A. According to the WHO-2018 (p.9) and other
5 references, the outdoor-to indoor noise
6 reductions against wind turbine noise with the
7 windows open are between 10 dBA and 12 dBA, not
8 15 dBA. If a residence provides only a 10 dBA
9 to 12 dBA noise reduction with the windows open,
10 it should not be exposed to more than 40 dBA to
11 42 dBA outdoor during the nighttime so that the
12 indoor recommendation of 30 dBA-8-h can be met.

13 Q. What is your conclusion?

14 A. WHO-2018 shows that an outdoor limit of 45 dBA
15 during the nighttime may not be sufficiently
16 protective if residents have open windows, a
17 condition that may occur during the summer and
18 as a result outdoor limits should be between 40
19 dBA to 42 dBA Leq-8-hour and not 45 dBA-Leq-8-h
20 so that the indoor recommendations from WHO-1999
21 of 30 dBA-Leq-8-h can be met. As I will explain
22 later in my testimony the short-term limit

1 should also be lower than 45 dBA-Leq for other
2 reasons.

3 Q. What are the findings of your review of the
4 short-term outdoor impacts on noise sensitive
5 receptors for Eight Point Wind?

6 A. The Application included computer noise modeling
7 by using the ISO-9613-2 propagation model with
8 no meteorological correction by using the
9 maximum broadband (overall) sound power levels
10 from the turbines under consideration as
11 stipulated for the project. Other assumptions
12 included the use of a ground factor G of 0.5 and
13 a correction of 2 dBA added to the results and a
14 height of evaluation of 1.5 meters for sound
15 sensitive receptors that represents the height
16 of the human ears above the ground. The
17 interpretation of the results in the Application
18 is that they correspond to the maximum 1-hour
19 sound levels from the Facility (1-hour and 8-
20 hour) at sensitive sound receptors that could
21 occur in a year.

22 Q. Do you agree with that interpretation?

1 A. No, I do not. I think that the actual maximum
2 short-term sound levels could be greater than
3 those calculated with those assumptions.

4 Q. Do you have any evidence supporting that?

5 A. Yes, in my review of studies concerning accuracy
6 of the ISO-9613-2 model I found one where the
7 use of the ISO-9613-2 sound propagation model
8 with similar assumptions and input values to the
9 ones that were used in the Application, resulted
10 in about a 3-dBA underprediction of the Leq-1-
11 hour noise descriptor for one out of six 1-hour
12 samples and one out of the two highest sound
13 pressure levels that were modeled and measured.

14 Q. What is the study you refer to and which is the
15 section that shows the underprediction?

16 A. The study is entitled "Massachusetts Study on
17 Wind Turbine Acoustics" (Ex. MMC-5) which was
18 prepared for the Massachusetts Clean Energy
19 Center and Department of Environmental
20 Protection. The findings relevant to this case
21 are shown on Figure 26, page 68, and is included
22 as Ex. MMC-5. The figure has three graphs and

1 the one at the bottom shows a correlation
2 between sound pressure levels estimated at a
3 receptor located 330 meters (1,083 feet)
4 downwind from the turbines as obtained with the
5 ISO-9613-2 sound propagation model and a ground
6 factor of G 0.5 plus a 2-dBA correction added to
7 the results. The figure correlates the
8 estimates to the sound pressure levels that were
9 measured after monitoring the 1-hour Leq-dBA
10 noise descriptor for six hours at that receptor.
11 This can easily be observed in Ex. MMC-6 where I
12 have included my notes on top of the relevant
13 graph. As it can be seen from the graph in one
14 out of the six hours, the sound pressure levels
15 using computer noise modeling were 3 dBA lower
16 than as measured after monitoring (43 dBA as
17 opposed to 46 dBA). The 3-dBA underestimate
18 occurred for one of the two highest sound
19 pressure levels. This also shows that although
20 the addition of 2 dBA to the ISO 9613-2 results
21 improves the accuracy of the estimates, it is
22 not sufficient for one out of two samples at the

1 maximum sound power levels. In this case a
2 correction of 5 dBA, not 2 dBA, is needed to
3 estimate the actual maximum 1-hour sound levels.

4 Q. You mentioned earlier in your testimony that the
5 Massachusetts Study (MA-Study) used the same or
6 similar input values to the ones used for Eight
7 Point Wind. What are the differences and how
8 are those differences relevant to this case?

9 A. There are two differences. The first is that
10 the receptor in the MA-Study was evaluated at
11 330 meters (1,083 feet) from the turbine but the
12 setbacks for Eight Point Wind are 1,400 feet.
13 Despite the differences, the findings are still
14 applicable to this case. In fact, I would
15 expect that the discrepancies would grow for
16 receptors at distances greater than 1,083 feet
17 and not decrease as research has found that the
18 underpredictions with the ISO-9613-2 model are
19 higher for more distant receptors. The second
20 difference is that the MA-Study evaluated sound
21 receptors at 1 meter above the ground while the
22 Application evaluated receptors at 1.5 meters

1 above the ground. Such difference may not be
2 relevant. While a height of evaluation of 1.5
3 meters may be appropriate for one-story
4 residences, it will not be appropriate for
5 residences with two or more stories. This is
6 because two-story residences should be evaluated
7 about 4 meters above the ground to estimate
8 levels at the second floor. For two-story
9 houses the predicted sound levels may be higher
10 (about 1.5 dBA for the closest receptors). At
11 this time there is no information in the
12 Application about whether the most impacted
13 receptors are one or two-story residences, but
14 this is something that should be considered for
15 the final design and for postconstruction
16 compliance sound tests.

17 Q. What do you recommend?

18 A. I recommend that all non-participating receptors
19 with sound levels exceeding 40 dBA-Leq-1-h as
20 forecasted with the ISO 9613-2 model, be
21 investigated to confirm that in fact they
22 correspond to single-story houses. Otherwise,

1 the preconstruction and postconstruction sound
2 impacts should be evaluated at 4 meters as
3 recommended by the reference cited in WHO-2009
4 (Section 1 of Annex I of the European Directive
5 2002/49/EC of June 25, 2002).

6 A. How could a 3-dBA underprediction in the Leq-1-
7 hour noise levels affect the accuracy of the
8 prediction of the Leq-8-h noise descriptor?

9 Q. It depends on how many times an underprediction
10 of 3-dB occurs in an eight-hour period. If, in
11 the best case, this occurs only once, the
12 underprediction of the Leq-8-h could be only
13 half of a decibel, but if the worst case occurs
14 during the eight-hours, the underprediction of
15 the Leq-8-h could be 3 dBA. If it occurs half of
16 the time, it will result in an underprediction
17 of approximately 2 dBA.

18 Q. If the actual sound levels after construction
19 could be higher than predicted in the
20 Application how is this relevant?

21 A. Sound pressure levels in the initial design are
22 estimated to be as high as 44 dBA-Leq-1-hour at

1 four non-participant receptors and greater than
2 42 dBA-Leq-1-hour at nine non-participating
3 receptors without the use of NROs in computer
4 modeling. In the worst case, if a 3-dBA
5 underprediction occurs for eight consecutive
6 hours, the maximum noise levels could exceed the
7 regulatory limit proposed by the Applicant and
8 as explained before, that would not comply with
9 an indoor recommendation of 30 dBA if the
10 windows are open.

11 Q. You mentioned earlier in your testimony that the
12 3-dBA underprediction occurred for one out of
13 the two highest sound levels for a receptor
14 located downwind from the turbines. Is it
15 possible that a receptor could be located
16 downwind from the closest turbine for eight
17 consecutive hours during any time of the day in
18 a year, when the turbines are generating the
19 highest sound power levels?

20 A. Yes, it is possible.

21 Q. Can such exceedance be mitigated after the
22 Project becomes operational?

1 A. Yes, a 3 dBA underprediction can be mitigated by
2 applying NROs on the closest turbine(s).

3 Q. If it can be mitigated by applying NROs what is
4 the concern?

5 A. The concern is that the mitigation that may be
6 needed could be higher. For instance, if sound
7 limits are 42 dBA or lower as previously stated
8 in my testimony and if an underprediction of 3
9 dBA occurs, the total noise reduction at the
10 most impacted receptors could be as high as 5
11 dBA. (44 dBA maximum impact plus 3 dBA
12 underprediction minus 42 dBA proposed regulatory
13 limit equal to 5 dBA). In addition, if the non-
14 participating receptor is a two-story house, the
15 sound levels at the second floor could be about
16 1.5 dBA greater than as estimated (45.5 dBA
17 rather than 44 dBA). In that case the noise
18 reduction at the receptor could be as high as
19 6.5 dBA.

20 Q. Is that feasible?

21 A. For some turbine models it may be feasible but
22 not for all. Documentation about NROs for the

1 turbines considered for the project are not
2 provided in the Application.

3 For those wind turbine models for which it is
4 not feasible, the only mitigation option would
5 be a shutdown for the periods when the sound
6 limits are exceeded. Both NROs and shutdowns
7 reduce the energy production making the Project
8 less efficient.

9 Q. What is your recommendation?

10 A. My recommendation is that NROs should not be
11 used for computer noise modeling to demonstrate
12 conformance with relevant criteria and that
13 minimization measures should be provided during
14 design for the most impacted receptors.

15 Q. What is your conclusion about the analysis of
16 short-term impacts and Certificate Conditions.

17 A. Short-term regulatory limits should be lower
18 than those set for Cassadaga Wind and may need
19 to be as low as 42-dBA-8-h-nighttime to comply
20 with the indoor recommendations of WHO-1999.
21 NROs should not be used for computer noise
22 modeling to demonstrate conformance with

1 relevant criteria but rather be left as
2 contingent mitigation options as
3 underpredictions and discrepancies between
4 computer noise modeling and post-construction
5 actual sound levels are likely to occur.

6 Q. What are your recommendations for participating
7 receptors.

8 A. I also recommend reducing the regulatory limit
9 for non-participating receptors, from 55 dBA as
10 ordered for Cassadaga Wind to 52 dBA-Leq-8-h) on
11 the basis that the difference between the short-
12 term limits and the long-term limits may be as
13 low as 2 dBA and not 5 dBA as assumed for
14 Cassadaga. This is based on an identified
15 threshold of 50 L_{night} in WHO-2009 for zero risk
16 of cardiovascular disease. Participating
17 receptors should be aware that indoor noise
18 levels with the windows open, or partially open,
19 may be higher than as recommended by WHO-1999
20 and may need to close their windows to reduce
21 the potential for annoyance or sleep
22 disruptions. Currently the Application shows

1 that the maximum Leq-1-h sound levels at
2 participating receptors are predicted to be 48
3 dBA, five dBA below the 52 dBA Leq-8-h
4 regulatory limit that I am recommending.

5 Q. Do you have any concerns with long-term sound
6 levels as proposed by the Applicant?

7 A. In Cassadaga Wind, the Siting Board imposed
8 Certificated Condition 80(b), which includes a
9 sound limit of 40 dBA L(night-outside), annual
10 equivalent continuous average nighttime sound
11 level from the Facility outside any existing
12 permanent or seasonal non-participating
13 residence, and a limit of 50 dBA L(night-
14 outside), annual equivalent continuous average
15 nighttime sound level from the Facility outside
16 any existing participating residence. Although
17 the clause is included in the Certificate
18 Conditions proposed by Eight Point Wind this is
19 not included in the protocol for post-
20 construction noise evaluations.

21 Q. Do you agree with excluding testing of the
22 Lnight-outside regulatory limit from the scope

1 of the compliance testing protocol?

2 A. No, I do not. I consider that the 40 dBA
3 L(night-outside) for non-participating receptors
4 which is based on the recommendations of WHO-
5 2009 is potentially more protective than the 45
6 dBA (dBA) Leq (8-hour) WHO-1999 recommendation
7 and therefore should be evaluated at the most
8 critical locations after the Project is built.
9 Alternatively, the Project should be designed
10 for a lower short-term limit as previously
11 stated.

12 Q. Is the WHO-2009 still applicable?

13 A. Yes. As stated in the most recent guideline
14 (WHO-2018) "the current guidelines complement
15 the [WHO Night Noise Guidelines] (NNG) from
16 2009."

17 Q. Has the Application included computer noise
18 modeling and calculations showing that the
19 design complies with the 40 dBA-Lnight
20 recommendation of WHO-2009 for non-participating
21 receptors?

22 A. Yes. The Application shows that the maximum

1 impact will be 40-dBA at non-participating
2 receptors. Also, that a maximum level of 45-dBA
3 Lnight will not be exceeded at non-participating
4 receptors.

5 Q. Do you have any issues regarding how the Lnight
6 levels were calculated and if so, could you
7 please describe what those issues are?

8 A. Yes. The calculations of the Lnight include
9 corrections on an hourly basis so that the
10 results with the ISO 9613-2/CONCAWE method never
11 exceed the Leq-1-hour calculated with the ISO
12 9613-2 at the particular wind speed that occurs
13 during each hour.

14 Q. Please explain.

15 A. The Application adopted two methods for
16 prediction of future operational noise levels
17 from the Project called the ISO-9613-2 and the
18 CONCAWE. The ISO-9613-2 method uses the ISO
19 9613-2 propagation standard with no
20 meteorological corrections to estimate the
21 short-term sound levels and the CONCAWE method
22 uses the ISO 9613-2 propagation standard in

1 conjunction with the CONCAWE meteorological
2 correction. As stipulated, both use the ISO-
3 9613-2 propagation standard but without the ISO
4 meteorological correction (Cmet). Instead, the
5 CONCAWE approach adds a meteorological
6 correction that is used in the original CONCAWE
7 propagation standard to the hourly calculation
8 of ISO-9613-2 components for estimates of long-
9 term sound impacts.

10 Q. Are the ISO-9613-2 input values and assumptions
11 the same for both methods.

12 A. No, they are not. The formulas are the same,
13 but the input values and assumptions used in the
14 studies are different. The ISO 9613-2, for
15 estimates of maximum short-term noise levels, is
16 calculated with a ground factor G 0.5 but uses a
17 ground factor of G 1 when used in conjunction
18 with the CONCAWE meteorological correction for
19 long-term estimates. In simple terms, a G
20 factor of 1 represents a better ground effect
21 that results in lower noise levels at receptors.
22 Then the CONCAWE meteorological correction is

1 calculated which can be either positive or
2 negative, in other words, it can be added or
3 subtracted to the ISO 9613-2 calculation
4 components in an hourly basis. Further
5 calculations of about 8,760 hours in a year are
6 conducted to arrive to an estimate of the long-
7 term energy-based average sound level L_{night} at
8 a particular receptor. The CONCAWE
9 meteorological corrections can be either
10 positive or negative because there are
11 atmospheric conditions that are favorable and
12 others that are unfavorable for propagation of
13 noise. In other words, it may increase or
14 decrease the sound levels at a particular
15 receptor.

16 Q. What is the issue with the estimates of long-
17 term sound levels?

18 A. The problem is that for every hour that the sum
19 of the ISO-9613-2 with $G=1$ and the CONCAWE
20 meteorological correction exceeds the sound
21 levels estimated with the ISO-9613-2 standard
22 with $G=0.5$ and maximum sound power levels, a

1 correction is applied to match the ISO-9613-2
2 results. In other words, this is done so that
3 the level never exceeds the ISO-9613-2 short-
4 term estimates.

5 Q. Is this approach reasonable?

6 A. In my opinion it is not. I have not found any
7 peer reviewed publication or standard that calls
8 for this. The correction also seems to be based
9 on the Applications' assumption that predictions
10 of the 1-hour-Leq sound levels with the ISO
11 9613-2 and no meteorological correction
12 (Cmet) correspond to the maximum sound levels
13 that can actually be measured, but as I
14 explained before the MA-Study contains evidence
15 showing that this is not the case. For one out
16 of six 1-hour-Leq samples (and one of the two
17 highest) the measurements exceeded the
18 predictions by three decibels. Therefore,
19 regardless of the assumptions and input values
20 used in the CONCAWE calculations, corrections
21 should not be applied to reduce the predictions
22 with the CONCAWE to match the ISO-9612-2 $G=0.5$

1 calculations because, as the evidence supports,
2 the actual measured sound levels can be up to 3
3 dBA higher than the estimates achieved by using
4 computer noise modeling.

5 Q. You mentioned earlier in your testimony that you
6 disagree with applying corrections to the
7 CONCAWE method to match the ISO-9613-2 results.
8 What is your opinion about the calculation with
9 CONCAWE meteorological corrections presented in
10 the Application and do you propose an
11 alternative?

12 A. The review of calculations of long-term
13 estimates is complicated. In fact, the
14 supporting data is contained in two spreadsheets
15 than contains about 390,000 data cells each.
16 However, the raw data without any corrections,
17 shows 1-h-Leq sound levels 1 to 2 dBA above the
18 ones predicted with the ISO-9613-2. In other
19 words, about 45 dBA to 46 dBA Leq-1-h, not 43 to
20 44 dBA for the most impacted receptors. I think
21 the unadjusted data results are closer to
22 maximum 1-hour Leq levels that it may occur.

1 Based on the information submitted by the
2 Applicant, the differences between the short-
3 term and the long-term calculations with
4 corrections for sensitive receptors is between 2
5 and 11 dBA. I consider is practical to analyze
6 whether the differences make sense. One of the
7 most practical approaches is to make an estimate
8 of the L_{night} based on the difference between
9 the maximum 1-hour sound power level generated
10 by a turbine in a year and the yearly energy-
11 average of all sound power levels generated by
12 the same wind turbine in a year based on the
13 statistics of wind direction for a site and the
14 turbine selected for a project. Basically, this
15 acknowledges that the main factor for the
16 generation of noise is the wind magnitude at the
17 hub height and ignores other variables that may
18 affect the sound levels at a receptor such as
19 wind direction and cloud coverage during the
20 nighttime. For this project I see that the
21 difference between the maximum sound power
22 levels and the equivalent nighttime sound power

1 levels during the nighttime time is about 3 dBA.
2 Essentially, if the facility does not want to
3 exceed the 40 dBA L_{night} WHO-2009
4 recommendation, the turbines should not produce
5 more than 43 dBA short-term sound levels at
6 receptors at the maximum sound power levels.
7 Therefore, I consider that using a difference of
8 3 dBA is more appropriate than a higher
9 difference. In this case, if the facility
10 doesn't want to exceed the long-term
11 recommendation of WHO-2009 equivalent to 40 dBA
12 L_{night}, it should not exceed a short-term level
13 of 43 dBA. This again shows the need for
14 considering short-term sound limits lower than
15 the 45 dBA-Leq-8-hour recommended by WHO in
16 1999.

17 Q. If for some reason a L_{night} of 40 dBA is
18 exceeded at a particular receptor, is it
19 possible to provide mitigation?

20 A. Yes, but as I explained before, there is a
21 concern about accuracies because of the
22 correction applied to the CONCAWE results to

1 match with the ISO 9613-2 results (between 1 and
2 2 dBA according to the Application) and also
3 there is no certainty about whether the
4 receptors are single or two-story residences.
5 This again shows that the NROs should not be
6 used in the design but rather being considered
7 as a contingent mitigation option.

8 Q. Are there any other concerns?

9 A. Yes, the NROs are more effective if they are
10 needed to reduce exceedances to a short-term
11 noise limit rather than a long-term limit. In
12 fact, when a short-term limit is exceeded, the
13 NRO will only be applied during the periods of
14 times when the short-term sound levels are
15 exceeded, most likely at the highest sound power
16 levels of generation. But for long-term sound
17 limits this works differently.

18 Q. Please explain.

19 A. Noise reduction operations are more effective at
20 high wind speeds, but they could be zero at
21 medium and low wind speeds. Therefore, the noise
22 reduction achieved at the receptor is lower than

1 the noise reduction applied on the turbines. For
2 instance, if a 2-dBA noise reduction is needed
3 at a receptor a higher NRO would need to be
4 applied on the closest turbines (about 3 dBA).
5 There is no NRO sound information provided for
6 the turbine selected for this project, but I
7 estimate that the noise reductions needed at the
8 turbines can be approximately 1-2 dBA higher
9 than the noise reduction needed at a receptor.
10 If the NRO is applied only to one turbine and
11 not to other closer turbines the NRO may need to
12 be even higher. This is another cause of concern
13 specially because although the long-term limits
14 that were imposed by the Siting Board in the
15 Cassadaga Wind case are included in the
16 Certificate Conditions proposed by the Applicant
17 for Eight Point Wind, evaluation of the Lnight
18 descriptor is not included in the protocol for
19 post-construction evaluations. What this also
20 means is that if the long-term sound levels are
21 only modeled by computer, there will be no
22 measurements to demonstrate whether the facility

1 exceed the long-term recommendation of 40 dBA
2 Lnight from WHO-2009.

3 Q. Is there any other alternative?

4 A. Yes. One is to measure the Lnight as I have
5 proposed in the DPS-Protocol to address such
6 measurements. Alternatively, the long-term
7 limits may be eliminated from post-construction
8 compliance measurements provided a lower short-
9 term limit is adopted and NROs are not used in
10 computer noise modeling. Since NROs are only
11 effective at high wind speeds and might not be
12 applied to all relevant turbines, this short-
13 term regulatory limit should be conservatively
14 estimated.

15 Q. Do you have any recommendation for that short-
16 term limit?

17 A. My best estimate at this time is that that limit
18 should be 42 dBA Leq so that the long-term
19 recommendation of WHO-2009 and the interior
20 noise levels could also comply with the indoor
21 recommendations of WHO-1999 when windows are
22 open or partially opened.

1 Q. You mentioned at the beginning of your testimony
2 that the new recommendation of WHO in WHO-2018
3 includes consideration of the daytime periods as
4 well, not only about the nighttime period.
5 Please explain.

6 A. Yes, the new guidelines propose the Lden noise
7 descriptor which considers the daytime, evening
8 time, and nighttime noise levels.

9 Q. Do those guidelines address specifically the
10 potential health impacts from wind turbine
11 noise?

12 A. Yes. Recently, the WHO released the WHO-2018
13 guidelines for noise which include consideration
14 of Wind Turbine Noise. The WHO-2018 guidelines
15 found that adverse health effects (such as
16 annoyance) are associated with a level
17 equivalent to 45 dBA Lden. Therefore, the
18 recommendation is that sound levels from wind
19 turbines should be lower than 45 Lden in a year.

20 Q. What is the Lden?

21 A. The Lden is another noise descriptor equivalent
22 to a yearly energy-based average with no

1 penalties applied to the daytime period, a 5-dBA
2 penalty applied to the evening period, and a 10
3 dBA penalty applied to the nighttime period.

4 Q. How are the daytime, evening time and nighttime
5 periods defined?

6 A. The definitions for all these periods of time in
7 a day may be different for Europe, the United
8 States, and other countries. For example, the
9 "nighttime period" in Europe spans from 11 p.m.
10 up to 7 a.m. the following morning, or from
11 10:00 p.m. to 6:00 am the following day (8-
12 hour), while in United States "nighttime period"
13 spans from 10 p.m. up to 7 a.m. (9-hour). In
14 addition, the "daytime period" in Europe spans
15 from 7 a.m. up to 7 p.m. or from 6:00 a.m. to
16 6:00 p.m. (12-hour) (WHO-2018, p. 9) while in
17 United States "daytime" spans from 7 a.m. to 6
18 p.m. (11-hour). The "evening time" in Europe
19 goes from 7 p.m. to 11:00 p.m. or from 6:00 a.m.
20 to 10:00 p.m. (4-hour) while in the United
21 States "evening time" spans from 6 p.m. up to
22 10:00 pm. Despite the differences in timing

1 definitions, the effects on the Lden noise
2 descriptor may be minimal and may result in
3 numbers that are quite similar with differences
4 in the order of a few decimal points.

5 Q. If a sound source is constant during the day
6 time, evening time, and nighttime (as defined in
7 the United States), how many decibels should
8 that noise source be in order not to exceed the
9 45-dBA Lden recommendation?

10 A. That sound source should have a constant average
11 sound pressure level lower than 38.2 dBA Leq
12 during the daytime (Lday), evening time (Leve),
13 and nighttime (Lnight) in a year so that after
14 all the penalties are applied it does not equal
15 to or exceed the 45 dBA Lden WHO-2018
16 recommendation. In other words, the daytime,
17 evening time, and nighttime average sound
18 exposure in a year should be about 6.8 dBA lower
19 than 45-dBA Lden WHO-2018 or equivalently 38.2
20 dBA.

21 Q. Are there any other corrections to be applied?

22 A. Possibly. For instance, it is technically

1 feasible to include the periods of time when the
2 noise sources are not generating noise in the
3 calculation of the Lden in a year. The effect
4 of not including any noise from the noise
5 sources (wind turbines in this case) during
6 these periods depends on the percentage of the
7 year the turbines are not generating and
8 producing noise, but they may result in an extra
9 allowance that could be approximately 1.1 dBA
10 for a noise source that is not generating sound
11 for approximately 15% of the time in a year.
12 That being said, the sound should be lower than
13 39.3 dBA for the yearly average of the Ldaytime,
14 Levening, and the Lnight ($38.2+1.1=39.3$). These
15 levels, when combined with the percentage of
16 time that noise source is not generating noise
17 and after the 5- and 10-dBA penalties are
18 applied to the evening time and the nighttime
19 (respectively), will result in a Lden of 45 dBA.
20 Q. How does a noise level of 39.3 dBA Leq in a year
21 equate to a maximum short-term threshold such as
22 the Leq-11-hour(daytime), 4-hour(evening time),

1 9-hour(nighttime).

2 A. As explained for the Lnight descriptor the
3 difference between the long-term and the maximum
4 short-term levels depend on the statistical
5 distribution of wind speed magnitudes at the
6 site and the turbine model selected for the
7 Project. Assuming that that difference is 3
8 dBA, a 39.3 dBA average in a year during the
9 daytime would approximately equate to a short-
10 term level of 42.3 dBA Leq during the daytime.
11 For a noise source that is constant in time the
12 average for the daytime and evening time periods
13 should be the same. Therefore, in my opinion,
14 the regulatory short-term limit for the daytime
15 and evening time should also be about 42 dBA so
16 that the 45 Lden recommendation is met.

17 Q. These are estimates for a noise source that is
18 constant in time. Are they applicable to wind
19 turbine noise that is not constant in time?

20 A. Yes, they are. The Netherlands has regulations
21 that use the Lden and the Lnight noise
22 descriptors. The limits have been set at 47-dBA

1 Lden and 41-dBA Lnight since 2011, a difference
2 of 6 dBA between the two noise descriptors. See,
3 Wind Farm Noise Measurements Assessment and
4 Control Colin H. Hansen, Con J. Doolan and
5 Kristy L. Hansen. (p.41) Wiley. 2017.

6 Q. What are the implications?

7 A. In order to comply with the WHO-2018
8 recommendation of 45 dBA Lden, a wind generating
9 facility should not exceed a level of 39 dBA Leq
10 in a year during the daytime, evening time and
11 nighttime. A 39 dBA Lnight is 1 dB lower than
12 the Lnight of 40 dBA recommended by WHO in 2009.
13 This again would translate to a short-term limit
14 of about 2 dBA to 4 dBA greater. In other
15 words, a short-term level of 41 dBA to 43 dBA. I
16 would recommend 42 dBA in this case, which is an
17 average between those two levels.

18 Q. If the short-term limit regulatory limit is kept
19 in 45 dBA in how many decibels the new WHO-2018
20 recommendation could be exceeded?

21 A. The Lden could be around 48-dBA, exceeding the
22 new recommendation by about 3 dBA.

1 Q. Can that be mitigated and how?

2 A. Yes, by applying NROs to the closest turbines or
3 eliminating some from the design. If NROs are
4 applied, they need to be greater than the noise
5 reduction needed at the receptor. I note however
6 that the Application does not state whether NROs
7 are available for the turbines considered for
8 the Project and the maximum noise reduction that
9 can be achieved. Also, there is no information
10 attached that includes the sound power levels
11 for NROs.

12 Q. What are the short-term sound results included
13 in the Application?

14 A. The Application provided tables with short-term
15 sound impacts using the Leq-1-h noise
16 descriptor. There are no receptors with short-
17 term levels exceeding 45-dBA-Leq-1-hour sound
18 levels.

19 Q. How many receptors may exceed a short-term sound
20 limit of 42 dBA-Leq-1-h?

21 A. There are 9 non-participating receptors with
22 short-term levels exceeding a 42-dBA-Leq-1-hour

1 sound levels.

2 Q. Are there any issues related to low frequency
3 sounds from the wind turbines in the Compliance
4 Protocol proposed by the Applicant?

5 A. Yes. In case 14-F-0490 the Siting Board adopted
6 Certificate Condition 80 (c) which requires the
7 facility to "[c]omply with a maximum noise limit
8 of 65 dB Leq at the full octave frequency bands
9 of 16, 31.5, and 63 Hertz outside of any non-
10 participant residence existing as of the
11 issuance date of this Certificate in accordance
12 with Annex D of ANSI standard S12.9-2005/Part 4
13 (Sounds with strong low-frequency content)."
14 That condition, although proposed by the
15 Applicant for Eight Point Wind is not included
16 in the protocol for post-construction noise
17 testing.

18 Q. What does Annex D of the ANSI Standard say?

19 A. Section D.2 of Annex D in ANSI S12.9-2005 Part
20 4, entitled "Sounds with strong low-frequency
21 content," states "[g]enerally, annoyance is
22 minimal when octave-band sound pressure levels

1 are less than 65 dB at 16, 31.5 and 63-Hz mid-
2 band frequencies."

3 Q. What is your recommendation for this case?

4 A. Post-construction monitoring of low frequency
5 sounds is protective of annoyance to low
6 frequency sounds and perceptible vibrations and
7 for that reason should be adopted for Eight
8 Point Wind as it was for Cassadaga Winds. This
9 is reflected in Exhibit__(MMC-8), the DPS-
10 Protocol.

11 Q. What is your opinion about Amplitude Modulation
12 for this project.

13 A. The Certificate Conditions designated as 75(e)
14 by Eight Point relates to the way complaints
15 from Amplitude Modulation are handled.

16 Q. Please explain the concept of amplitude
17 modulation and the Application's analysis and
18 conclusions related to amplitude modulation.

19 A. In simple terms, amplitude modulation is a
20 repetitive sound that occurs with a frequency of
21 about one second or less. This is commonly
22 described as a repetitive "swish" or "thump"

1 associated with turbine operation. "Recent
2 evidence suggests that at times this 'swish' can
3 become more of a pronounced 'thump,' leading to
4 complaints from wind farm neighbors" (UK-2016,
5 p. 1)." The interval of measurement has to be a
6 fraction of a second (one tenth), to allow the
7 problem to be described and analyzed. Once the
8 amplitude modulation is properly measured, the
9 amplitude modulation depth can be estimated. In
10 simple terms the amplitude modulation depth is
11 the number of decibels the amplitude of sound
12 fluctuates from peak to trough.

13 Q. Can amplitude modulation be predicted at this
14 time, before the Project is built, and what is
15 the recommendation of the UK-2016 document for
16 decision makers such as the Siting Board?

17 A. One of the main findings of the UK document 2016
18 is that amplitude modulation cannot be predicted
19 at this time "[t]he prevalence of unacceptable
20 AM has not been evaluated as part of this study,
21 and current state of the art is that the likely
22 occurrence cannot be predicted at the planning

1 stage. That does not preclude future research
2 to determine the likelihood of AM occurring
3 coming forward, and the development of a risk
4 based evaluation, or similar. Due to the lack
5 of ability to predict AM occurring on a site,
6 and the reported difficulties in applying
7 Statutory Nuisance provisions to control AM on
8 existing sites, it is likely that the default
9 position for a decision maker would be to apply
10 the condition on all sites unless evidence is
11 presented to the contrary." (Id. at 4).

12 Q. If amplitude modulation cannot be predicted at
13 this time, what can be done to identify the
14 problem should it occur?

15 A. Since amplitude modulation cannot be predicted
16 at the planning stages for the proposed Project,
17 the important issue is to address how amplitude
18 modulation will be evaluated and how the impacts
19 will be mitigated if they occur.

20 Q. What are the options for mitigation of amplitude
21 modulation?

22 A. The UK 2016 document states in section 4.5.29,

1 pages 71 and 72 "[w]ith current technologies,
2 mitigation in most cases will likely be achieved
3 through pitch control of the turbine blades, or
4 in the worst case the switching off of one or
5 more turbines during periods of unacceptable
6 AM."

7 Q. Do you have any recommendations for Compliance
8 testing?

9 A. Yes, I do. In Case 14-F-0490 the Siting Board
10 adopted Certificate Condition 72 requiring the
11 Applicant to perform two compliance tests: one
12 during "leave-on" conditions; and another one
13 with "leaf-off" conditions. For Cassadaga Wind
14 DPS Staff did not proposed a compliance
15 protocol. Absent of any alternatives, the
16 Siting Board adopted the protocol presented by
17 the Applicant. The Applicant here has proposed
18 addressing the complaints and testing the
19 Facility with protocols that were filed with the
20 Application. I have objections to the protocols
21 which are presented in my testimony and in
22 Exhibit__(MMC-13) with edits and comments on the

1 most relevant issues discussed herein. This
2 does not address the parts that a compliance
3 protocol should have but that in my opinion are
4 missed. In general, I do not recommend the
5 adoption of the Protocols as presented in the
6 application as it will not properly evaluate
7 whether the facility as designed and as built
8 will in fact avoid, offset, or minimize, the
9 adverse environmental noise or vibration impacts
10 upon the local community for the duration of the
11 certificate.

12 Q. Are you recommending a Protocol for
13 postconstruction noise evaluations?

14 A. Yes. The protocol is included in Exhibit MMC-8.

15 Q. Are there any differences between the
16 Certificate Conditions Staff is recommending for
17 noise and vibrations and the Certificate
18 Conditions proposed by the Applicant as related
19 to Compliance Filings?

20 A. Yes. All the differences can be seen in a red-
21 line comparison included in Exhibit__(MMC-12).
22 In Certificate Condition 65(c)(i) I am including

1 edits to fix typos related to the standards used
2 to report sound power levels from the turbines.
3 In Certificate condition 65 (c)(ii) I am
4 including minor edits. In certificate condition
5 65 (d) I am recommending insertions as follows:
6 first, I am expanding the requirements for
7 revised computer modeling to allow the Applicant
8 flexibility in case they want to introduce
9 changes in revised modelling provided these
10 changes result in more conservative results.
11 Second, as explained in my testimony, I also
12 recommend that NROs not be used in the design,
13 to demonstrate conformance with any limit
14 imposed by the Siting Board as a compliance
15 filing requirement. For that reason, I am
16 proposing changes requiring the Applicant not to
17 use NROs in the compliance filings. Third, I am
18 introducing edits to require the Applicant to
19 confirm that the sensitive receptors with sound
20 results approaching any noise limits of the
21 final Order are in fact single-story residences.
22 If they are found to be two-story buildings or

1 more, the sound levels should be evaluated at 4
2 meters, not at 1.5 meters. Forth, I am
3 recommending incorporating my recommendations
4 for elimination of turbines and the use of some
5 already identified alternative locations in
6 replacement of the text proposed by the
7 Applicant for Certificate Condition 77 (c).
8 Fifth, in certificate Condition 65 (d) (i) I am
9 recommending requiring the Applicant to evaluate
10 the new recommendations from WHO-2018 consisting
11 of noise levels lower than 45 dBA Lden. As an
12 alternative to this, I am recommending lower
13 short-term regulatory limits as shown in my
14 alternate proposed Certificate Condition 74(a)
15 in Exh MMC-11. Sixth: Although the recommended
16 decision for Cassadaga refers to a 50 dBA
17 (Lnight-outside) for boundary lines I agree in
18 having Certificate Condition 65 (d) (iii)
19 expressing this requirement by using a short-
20 term limit for this compliance filing at
21 boundary lines. That is because is practical to
22 generate sound contour drawings with the ISO

1 model for boundary lines with the sound turbines
2 at maximum power levels but not feasible to
3 generate yearly noise contours with the CONCAWE
4 meteorological correction.

5 Q. Are there any differences between the
6 Certificate Conditions Staff is recommending for
7 noise and vibrations and the Certificate
8 Conditions proposed by the Applicant as related
9 to Postconstruction Compliance Evaluations?

10 A. Yes. In Certificate Condition 66, and as
11 explained in my testimony, I am recommending
12 adopting the Sound Testing Compliance Protocol
13 presented by DPS in Exh-8 and not the Protocol
14 presented by the Applicant. Should the Siting
15 Board order any changes to the certificate
16 conditions recommended by DPS or the Applicant I
17 am recommending in Certificate Condition 66,
18 requiring the Applicant to reflect those changes
19 exclusively in the Protocol which should be
20 filed as indicated in my proposed Certificate
21 Condition 66. For the reasons explained above, I
22 am also recommending eliminating Certificate

1 Condition 66 (a) proposed by the Applicant.

2 Since the protocol presented by Staff already
3 contains all the elements included in
4 Applicant's Certificate Condition 66(b), 66(c),
5 and 66(d), I am recommending the elimination of
6 those provisions.

7 Q. Please explain what is the next change that you
8 recommend.

9 A. Certificate Condition 68 proposed by the
10 Applicant reads "[i]f the results of the first
11 or the second Sound Compliance test performed by
12 the Certificate Holder or any tests performed by
13 DPS, upon reasonable notice to the Certificate
14 Holder and following the Protocol approved in
15 the Compliance Filing for the tests to be
16 performed by the Certificate Holder, and after a
17 reasonable period has elapsed for discussions
18 between DPS and the Certificate Holder's
19 acoustical consultant has elapsed, (...) indicate
20 that the Facility (...)"

21 I disagree with this condition. First, the
22 Applicant and DPS Staff should not follow the

1 protocol presented by the Applicant as this
2 protocol is insufficient. Second, I recommend
3 that if the Siting Board decides to grant a
4 Certificate to Eight Point any post-construction
5 monitoring should be conducted by following the
6 Sound Testing Compliance protocol presented by
7 DPS and attached to this testimony as
8 Exhibit__(MMC-8).

9 Q. Are there any differences between the
10 Certificate Conditions Staff is recommending and
11 the Certificate Conditions proposed by the
12 Applicant as related to regulatory noise limits
13 to the facility?

14 A. Yes. Based on my discussions in my testimony, I
15 am recommending in Certificate Condition 74(b)
16 the facility also be required to demonstrate
17 compliance with the new WHO guidelines of 45-dBA
18 Lden for any existing permanent or seasonal non-
19 participating residence by post-construction
20 noise testing after the facility is built.
21 Alternatively, if the Siting Board decides not
22 to impose a certificate condition of 45 dBA

1 Lden, 40 dBA L(night) or both, I recommend
2 reducing the short-term regulatory noise limit
3 from 45 dBA Leq (8-hour) to 42 dBA Leq (8-hour)
4 for any existing participating receptors and
5 from 55 (dBA) Leq (8-hour) to 52 (dBA) Leq (8-
6 hour) for any existing non-participating
7 receptors. This option is reflected in my
8 alternate conditions included in Exh-11. In
9 addition, I'm recommending that the noise
10 descriptor for the 65-dB Leq low-frequency noise
11 limit included in Certificate Condition 74(d) be
12 clarified as 65 dB Leq-1-hour. This is
13 consistent with the requirements for compliance
14 filings for Cassadaga and also with the noise
15 descriptor used in Certificate Condition 65 (d)
16 (iv) proposed by the Applicant.

17 Q. Are there any differences between the
18 Certificate Conditions Staff is recommending and
19 the Certificate Conditions proposed by the
20 Applicant as related to complaints from noise
21 and vibration from the facility?

22 A. Yes. I am proposing an insertion in Certificate

- 1 Condition 75(c) to clarify that the
2 notifications required in this clause relate to
3 the Applicant. In addition, I recommend that
4 complaints be reported monthly during the first
5 three years of operation and quarterly after
6 that rather than monthly during the first full
7 year of commercial operations as adopted for
8 Cassadaga. If no noise or vibration complaints
9 are received, I also recommend requiring the
10 Certificate Holder to submit a letter to the
11 Secretary indicating that no complaints were
12 received during the reporting period rather than
13 excepting the Applicant of any filings if no
14 noise or vibration complaints are received.
- 15 Q. Are there any differences between Certificate
16 Conditions proposed by Staff and the Applicant
17 as related to complaints from Amplitude
18 Modulation (AM) from the Project?
- 19 A. Yes. Given the discrepancies that could occur
20 between computer noise modeling and actual post-
21 construction noise measurements I recommend that
22 complaints related to Amplitude Modulation be

1 investigated if measured or modeled sound levels
2 at the location(s) being evaluated exceed 40 dBA
3 L1hr, rather than based on modeled levels
4 exceeding 40 dBA L1hr exclusively as ordered for
5 Cassadaga Wind. In addition, I recommend edits
6 on the clause related to Amplitude Modulation as
7 ordered for Cassadaga. The edits are consistent
8 with the discussion in page 60 of the
9 Cassadaga's Order that states "[t]he RD also
10 adopted a restriction on the Facility's
11 production of amplitude modulated sounds, such
12 as complaints of swishing or thumping type
13 sounds. Should such amplitude modulated sounds
14 be found to exceed a noise level of 45 dBA for
15 more than 5 percent of the evaluation period,
16 the Certificate Holder would be required to
17 implement minimization measures." Consequently
18 the 10% has been changed to 5%. In addition, I
19 consider that the time frame of evaluation of
20 Amplitude Modulation should be clearly
21 specified. I am proposing a time frame of
22 evaluation of 8-hours which I consider is

1 appropriate. The text "amplitude modulation
2 depth is 5 dB or lower for a minimum of 90% any
3 hour" it is confusing. First, I think that the
4 90% was set as the complement of the 10%
5 indicated in the same clause. Therefore the 90%
6 should be 95%. Second, the text should be
7 referring to the penalty for Amplitude
8 Modulation which is set at the beginning of the
9 same clause. For that reason, I am proposing
10 edits so that the Application of the AM penalty
11 makes sense and is consistent with the intent
12 expressed in the discussion of the order and the
13 first portion of this clause.

14 Q. Is there any other way to address potential
15 issues with amplitude modulation sound?

16 A. Yes, by reducing the sound limits to which the
17 AM penalty is applied. The UK-2016 document
18 recommended amplitude modulation penalties
19 between 3 and 5 dBA. The 3-dBA penalty is
20 applied if an AM depth of 3 dBA occurs while a 5
21 dBA penalty is applied if an AM depth greater
22 than 5 dBA occurs. If the short-term goals and

1 limits are reduced to 42 dBA or lower an
2 amplitude modulation penalty may not be needed.

3 Q. Are there any advantages when doing this?

4 A. Yes. There is no need to measure amplitude
5 modulation. This clause could be eliminated as I
6 am proposing in my alternative to my proposed
7 certificate condition 75(e) in Exhibit__(MMC-
8 11). As I previously said, the short-term limit
9 should be 42 dBA to meet the WHO recommendations
10 of 1999, 2009, and 2018 and at that level, the
11 AM penalty may not be longer necessary.

12 Q. Is there any other change recommended to the
13 Certificate Conditions proposed by the
14 Applicant?

15 A. Yes. Certificate Condition 75(f) is edited to
16 reflect that any re-testing should follow the
17 provisions included in DPS Sound Testing
18 Compliance Protocol, including section 10 of the
19 protocol. Given that the protocol is limited to
20 testing a few residential positions within the
21 first year of operation, these provisions should
22 apply to any re-test required in response to

1 legitimate complaints from any sensitive
2 receptors existing as of the date of the Order.

3 Q. What are your final recommendations about the
4 proposed facility.

5 A. The design should keep the noise reduction
6 operations as a contingency option to mitigate
7 any discrepancies between predicted and actual
8 sound levels. Should sound levels after
9 construction exceed relevant criteria or any
10 Certificate conditions imposed by the Siting
11 Board at the non-participating or participating
12 receptors, then NROs should be applied as
13 necessary on relevant turbines to bring noise
14 levels back into compliance.

15 Q. Are there any mitigation measures that could be
16 implemented if a non-conformance operational
17 situation is found?

18 A. Yes. NROs are the most practical mitigation
19 measure that could be implemented after the
20 Project is built provided they are sufficient to
21 mitigate any actual exceedances.

22 Q. How are identified the Certificate Conditions

1 that you are recommending for this Project?

2 A. My recommended Certificate conditions set forth
3 below are included in Exhibit__(MMC-7) and an
4 alternative is included in Exhibit__(MMC-11).

5 Q. Are those conditions based on your testimony and
6 the record in this case?

7 A. Yes.

8 Q. Does the proposed Facility avoid or minimize
9 environmental impacts to the maximum possible
10 extent?

11 A. No. I believe that the potential adverse
12 environmental noise impacts from operation of
13 the facility have not been avoided or minimized
14 to the maximum extent practicable. I also
15 believe that additional minimizations measures
16 such as elimination or relocation of turbines
17 need to be explored. As stated at the beginning
18 of my testimony my recommendations to reduce the
19 impacts on the most impacted receptors are that
20 the Applicant 1) eliminates Turbine #10 and use
21 ALT1, which will reduce the impacts on
22 receptors 327 and 329; 2) eliminates Turbine #5

1 and use ALT2, which will reduce the impacts on
2 receptors 692 and 325; 3) eliminates ALT3 from
3 consideration, as its use would burden
4 receptors 456 and 454; and 4) eliminates Turbine
5 #20 and use adjacent turbine ALT4, which will
6 reduce the impacts on receptors 771 and 522.

7 Q. What is your recommendation to the Siting Board
8 regarding granting a Certificate to the
9 Applicant in light of the environmental noise
10 impacts?

11 A. My recommendation as related to adverse
12 environmental noise and vibration effects is
13 that the Project should be approved subject to
14 the Certificate Conditions, the post-
15 construction protocol, and the regulatory limits
16 that I am recommending for this project so that
17 the adverse environmental noise effects of the
18 operation of the Facility are minimized or
19 avoided to the maximum extent practicable using
20 verifiable measures. The Applicant should
21 present updated computer noise modeling results
22 including the elimination and relocation of

1 turbines as I previously described to
2 demonstrate that the adverse operational noise
3 impacts have been minimized or avoided to the
4 maximum extent practicable. The final computer
5 model should determine whether additional
6 turbines need to be relocated or eliminated in
7 order to comply with relevant thresholds and
8 criteria as recommended in this testimony. In
9 addition, the Applicant's proposed certificate
10 conditions and Postconstruction Compliance
11 Protocol is not sufficient to demonstrate that
12 the Facility will in fact avoid, offset or
13 minimize the impacts upon the most sensitive
14 receptors to the maximum extent practicable
15 using verifiable measures. Further, I recommend
16 adoption of DPS- Staff proposed certificate
17 conditions on noise and protocol for
18 demonstration of compliance after construction,
19 if the project is finally approved. The
20 Applicant should also present updated computer
21 noise modeling results as a compliance filing if
22 any change is introduced to the design such as

1 different turbine model or turbine locations,
2 any changes on the list of receptors including
3 any changes on participation status, to
4 demonstrate that the adverse operational noise
5 impacts have been minimized or avoided to the
6 maximum extent practicable before a final design
7 can be approved and construction can begin.

8 Q. Does this conclude your testimony at this time?

9 A. Yes.