

BEFORE THE
STATE OF NEW YORK
BOARD ON ELECTRIC GENERATION
SITING AND THE ENVIRONMENT

In the Matter of

Baron Winds LLC

Case 15-F-0122

February 22, 2019

Prepared Testimony of:

REDACTED

Miguel Moreno-Caballero
Utility Engineering
Specialist 3
(Acoustics)
Office of Electric,
Gas, and Water

State of New York
Department of Public
Service
Three Empire State
Plaza
Albany, New York 12223-
1350

1 Q. Will you please state your name, employer, and
2 business address?

3 A. My name is Miguel Moreno-Caballero and I am
4 employed by the New York State Department of
5 Public Service (DPS or the Department), located
6 at Three Empire State Plaza, Albany, New York,
7 12223.

8 Q. Mr. Moreno what is your position at the
9 Department?

10 A. I am a Utility Engineering Specialist 3
11 (Acoustics) in the Environmental Certification
12 and Compliance section of the Office of
13 Electric, Gas and Water (Staff).

14 Q. Please summarize your educational background and
15 professional experience.

16 A. I attended the Pontifical Xaverian University in
17 Bogota, Colombia and received a Bachelor of
18 Science degree in Civil Engineering in 1986.
19 Thereafter, I continued my education at
20 Universidad del Norte in Barranquilla, Colombia
21 and graduated with a Masters in Business
22 Administration in 1992. I have accumulated more

1 than 20 years of experience in the field of
2 acoustics and noise control. I owned and
3 operated my own business in Colombia, South
4 America for about 13 years, where I worked as an
5 acoustical consultant and acoustical contractor.
6 I designed and built noise abatement solutions
7 for emergency generators, industrial machinery,
8 HVAC equipment, and interior acoustical designs
9 for indoor spaces. I obtained extensive
10 experience in noise control including noise
11 surveys and computer simulations of aircraft
12 noise for two international airports.

13 After my arrival to the United States, I
14 was employed as a Senior Acoustical Consultant
15 by an acoustical consultant firm in Washington
16 D.C., from October 2005 until May 2008. There,
17 I analyzed sound surveys and performed computer
18 noise modeling for roadways and highways and
19 designed mitigation measures such as barriers
20 and selected building envelope specifications
21 for environmental noise control. I also
22 designed noise control solutions for mechanical

1 equipment and interior acoustics for indoor
2 spaces for a variety of projects. From May 2008
3 to June 2009, I was employed by an acoustical
4 consultant company in Manhattan and worked for
5 several acoustical and noise control projects
6 including data centers and corporate projects.

7 I joined the Department in November 2013.
8 My duties include reviewing Public Service Law
9 (PSL) Article VII and Article 10 pre-
10 applications, applications, environmental noise
11 assessments, noise surveys and mitigation
12 measures. I also review sound collection
13 protocols and witness sound measurements to
14 ensure compliance with Certificate Conditions.
15 I am a full-member of the Institute of Noise
16 Control Engineering and an Associate member of
17 the Acoustical Society of America.

18 Q. Mr. Moreno, which projects have you reviewed
19 under PSL Article 10 and Article VII
20 regulations?

21 A. Under Article VII regulations, I have reviewed
22 the applications for the following certified

1 cases: New York Power Authority, Case 13-T-0515;
2 DMP New York, Inc., Williams Field Services
3 Company LLC, Cases 13-T-0538 and 13-T-0350; PSEG
4 Power New York, Inc. Case 15-F-0040; and
5 Consolidated Edison Company of New York, Inc.,
6 Case 13-T-0586. Although currently pending or
7 uncertified, I also reviewed environmental noise
8 assessments for the following Article VII
9 projects: West Point Partners LLC, Case 13-T-
10 0292; Poseidon Transmission, LLC, Case 13-T-
11 0391; In the Matter of Alternating Current
12 Transmission Upgrades - Comparative Proceeding,
13 Case 13-E-048; Vermont Green Line Devco, LLCI,
14 Case 16-T-0260; and Niagara Mohawk Power
15 Corporation, Case 15-T-0305. I am currently
16 working on numerous PSL Article 10 proceedings
17 (and some potentially affiliated Article VII
18 filings) regarding wind generating facilities at
19 various stages including the following projects:
20 Cassadaga Wind, LLC, Case 14-F-0490 already
21 certified by the New York State Board on
22 Generation siting and the Environment (Siting

1 Board); Lighthouse Wind, LLC, Case 14-F-0485;
2 Baron Winds, LLC, Case 15-F-0122; Bull Run
3 Energy, LLC, Case 15-F-0377; Eight Point Wind,
4 LLC, Case 16-F-0062; Atlantic Wind, LLC -Deer
5 River, Case 15-F-0267; Canisteo Wind Energy,
6 LLC, Case 16-F-0205; Case 16-F-0267;; Number
7 Three Wind LLC, Case 16-F-0328;; Heritage Wind
8 LLC, Case 16-F-0546; Bluestone Wind, LLC, Case
9 16-F-0559; Alle-Catt Wind Energy, LLC, 17-F-
10 0282 and Atlantic Wind, LLC, -Mad River-, Case
11 16-F-0713. I am also assigned on multiple PSL
12 Article 10 proceedings (and some potentially
13 affiliated Article VII filings) regarding solar
14 generating facilities at various stages
15 including the following projects: Mohawk Solar,
16 LLC, Case 17-F-0182; Hecate Energy Albany 1, LLC
17 and Hecate Energy Albany 2, LLC, Case 17-F-0617;
18 and Hecate Energy Greene County 1, LLC, Hecate
19 Energy Greene 2, LLC, and Hecate Energy Greene
20 County 3, LLC, Case 17-F-0619.

21 Q. Are you sponsoring or relying upon any other
22 exhibits?

1 A. Yes. I am sponsoring Exhibit__(MMC-1); through
2 Exhibit__(MMC-13).

3 Q. Please briefly describe those exhibits.

4 A. Exhibit__(MMC-1) contains the document entitled
5 "Guidelines for Community Noise," World Health
6 Organization, 1999 (WHO 1999), which I will
7 refer to as "WHO-1999."

8 Exhibit__(MMC-2) contains a link to download the
9 document entitled "Guidelines and
10 Recommendations," which I will refer to as "WHO-
11 2009."

12 Exhibit_(MMC-3) contains an executive summary of the
13 most recent guidelines from the World Health
14 Organization (WHO) regional office for Europe
15 entitled "Environmental Noise Guidelines for the
16 European Region," published in October 2018,
17 which I will refer to as "WHO-2018-ES."

18 Exhibit_(MMC-4) contains the most recent guidelines
19 from the WHO regional office for Europe entitled
20 "Environmental Noise Guidelines for the European
21 Region," published in October 2018, which I will
22 refer to as "WHO-2018."

1 Exhibit_(MMC-5), contains a study entitled
2 "Massachusetts Study on Wind Turbine Acoustics.
3 Prepared for: Massachusetts Clean Energy Center
4 and Department of Environmental Protection.
5 Submitted by RSG Inc. Report 2.18.2016," which I
6 will refer to as the "MA-STUDY-2016" in my
7 testimony.

8 Exhibit_(MMC-6) contains my notes on Figure 26, page
9 69 of the MA-STUDY-2016.

10 Exhibit__(MMC-7) contains a Sound Testing Compliance
11 Protocol that I have developed and am proposing
12 for this Project which I will refer to as "DPS-
13 Protocol."

14 Exhibit__(MMC-8) contains Table 2 of a reference
15 called "Percentiles of Normal Hearing-Threshold
16 Distribution Under Free-Field Listening
17 Conditions in Numerical Form." Kenji Kurakata,
18 Tazu Mizunami, and Kuzama Matsushita. Acoust.
19 Sci. & Tech. 26, 5 (2005), which I will refer to
20 as "KURAKATA-2005."

21 Exhibit__(MMC-9) contains a drawing showing the
22 turbines proposed for this Project and the

1 locations of non-participating residences
2 differentiated to indicate the non-cumulative
3 mitigated short-term noise levels reported in
4 the Application.

5 The Certificate Conditions that I am proposing on
6 noise and vibration are contained in Exhibit__
7 (SSP-2) which contains all Staff-Policy Panel
8 sponsored Certificate Conditions for this
9 Project.

10 Exhibit__(MMC-10) contains an alternative to the
11 certificate conditions on noise and vibration
12 for this Project that I am presenting for
13 consideration, including both a redlined and a
14 clean version.

15 Exhibit__(MMC-11) contains a redlined comparison
16 between the certificate conditions proposed by
17 the Applicant and the Certificate Conditions
18 imposed by the Siting Board in Case 14-F-0490.

19 Exhibit__(MMC-12) contains a drawing showing the
20 turbines proposed for this Project and the
21 locations of non-participating residences
22 differentiated to indicate the cumulative

1 mitigated short-term noise levels reported in
2 the Application.

3 Exhibit__ (MMC-13) contains my preliminary comments
4 and edits on the protocols presented in the
5 Application.

6 Q. Mr. Moreno, what is your role under PSL Article
7 10 regulation review?

8 A. Under Article 10, my duties include the review
9 of preliminary scoping statements, stipulations
10 and applications as they relate to the noise
11 assessments and avoidance or minimization of
12 environmental noise impacts from major electric
13 generation facilities. My role regarding wind
14 generating projects consists of the review of
15 sections of the Application related to noise
16 impact assessments from construction and
17 operation of the facilities, which includes pre-
18 construction ambient noise surveys, analysis of
19 existing or potential future prominent tones,
20 noise modeling parameters, assumptions and
21 results, amplitude modulation, low-frequency
22 noise, infrasound, potential for hearing damage,

1 indoor and outdoor speech interference,
2 interference with the use of outdoor public
3 facilities and public areas, community complaint
4 potential or annoyance, and the potential for
5 interference with technological, industrial or
6 medical activities that are sensitive to
7 vibration or infrasound. In addition, my role
8 also includes the review of applicable noise
9 standards and guidelines, local regulations on
10 noise, design goals for the facilities, noise
11 abatement measures, complaint and resolution
12 plans for noise from construction and operation
13 of the Facility, and proposed post-construction
14 noise evaluations and compliance for conformance
15 with Certificate Conditions.

16 Q. Why is the noise expected to be generated from
17 the Baron Winds LLC Facility (Facility or
18 Project) an important issue for the Siting Board
19 to consider in this proceeding?

20 A. Public Service Law §164 and the implementing
21 regulations at 16 NYCRR §1001.19, require an
22 applicant for a Certificate of Environmental

1 Compatibility and Public Need (Certificate), to
2 provide certain information concerning the noise
3 and vibration impacts of the construction and
4 operation of a facility. In addition, the
5 various noise levels expected from a major
6 electric generating facility, including a wind
7 generating facility like this Project, are
8 important factors in determining the nature of
9 the probable environmental impacts of the
10 construction and operation of the proposed
11 facility and whether it avoids or minimizes
12 environmental impacts to the maximum extent
13 practicable.

14 Q. Can you please describe the different labels
15 such as L_{eq} , and the L_{90} , often used to describe
16 noise levels?

17 A. Noise levels frequently fluctuate over a wide
18 range and over time, so different sound
19 descriptors have been developed to describe
20 sound pressure levels over a period of time.
21 The "Leq" is the equivalent-continuous sound
22 pressure level of a noise source. It is the

1 single sound pressure level that, if constant
2 over a specified time period, would contain the
3 same sound energy as the actual monitored sound
4 that varies in level over the measurement
5 period. Guidelines for noise are sometimes
6 expressed in terms of maximum noise levels
7 specifying the period of time over which the
8 measurements are taken. For example, 45 dBA L_{eq}
9 (8 hours) means that the noise levels evaluated
10 during 8 hours have an energy average equivalent
11 to a constant level of 45 dBA.

12 Q. What is a percentile level?

13 A. The L_n is the percentile level, where n is any
14 number between 0 and 100. The number designated
15 by n corresponds to the percentage of the
16 measurement time period by which the stated
17 sound level has been exceeded. (James P. Cowan,
18 Handbook of Environmental Acoustics, J. Wiley
19 [1994], p. 41). For instance, the L_{90} is the
20 sound level that is exceeded 90 percent of the
21 time, usually regarded as the "residual level"
22 or the background noise without the source in

1 question or discrete sound events (Cowan, p.
2 41).

3 Q. What does the designation "dBA" Mean?

4 A. "dB" is a designation for "decibel" which is
5 equivalent to a tenth of a "Bell" (a unit named
6 after Alexander Graham Bell). A Bell is too
7 large to describe the acoustic environment and
8 for that reason was broken into tenths or
9 "decibels." (Cowan, p. 41). The "A" letter after
10 the "dB" designation denotes one of the most
11 common weighting networks in acoustics and noise
12 control. The human ear does not sense all
13 frequencies in the same manner, and the human
14 ear does not hear sounds at different
15 frequencies the same way a typical microphone in
16 a sound level meter does. (Cowan p. 36). For
17 that reason, the "A-weighted" scale was
18 developed and is comprised of a series of
19 corrections applied to the sound levels measured
20 by a sound level meter at all frequencies of the
21 human audible spectra to resemble human hearing.
22 (Cowan p. 31). Although the normal hearing range

1 in humans goes from 20 Hertz up to 20,000 Hertz,
2 humans are more sensitive to sound with
3 frequencies between 200 Hertz and 10,000 Hertz
4 (Cowan p. 36) and for that reason the greatest
5 corrections are applied to the low frequencies.
6 (e.g. minus 57 dB at 16 Hertz). In addition, we
7 hear the sound levels between 500 Hertz and
8 4,000 Hertz similar to the way it is perceived
9 by a sound level meter microphone and for that
10 reason the corrections are lower ranging from
11 minus 3.2 dB at 500 Hertz up to 1.0 dB at 4,000
12 Hertz. After all corrections are applied to each
13 frequency sound level, the individual
14 contributions to the dBA level are added up and
15 the result is noted as "overall," "broadband"
16 "dBA" or "dBA-weighted" noise level.

17 Q. Does the proposed Project avoid or minimize the
18 adverse environmental noise impacts to the
19 maximum extent practicable?

20 A. No. I believe that potential adverse
21 environmental noise impacts from operation of
22 the facility have not been avoided or minimized

1 to the maximum extent practicable. Forecasting
2 of operational noise levels from the Project
3 only shows conformance with relevant criteria if
4 noise reduction operations (NRO's) on the wind
5 turbines are incorporated in the computer noise
6 modeling during the design phase. Should actual
7 sound levels exceed relevant criteria at the
8 most potentially impacted noise receptors after
9 a project is built, the room for increasing
10 noise reduction operations further may be
11 limited and it will reduce power generation. In
12 addition, I recommend that the Project should be
13 evaluated not only based on its sound impacts on
14 sensitive noise receptors but more importantly
15 in a cumulative basis with the interaction of
16 noise emissions of the adjacent operational
17 Cohocton Generating Facility. Sound impacts are
18 greater when they are evaluated in conjunction
19 with the noise emissions from the existing
20 facility. In addition, I do not find the
21 Certificate Conditions proposed by the Applicant
22 and the protocol for post-construction

1 evaluations to be appropriate for this Project.

2 Q. Please explain your general impressions of the
3 Certificate Conditions proposed in the
4 Application for this Project.

5 A. I find that the Application Certificate
6 Conditions proposed for Baron Winds have many
7 issues that are similar to those litigated and
8 ultimately decided by the Siting Board in Case
9 14-F-0490 Cassadaga Wind LLC. For this reason,
10 I may not reiterate many of those issues but
11 will compare how the Certificate Conditions
12 proposed by the Applicant for Baron Winds LLC
13 compare with the Certificate Conditions imposed
14 by the Siting Board for Cassadaga Wind LLC. To
15 illustrate the similarities and to expedite
16 review, I have provided a redlined tracked
17 comparison between the approved Certificate
18 Conditions for Cassadaga Wind and those proposed
19 by Baron Winds, which is included in my
20 testimony as Exhibit MMC-11.

21 Q. Please explain the results of sound impacts
22 included in the most recent Application

1 Supplement dated February 1st, 2019.

2 A. The Application has proposed a short-term design
3 goal of 45 dBA Leq for all non-participating
4 residences and cabins. According to the
5 supplemental information, the new design
6 complies with that limit for nonparticipating
7 residences and cabins. However, I note that to
8 comply with that goal, two turbines needed to be
9 turned-off from the computer noise modeling and
10 Noise Reduction Operations (NRO's) on several
11 turbines have been needed to be incorporated
12 into the model as well. As I will explain in my
13 testimony, my recommendation is not to use NRO's
14 during the siting process or design phase but
15 leave them as contingency options in case post-
16 construction mitigation is needed.

17 Q. Please explain what a Noise Reduction Operation
18 (NRO) is.

19 A. As explained in the Preconstruction Noise
20 Impacts Assessment presented with the original
21 Application (pp. 142-143), NROs are changes
22 introduced to the operation of the wind turbines

1 to reduce noise generation. This is usually
2 accomplished by adjusting turbine blade pitch,
3 slowing the rotor speed of the turbines, which
4 reduces aerodynamic noise produced by the
5 blades.

6 Q. How many turbines needed NRO's or being turned-
7 off from computer model so that the Project
8 complies with a maximum short-term noise level
9 of 45-dBA-Leq-1h.

10 A. According to the information included in the
11 most recent supplement, three turbines were
12 turned-off from the computer noise model (T1,
13 T72, and T74) and NRO's were applied on twenty
14 eight turbines: five turbines were modeled with
15 5 dBA NRO's, one turbine with an NRO of 4.5 dBA,
16 three turbines with NRO's of 4 dBA, six turbines
17 with NRO's of 3 dBA, six turbines with NRO's of
18 2 dBA and seven turbines with NRO's of 1 dBA .

19 Q. Has the Application Supplement stated whether
20 NRO's are available and has the Supplement
21 included Sound Power information from the
22 manufacturers?

1 A. The Application Supplement states: "In the case
2 of Gamesa G114, the sound spectrum used was
3 obtained from an IEC 61400-11 test of the
4 turbine, for the wind speed with the maximum
5 sound power emissions. This spectrum was then
6 scaled to the published apparent sound power for
7 this turbine." What this means is that the
8 sound power level information at different
9 frequencies of the spectra was only available
10 for the wind speed that generates the maximum
11 sound power levels but not for lower speeds. As
12 I will explain later in my testimony, this may
13 have implications in the calculation of long-
14 term noise impacts at sensitive receptors.

15 Q. What are the short-term impacts from the
16 Facility without NRO's applied on the turbines?

17 A. Nineteen non-participating residences are
18 forecasted to exceed a noise level of 45 dBA-
19 Leq-1-h. The maximum noise impact is modeled to
20 be as high as 49 dBA. In addition, two cabins
21 are forecasted with short-term noise levels
22 greater than 45-dBA-Leq-1-h, one of them with

1 levels as high as 55-dBA-Leq-1-h.

2 Q. Those are the results from the proposed Project
3 only. What would the results be in combination
4 with the existing operational Cohocton Wind
5 Facility?

6 A. Without turbines T1, T72 and T74 and with NRO's
7 applied to the turbines, there are eight non-
8 participating receptors and one non-
9 participating cabin with short-term levels
10 exceeding 45-dBA-Leq-1-hour sound levels. If
11 turbines T1, T72 and T74 are not eliminated and
12 if NRO's are not used for computer noise
13 modeling, the number of residences exceeding a
14 noise level of 45 dBA-leq-1-hour goes from 19 to
15 36, with sound levels as high as 50-dBA (there
16 is one receptor forecasted as high as 58 dBA but
17 it seems to be caused by sound emissions from
18 the Cohocton facility). In addition, the number
19 of cabins exceeding 45-dBA-Leq-1-h goes from two
20 to three.

21 Q. What are the noise levels from the Cohocton
22 facility exclusively?

1 A. According to the information provided in the
2 Supplement, four receptors already exceed a
3 noise level of 45-dBA-Leq-1-h because of sound
4 emissions generated by the Cohocton facility.

5 Q. What is your recommendation for evaluating
6 cumulative noise impacts? Should a wind
7 generating facility be evaluated exclusively on
8 its noise impacts or in combination with the
9 noise impacts from any other existing wind
10 generating facilities in the vicinity?

11 A. In my opinion, for facilities proposed on
12 locations that are proximal to other existing or
13 proposed facilities, only a cumulative
14 assessment reveals the severity of the impacts
15 that may occur. Although the noise impacts from
16 the proposed facility are important, the
17 cumulative impacts are in those cases, more
18 important. The issue under discussion is not
19 new. In my review of relevant references, I
20 found that this question was properly addressed
21 by the Noise Working Group in the implementation
22 of the regulations for wind farms in the United

1 Kingdom. In the final report of the reference
2 entitled "The Assessment and Rating of Noise
3 from Wind Farms," dated September 1996, the
4 Noise Working Group discussed its findings in
5 section 11 of the executive summary, noise
6 limits, page vi. The report represents the
7 consensus of the group of experts that had "a
8 breadth and depth of experience in assessing and
9 controlling the environmental noise impact of
10 noise from wind farms." Point 16 concludes: "The
11 Noise Working Group is of the opinion that
12 absolute noise limits and margins above
13 background should relate to the cumulative
14 effect of all wind turbines in the area
15 contributing to the noise received at the
16 properties in question. It is clearly
17 unreasonable to suggest that, because a wind
18 farm has been constructed in the vicinity in the
19 past which resulted in increased noise levels at
20 some properties, the residents of those
21 properties are now able to tolerate higher noise
22 levels still. The existing wind farm should not

1 be considered as part of the prevailing
2 background noise."

3 Q. How is this conclusion applicable to this
4 Project?

5 A. Both the World Health Organization guidelines
6 (1999, 2009 and 2018) and the NYS Siting Board
7 in Case 14-F-0490 have recommended and adopted
8 "absolute" thresholds. From an impacted
9 receptor perspective, it is more important how
10 much wind turbine noise is perceived at that
11 receptor in total, than knowing who is
12 responsible for one portion of the noise or the
13 other. The same applies to perceptible airborne
14 vibrations and prominent tones: it is more
15 important to know whether they will occur or
16 exceed a limit than to know how much is caused
17 by one facility or the other. In my opinion, if
18 noise levels from an existing facility are
19 already equal to or exceed any identified
20 threshold, there is no more room for additional
21 noise. If, on the other hand, noise levels from
22 an existing facility are lower than any

1 identified threshold, the new proposed
2 facility(ies) should be designed so that the
3 cumulative noise levels are lower than or at
4 most equal to that identified threshold. This
5 requires that any project(s) proposed in close
6 proximity to other existing or proposed projects
7 locate its turbines at some distance from other
8 existing or proposed turbines in the project
9 area. For Baron Winds, the two projects
10 overlap, with Baron Wind's turbines surrounding
11 existing turbines from the Cohocton Generating
12 Facility.

13 Q. Do you think that a short-term goal of 45 dBA-
14 Leq-1-h is sufficiently protective of any noise
15 impacts.

16 A. No, I do not. The Applicant selected a 45-dBA-
17 Leq-1-h based on the outdoor recommendation from
18 WHO-1999 for the nighttime, however, there is no
19 discussion of another recommendation from WHO-
20 1999, which is not to exceed an indoor noise
21 level of 30-dBA-Leq-8-hour indoor during the
22 nighttime.

1 Q. Is it possible that the Facility as designed
2 could comply with an indoor noise level of 30
3 dBA-Leq-8-h during the nighttime?

4 A. Not in the summer. If people open the windows
5 during the nighttime, indoor noise levels could
6 be greater than 30 dBA. For Cassadaga Wind, the
7 discussion was based on the assumption that the
8 outdoor-to-indoor noise reduction provided by a
9 building envelope was 15-dBA. However, I have
10 found evidence that the outdoor-to-indoor noise
11 reduction may not be as high as 15-dBA,
12 warranting lower outdoor noise levels so that
13 the 30-dBA-Leq-8-hour indoor recommendation is
14 met.

15 Q. What is that evidence?

16 A. The new guideline from WHO, which I refer to as
17 WHO-2018, in section 2.2.2., page 9, states:
18 "The differences between indoor and outdoor
19 levels are usually estimated at around 10 dB for
20 open, 15 dB for tilted or half-open and about 25
21 dB for closed windows. When considering more
22 accurate estimation of indoor levels, using a

1 range of different predictors, the relevant
2 scientific literature can be consulted (Locher,
3 et al., 2018).” (Locher B, Piquerez A,
4 Habermacher M, Ragettli M, Rösli M, Brink M et
5 al. (2018). Differences between outdoor and
6 indoor sound levels for open, tilted, and closed
7 windows. Int J Environ Res Public Health. 15(1):
8 149).

9 Q. Has this been corroborated by other authors?

10 A. Yes. In the article entitled “Wind Turbine Noise
11 and Sleep: Pilot Studies on the Influence of
12 Noise Characteristics” by Julia Ageborg Morsing,
13 Michael G. Smith, Mikael Ögren, Pontus Thorsson,
14 Eja Pedersen, Jens Forssén and Kerstin Persson
15 Waye, I found that the difference between the
16 LAeq,8h outdoor and indoor for windows with a
17 gap was between 10.5 dBA and 10.9 dB (See table
18 1 of the article). In that case, indoor levels
19 were measured at the pillow position. In
20 another study in the same reference (Study B),
21 the outdoor-to-indoor noise reductions were
22 about 12.2 dB for windows with a gap. In another

1 article entitled "Wind Farm Noise: Paper ICA
2 2016-440. Physiological effects of wind turbine
3 noise on sleep," by Michael G. Smith, Mikael
4 Ögren, Pontus Thorsson, Eja Pedersen and Kerstin
5 Persson Waye, published in Buenos Aires on
6 September 2016, I found information that allowed
7 me to conclude that for that study the outdoor-
8 to-indoor noise reduction provided by windows
9 slightly open was 12 dBA (See Table 1). I find
10 that an assumption between 10 to 12 dBA is
11 reasonable.

12 Q. What are the implications of this?

13 A. That outdoor noise levels should be between 40
14 and 42 dBA leq-8-h, but not greater than 42 dBA,
15 so that the recommendation of 30 dBA-8-hour
16 indoor during the nighttime from WHO-1999 is
17 met.

18 Q. Is the outdoor noise limit of 45 dBA-Leq-8-h
19 that WHO recommended in 1999 still Applicable?

20 A. No. WHO withdrew this recommendation in October
21 of 2018.

22 Q. Is the indoor noise limit of 30 dBA-Leq-8-h that

1 WHO recommended in 1999 still Applicable?

2 A. Yes. This recommendation was retained by WHO in
3 the most recent guideline (WHO-2018).

4 Q. If noise levels should not be more than 42 dBA-
5 Leq-8-hour during the nighttime to comply with
6 the 30 d-BA indoor recommendation, how many
7 receptors for the proposed Facility exceed an
8 outdoor noise level of 42 dBA?

9 A. If noise reduction operations are applied in the
10 model and turbines T1, T72 and T74 are turned
11 off, 30 receptors are expected to exceed 42-dBA
12 Leq-1-h or 8-h. If noise emissions from the
13 Cohocton facility are added, 55 receptors may
14 exceed 42-dBA-Leq-1-h. If noise reduction
15 operations are not used in the model, turbines
16 T1, T72 and T74 are not eliminated and Cohocton
17 impacts are accounted for, 90 receptors are
18 expected to exceed 42 dBA-Leq-1-h.

19 Q. How are the long-term noise impacts evaluated?

20 A. The long-term noise impacts are evaluated with
21 the use of the Lnight noise descriptor. The
22 Lnight is an energy-based average of all the

1 noise levels during the nighttime period in a
2 year.

3 Q. Is there any recommended limit?

4 A. Yes. In 2009, WHO recommended not to exceed 40
5 dBA Lnight - a recommendation that the Siting
6 Board adopted for Case 14-F-0490 by imposing a
7 certificate condition to be demonstrated with
8 post-construction sound measurements.

9 Q. What are the estimated long-term impacts from
10 the proposed Facility?

11 A. With noise corrections applied to the results,
12 the Application concludes that no receptor will
13 be exposed to noise levels greater than 40 dBA
14 Lnight.

15 Q. Do you agree with that conclusion?

16 A. No, I do not. I believe that the real impacts
17 may be greater.

18 Q. Why?

19 A. Because noise corrections were applied to the
20 calculations so that the estimates with the
21 CONCAWE corrections do not exceed the results
22 with the ISO-9613-2 with no meteorological

1 corrections and because random numbers have been
2 introduced in the calculations.

3 Q. Do you have any concerns with long-term sound
4 levels as proposed by the Applicant?

5 A. In Cassadaga Wind, the Siting Board imposed
6 Certificate Condition 80(b), which includes a
7 sound limit of 40 dBA L(night-outside), annual
8 equivalent continuous average nighttime sound
9 level from the facility outside any existing
10 permanent or seasonal non-participating
11 residence, and a limit of 50 dBA L(night-
12 outside), annual equivalent continuous average
13 nighttime sound level from the facility outside
14 any existing participating residence. That
15 clause is not included in the Certificate
16 Conditions proposed by the Applicant for Baron
17 Winds or the protocol for post-construction
18 noise evaluations.

19 Q. Do you agree with excluding testing of the
20 Lnight-outside regulatory limit from the scope
21 of the compliance testing protocol?

22 A. No, I do not. The 40 dBA L(night-outside)

1 requirement for non-participating receptors,
2 which is based on the recommendations of WHO-
3 2009, is potentially more protective than the 45
4 dBA-Leq (8-hour) WHO-1999 recommendation and,
5 therefore, should be evaluated at the most
6 critical locations after the Project is built.
7 Alternatively, the Project should be designed
8 for a lower short-term limit as previously
9 stated.

10 Q. Is the WHO-2009 still applicable?

11 A. Yes. As stated in the most recent guideline
12 (WHO-2018, p. 28) "the current guidelines
13 complement the NNG [WHO Night Noise Guidelines]
14 from 2009."

15 Q. Does the Application include computer noise
16 modeling and calculations showing that the
17 design complies with the 40 dBA-Lnight
18 recommendation of WHO-2009 for non-participating
19 receptors?

20 A. Yes. The Application claims that the maximum
21 impact will be 40-dBA at non-participating
22 receptors. Also, it claims that a maximum level

1 of 50-dBA Lnight will not be exceeded at
2 participating receptors.

3 Q. Do you have any issues regarding how the Lnight
4 levels were calculated and if so, could you
5 please describe what those issues are?

6 A. Yes. The calculations of the Lnight in the
7 Application included corrections on an hourly
8 basis so that the results with the ISO 9613-
9 2/CONCAWE method never exceed the Leq-1-hour
10 calculated with the ISO 9613-2 at the particular
11 wind speed that occurs during each hour.

12 Q. Please explain.

13 A. The Application adopted two methods for
14 prediction of future operational noise levels
15 from the Project called the ISO-9613-2 and the
16 CONCAWE. The ISO-9613-2 method uses the ISO
17 9613-2 propagation standard with no
18 meteorological corrections to estimate the
19 short-term sound levels as I explained
20 previously in my testimony and the CONCAWE
21 method uses the ISO 9613-2 propagation standard
22 in conjunction with the CONCAWE meteorological

1 correction. As stipulated, both use the ISO-
2 9613-2 propagation standard but without the ISO
3 meteorological correction (Cmet). Instead, the
4 CONCAWE approach adds a meteorological
5 correction that is used in the original CONCAWE
6 propagation standard to the hourly calculation
7 of ISO-9613-2 components for estimates of long-
8 term sound impacts.

9 Q. Are the ISO-9613-2 input values and assumptions
10 the same for both methods.

11 A. No, they are not. The formulas are similar but
12 the input values and assumptions used in the
13 studies are different. The ISO 9613-2, for
14 estimates of maximum short-term noise levels, is
15 calculated with a ground factor G 0.5 but uses a
16 ground factor of G 1 when used in conjunction
17 with the CONCAWE meteorological correction for
18 long-term estimates. In simple terms, a G
19 factor of 1 represents a better ground effect
20 that results in lower noise levels. Initially,
21 the CONCAWE meteorological correction is
22 calculated, which can be either positive or

1 negative. In other words, it can be added or
2 subtracted to the ISO 9613-2 calculation
3 components in an hourly basis. Further
4 calculations based on 8,760 hours in a year are
5 conducted to arrive to an estimate of the long-
6 term energy-based average sound level L_{night} at
7 a particular receptor. The CONCAWE
8 meteorological corrections can be either
9 positive or negative because there are
10 atmospheric conditions that are favorable and
11 others that are unfavorable for propagation of
12 noise. In other words, it may increase or
13 decrease the sound levels at a particular
14 receptor.

15 Q. What is the issue with the estimates of long-
16 term sound levels?

17 A. The problem is that in the Application, for
18 every hour that the sum of the ISO-9613-2 with
19 $G=1$, and the CONCAWE meteorological correction
20 exceeds the sound levels estimated with the ISO-
21 9613-2 standard with $G=0.5$, and maximum sound
22 power levels, a correction is applied to match

1 the ISO-9613-2 results. In other words, this is
2 done so that the level never exceeds the ISO-
3 9613-2 short-term estimates.

4 Q. Is this approach reasonable?

5 A. In my opinion it is not. I have not found any
6 peer reviewed publication or standard that calls
7 for this. The correction also seems to be based
8 on the Application's assumption that predictions
9 of the 1-hour-Leq sound levels with the ISO
10 9613-2 and no meteorological correction (Cmet)
11 correspond to the maximum sound levels that can
12 actually be measured but, as I will explain, the
13 MA-Study contains evidence showing that this is
14 not the case. For one out of six 1-hour-Leq
15 samples (and one of the two highest) the
16 measurements exceeded the predictions by three
17 decibels. Therefore, regardless of the
18 assumptions and input values used in the CONCAWE
19 calculations, corrections should not be applied
20 to reduce the predictions with the CONCAWE to
21 match the ISO-9612-2 G=0.5 calculations because,
22 as the evidence supports, the actual measured

1 sound levels can be higher than the estimates
2 achieved by using computer noise modeling.

3 Q. What is the evidence contained in the MA Study?

4 A. In my review of studies concerning accuracy of
5 the ISO-9613-2 model I found one where the use
6 of the ISO-9613-2 sound propagation model with
7 similar assumptions and input values to the ones
8 that were used in the Application, resulted in
9 about a 3-dBA underprediction of the Leq-1-hour
10 noise descriptor for one out of six 1-hour
11 samples and one out of the two highest sound
12 pressure levels that were modeled and measured.

13 Q. What is the study you refer to and which is the
14 section that shows the underprediction?

15 A. The study is entitled "Massachusetts Study on
16 Wind Turbine Acoustics" (Exhibit MMC-5) which
17 was prepared for the Massachusetts Clean Energy
18 Center and Department of Environmental
19 Protection. The findings relevant to this case
20 are shown on Figure 26, page 68, and is included
21 as Exhibit MMC-6. The figure has three graphs
22 and the one at the bottom shows a correlation

1 between sound pressure levels estimated at a
2 receptor located 330 meters (1,083 feet)
3 downwind from the turbines as obtained with the
4 ISO-9613-2 sound propagation model and a ground
5 factor of G 0.5 plus a 2 BA correction added to
6 the results. The figure correlates the
7 estimates to the sound pressure levels that were
8 measured after monitoring the 1-hour Leq-dBA
9 noise descriptor for six hours at that receptor.
10 This can easily be observed in Exhibit MMC-6
11 where I have included my notes on top of the
12 relevant graph. As it can be seen from the
13 graph (Exhibit MMC-6) in one out of the six
14 hours, the sound pressure levels using computer
15 noise modeling were 3 dBA lower than as measured
16 after monitoring (43 dBA as opposed to 46 dBA).
17 The 3-dBA underestimate occurred for one of the
18 two highest sound pressure levels. This also
19 shows that although the addition of 2 dBA to the
20 ISO 9613-2 results improves the accuracy of the
21 estimates, it is not sufficient for one out of
22 two samples at the maximum sound power levels.

1 In this case a correction of 5-dBA and not 2-dBA
2 is needed to estimate the actual maximum 1-hour
3 sound levels.

4 Q. You mentioned earlier in your testimony that the
5 Massachusetts Study (MA-Study) used the same or
6 similar input values to the ones used for Baron
7 Winds. What are the differences and how are
8 those differences relevant to this case?

9 A. There are two differences. The first is that
10 the receptor in the MA-Study was evaluated at
11 330 meters (1,083 feet) from the turbine but the
12 setbacks for Baron Winds are 1,000 feet for
13 participating receptors and 1,500 feet for non-
14 participating receptors. Despite the
15 differences, the findings are still applicable
16 to this case. In fact, I would expect that the
17 discrepancies would grow for receptors at
18 distances greater than 330 meters (1,083 feet)
19 and not decrease. The second difference is that
20 the MA-Study evaluated sound receptors at 1
21 meter above the ground while the Application
22 evaluated receptors at 4 meters above the

1 ground. I estimate that the predicted sound
2 levels at 4 meters may be higher (about 1.5 dBA
3 for the closest receptors) but still
4 insufficient to compensate entirely a 3 dBA
5 underprediction. In addition, the MA-Study did
6 not evaluate receptor at 4 meters which may be
7 appropriate for two-story houses and therefore
8 it is unknown whether the 3-dBA underprediction
9 also occurs at 4 meters.

10 Q. Can such exceedance be mitigated after the
11 Project becomes operational?

12 A. Yes, a 3 dBA underprediction can be mitigated by
13 applying NRO's on the closest turbine(s).

14 Q. If it can be mitigated by applying NRO's what is
15 the concern?

16 A. The concern is that the redesign already uses
17 noise reductions equivalent to 5 dBA on five
18 turbines, 4.5 dBA on one and 4 dBA on three and
19 for those turbines the room to increase the
20 noise reductions further is limited and that
21 will reduce power production as well. For those
22 wind turbines, the only mitigation option would

1 be a shutdown for the periods when the sound
2 limits are exceeded. In addition, the Applicant
3 has not proposed a Certificate Condition to
4 measure the Lnight descriptor after construction
5 and its evaluation is not found in the
6 postconstruction protocol either.

7 Q. Is there any other assumption or correction you
8 disagree with?

9 A. Yes, the application of random numbers to the
10 estimates of hourly sound levels at a particular
11 receptor. I disagree with the generation and
12 introduction of random numbers to the
13 calculations for different reasons: first, they
14 are in my opinion unnecessary; second, they
15 introduce distortions to the results; third,
16 they make the calculations un-replicable; and
17 fourth, results may be different depending on
18 the specific random numbers that are generated.
19 In addition, I have not found any standard or
20 guidelines written by other authors that
21 recommend the generation of random numbers to be
22 introduced in the calculations of computer noise

1 sound levels at receptors.

2 Q. Any other concerns?

3 A. Yes, if the intent of the introduction of random
4 numbers is to replicate transient changes in
5 sound levels that may occur by changes in
6 propagation conditions due to temperature or
7 weather changes, this may not be in line with
8 the requirements of Exhibit 19(d), 16 NYCRR
9 §1001.19(d), that requires an applicant to
10 ignore any attenuation of sound that result on
11 transient changes of weather and temperature.

12 Q. If no corrections are applied to match the
13 results obtained with the CONCAWE to the ISO-
14 9613-2 and if random numbers are not generated
15 what would be the sound results of the Lnight
16 noise descriptor.

17 A. From the information included in the Supplement,
18 including corrections and NRO's and turbine
19 elimination, seven sound receptors will be
20 impacted in the cumulative analysis: five with
21 an Lnight of 41 dBA, one at 46 dBA and another
22 at 51 dBA. No information is included for the

1 Lnight without corrections and NRO's applied in
2 a cumulative basis.

3 Q. You mentioned earlier in your testimony that you
4 disagree with applying corrections to the
5 CONCAWE approach to match the ISO-9613-2 results
6 and the introduction of random numbers. What is
7 your opinion about the calculation with CONCAWE
8 meteorological corrections presented in the
9 Application?

10 A. The raw data without any corrections, showed for
11 the original design, 1-h-Leq sound levels 1 to 2
12 dBA above the ones predicted with the ISO-9613-
13 2. I believe the unadjusted data results are
14 closer to the maximum 1-hour Leq levels. The
15 review of calculations of long-term estimates is
16 complicated. [REDACTED]

17 [REDACTED] [REDACTED]

18 [REDACTED] [REDACTED]

19 I consider it is important to analyze whether
20 the differences make sense and also analyze what
21 the short-term sound limit should be so that the
22 Lnight could be met. One of the most practical

1 approaches is to make an estimate of the L_{night}
2 based on the difference between the maximum 1-
3 hour sound power level generated by a turbine in
4 a year and the yearly energy-based average of
5 all sound power levels generated by the same
6 wind turbine in a year based on the statistics
7 of wind direction for a site and the turbine
8 selected for a project. Basically, this
9 acknowledges that the main factor for the
10 generation of noise is the wind magnitude at the
11 hub height and ignores other variables that may
12 affect the sound levels at a receptor such as
13 wind direction and cloud coverage during the
14 nighttime.

15 Q. Is this a valid assumption?

16 A. Yes. NARUC-2011 reports that wind turbine noise
17 is not directional. This means that the sound
18 levels are similar regardless of whether the
19 receptor is located upwind, downwind, and cross
20 wind conditions.

21 Q. What specifically does NARUC-2011 say?

22 A. "The assumption of an omni-directional wind

1 means that the sound power level of the turbine,
2 which is measured in the IEC 61400-11 procedure
3 downwind of the unit, is modeled as radiating
4 with equal strength in all directions; i.e. the
5 sound level in every direction is the downwind
6 sound level. Although this may seem to depict an
7 unrealistic situation and over-predict upwind
8 sound levels, the fact of the matter is that
9 this approach generally results in predictions
10 that are consistent with measurements
11 irrespective of where the receptor point is
12 located. Although somewhat counterintuitive, the
13 reason for this is that wind turbine noise under
14 most normal circumstances is not particularly
15 directional and generally radiates uniformly in
16 all directions. As an example, the plot below
17 shows the sound levels measured in three
18 directions 1000 ft. from a typical unit in a
19 rural project in [s]outhern Minnesota. Although
20 there are periods when the levels differ,
21 implying some directionality, the majority of
22 the time all three sound levels are generally

1 about same irrespective of the wind direction.
2 Moreover, the sound level at the downwind
3 position is almost never elevated relative to
4 other directions as one might expect."

5 Q. Please explain what this means.

6 A. A receptor is downwind if the wind is blowing
7 and reaches the turbine before reaching the
8 receptor, in other words, the wind blows from
9 the turbine to the receptor. Upwind is the
10 opposite, the wind reaches the receptor first
11 and the turbine after, in other words, the wind
12 blows from the receptor to the turbine.
13 Crosswind is when the receptor is not located
14 downwind or upwind from the noise sources, in
15 other words, the wind blows in a way that can
16 reach the turbine or the receptor at the same
17 time or one of the two first, but not the other.
18 In the original CONCAWE method, receptors
19 located downwind from the noise sources are
20 supposed to have greater sound levels than the
21 receptors located on the other side of the
22 turbine (upwind). Receptors upwind are supposed

1 to have lower noise levels and receptors located
2 crosswind are supposed to have sound levels
3 between those calculated for receptors located
4 downwind and upwind from the turbines. But, as
5 described in NARUC-2011 and other publications,
6 for receptors very close to the turbines this
7 does not seem to happen.

8 Q. Are you criticizing the CONCAWE method that was
9 stipulated?

10 A. No, I am objecting to the way that it was
11 applied, by adjusting sound levels so that they
12 do not exceed the ISO-9613 method, which will
13 have the effect of reducing, not increasing, the
14 results. A better practice would have been not
15 introducing any adjustment, or if adjustments
16 were introduced to decrease the maximum levels,
17 they should also have been introduced to
18 increase lower sound levels.

19 Q. Why do you think this does not happen?

20 A. As described by the NARUC-2011 guidelines, one
21 of the reasons may be because wind turbine noise
22 is not quite "directional" at all frequency

1 bands. For instance, low frequency noise
2 propagates in all directions, not in a single
3 direction. The other reason could be that the
4 CONCAWE Standard was developed based on three
5 Petrochemical plants where receptors are located
6 either downwind, upwind or crosswind from the
7 plants. For wind turbine noise, especially if a
8 receptor is surrounded by several turbines, a
9 receptor could be simultaneously located
10 downwind from some turbine(s) and upwind or
11 crosswind from other turbine(s).

12 Q. Do other references indicate that the difference
13 between downwind, upwind and cross wind
14 conditions may be minimal for the most impacted
15 receptors, closest to the turbines?

16 A. Yes. The MA-Study, Figure 20, shows sound levels
17 for a receptor located at 330 meters (1,083
18 feet) from the turbines and the results are
19 basically the same: many data points present
20 both underpredictions and overpredictions and,
21 for that reason, they locate on both sides of
22 the diagonal that represents a perfect match.

1 Although upwind data shows more deviation with
2 respect to the center line than the crosswind
3 and downwind condition, they all occur on both
4 sides of the diagonal line. I should note that
5 the addition of 2-dB was needed for all wind
6 directions and not for downwind conditions
7 exclusively, to improve the accuracy between
8 predictions and actual noise measurements.

9 Q. Do any other references address this issue?

10 A. Yes. The Institute of Acoustics in the
11 publication entitled: "A Good Practice Guide to
12 the Application of ETSU-R-97 for the Assessment
13 and Rating of Wind Turbine Noise," dated MAY
14 2013, section 4.4.2. on page 22, states: "Based
15 on evidence from the Joule projectⁱⁱⁱ [ⁱⁱⁱ Wind
16 Turbine Noise, Dick Bowdler and Geoff Leventhall
17 (Eds). Multi-Science Publishing Co Ltd (2011)]
18 in conjunction with advice in BS 8233 and ISO
19 9613-2, current practice suggests that for a
20 range of headings from directly downwind (0°) up
21 to 10 degrees from crosswind (80°), there may be
22 little to no reduction in noise levels..." Figure

1 6 on the same page also shows that for receptors
2 located within 5.25 times the tip height of the
3 turbine (2,584 feet in this case based on the
4 turbines proposed for this Project) the sound
5 levels downwind and upwind are basically the
6 same and for the cross wind condition there may
7 be a difference of 2 dB in a narrow angle of
8 only 20 degrees out of 180.

9 Q. What are the results and the implications?

10 A. This shows that what may be most important is
11 the wind magnitude only, not the wind direction.
12 Other factors such as solar radiations do not
13 play any role for calculation of the nighttime
14 sound levels and may play only a minor role
15 during the daytime. Cloud coverage may also
16 play a minor role when the turbines are
17 producing low noise emissions and may not modify
18 the results at wind speeds greater than the cut-
19 in speed. Several meteorological categories are
20 only relevant when the turbines are not rotating
21 and for that reason they do not play any role in
22 the calculations.

1 A. Based on the statistics of wind speed for the
2 Project, excluding all irrelevant factors and
3 meteorological conditions that may play a minor
4 role, and for the two turbines selected for this
5 Project, I find the following: [REDACTED]
6 [REDACTED] [REDACTED]
7 [REDACTED] [REDACTED] [REDACTED]
8 [REDACTED] [REDACTED] [REDACTED]
9 [REDACTED]
10 [REDACTED]
11 [REDACTED]
12 [REDACTED]
13 [REDACTED] [REDACTED]
14 [REDACTED]
15 [REDACTED]
16 [REDACTED]e
17 [REDACTED] [REDACTED] [REDACTED]
18 [REDACTED] [REDACTED]
19 [REDACTED]
20 [REDACTED]
21 [REDACTED] [REDACTED]
22 [REDACTED]

1 Q. What are the results for the GAMESA turbine?

2 A. [REDACTED]

3 [REDACTED]

4 [REDACTED]

5 [REDACTED]

6 [REDACTED]

7 [REDACTED]

8 [REDACTED]

9 [REDACTED]

10 [REDACTED]

11 [REDACTED]

12 [REDACTED]

13 [REDACTED]

14 [REDACTED]

15 [REDACTED]

16 [REDACTED]

17 [REDACTED]

18 [REDACTED]

19 Q. Since the Project as recently supplemented
20 includes both turbines in the layout, what would
21 the conclusions be in this case?

22 A. My recommendation is that the regulatory limits

1 should be based on the most protective results
2 for the two turbines that were analyzed so that
3 the WHO guidelines of 2009 are met with any of
4 the two turbine models.

5 Q. How do your results compare with your recent
6 testimony for Eight Point Wind?

7 A. Although the wind speed statistics and the
8 turbine models used for the Project are
9 different in that case, the conclusions are
10 similar. For that project I recommended a
11 maximum short-term noise level of 42 dBA-Leq-8-
12 hour.

13 Q. If for some reason an Lnight of 40 dBA is
14 exceeded at a particular receptor, is it
15 possible to provide mitigation?

16 A. Yes, but as I explained before, there are
17 twenty-eight turbines where NRO's were applied:
18 five turbines where an NRO of 5 dBA was used,
19 one where an NRO of 4.5 dBA was used, and six
20 where a 3 dBA NRO were used to demonstrate
21 conformance with relevant criteria through
22 computer noise modeling. Without those NRO's in

1 the model and if turbines T1, T72 and T74 are
2 not eliminated, the results will show that more
3 receptors will exceed the Lnight.

4 Q. Are there any other concerns?

5 A. Yes, the NRO's are more effective if they are
6 needed to reduce exceedances to a short-term
7 noise limit rather than a long-term limit. In
8 fact, when a short-term limit is exceeded, the
9 NRO will only need to be applied during the
10 periods of times when the short-term sound
11 levels are exceeded, most likely at the highest
12 sound power levels of generation. But for long-
13 term sound limits this works differently.

14 Q. Please explain.

15 A. Noise Reduction Operations are more effective at
16 high wind speeds, but they could be zero at
17 medium and low wind speeds. Therefore, the noise
18 reduction achieved at the receptor is lower than
19 the noise reduction applied on the turbines. For
20 instance, if a 2-dBA noise reduction is needed
21 at a receptor a higher NRO would need to be
22 applied on the closest turbines (e.g., 3 dBA).

1 If the NRO is applied only to one turbine and
2 not to other closer turbines the NRO may need to
3 be even higher.

4 Q. Why is that significant?

5 A. This is another cause of concern specially
6 because although the long-term limits that were
7 imposed by the Siting Board in the Cassadaga
8 Wind case are included in the Certificate
9 Conditions proposed by the Applicant for Baron
10 Winds, evaluation of the Lnight descriptor is
11 not included in the protocol for post-
12 construction evaluations. What this also means
13 is that if the long-term sound levels are only
14 modeled by computer, there will be no
15 measurements to demonstrate whether the Facility
16 exceeds the long-term recommendation of 40 dBA
17 Lnight from WHO-2009.

18 A. Is there any other alternative?

19 Q. Yes. One alternative is to require the Applicant
20 to measure the Lnight as the Siting Board did
21 for Case 14-F-0490 and also measure the Lnight
22 as I have proposed in the DPS-Protocol.

1 Alternatively, the long-term limits may be
2 eliminated from Certificate Conditions and post-
3 construction compliance measurements provided a
4 lower short-term limit is adopted and NRO's are
5 not used in computer noise modeling. Since NROs
6 are only effective at high wind speeds and may
7 not be applied to all relevant turbines, this
8 short-term regulatory limit should be
9 conservatively estimated.

10 Q. Do you have a recommendation about what that
11 limit should be?

12 A. Yes, the limit should be 42-dBA-Leq-8-h or
13 lower.

14 A. Do you have any other concerns about the long-
15 term impacts from the proposed Facility other
16 than those mentioned for the nighttime long-term
17 Lnight noise descriptor?

18 A. Yes. The World Health Organization released new
19 guidelines in October of 2018, after the
20 Application was filed, with specific
21 recommendations to address wind turbine noise
22 and with potential implications that I consider

1 important to be considered by the Siting Board.

2 Q. What are the most important findings from your

3 review of WHO-2018 as related to this Project?

4 A. As mentioned before, one of the most important

5 findings is that WHO-2018 withdrew the outdoor

6 short-term recommendation of not exceeding 45

7 dBA-Leq-8-hour during the nighttime that it had

8 recommended in 1999. WHO-1999 was the basis for

9 recommending the Siting Board to apply this

10 short-term limit to the Cassadaga Wind project

11 in Case 14-F-0490. In addition, WHO-2018 (p. 9)

12 recommends a lower outdoor-to-indoor noise

13 reduction provided by the residential buildings

14 than the one that was assumed in 1999 for

15 transportation noise sources, as well as

16 maintaining the indoor noise levels as

17 recommended in 1999. Furthermore, the new

18 recommendation from WHO-2018 is protective not

19 only of the nighttime period but of the daytime

20 and evening time periods as well and more

21 importantly it may require a lower short-term

22 and long-term nighttime noise limit than as

1 recommended in 1999 and 2009, which was also the
2 basis for recommending the Siting Board adopt a
3 short-term and long-term limit for Cassadaga
4 Wind. After analyzing the recommendations of
5 WHO-1999, WHO-2009, and the WHO-2018
6 independently, I conclude that the short-term 45
7 dBA-Leq-8-h outdoor limit is not the most
8 protective among all three guidelines and that a
9 lower limit, on the order of 42-dBA, should be
10 adopted so that all three WHO guidelines and
11 recommendations are met and that the potential
12 adverse effects from the Facility are minimized.

13 Q. You mentioned at the beginning of your testimony
14 that you were introducing the new WHO-2018
15 guidelines as an exhibit in your testimony for
16 this case. Please explain why this is
17 important.

18 A. Yes, the new guidelines propose the Lden noise
19 descriptor which considers the daytime, evening
20 time, and nighttime noise levels.

21 Q. Do those guidelines specifically address the
22 potential health impacts from wind turbine

1 noise?

2 A. Yes. The guidelines include consideration of
3 Wind Turbine Noise.

4 Q. What are the findings?

5 A. The WHO-2018 guidelines found that adverse
6 health effects (such as annoyance) are
7 associated with a level equivalent to 45 dBA
8 Lden. Therefore, the recommendation is that
9 sound levels from wind turbines should be lower
10 than 45-dBA Lden in a year.

11 Q. What is the Lden?

12 A. The Lden is another noise descriptor equivalent
13 to a yearly energy-based average with no
14 penalties applied to the daytime period, a 5-dBA
15 penalty applied to the evening period, and a 10-
16 dBA penalty applied to the nighttime period.

17 Q. How are the daytime, evening time and nighttime
18 periods defined?

19 A. The definitions for all these periods of time in
20 a day may be different for Europe, the United
21 States, and other countries. For example, the
22 "nighttime period" in Europe spans from 11 p.m.

1 up to 7 a.m. the following morning, or from
2 10:00 p.m. to 6:00 am the following day (8-
3 hour), while in United States "nighttime period"
4 spans from 10 p.m. up to 7 a.m. (9-hour). In
5 addition, the "daytime period" in Europe spans
6 from 7 a.m. up to 7 p.m. or from 6:00 a.m. to
7 6:00 p.m. (12-hour) (WHO-2018, p. 9) while in
8 United States "daytime" spans from 7 a.m. to 6
9 p.m. (11-hour). The "evening time" in Europe
10 goes from 7 p.m. to 11:00 p.m. or from 6:00 p.m.
11 to 10:00 p.m. (4-hour) while in the United
12 States "evening time" spans from 6 p.m. up to
13 10:00 pm. Despite the differences in timing
14 definitions, the Lden noise levels for both may
15 result in numbers that are quite similar with
16 differences in the order of a few decimal
17 points.

18 Q. If a sound source is constant during the day
19 time, evening time, and nighttime (as defined in
20 the United States), how many decibels should
21 that noise source be in order not to exceed the
22 45-dBA Lden recommendation?

1 A. That sound source should have a constant average
2 sound pressure level lower than 38.2 dBA Leq
3 during the daytime (Lday), evening time (Leve),
4 and nighttime (Lnight) in a year so that after
5 all the penalties are applied it does not equal
6 or exceed the 45 dBA Lden WHO-2018
7 recommendation. In other words, the daytime,
8 evening time, and nighttime average sound
9 exposure in a year should be about 6.8 dBA lower
10 than 45-dBA Lden WHO-2018 or equivalently 38.2
11 dBA.

12 Q. Are there any other corrections to be applied?

13 A. Possibly. For instance, it is technically
14 feasible to include the periods of time when the
15 noise sources are not generating noise in the
16 calculation of the Lden in a year. The effect
17 of not including any noise from the noise
18 sources (wind turbines in this case) during
19 these periods depends on the percentage of the
20 year the turbines are not producing noise, but
21 they may result in an extra allowance that could
22 be approximately 0.9 dBA for a noise source that

1 is not generating sound for approximately 10% of
2 the time in a year. That being said, the sound
3 should be lower than 39.1 dBA for the yearly
4 average of the Ldaytime, Levening, and the
5 Lnight ($38.2+0.9=39.1$). These levels, when
6 combined with the percentage of time that noise
7 source is not generating noise and after the 5
8 and 10-dBA penalties are applied to the evening
9 time and the nighttime (respectively), will
10 result in a Lden of 45 dBA.

11 Q. How does a noise level of 39.1 dBA Leq in a year
12 equate to a maximum short-term threshold such as
13 the Leq-11-hour (daytime), 4-hour (evening
14 time), 9-hour (nighttime).

15 A. As explained before, the difference between the
16 long-term Lnight descriptor and the maximum
17 short-term noise descriptor (such Leq-1-h or 8-
18 h) depends on the statistical distribution of
19 wind speed magnitudes at the site and the
20 turbine model selected for the Project.
21 Assuming that the difference is 2 dBA, a 39.1
22 dBA average in a year during the daytime would

1 approximately equate to a short-term level of
2 41.1 dBA Leq during the daytime. For a noise
3 source that is constant in time the average for
4 the daytime and evening time periods should be
5 the same. Therefore, in my opinion, the
6 regulatory short-term limit for the daytime and
7 evening time should be about 41 dBA so that the
8 45-dBA Lden recommendation is met.

9 Q. These are estimates for a noise source that is
10 constant in time. Are they applicable to wind
11 turbine noise that is not constant in time?

12 A. Yes, they are. The Netherlands has regulations
13 that use the Lden and the Lnight noise
14 descriptors. The limits have been set at 47-dBA
15 Lden and 41-dBA Lnight since 2011, a difference
16 of 6 dBA between the two noise descriptors (See,
17 Wind Farm Noise Measurements Assessment and
18 Control Colin H. Hansen, Con J. Doolan and
19 Kristy L. Hansen. p.41. Wiley. 2017). For Baron
20 Winds, the difference between the sound power
21 level that generates the Lnight and the Lden in
22 a year is 6.6 dBA for both turbines proposed for

1 the Project, similar to the 6 dBA assumed in the
2 Netherlands.

3 Q. What are the implications in this case?

4 A. [REDACTED]
5 [REDACTED]er
6 [REDACTED]
7 [REDACTED] [REDACTED] [REDACTED]
8 [REDACTED]
9 [REDACTED]
10 [REDACTED] [REDACTED]
11 [REDACTED]
12 [REDACTED]
13 [REDACTED] [REDACTED]
14 [REDACTED] [REDACTED]
15 [REDACTED]
16 [REDACTED] [REDACTED]
17 [REDACTED]
18 [REDACTED]
19 [REDACTED]
20 [REDACTED] [REDACTED]
21 [REDACTED]
22 [REDACTED]

1 [REDACTED]
2 [REDACTED]
3 [REDACTED]
4 [REDACTED]
5 [REDACTED]
6 [REDACTED]
7 [REDACTED]
8 [REDACTED] [REDACTED]
9 [REDACTED]
10 [REDACTED]
11 [REDACTED]

12 Q. If the new WHO-2018 recommendation is exceeded
13 can that be mitigated and, if so, how?

14 A. Yes, the exceedance could be mitigated by
15 applying NRO's to the closest turbines or
16 eliminating some from the design. If NRO's are
17 applied, they need to be greater than the noise
18 reduction needed at the receptor but, as
19 explained before, for the turbines where the
20 maximum NRO of 5 dBA was already used in
21 computer noise models to demonstrate
22 conformance, there may be low or no additional

1 room for increasing the NRO's.

2 Q. How many receptors may exceed a short-term sound
3 limit of 42 dBA-Leq-1-h with and without the
4 application of NRO's in a non-cumulative basis?

5 A. With NRO's applied to the model there are about
6 30 non-participating receptors and 3 non-
7 participating cabins with short-term levels
8 exceeding a 42-dBA-Leq-1-hour sound levels.
9 Without NRO's there are about 77 non-
10 participating receptors and 5 non-participating
11 cabins exceeding that threshold.

12 Q. How many receptors may exceed a cumulative
13 short-term sound limit of 42 dBA-Leq-1-h with
14 and without the application of NRO's?

15 A. With NRO's applied to the model there are about
16 55 non-participating receptors and 4 non-
17 participating cabins with cumulative short-term
18 levels exceeding a 42-dBA-Leq-1-hour sound
19 level. Without NRO's, there are about 90 non-
20 participating receptors and 5 non-participating
21 cabins exceeding that threshold.

22 Q. Do you have any recommendations for

1 Participating receptors?

2 A. Yes. For Cassadaga Wind, Case 14-F-0490, the
3 Siting Board imposed Certificate Condition
4 70(d)(ii) limiting the long-term noise levels to
5 50-dBA-Lnight as a compliance filing requirement
6 and on the assumption of a 5 dBA difference
7 between long-term and short-term descriptors
8 imposed a Certificate condition requiring post
9 construction noise measurement to demonstrate
10 that the sound levels do not exceed 55 dBA-Leq-
11 8-hour. On the basis that the difference
12 between those descriptors may be 2 dBA and not 5
13 dBA, I advise that the short-term limits at
14 participating residences and any portion of land
15 on non-participating property be limited to 52
16 dBA-Leq-8-h.

17 Q. How many participating receptors exceed a sound
18 limit of 55 and 52-dba-leq-8-hour?

19 A. With the current design, no participating
20 receptor and no non-participating property line
21 are forecasted to exceed 55-dBA Leq-1-h with or
22 without NROs in a cumulative or non-cumulative

1 basis. One participating receptor is expected
2 to exceed 52-dba if no noise reductions are
3 applied in a cumulative and non-cumulative
4 basis. This seems to be caused by Baron Winds,
5 not the Cohocton facility. Only one boundary
6 line is reported to exceed 52 dBA in a
7 cumulative analysis if NROs are not applied.

8 Q. What are the results of impacts from low
9 frequency sound?

10 A. The Application identified 65 dB as a goal for
11 low frequency sounds at the full octave bands of
12 16, 31.5 and 63 Hertz. Only one receptor, a non-
13 participating cabin, is reported to be exposed
14 to 66 dB at 16 Hz. However, that does not mean
15 that the potential low-frequency impacts have
16 been minimized to the maximum extent
17 practicable.

18 Q. Please explain.

19 A. The Application Supplemental PNIA states: "Since
20 Gamesa does not published [sic] 1/1 or 1/3
21 octave band noise reduced operation (NRO) data
22 for this turbine, the maximum sound power was

1 shifted down to correspond to the desired amount
2 of sound level reduction when NROs were
3 required." What this means is that this
4 information may not be available and for that
5 reason it was estimated by reducing all sound
6 power levels at all frequency bands by the same
7 number of decibels. In other words, if an
8 overall NRO of 5 dBA was needed, all sound power
9 levels at all frequency bands of the spectra
10 were assumed to be 5 dB lower.

11 Q. Is this correct?

12 A. No. An NRO may be effective to reduce overall
13 broadband noise levels but not low frequency
14 sound levels. This may result in underestimates
15 of the low frequency noise impacts at sensitive
16 receptors. I have seen that on manufacturer's
17 data for some turbines and found that this also
18 was discussed by another author. In fact, Frits
19 van der Berg in his article "Wind turbine noise:
20 an overview of acoustical performance and
21 effects on residents," states: "As is shown in
22 Figure 6 for one particular turbine, this

1 effectively reduces broad band A-weighted
2 levels, but does not have much influence on the
3 low frequency (≤ 125 Hz) octave bands"
4 (Australian Acoustical Society. Proceeding of
5 Acoustics 2013. 17-20 November, Victor Harbor,
6 Australia). From Figure 6 it can be seen that
7 the difference in noise levels at the 63 Hz full
8 octave bands are basically the same, in other
9 words, the noise reduction at the 63 Hz band
10 from NRO from 1 dBA to 6 dBA is practically
11 nothing. For the 16 Hz, which is typically the
12 most problematic, the noise reduction can be
13 practically zero.

14 Q. What are the implications?

15 A. There are 71 non-participating receptors where
16 low-frequency noise levels are forecasted with
17 sound levels equal to or greater than 61 dB in
18 the non-cumulative assessment and 95 receptors
19 exceeding 61 dB at 16 Hz in a cumulative
20 assessment. Some of those receptors are located
21 close to the GAMESA turbines and for those
22 receptors the low frequency impacts may be

1 underestimated, which means that they may exceed
2 a 65 dB threshold at 16 Hz. The Supplement
3 already uses up to 5 dBA NRO's for some Gamesa
4 turbines where the sound levels for low
5 frequency bands were reduced by 5 dBA although
6 the proper reduction may be zero.

7 Q. How can this problem be solved?

8 A. The same Certificate Conditions on low frequency
9 sounds imposed by the Siting Board in Cassadaga
10 Wind, Case 14-F-0490, should be adopted for this
11 Project consisting of modeling with the final
12 turbines proposed for the Project and measuring
13 low-frequency sounds after the Project is built.
14 The computer noise modeling should be updated to
15 reflect the actual sound information from the
16 manufacturer during compliance filings. Should
17 computer noise modeling show exceedances,
18 mitigation of low frequency sound levels should
19 be explored during the design phase. This may
20 consist of replacement of turbine models as
21 needed or turbine elimination.

22 Q. Can a turbine replacement solve the problem?

1 A. Yes. I have seen manufacturers' information that
2 showed that a model option with serrated edges
3 was capable of providing noise reduction at low
4 frequency bands.

5 Q. Please explain what is the first issue that you
6 find in the Certificate Conditions proposed by
7 the Applicant for Baron Winds?

8 A. For Cassadaga Wind, the Siting Board imposed
9 Certificated Condition 80, with a short-term
10 sound limit of 45 (dBA) Leq (8-hour) at any
11 permanent or seasonal non-participant residence
12 and 55 dBA Leq (8-hour) nighttime for any
13 participant residence existing as of the
14 issuance date of the Certificate. In contrast,
15 in Certificate Condition 76, proposed by the
16 Applicant for Baron Winds, the limits apply to
17 the nighttime period exclusively, not for any
18 other time of the day as imposed for Cassadaga.

19 Q. Do you agree with that change?

20 A. No, I do not. As discussed in Case 14-F-0490, I
21 advise that the limits should be applied to the
22 daytime and nighttime for several reasons.

1 First, a Certificate Condition for the nighttime
2 exclusively has no precedent under Article 10,
3 Article X, and Article VII Orders. Second, a
4 Certificate Condition exclusive for the
5 nighttime would leave, without any basis, the
6 application of tonal and Amplitude Modulation
7 penalties for the daytime, which are, in
8 addition to the noise levels, contributing
9 factors for annoyance. Third, having no
10 restrictions on noise for the daytime may
11 potentially result in situations where NRO's may
12 be applied to comply with nighttime limits
13 exclusively, but not during the daytime period
14 as well. Fourth, although the recommendation
15 was based on a night limit for the nighttime
16 provided by WHO-1999 (Exhibit MMC-1), the most
17 recent recommendations from WHO (WHO-2018,
18 Exhibits MMC-3 and MMC-4) uses a noise
19 descriptor that includes consideration of all
20 time periods in a day, not the nighttime only.

21 Q. Has the Siting Board made a determination on
22 this issue?

- 1 A. Yes, in Case 14-F-0490 the Siting Board imposed
2 the 45 (dBA) Leq (8-hour) sound limit regardless
3 of the time of day or night which means that the
4 limit shall not be exceeded during any eight
5 consecutive hours during the day.
- 6 Q. Are there any other issues with short-term goals
7 as related to proposed Certificate Condition 76?
- 8 A. Yes. The Applicant for Cassadaga Wind initially
9 presented two different goals, one for full-year
10 or permanent residences and another for seasonal
11 residences that was three decibels greater.
12 Staff's position in that case was that the
13 limits should be the same regardless of
14 occupancy, which was imposed as Certificate
15 Condition 80 specifying that the limit applies
16 to both seasonal and permanent residences. Such
17 language is excluded from the text of the
18 proposed Certificate Condition 68 for this case
19 and should be incorporated as is currently
20 included in the recommended DPS Certificate
21 Condition 72 (a).
- 22 Q. What is the next issue that you find with the

1 certificate conditions proposed by the
2 Applicant?

3 A. As explained earlier in my testimony, although
4 the Siting Board imposed in the Cassadaga Wind
5 Case 14-F-0490 Certificate Condition 80(b) with
6 a long-term limit of 40 dBA Lnight at any non-
7 participating residence and 50 dBA Lnight at any
8 non-participating residence, those limits are
9 excluded from the Certificate Conditions
10 proposed by the Applicant for Baron Winds. In
11 addition, evaluation of the Lnight descriptor is
12 not included in the protocol for post-
13 construction evaluations. What this means is
14 that there will be no measurements to
15 demonstrate whether the Facility exceeds the
16 long-term recommendation of 40 dBA Lnight from
17 WHO-2009 and the limit of 50 dBA Lnight for
18 participating receptors, which was based on the
19 identified threshold for zero risk of
20 cardiovascular disease identified by WHO-2009.
21 The condition has been included in Staff
22 Certificate condition 72 (b).

1 Q. Are there any issues related to low frequency
2 sounds from the wind turbines in the Certificate
3 Conditions proposed by the Applicant?

4 A. Yes. In Case 14-F-0490 the Siting Board adopted
5 Certificate Condition 80(c), which requires the
6 facility to "[c]omply with a maximum noise limit
7 of 65 dB Leq at the full octave frequency bands
8 of 16, 31.5, and 63 Hertz outside of any non-
9 participant residence existing as of the
10 issuance date of this Certificate in accordance
11 with Annex D of ANSI standard S12.9-2005/Part 4
12 (Sounds with strong low-frequency content)."
13 That condition is not proposed by the Applicant
14 for Baron Winds.

15 Q. What does Annex D of ANSI Standard S12.9 say?

16 A. Section D.2 of Annex D in ANSI S12.9-2005 Part
17 4, entitled "Sounds with strong low-frequency
18 content," states "[g]enerally, annoyance is
19 minimal when octave-band sound pressure levels
20 are less than 65 dB at 16, 31.5 and 63-Hz mid-
21 band frequencies."

22 Q. What is your recommendation for this case?

- 1 A. A Certificate Condition for low frequency noise
2 is protective of annoyance to low frequency
3 sounds and perceptible vibrations and for that
4 reason should be adopted for Baron Winds as it
5 was for Cassadaga Wind. This is reflected in
6 DPS-Staff proposed Certificate Condition 72(d)
- 7 Q. Are there any issues related to Certificate
8 Conditions proposed by the Applicant as related
9 to complaints from the wind turbines?
- 10 A. Yes. In Case 14-F-0490, the Siting Board
11 adopted Certificate Condition 81, which has
12 different requirements for the facility related
13 to the way that noise and vibration complaints
14 should be handled. These provisions are not
15 found in the Certificate Conditions proposed by
16 the Applicant for Baron Winds. These provisions
17 are included in DPS Staff's proposed Certificate
18 Condition 73 for this Project.
- 19 Q. What is the importance of this Certificate
20 Condition?
- 21 A. All these conditions are very important,
22 particularly Certificate Conditions designated

1 as 81(c) and 81(d) in the Cassadaga Wind
2 Project, because they relate to the way
3 complaints from Amplitude Modulation are
4 handled. Amplitude Modulated sounds from wind
5 turbines and how they increase annoyance to
6 sounds from Wind Turbines was thoroughly
7 discussed in the Cassadaga case. In that Case,
8 the Siting Board adopted the recommendation from
9 DPS Staff and imposed a Certificate Condition
10 for AM with a 5 dBA AM penalty. Given the
11 importance of having requirements for the
12 Facility to handle complaints, Staff is
13 proposing for Baron Winds the provisions adopted
14 by the Siting Board for Cassadaga Wind to handle
15 complaints, including those related to Amplitude
16 Modulated sounds along with some modifications
17 that I will discuss later in my testimony.

18 Q. Please explain the concept of amplitude
19 modulation and the Application's analysis and
20 conclusions related to amplitude modulation.

21 A. In simple terms, amplitude modulation is a
22 repetitive sound that occurs with a frequency of

1 about one second or less. This is commonly
2 described as a repetitive "swish" or "thump"
3 associated with turbine operation. "Recent
4 evidence suggests that at times this 'swish' can
5 become more of a pronounced 'thump,' leading to
6 complaints from wind farm neighbors." "(UK-2016,
7 p. 1)."

8 Q. Are there any differences between Certificate
9 Conditions proposed by Staff and the Applicant
10 as related to complaints from Amplitude
11 Modulation (AM) from the Project?

12 A. Yes. Given the discrepancies that could occur
13 between computer noise modeling and actual post-
14 construction noise measurements, I recommend
15 that complaints related to Amplitude Modulation
16 be investigated if measured or modeled sound
17 levels at the location(s) being evaluated exceed
18 40 dBA L1hr, rather than based on modeled levels
19 exceeding 40 dBA L1hr exclusively, as ordered
20 for Cassadaga Wind (Certificate Condition 81
21 (d)). That change is reflected in Staff's
22 Certificate Condition 73 (d). In addition, I

1 recommend edits on the clause related to
2 Amplitude Modulation as ordered for Cassadaga.
3 The edits are consistent with the discussion on
4 page 60 of the Cassadaga Wind Order that states
5 "[t]he RD also adopted a restriction on the
6 Facility's production of amplitude modulated
7 sounds, such as complaints of swishing or
8 thumping type sounds. Should such amplitude
9 modulated sounds be found to exceed a noise
10 level of 45 dBA for more than 5 percent of the
11 evaluation period, the Certificate Holder would
12 be required to implement minimization measures."

13 Q. Are there any issues related to the Applicant's
14 proposed certificate condition on Amplitude
15 Modulation?

16 A. Yes. I consider that the time frame of
17 evaluation of Amplitude Modulation should be
18 clearly specified. I am proposing a timeframe of
19 evaluation of 8-hours which I consider to be
20 appropriate. The text "amplitude modulation
21 depth is 5 dB or lower for a minimum of 90% any
22 hour" is confusing. First, I think that the 90%

1 was set as the complement of the 10% indicated
2 in the same clause. Therefore, the 90% should be
3 95%. Second, the text should refer to the
4 penalty for Amplitude Modulation which is set at
5 the beginning of the same clause. For that
6 reason, I am proposing edits so that the
7 Application of the AM penalty makes sense and is
8 consistent with the intent expressed in the
9 discussion of the order and the first portion of
10 this clause.

11 Q. Is there any other way to address potential
12 issues with amplitude modulation sound?

13 A. Yes, by reducing the sound limits to which the
14 AM penalty is applied. The UK-2016 document
15 recommended amplitude modulation penalties
16 between 3 and 5 dBA. The 3 dBA penalty is
17 applied if an AM depth of 3 dBA occurs while a 5
18 dBA penalty is applied if an AM depth greater
19 than 5 dBA occurs. If the short-term goals and
20 limits are reduced to 42 dBA or lower an
21 amplitude modulation penalty may not be needed.

22 Q. Are there any advantages when doing this?

- 1 A. Yes. There is no need to measure amplitude
2 modulation. Therefore, Certificate Condition 73
3 (d) could be eliminated as proposed in my
4 alternative to Certificate Conditions in
5 Exhibit__(MMC-10). As I previously stated, the
6 short-term limit should be equal to or lower
7 than 42 dBA to meet the WHO recommendations of
8 1999, 2009, and 2018 and, at that level, the AM
9 penalty may no longer be necessary.
- 10 Q. Do you have any recommendations about how
11 complaints should be reported?
- 12 A. Yes. My recommendations are reflected in
13 Certificate Condition 73(c), Exhibit__SSP-2. For
14 this case I recommend that complaints be
15 reported monthly during the first three years of
16 operation and quarterly after that rather than
17 monthly during the first full year of commercial
18 operations as adopted for Cassadaga. If no
19 noise or vibration complaints are received. I
20 also recommend requiring the Certificate Holder
21 to submit a letter to the Secretary indicating
22 that no complaints were received during the

1 reporting period rather than excepting the
2 Applicant of any filings if no noise or
3 vibration complaints are received.

4 Q. Do you have any recommendations for Compliance
5 testing?

6 A. Yes, I do. In Case 14-F-0490, the Siting Board
7 adopted Certificate Condition 72 requiring the
8 Applicant to perform two compliance tests: one
9 during "leaf-on" conditions; and another one
10 with "leaf-off" conditions. Those provisions
11 are not proposed by the Applicant for Baron
12 Winds. DPS Staff is proposing similar language
13 in its recommended Certificate Condition 70.
14 One of the changes Staff is requesting, as
15 related to Certificate Condition 71 adopted for
16 Cassadaga, refers to the Compliance Protocol.
17 For Cassadaga Wind DPS Staff did not propose a
18 compliance protocol. Absent of any alternatives
19 the Recommended Decision (RD) and the Siting
20 Board's Order adopted the protocol presented by
21 the Applicant. The Applicant here has proposed
22 addressing complaints and testing the Facility

1 with a protocol that was initially filed with
2 the Application and that was recently modified
3 in response to interrogatory request "Oehlbeck-
4 IR-1". I have objections to the most recent
5 protocol which are presented in Exhibit MMC-13
6 with side comments on the most relevant issues.
7 This does not address the parts of a compliance
8 protocol that should have been but that in my
9 opinion are missed.

10 Q. What are the most important issues with the
11 Protocol presented in the Application?

12 A. The most important issue is that the protocol
13 presented with the Supplement only proposes
14 testing of the short-term noise descriptor for
15 the nighttime at non-participating receptors.
16 Testing of the long-term noise descriptor
17 Lnight, as imposed by the Siting Board in Case
18 14-F-0490, is excluded as well as testing during
19 the daytime and testing at participating
20 residences. In addition, testing of the low
21 frequency noise levels, as ordered by the Siting
22 Board in Case 14-F-0490, is also excluded from

1 the protocol. In addition, there are no
2 provisions for measurement of Amplitude
3 Modulation and perceptible vibrations.

4 Q. Are there any other issues with the compliance
5 protocol?

6 A. Yes. Section 2.6.4 Data Analysis states: "For
7 any one-hour period during which Turbine-plus-
8 background sound levels exceed 45 dBA Leq,
9 Background will be subtracted to determine the
10 sound level attributable to the Project
11 (Turbine-only level). The Background level is
12 the adjusted Background Leq with a factor added
13 for uncertainty according to ANSI S12.9 Part 3
14 Clause 7.3.". The introduction of the word
15 "added" is not appropriate. ANSI Standard
16 requires the addition of the uncertainty for the
17 party that needs to demonstrate a violation (DPS
18 in this case) and the subtraction of the
19 uncertainty for the party that needs to
20 demonstrate "compliance," in this case, the
21 Certificate Holders. The way this provision is
22 drafted, demonstration of compliance by the

1 Certificate Holder will be potentially easier
2 and demonstration of violation by any other
3 party including DPS harder. In addition, the
4 uncertainty factors specified by ANSI S 12.9
5 Part 3 are greater if the time between the
6 measurement of operational sound and background
7 sounds is greater. The intent is to encourage
8 both parties to measure background levels very
9 close to the time when operational sound levels
10 are measured so that background conditions are
11 similar. The way this provision is written it
12 can make demonstration of compliance by the
13 Certificate Holders easier if measurements are
14 delayed or taken later rather of sooner, which
15 makes absolutely no sense. On the other hand,
16 this clause will force other parties including
17 DPS Staff to take readings very close to the
18 measurement of operational noise levels but not
19 the Certificate Holders.

20 Q. How do you recommend this be corrected?

21 A. The provision should include the addition of
22 uncertainties for the party that needs to

1 demonstrate a violation (e.g., DPS Staff) and
2 the subtraction of uncertainties for the party
3 that needs to demonstrate conformance, in this
4 case the Certificate Holder. From the analysis
5 of certificate conditions on noise imposed by
6 the Siting Board in Case 14-F-0490, it is clear
7 that demonstration of compliance corresponds to
8 the Certificate Holder's (See Case 14-F-0490,
9 Certificate Conditions 71, 72(a), 72(b), 72(e),
10 81(c) and 81(d). Alternatively, this provision
11 should be eliminated from the Protocol so that
12 the results as determined by the Certificate
13 Holder and DPS Staff are the same, provided any
14 background measurements are taken no later than
15 one hour before or after any shutdown. The
16 latter approach is proposed in the Staff's
17 Protocol.

18 Q. Do you have any other issues with the proposed
19 protocol?

20 A. Yes. Section 2.5 Data Collection states: "The
21 sound monitoring period will last at least two
22 weeks or until at least 20 clean shutdowns have

1 occurred, whichever is later. A clean shutdown
2 is one where the maximum 10-minute hub height
3 wind speed of the closest turbine exceeds 4 m/s
4 ...". First, this provision refers to maximum
5 sound levels since the protocol presented in the
6 Application only proposes measurement of short-
7 term impacts. For that purpose, a wind speed of
8 4 m/s is irrelevant. It only means that the
9 turbines will be rotating at minimal noise
10 production. Noise levels should be measured at
11 the worst operational noise conditions which
12 usually correspond to wind speeds greater than 4
13 meters per second (Wind turbines typically reach
14 the maximum sound power levels at wind speeds
15 greater than 7 meters per second). This
16 provision may result in 40 operational 1-hour
17 sound levels that do not correspond to the worst
18 noise conditions and, therefore, are not
19 appropriate for determination of the maximum
20 noise impacts.

21 Q. Do you have any other issues with the proposed
22 protocol?

- 1 A. Yes. Section 2.6.6.a states: "Tonal periods will
2 be further screened to determine if the tonal
3 sound is audible using Table 7 of ISO 387-7
4 (2005)". DPS-Staff has not been able to find the
5 referred standard. The way that this issue was
6 addressed in the protocol imposed by the NYS
7 Public Service Commission in Case 10-T-0350 was
8 by using the hearing thresholds for a 95%
9 confidence level as specified by Kurakata-2005.
10 In other words, sound levels exceeding these
11 thresholds will be only audible for 5 percent of
12 the people and inaudible for 95 percent of the
13 people. This potentially restricts the
14 application of a tonal penalty as adopted by the
15 Siting Board for Case 14-F-0490. For that case,
16 the Board adopted a 5-dB tonal penalty
17 regardless of the time period of evaluation.
- 18 Q. Do you have any other issues and what is your
19 opinion on the protocol presented with the
20 Supplement on the Application?
- 21 A. There are more issues and they are indicated in
22 Exhibit MMC-13. In general, I do not recommend

1 the adoption of the Protocol as presented in the
2 Application as it will not properly evaluate
3 whether the Facility as designed and as built
4 will in fact avoid, offset, or minimize, the
5 adverse environmental noise or vibration impacts
6 upon the local community for the duration of the
7 certificate.

8 Q. Do you have any issues with the Complaint
9 Resolution Protocol?

10 A. Yes. Those issues are explained with side
11 comments on the Complaint Resolution Protocol
12 recently submitted Exhibit__ (MMC-13).

13 Q. Are you recommending a Protocol for
14 postconstruction noise evaluations?

15 A. Yes. I am proposing a different Protocol for
16 demonstration of operational compliance
17 developed for this Project. I am attaching a
18 copy of the compliance protocol presented with
19 the Application with my comments on some
20 portions of the text.

21 Q. Please explain what is the next change that you
22 recommend.

- 1 A. Certificate Condition 71 presented in the
2 Application states: "The Certificate Holder
3 shall perform sound monitoring and compliance
4 protocols pursuant to the Baron Winds Sound
5 Monitoring and Compliance Protocol submitted
6 with the Application." I disagree with this
7 condition. First, the Applicant and DPS Staff
8 should not follow the protocol presented by the
9 Applicant as this protocol is insufficient and
10 contains many issues as discussed here and in
11 Exhibit__ (MMC-13). Second, I recommend that if
12 the Siting Board decides to grant a Certificate
13 to Baron Winds any post-construction monitoring
14 should be conducted by following the Sound
15 Testing Compliance protocol presented by DPS and
16 attached to this testimony as Exhibit__ (MMC-7).
- 17 Q. Do you have any recommendations for Compliance
18 Filings?
- 19 A. Yes, I do. In case 14-F-0490 the Siting Board
20 adopted Certificate Conditions 70(a) and 70(b),
21 which require the Applicant to file final
22 construction drawings indicating changes in

1 turbine locations or substation components, if
2 any, and present GIS files, dimensions, proposed
3 grading and elevations for turbines, and any
4 mitigation measures adopted for the Substation
5 Collector. These provisions are not presented
6 by the Applicant for Baron Winds but are
7 presented by DPS Staff in proposed Certificate
8 Conditions.

9 Q. Are there any differences between the
10 Certificate Conditions Staff is recommending for
11 noise and vibrations and the Certificate
12 Conditions proposed by the Applicant as related
13 to Compliance Filings?

14 A. Yes. In Certificate Condition 68(c)(i) I am
15 including edits to fix typos related to the
16 standards used to report sound power levels from
17 the turbines. In Certificate Condition
18 68(c)(ii) I am including edits to reflect that
19 sound power levels should not exceed the final
20 overall and full-octave band levels presented in
21 the Application or any subsequent supplement.
22 In Certificate Condition 68(d) I am recommending

1 that NROs not be used in the design, to
2 demonstrate conformance with any limit imposed
3 by the Siting Board as a compliance filing
4 requirement. Also, in Certificate Condition
5 68(d)(i) and 72(b), I am recommending requiring
6 the Applicant to evaluate the new
7 recommendations from WHO-2018 consisting of
8 noise levels lower than 45 dBA Lden. As an
9 alternative to this, I am recommending lower
10 short-term regulatory limits as shown in my
11 alternate proposed Certificate Condition 72(a) in
12 Exhibit__ (MMC-10).

13 Q. Are there any issues related to sound limits at
14 the boundary lines?

15 A. Yes. Certificate Condition 68(d)(iii) has been
16 included to reflect the discussions in the
17 Cassadaga's order which was not reflected in the
18 final approved Certificate Conditions. In that
19 case the Order states, on pages 71 and 73:
20 "[a]rea of property to be measured ... The
21 Examiners explained that although the Applicant
22 also agreed to adopt a long-term design goal of

1 50 dBA Leq-1-year for the nighttime period at
2 all participant receptors' property lines, it
3 applied that measure only to the portion of a
4 real property plot that is within 150 feet of an
5 existing roadway. The RD recommended that we
6 impose the design goal as a regulatory limit
7 across the entire property to preserve the
8 enjoyment of the entire property.... We agree with
9 Concerned Citizens and DPS Staff. Cassadaga
10 Wind's 150-foot from a public roadway limit is
11 arbitrary. Notwithstanding the lack of
12 specificity in the experience that Cassadaga
13 Wind relies on to support its position, we do
14 not agree that such experience is relevant for
15 the local community at issue in this case.
16 Accordingly, we adopt the RD's recommendation."
17 That recommendation is reflected in my proposed
18 Certificate Condition 68(d)(iii). In addition,
19 although the recommended decision refers to a 50
20 dBA (Lnight-outside) limit, I consider it more
21 practical to express this requirement by using a
22 short-term limit for this compliance filing at

1 boundary lines. That is because it is practical
2 to generate sound contour drawings with the ISO
3 model for boundary lines with the sound turbines
4 at maximum power levels but not feasible to
5 generate yearly noise contours with the CONCAWE
6 meteorological correction. As explained in my
7 discussions above, the difference between the
8 Long-term L_{night} and the short-term descriptor
9 Leq may not be 5 dBA but rather as low as 2 dBA.
10 For that reason, I recommend a short-term limit
11 of 52 dBA Leq-8-hour for boundary lines as a
12 compliance filing in my alternate Certificate
13 Conditions included in Exhibit__ (MMC-10),
14 Certificate Condition 68(d)(iii).

15 Q. Do you have any other recommendations?

16 A. Yes. In the event that the final turbine model
17 selected for the Project has manufacturer's data
18 showing higher sound levels in the overall
19 broadband (dBA) noise level and also at any key
20 low frequencies (16, 31.5 or 65 Hz), the re-
21 evaluation of predictions and conformance with
22 relevant guidelines, criteria, and goals should

1 also include the new data at the low frequency
2 range in order to understand the anticipated
3 impacts of the different turbine model(s).

4 Q. What is your conclusion about the analysis of
5 short-term impacts and Certificate Conditions?

6 A. Short-term regulatory limits should be lower
7 than those set for Cassadaga Wind and may need
8 to be as low as 42-dBA-8-h-nighttime to comply
9 with the indoor recommendations of WHO-1999, the
10 Lnight recommendations of 2009, and the Lden
11 recommendation of 2018. The levels should apply
12 to all non-participating receptors regardless of
13 occupancy. In addition, short-term limits
14 should be set for the daytime, as well. These
15 recommendations are reflected in Certificate
16 Conditions 72(a) and (b) and in my alternate set
17 of Certificate Conditions (Certificate Condition
18 72(a)).

19 Q. What are your recommendations for participating
20 receptors.

21 A. I also recommend reducing the regulatory limit
22 for non-participating receptors, from 55 dBA as

1 ordered for Cassadaga Wind to 52 dBA-Leq-8-h on
2 the basis that the difference between the short-
3 term limits and the long-term limits may be as
4 low as 2 dBA and not 5 dBA as assumed for
5 Cassadaga. This recommendation is based on an
6 identified threshold of 50 Lnight in WHO-2009
7 for zero risk of cardiovascular disease.
8 Participating receptors should be aware that
9 indoor noise levels with the windows open, or
10 partially open, may be higher than as
11 recommended by WHO-1999 and may need to close
12 their windows to reduce the potential for
13 annoyance or sleep disruptions. Currently, the
14 Application shows that the maximum Leq-1-h sound
15 levels at participating receptors are predicted
16 to be below the 52 dBA Leq-8-h regulatory limit
17 that I am recommending.

18 Q. Do you have any recommendations for mitigation
19 of noise and vibration after the Project is
20 built?

21 A. Yes. In case 14-F-0490 the Siting Board adopted
22 Certificate Condition 73, which contained a

1 series of steps and provisions for mitigation in
2 case a compliance or violation test shows that
3 the Facility exceeds any Certificate Conditions.
4 Those conditions require presenting operational
5 and physical minimization measures to the Board
6 or the Commission, providing mitigation measures
7 within reasonable time frames, retesting the
8 mitigation measures implemented for compliance,
9 as well as a restriction that prohibits the
10 Facility to operate without the mitigation
11 measures that are approved by the Siting Board
12 or the Public Service Commission. These
13 provisions are not included in the Certificate
14 Conditions proposed by the Applicant for Baron
15 Winds. Given their importance, those provisions
16 as adopted for Cassadaga Wind, are reflected in
17 DPS Staff's proposed Certificate Condition 71.

18 Q. Are there any differences between the
19 Certificate Conditions Staff is recommending for
20 noise and vibrations and the Certificate
21 Conditions proposed by the Applicant as related
22 to Postconstruction Compliance Evaluations?

- 1 A. Yes. In Certificate Condition 69, and as
2 explained above, I am recommending adopting the
3 Sound Testing Compliance Protocol presented by
4 DPS in Exhibit__ (MMC-7) and not the Protocol
5 presented by the Applicant. Since the protocol
6 presented by Staff already contains all the
7 elements included in Cassadaga's Certificate
8 Conditions 71(a), (b), and (c), I advise those
9 provisions are not needed. For the same reasons,
10 I am recommending the elimination of Applicant's
11 Certificate Conditions 70(a), (b), (c), and (d).
- 12 Q. Are there any differences between the
13 Certificate Conditions Staff is recommending and
14 the Certificate Conditions proposed by the
15 Applicant as related to regulatory noise limits
16 to the Facility?
- 17 A. Based on my discussions in my testimony, I am
18 recommending in Certificate Condition 72(b) that
19 the Facility also be required to demonstrate
20 compliance with the new WHO guidelines of 45-dBA
21 Lden for any existing permanent or seasonal non-
22 participating residence by post-construction

1 noise testing after the Facility is built.
2 Alternatively, if the Siting Board decides not
3 impose a Certificate Condition of 45 dBA Lden,
4 40 dBA L(night), or both, I recommend reducing
5 the short-term regulatory noise limit from 45
6 dBA Leq (8-hour) to 42 dBA Leq (8-hour) for any
7 existing participating receptors and from 55
8 (dBA) Leq (8-hour) to 52 (dBA) Leq (8-hour) for
9 any existing non-participating receptors. This
10 option is reflected in my alternate conditions
11 included in Exhibit MMC-10 (Certificate
12 Condition 72(a)). In addition, I am
13 recommending that the noise descriptor for the
14 65-dB Leq low-frequency noise limit included in
15 Certificate Condition 60(d) be clarified as 65
16 dB Leq-1-hour. This is consistent with the
17 requirements for compliance filings for
18 Cassadaga (Case 14-F-0490, Certificate Condition
19 70(d)(iii) and also with the noise descriptor
20 specified in Certificate Condition 69(b)(3)
21 proposed by the Applicant. I am also
22 recommending clarifying that section D.2.(1) is

1 the relevant section of ANSI S12.9-200/Part 4
2 for the 65 dB-1-h limit for low frequency sounds
3 proposed in Staff's Certificate Conditions.
4 Also, in Staff's Certificate Condition 71, I am
5 clarifying that "compliance" tests will refer to
6 tests performed by the Applicant and "violation"
7 tests will refer to those performed by DPS
8 Staff. This to be consistent with the content
9 and intent of ANSI Standard S12.9 Part 3.
10 Finally, in Staff's Certificate Condition 74, I
11 am clarifying that the Certificate Holder should
12 keep both a schedule and a log of Noise Reduced
13 Operations.
14 Q. Are the number and models of turbines presented
15 in the Application the same currently considered
16 for the project?
17 A. No. According to the information contained in
18 the most recent supplement the number of
19 turbines was reduced from 76 to 69. In addition,
20 according to the sound data filed in the
21 Application, the turbines as originally proposed
22 were Vestas 117 3.3/3.45 MW and Vestas 136-3.45

1 MW. In the latest supplement, the turbines
2 considered for the project are Nordex N117 3600
3 and GAMESA G114 2625.

4 Q. Had you identified the turbines that should have
5 been eliminated from the original design?

6 A. Yes, turbines where the maximum NRO's of 7.5 dBA
7 were applied were in my opinion the best
8 candidates for elimination.

9 Q. To the best of your knowledge, as a result of
10 the proposed modifications, were any of the
11 turbines where the maximum NRO's of 7.5 dBA were
12 applied proposed to be eliminated from design?

13 A. Turbines T1 and T74 were turned off in the
14 computer model and in my opinion, they need to
15 be eliminated from design. None of the other
16 turbines with NRO's of 7.5 dBA were eliminated.
17 Still, in my opinion, some of them should be
18 eliminated.

19 Q. Are there any concerns?

20 A. Yes, the elimination of turbines where the
21 maximum NRO's were applied and where the sound
22 levels at impacted receptors are the highest is

1 preferred. In addition, the use of NRO's for
2 computer noise modeling shows that the proposed
3 layout does not conform with relevant thresholds
4 and criteria unless NRO's are incorporated in
5 the design. For those turbines additional NRO's
6 required to comply with Certificate Conditions
7 may be limited or unfeasible. In addition,
8 NRO's also reduce the production of energy.

9 Q. Have you identified the turbines that would be
10 recommended to be either eliminated or
11 relocated?

12 A. Yes. Based on the modeling results under ISO
13 9613-2 and the geographical information system
14 (GIS) information provided by the Applicant,
15 Staff has generated drawings identifying non-
16 participant noise sensitive receptors within the
17 Project area differentiated by colors. The
18 sound levels can be seen in the legends of these
19 drawings Exhibit__ (MMC-9). Turbines that are
20 identified as candidates for elimination are:
21 T1, T72 and T74 which needed to be turned off in
22 computer noise modeling. T7 and/or T-18; T24,

1 T46, T47 and T-93; and T52 and/or T60.

2 Q. What is your recommendation?

3 A. My recommendation is that Noise Reduction
4 Operations should not be used for computer noise
5 modeling to demonstrate conformance with
6 relevant criteria and that minimization measures
7 should be provided during design for the most
8 impacted receptors.

9 Q. Are there any mitigation measures that could be
10 implemented if a non-conformance operational
11 situation is found?

12 A. Yes. NRO's are the most practical mitigation
13 measure that could be implemented after the
14 Project is built provided they are sufficient to
15 mitigate any actual exceedances.

16 Q. What are your final recommendations about the
17 proposed Facility.

18 A. The design should keep the noise reduction
19 operations (NROs) as a contingency option to
20 mitigate any discrepancies between predicted and
21 actual sound levels. Should sound levels at the
22 non-participating or participating receptors

1 exceed relevant criteria or any Certificate
2 Conditions imposed by the Siting Board after
3 construction, then NRO's should be applied as
4 necessary on relevant turbines to bring noise
5 levels back into compliance.

6 Q. Does the proposed Facility avoid or minimize
7 environmental impacts to the maximum possible
8 extent?

9 A. No. I believe that the potential adverse
10 environmental noise impacts from operation of
11 the Facility have not been avoided or minimized
12 to the maximum extent practicable. I also
13 believe that additional minimization measures
14 such as elimination or relocation of turbines
15 needs to be explored.

16 Q. What is your recommendation to the Siting Board
17 regarding granting a Certificate to the
18 Applicant in light of the environmental noise
19 impacts?

20 A. My recommendation as related to adverse
21 environmental noise and vibration effects is
22 that the Project should be approved subject to

1 the Certificate Conditions, the post-
2 construction protocol, the regulatory limits
3 that I am recommending for this project, and a
4 redesign to include elimination of turbines
5 without the use of NRO's so that the adverse
6 environmental noise effects of the operation of
7 the Facility are minimized or avoided to the
8 maximum extent practicable. In my opinion the
9 alternative presented in the Application
10 Supplement does not avoid, offset or minimize
11 the impacts caused by the Facility upon the
12 local community for the duration that the
13 Certificate is issued to the maximum extent
14 practicable using verifiable measures. The
15 Applicant should present updated computer noise
16 modeling results considering the elimination of
17 turbines that I am recommending and demonstrate
18 that the adverse operational noise impacts have
19 been minimized or avoided to the maximum extent
20 practicable. The final computer model should
21 determine whether additional turbines need to be
22 relocated or eliminated in order to comply with

1 relevant thresholds and criteria as recommended
2 in this testimony. In addition, the Applicant's
3 proposed Certificate Conditions and
4 Postconstruction Compliance Protocol are not
5 sufficient to demonstrate that the Facility will
6 in fact avoid, offset or minimize the impacts
7 upon the most sensitive receptors to the maximum
8 extent practicable using verifiable measures.
9 Further, I recommend adoption of DPS Staff
10 proposed Certificate Conditions on noise and
11 protocol for demonstration of compliance after
12 construction, if the Project is finally
13 approved. The Applicant should present updated
14 computer noise modeling results as a compliance
15 filing to reflect any change introduced to the
16 design such as different turbine model(s) or
17 turbine locations, any changes on the list of
18 receptors including any changes on participation
19 status, to demonstrate that the adverse
20 operational noise impacts have been minimized or
21 avoided to the maximum extent practicable before
22 a final design can be approved and construction

1 can begin.

2 Q. Does this conclude your testimony at this time?

3 A. Yes.