

**APPENDIX A**  
**LETCHWORTH**

**Permits and Regulatory Correspondence**

## Approval of Plans for Public Water Supply Improvement

This approval is issued under the provisions of 10 NYCRR, Part 5:

1. Applicant United Water New York, Inc.	2. Location of Works (C, V, T)  (T) Haverstraw	3. County  Rockland	4. Water District (Specific Area Served) Ramapo High
5. Type of Project			
<div><input type="checkbox"/> 1 Source</div> <div><input type="checkbox"/> 2 Transmission</div> <div><input type="checkbox"/> 3 Pumping Units</div> <div><input type="checkbox"/> 4 Chlorination</div> <div><input type="checkbox"/> 5 Fluoridation</div> <div><input checked="" type="checkbox"/> 6 Other Treatment</div> <div><input type="checkbox"/> 7 Distribution</div> <div><input type="checkbox"/> 8 Storage</div> <div><input checked="" type="checkbox"/> 9 Other</div>			
<p>Remarks: Log #17981, NY4303673 for a project to increase seasonal peak plant production to approximately 3.0 MGD through addition of a 14 inch diameter line and a static mixer with polyaluminum chloride (PACl) coagulant, potassium permanganate, and future use injection ports bypassing a mixing pot (to be demolished) and a mixing basin (to be physically disconnected); installation of transverse masonry walls with 2' 8" wide by 5' high exits which convert two existing sedimentation basins into flocculation basins with variable speed flocculators (three each) and masonry baffle walls sequentially followed by upflow settling basins with tube settlers, mechanical sludge removal to lagoons, and reinforced fiberglass exit troughs; upsized 20" exit pipes from the settling basins to the existing dual media filters; continued post filtration additions of sodium hypochlorite, caustic soda and Seaquest; chlorine contact within and existing clear well; a new transformer, automatic switch and diesel standby generator unit on a fenced outdoor slab; a new booster pump station (two pumps at 1.5 MGD, 235 feet TDH); new backwash water pump motors; various new valves, monitoring and control and appurtenances.</p>			

By initiating improvement of the approved supply, the applicant accepts and agrees to abide by and conform with the following:

- a. THAT the proposed works be constructed in complete conformity with the plans and specifications approved this day or approved amendments thereto.
- b. THAT the proposed works not be placed into operation until such time as a Completed Works Approval is issued in accordance with Part 5 of the New York State Sanitary Code.

See attached for Special Conditions c through u.

ISSUED FOR THE STATE COMMISSIONER OF HEALTH

June 11, 2007

\_\_\_\_\_, P.E.  
Designated Representative

Michael J. Montysko, PE  
Chief, Design Section, Bureau of Water Supply Protection

## General

6. Type of Ownership		<input type="checkbox"/> 68 Private—Other	<input type="checkbox"/> 1 Authority	<input type="checkbox"/> 30 Interstate
<input type="checkbox"/> Municipal	<input type="checkbox"/> Commercial	<input type="checkbox"/> Private—Institutional	<input type="checkbox"/> 19 Federal	<input type="checkbox"/> 40 International
<input type="checkbox"/> Industrial	<input checked="" type="checkbox"/> 9 Water Works Corp.	<input type="checkbox"/> 26 Board of Education	<input type="checkbox"/> 20 State	<input type="checkbox"/> 8 Indian Reservation
7. Estimated Total Cost \$4,000,000		8. Population Served 30% of 300,000		9. Drainage Basin Hudson River
10. Federal Aid Involved? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> 2 No		11. WSA Project? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> 2 No WSA 9947 issued 7/18/06		

## Source

12. <input type="checkbox"/> Surface Name: Class:		13. Est. Source Development Cost
<input type="checkbox"/> Ground Name:		
14. Safe Yield	15. Description	

## Treatment

16. Type of Treatment			
<input type="checkbox"/> 1 Aeration	<input checked="" type="checkbox"/> 4 Sedimentation	<input type="checkbox"/> 7 Iron Removal	<input type="checkbox"/> 10 Softening
<input type="checkbox"/> 2 Microstrainers	<input checked="" type="checkbox"/> 5 Clarifiers	<input type="checkbox"/> 8 Chlorination	<input type="checkbox"/> 11 Corrosion Control
<input type="checkbox"/> 3 Mixing	<input type="checkbox"/> 6 Filtration	<input type="checkbox"/> 9 Fluoridation	<input checked="" type="checkbox"/> 12 Other
16. Name of Treatment Works Letchworth WTP	18. Max. Treatment Capacity Peak 3.0 MGD, 1.0 MGD ave. annual, and 45 MG/month	19. Grade of Plant Operator Req. IA & IIA	20. Est. Cost \$3,000,000
21. Description: See Remarks 5.			

## Distribution

22. Type of Project Distribution Mains		23. Type of Storage	24. Est. Distribution Cost
<input type="checkbox"/> 1 Cross Connection		Elevated _____ gals.	
<input type="checkbox"/> 2 Interconnection		Underground _____ gals.	
<input type="checkbox"/> 3 Transmission			
<input type="checkbox"/> 4 Fire Pump Cl <sub>2</sub>			
25. Anticipated Distribution (This Project)  System Demand: Avg. 31 MGD    Max. 45 MGD    Peak 61.2 MGD			26. Designed for fire flow?  <input type="checkbox"/> Yes <input type="checkbox"/> No
27.			



**SPECIAL CONDITIONS FOR LOG NO. 17981**

**Letchworth Water Treatment Plant**  
**United Water New York, Inc., NY 4303673**

**Upgrade of Letchworth WTP with a Static Mixer, Variable**  
**Speed Flocculators, Tube Settlers, a Diesel Power Generator and various**  
**Hydraulic Improvements and Electrical Modifications**

**(T) Haverstraw, Rockland County**

- c. THAT the proposed works be constructed in compliance with all applicable Federal, State and local regulations.
- d. THAT United Water New York shall amend, revise and/or develop emergency plans as necessary to properly account for the new source, new transmission main and other new water system facilities and UWN Y shall advise municipalities within the service area of the changes.
- e. THAT locked access to vaults/chambers and other facilities, access gates and other security measures shall be at least annually inspected and reevaluated for adequacy by UWN Y, Inc. with findings included within each December operator's report.
- f. THAT a professional engineer shall supervise the construction of this project and shall implement any changes and/or additions agreed to by the New York State Department of Health.
- g. THAT the engineer of record shall provide manuals and parts lists for installed equipment and shall also provide a set of as-built plans (with equipment manufacturers and model numbers noted) to United Water New York, Inc., who shall then maintain and update these documents as needed.
- h. THAT disinfection of all water mains conform to AWWA standard C651, with exclusion of "Sec. 5.1 Tablet Method"; disinfection of the treatment plant conforms to AWWA standard C653; and disinfection of clear wells and other water storage facilities conforms to AWWA standard C652.
- i. THAT the existing mixing pot and the existing mixing basin will be bypassed and physically disconnected.
- j. THAT, in addition to the overflow and drain, each flocculation chamber and each clarifier will be provided a down turned air vents with screens.
- k. THAT a locked manhole or observation port will be placed in each clarifier roof to provide view of the tube settlers and troughs.
- l. THAT all observation ports and accesses shall be capped or covered with overhanging edges, curbed and locked to prevent entrance of rain, runoff or unauthorized people.
- m. THAT prior to completed works approval, with New York State endorsement, the temporary diesel booster pump will be replaced with a package finished water booster pumping station with two or

more pumps capable of pumping approximately 1.5 MGD each at 235 TDH with documentation by make and model included within or appended to the as-built plans.

- n. THAT replaced motors for each existing Worthington 3LR-12 backwash water pump will be documented by make and model within the as-built plans.
- o. THAT existing lines labeled for Calgon will be used for Sequest.
- p. THAT all chemical feed lines will be provided with an anti-siphon device in addition to any device which may be within the chemical pump housing.
- q. THAT devices permanently installed at the three reservoirs for accurately measuring storage and releases in accord with WSA 9947 Special Condition 2, may be included within the as-built plans or may be appended to them and temporary stage recording devices may be installed and used for demonstration studies at plant startup.
- r. THAT demonstration studies, based upon performance criteria within New York State "Table A", will be conducted at startup to evidence that the upgraded plant can be operated with polyaluminum chloride (PACl) coagulant to progressively produce potable water at approximately 1.5 MGD, 2.2 MGD and finally 3.0 MGD, according to a proposal endorsed by the New York State Department of Health with intermediate test results daily emailed to the Rockland County Department of Health and the New York State Department of Health and immediate reduction or curtailment of production with any aberrant monitoring observations or test results.
- s. THAT the plant will comply with the operating schedule in WSA 9947 Special Condition 1 with an average annual production not exceeding 1.0 MGD and monthly production not exceeding 45 MG [1.5 MGD monthly average or two weeks at 3.0 MGD].
- t. THAT plant production will be lowered to 0.5 MGD or less each fall/winter so that the flocculation basins and clarifiers may be inspected/repared.
- u. THAT based upon reservoir operation records, studies of fisheries, and other factors, a critique of the reservoir operation schedule will be annually included within an operators report with refinements to the operation schedule proposed to assure 45 MG is available for taking during August and during September with successive years of a drought.



# STATE OF NEW YORK DEPARTMENT OF HEALTH

Flanigan Square, 547 River Street, Troy, New York 12180-2216

Richard F. Daines, M.D.  
*Commissioner*

June 11, 2007

Gary Albertson, VP.  
United Water New York  
700 Kinderkamack Road  
Oradell, NJ 07649

RE: Log No. 17981, NY4303673, WSA 9947  
Approval of Plans and Specifications  
Upgrade of Letchworth WTP to Seasonal Peak  
Operation of 3.0 MGD with Static Mixer, Variable  
Speed Flocculators, Tube Settlers and Hydraulic  
Improvements and Electrical Modifications  
United Water New York  
(T) Haverstraw, Rockland County

Dear Mr. Albertson:

We have, this day, approved the plans and specifications submitted by Janine B. Witko, P.E., of Black & Veatch, L.L.P., for a project to increase seasonal peak plant production to approximately 3.0 MGD through addition of a 14 inch diameter line and a static mixer with polyaluminum chloride (PACl) coagulant, potassium permanganate, and future use injection ports bypassing a mixing pot (to be demolished) and a mixing basin (to be physically disconnected); installation of transverse masonry walls with 2' 8" wide by 5' high exits which convert two existing sedimentation basins into flocculation basins with variable speed flocculators (three each) and masonry baffle walls sequentially followed by upflow settling basins with tube settlers, mechanical sludge removal to lagoons, and reinforced fiberglass exit troughs; upsized 20" exit pipes from the settling basins to the existing dual media filters; continued post filtration additions of sodium hypochlorite, caustic soda and Seaquest; chlorine contact within and existing clear well; a new transformer, automatic switch and diesel standby generator unit on a fenced outdoor slab; a new booster pump station (two pumps at 1.5 MGD, 235 feet TDH); new backwash water pump motors; various new valves, monitoring and control and appurtenances.

Application for this project was duly made by you and received in this office on January 19, 2007, and final drawings were received on April 6, 2007, with additional documentation subsequently provided.

We call your attention to Standard Conditions a & b and Special Conditions c through u of our DOH form 1017 entitled: "Approval of Plans for Public Water Supply Improvement."

We are enclosing a Certificate of Approval. A set of the approved plans and specifications is being retained in our files, a second set is being sent to the Rockland County Department of Health, and the third set is being returned to your consultant.

Sincerely,

Kenneth W. Caffrey, P.E.  
Senior Sanitary Engineer  
Bureau of Water Supply Protection

Enclosure

cc: Black & Veatch, L.L.P., Attn: Janine B. Witko, P.E.  
Rockland County Department of Health, Attn: Daniel Miller, Ph.D.  
NYDEC- Albany, Attn: Michael Holt, P.E.  
NYDEC- Region 3, Attn: Michael Merriman  
Public Service Commission, Attn: Thomas G. Dvorsky  
NYSDOH, Attn: George Philip, P.E.

Palisades Interstate Park Commission  
Administration Building  
Bear Mountain, NY 10911-0427  
Tel: 845-786-2701  
Fax: 845-786-2776

Michael Tesik  
Capital Facilities Regional Manager I

FAX: 845-786-5367

February 9, 2007

Albert J. Capuzzi, P.E.  
Project Manager  
Black & Veatch New York, LLP  
120 White Plains Rd., Suite 110  
Tarrytown, NY 10591

**RE: Proposed Modifications to Letchworth Village WTP**

Dear Mr. Capuzzi,


I have reviewed your responses to my January 31, 2007 letter regarding the project noted above.

I will reserve most comments until I receive the revised drawings.

I do, however, have the following comments/questions regarding the standby generator:

1. The additional information which you provided is satisfactory to justify the diesel powered unit.
2. Because the fuel tank is 1000 gallons, you will need to register the tank (Petroleum Bulk Storage) with the New York State Department of Environmental Conservation. Because the threshold for tank registration is set at 1000 gallons for a facility, any other fuel storage tanks, regardless of size, must also now be registered. Please provide us with a copy of the registration certificate when you receive it.
3. The Rockland County Department of Environmental Health has additional PBS testing requirements above and beyond those of the DEC. Please contact them for this information.

Sincerely,

  
Larry Soeller, P.E.  
Senior Park Engineer

cc: Jim Hall, PIPC  
Michael Tesik, PIPC  
Bob Raczko, UWN

139099  
PIPC

C-3.1



Palisades Interstate Park Commission  
Administration Building  
Bear Mountain, NY 10911-0427  
Tel: 845-786-2701  
Fax: 845-786-2776

Michael Tesik  
Capital Facilities Regional Manager I

FAX: 845-786-5367

January 31, 2007

Albert J. Capuzzi, P.E.  
Project Manager  
Black & Veatch New York, LLP  
220 White Plains Rd., Suite 275  
Tarrytown, NY 10591

**RE: Proposed Modifications to Letchworth Village WTP**

Dear Mr. Capuzzi,

Jim Hall, the Acting Executive Director of the Palisades Interstate Park Commission, asked me to review the proposed modifications to the Letchworth Village Water Treatment Plant and respond to your proposal on his behalf. As per the water plant license agreement between UWNYS and NYSOPRHP, all renovations and modifications to the existing facilities must be approved by the Palisades Region (PRPC) of NYSOPRHP.

I have reviewed the Engineer's Report and drawings which were prepared for submission to the NYS and Rockland County Departments of Health. The PRPC defers comment on the needs assessment and feasibility of the proposed improvements to those agencies responsible for protecting the public health. Our comments will be related the site plan, aesthetics, recreational access and environmental protection.

The projects proposed are:

1. Improve the hydraulics through the plant to achieve a 3 MGD peaking capacity.
2. Upgrade the electrical service and provide a stand-by emergency generator.
3. Replace the temporary diesel powered pump with a packaged finished water pumping station and a stand-by emergency generator.

I have the following comments/questions:

1. Please provide a Storm Water Pollution Prevention Plan (SWPPP) for all projects. The SWPPP must follow the guidelines established by the NYS Department of Environmental Conservation (DEC).
2. Sheet 2 of 7 shows the overflow from the settling tanks being discharged directly into the Minisceongo Creek. Since this overflow has chemicals added for coagulation, discharge into the creek is regulated by DEC. Please provide a copy of the SPDES permit for this discharge. It would be preferable to discharge the overflow of partially treated water to the backwash settling lagoons.

139099  
PRPC



C-3.1

3. All grassed areas are to be restored with top soil and seeded upon completion of excavation work.
4. Sheet 2 of 7 shows the location of the new transformer and generator to be in the middle of the access road for the reservoirs. Please relocate them in order to maintain the road access.
5. Please provide an artist's rendering of the proposed transformer and generator so that the visual impacts can be evaluated.
6. Neither the drawings nor the engineer's report indicate the specifications for the proposed generator. An LP gas powered generator with an EPA approved sound attenuating enclosure is preferred. Prior to soliciting bids for the generator, please provide a copy of the specification for our review.
7. Please provide a site plan showing the proposed route for the new underground electric service from Call Hollow Rd.
8. Please provide an artist's rendering of the proposed pumping station and generator so that the visual impacts can be evaluated.
9. Prior to construction of the pump station, you must submit plans stamped by a NYS licensed Architect or Engineer and obtain a building permit from PIPC Office of Design and Construction.
10. Access to the reservoirs by Park staff must be maintained during all phases of construction.

Sincerely,



Larry Soeller, P.E.  
Senior Park Engineer

cc: Jim Hall, PIPC  
Michael Tesik, PIPC  
Bob Raczko, UWN



F-61

January 12, 2007

Mr. Kenneth Caffrey  
Bureau of Water Supply Protection, Room 400  
New York State Department of Health  
Flanigan Square  
547 River Street  
Troy, NY 12180-2216

Subject: United Water New York Short Term Water Supply Program  
Letchworth Water Treatment Facility Upgrade Permit Application

Dear Mr. Caffrey:

United Water New York (UWNY) is pleased to submit the attached Engineer's Report and permit application for a project to increase Letchworth plant capacity from 1.0 to 3.0 mgd. The enclosed information includes New York State Department of Health (NYSDOH) "Application for Approval of Plans for Public Water Supply Improvement", and an Engineer's Report completed by Black & Veatch.

The project will take place over an 18-month period, beginning after NYSDOH approval and finishing by mid-2008. The first phase will consist primarily of process, mechanical and hydraulic plant upgrades, which are expected to be completed by June 2007. The second phase will consist primarily of external electrical work, plant automation and installation of a new high lift pump station.


Upon your review of this package, we expect to have detailed design drawings for the first phase available within a week, in order to begin work immediately. Second phase detailed drawings will be available one to two months later.

This is an important project for UWNY, as the increased capacity from the upgrade will be applied directly to our water supply commitments. Upon completion of the first phase, the plant will be commissioned and put on line. We expect this milestone to be achieved by June 2007. Given this accelerated schedule, we would appreciate a determination on the attached package at your earliest convenience.



We look forward to working with you on this important project. If you have questions, please feel free to call me at 201-634-4236, or Michael McDonald at 201-986-4740.


Yours Truly;



**Gary Albertson, P.E.**  
Vice President - United Water

**Attachments:** Application for Approval of Plans for Public Water Supply Improvement  
Engineer's Report

**Cc:** Dan Miller, PhD, RCDOH  
Michael Pointing – GM, UWNYS  
John Dillon – Corporate Attorney, UW  
Alan Weland, P.E. – Director of Engineering, UWNYS  
Michael McDonald, P.E. – Program Manager, B&V

Applicant United Water New York		Location of works (C,V,T) Haverstraw (T)		County Rockland	Water District (area served) Ramapo High (PD20)					
Type of Ownership <input checked="" type="checkbox"/> Municipal <input type="checkbox"/> Industrial		<input type="checkbox"/> Commercial <input checked="" type="checkbox"/> Water Works Corp.	<input checked="" type="checkbox"/> Private - Other <input type="checkbox"/> Private - Institutional <input type="checkbox"/> Board of Education	<input type="checkbox"/> Authority <input type="checkbox"/> Federal <input type="checkbox"/> State	<input type="checkbox"/> Interstate <input type="checkbox"/> International <input type="checkbox"/> Native American Reservation					
<input checked="" type="checkbox"/> Modifications to existing system. If checked, provide PWS ID# NY4303673										
<input type="checkbox"/> New System? If checked, provide capacity development (viability) analysis*										
<input type="checkbox"/> If this project involves a new system, new water district, or a district extension provide boundary description location details in digital format on CD or Floppy Disk. If digital boundary location details are not available provide a text description.										
<input type="checkbox"/> Digital GIS Data Provided <input type="checkbox"/> Digital CAD Data Provided <input type="checkbox"/> Other Digital Data provided <input type="checkbox"/> Text Description Provided										
Funding Source <input checked="" type="checkbox"/> Private <input type="checkbox"/> DWSRF** <input type="checkbox"/> Federal <input type="checkbox"/> Other _____										
If DWSRF is checked, provide DWSRF # <table border="1" style="display: inline-table;"><tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr></table>										
Estimated Project Cost										
Source \$ _____		Treatment \$ 3,000,000		Storage \$ _____						
Pumping \$ 500,000		Engineering \$ 350,000		Legal/Permitting \$ 150,000						
				Distribution \$ _____						
				Total \$4,000,000						
Type of Project <input type="checkbox"/> Source <input type="checkbox"/> Transmission		<input type="checkbox"/> Corrosion Control <input checked="" type="checkbox"/> Pumping Unit <input type="checkbox"/> Chlorination	<input type="checkbox"/> U.V. Disinfection <input type="checkbox"/> Fluoridation <input checked="" type="checkbox"/> Other Treatment	<input type="checkbox"/> Distribution <input type="checkbox"/> Storage <input type="checkbox"/> Other						
Project Description This project includes treatment, hydraulic and pumping systems designed to increase the capacity of the Letchworth Water Treatment plant from 1 mgd to 3 mgd maximum day capacity. The treatment includes retrofitting the existing gravity sedimentation basins with tube settlers. Hydraulic improvements include replacing the 8" filter inlet piping and valves with 12". A new pump station will replace the diesel pumping system. Additionally, the improvements will include full back-up power and full automation.										
Population										
Total population of Service area 300,000		% population actually served 85%		% population served affected by project 30%						
Latest total consumption data (in MGD)			NYS Professional Licensed Engineer Stamp & Signature***							
Avg. day 31 Year 2006										
Max. day 45 Year 2006										
Peak hr. 61.2 Year 2006										
Name of design engineer Janine B. Witko, P.E.										
Address 120 White Plains Road, Suite 110, Tarrytown, NY 10591 Telephone No. 914-524-8316, ext 12										
E-Mail witkojb@bv.com Fax No. 914-524-8368										
Name and title of applicant or designated representative GARY ALBERTSON, VP- UNITED WATER.										
Address 700 KINDERKAMACK RD, ORADELL, NJ 07649										
 Signature of Applicant					JAN. 11, 2007 Date					

**NOTE:** All applications must be accompanied by 3 sets of plans, 3 sets of specifications and an engineer's report describing the project in detail. The project must first be discussed with the appropriate city, county, district or regional public health engineer. Signature by a designated representative must be accompanied by a letter of authorization.

\*Additional information regarding capacity development may be found at: <http://www.health.state.ny.us/nysdoh/water/main.htm>

\*\*Current DWSRF project listings may be found at:

<http://www.health.state.ny.us/nysdoh/water/main.htm>

\*\*\*By affixing the stamp and signature the Design Engineer agrees that the plans and specifications have been prepared in accordance with the most recent version of the recommended standards for water works and in accordance with the NYS Sanitary Code.



**APPENDIX B**  
**BEDROCK WELLS**


**Wesel 32**

## **Wesel 32**

Wesel 32 is permitted by NYSDEC for 300 gpm and taps the underlying bedrock aquifer. Recent production capacity indicates Wesel 32 has been utilized at rates between 175 gpm and 225 gpm, less than the original long-term operating capacity estimate of 300 gpm (and permitted rate). Wesel 32 was operating at approximately 175 gpm with an excess of 50 feet of submergence above the pump intake during the August 2001 3-day system peak demand period. Current pumping test data results indicate the specific capacity of Wesel 32 is similar to the results of the original testing, with no significant production-limiting decline noted. Based on the results of original testing, operational history, and results of current testing, Wesel 32 is capable of sustaining the short-term (3-day) peaking at a rate of 300 gpm during a drought demand period similar to August 2001. This 3-day peak pumping rate represents an increase of 125 gpm over the 2001 peak system demand operating rate.

UNITED WATER NEW YORK  
ROCKLAND COUNTY, NEW YORK

HISTORIC SPECIFIC CAPACITY  
WESEL ROAD 32



Column length = 175'




PUMP DESCRIPTION: Driver	Electric, 30HP	Head 6x6x12	Column	6x1-3/16
<input type="checkbox"/> GUARANTEED FIELD				
<input type="checkbox"/> PERFORMANCE: Capacity	225 gpm	Head 350 ft.	Eff. 79 %	BHP 24.6

HYDRAULIC PERFORMANCE		WARRANTY		CURVE IMPELLER NO.		IMPELLER DIA		TAKEN FROM	
1	2616465	$5^{15/16}$	35481	37215	37225	37322	size	8 LB	RPM
2	2616465	$5^{11/16}$ x $5^{13/16}$							1760
3	2616465	$5^{7/16}$ x $5^{13/16}$							CURVE
4	2616465	$5^{5/16}$ x $5^{13/16}$							2831691

Guaranteed at designated point only, and contingent on:  
 Proper flow to pump section  
 Proper submergence  
 Fluid free of gas, air & extraneous  
 Proper lateral setting of impeller

PEERLESS REF. NO.:  
 Item  
 Laboratory Performance  
 BOWL 2616457 CIE  
 1.8' 2.5' 4.2' Column loss -





# ***Layne Christensen Company***

Route 30, P.O. Box 917 • Schoharie, New York 12157 • Phone: (518) 295-8288 • Fax: (518) 295-8289

May 31, 2007

United Water New York  
360 West Nyack Road  
West Nyack, NY 10994

Attention: Mr. Robert Raczko, Engineer

***Reference: UWNY Wesel #32 Pump Replacement Report***

Dear Mr. Raczko:

Layne Christensen Company is pleased to submit this letter report with respect to the installation of a new pump complete with motor, discharge head, steel base plate, 6-inch column piping and shafting. The work was completed on May 24, 2007.

Layne Christensen pulled the existing pump setting installed a new Gould's 10WALC, 8-stage vertical turbine pump cast iron bronze fitted with stainless steel collets and bolting. The design conditions for the new pump are 300 GPM @ 375' TDH with a secondary design point of 230 GPM @ 316' TDH. The new motor is a U.S. Electric 40 HP, 1800 RPM, premium efficient and inverter duty, compatible for use with a VFD. The installation also included those items listed in the first paragraph. A flow test was conducted as a final step to determine if the new pump was operating on its curve. The results of this test are summarized on Attachment 1. The pumping levels during the flow test were measured in the well with an electric water level meter.

## **Conclusions**

Based on the results of the flow test the new pump is operating above curve. A plot of the data points obtained during the flow test is provided in Attachment 2.

Please contact us should you have any questions or wish to discuss these results in further detail.

We thank you for this continued opportunity to be of service.

Sincerely,

**LAYNE CHRISTENSEN COMPANY**



Stephen Crook, P.G.  
District Manager



## ATTACHMENT 1

# **Pumping Test Record**

5/24/2007

## **UWNY WESEL ROAD WELL**


Time (Minutes)	Flow (Q) (GPM)	Pressure (PSI)	Pressure (FT)	Pumping Level (FT)	Static Level (FT)	Drawdown (FT)	Total Dynamic Head (FT)	Specific Capacity (GPM/FT)
15	137	186	429.66	60.02	9.92	50.10	489.68	2.73
30	280	131	302.61	116.72	9.92	106.8	419.33	2.62
45	312	114	263.34	138.60	9.92	128.68	401.94	2.42
			0			0	0	#DIV/0!



## ATTACHMENT 2

# GOULDS PUMPS

PROPOSAL NO.	GOULDS S.O. NO.	INQUIRY NO.	CUSTOMER P.O. NO.	P.O. DATE	ITEM NO.	CUSTOMER
CT	ESEL ROAD #32	SERVICE	GPM CAPACITY	FT. TDH	% EFFICIENCY	RPM
			300	375	83.5	1770




Curve No.	E6410WBPC1
Model	10WALC
RPM	1770
EFFICIENCY CORRECTION	
1-STAGE	-3.0
2-STAGE	-2.0
3-STAGE	-1.0
4-STAGE	0.0
Impeller	ENCLOSED
Ns =	1700
K =	4.60 LBS/FT
K(Bal.) =	N/A
Bowl O.D.	9.50"
Bowl Lateral	0.63"
Max. PSI	375
Disch size	4", 6", 8"
TURBINE OPERATIONS	
Lubbock, Texas	
BOWL PERFORMANCE CURVE BASED ON PUMPING CLEAR, NON-AERATED WATER. RATED POINT ONLY IS GUARANTEED. CURVES REPRESENT SINGLE STAGE PERFORMANCE BASED ON TEST OF MULTI-STAGE BOWL ASSEMBLY. EFFICIENCY CORRECTION IS REQUIRED FOR LESSER STAGES.	

## Model 10WALC

June 2005

Goulds Pumps




**Eckerson 71**

## **Eckerson 71**

Eckerson 71 is permitted by NYSDEC for 500 gpm and taps the underlying bedrock aquifer. Recent production capacity indicates Eckerson 71 has been utilized at rates between 200 gpm and 250 gpm, not at the permitted rate of 500 gpm. Eckerson 71 was operating at approximately 165 gpm with approximately 10 feet of submergence above the pump intake during the August 2001 3-day system peak demand period. Current pumping test data results indicate the specific capacity of Eckerson 71 is similar, if not higher, than the results of the original testing, with no significant production-limiting decline noted. Based on the results of original testing, operational history, and results of current testing, Eckerson 71 is capable of short-term (3-day) peaking at a rate of 300 gpm during a drought demand period similar to August 2001. This 3-day peak pumping rate represents an increase of 135 gpm over the 2001 peak system demand operating rate.


**UNITED WATER NEW YORK  
ROCKLAND COUNTY, NEW YORK**

**HISTORIC SPECIFIC CAPACITY  
ECKERSON 71**





OLD PUMP  
 UWNY Eckerson Rd Well #71 50HP, #10LC30 8-stage 300GPM @ 368' TDH  
 200ft - 6"x1 1/4" Col/Shaft



# RINBRAND WELL DRILLING COMPANY INC.

ARTESIAN  
WELL  
CONTRACTORS  
pumps • water works installations

14 WALDRON AVENUE  
GLEN ROCK, NJ 07452-2831  
TEL (201) 652-4274 / FAX (201) 445-4591  
established 1919

May 31, 2007

United Water New York  
360 W. Nyack Road  
West Nyack, NY 10994

To: Bob Raczko 1-845-623-1500 ex2267 / 1-845-620-3318fax

From::Steve Rinbrand

RE: Eckerson #71

Bob, The New Gould Bowl Unit #8RJHC-16Stage w/5.25 trim impellers  
Regular Construction Bowl Unit (300GPM @ 400'TDH) was installed  
on 5-23-07 and step test on 5-24-07

The Pump appears to pump on curve - see attached curve.

Sincerely,

  
Stephen Rinbrand

CC: Bill Prehoda @ LBG.

member


2page fax - hard copy in mail

  
NEW JERSEY  
WELL CONTRACTORS  
ASSOCIATION

5-24-07 UWN Y Eckerson #71 (300GPM @ 400' TDH) (173PSI)

GOULDS PROPOSAL NO.	GOULDS S.O. NO.	INQUIRY NO.	CUSTOMER P.O. NO.	P.O. DATE	ITEM NO.	CUSTOMER	50HP.
PROJECT Eckerson #71		SERVICE #8RJHC-16 Stage		F.T. TDH 400' TDH		% EFFICIENCY 1800RPM	

275ft of 6"x 13/16" Column & Shaft plus 10ft 5" Tail Pipe & Cone Strainer  
 2 - 1" PVC M-scope pipe w/SS Couplings. 275ft each



**Rinbrand Well Drilling Co., Inc.**  
**14 Waldron Ave., Glen Rock, NJ 07452**  
**201-852-4274 / 201-445-4591 fax Est.1919**

Page 1

United Water New York - Step Test  
 Well No. Eckerson #71

Date 5/24/2007  
 Line Pressure=  
 Shut Off TDH= 497' TDH or 215 PSI

Time	PWL'	PSI	Orifice"	GPM	Time	PWL'	PSI	Orifice	GPM
1:10	start	175	9.5	200	1:56	58.44	140	29	350
1:11	31.68	180	9.5	200	1:57	59.17	140	29	350
1:13	34.35	180	9.5	200	2:00	60.88	139	29	350
1:14	35	180	9.5	200	2:03	62.62	137	29	350
1:16	36.14	180	9.5	200	2:06	63.93	137	29	350
1:20	38.05	180	9.5	200	2:09	65.02	137	29	350
1:24	39.4	180	9.5	200	2:10	65.4	137	29	350
1:25	open up	***	***	250	Misc Info				
1:26	41.66	177	15	250	1:24	455.2'TDH	1779RPM		
1:27	42.54	176	15	250	1:39	454.3'TDH	1781RPM		
1:30	44.36	176	15	250	1:54	425.8'TDH	1782RPM	Amps 46-45-47	
1:33	45.69	176	15	250	2:10	381.9'TDH	1775RPM	Amps 47-46.5-49.5	
1:35	46.39	176	15	250					
1:39	47.7	176	15	250					
1:40	open up	***	***	300					
1:41	50	161	21.5	300					
1:42	50.79	161	21.5	300					
1:45	52.57	160	21.5	300					
1:50	54.72	160	21.5	300					
1:54	56.2	160	21.5	300					
1:55	open up	***	***	350					
Type/HP Turbine 50HP 1800RPM					Orifice" 4" Pipe" 6"				
Pump Gould #8RJHC (300GPM @ 400'TDH)					Airline M-scope 2 - 1"PVC 275ft each				
Stages 16 Stage (5.25"Trim impellers)					SWL 23.3ft				
Discharge 6"					Well Dia 18"x12" 28'2" of 18"/58'3" of 12" casing				
Setting 275ft					Depth 406ft				
Witness Max Dieber					RWD Cliff Rinbrand				

**Rinbrand Well Drilling Co., Inc.**  
 14 Waldron Ave., Glen Rock, NJ 07452  
 201-652-4274 / 201-445-4591 fax Est. 1919

Page 1 of 3

United Water New York - Step Test  
 Well No. Eckerson Rd #71

Date 3-14-06  
 Line Pressure= 74PSI  
 Shut Off TDH= 424'TDH or 183PSI

Time	PWL'	PSI	Orifice"	GPM	Time	PWL'	PSI	Orifice"	GPM
10:00	47.42	150	9 1/2	200	11:01	75.3	138	15	250
10:01	54.67	150	9 1/2	200	11:02	76.12	138	15	250
10:02	56.94	150	9 1/2	200	11:03	76.8	138	15	250
10:03	57.78	150	9 1/2	200	11:04	77.25	138	15	250
10:04	58.6	150	9 1/2	200	11:05	77.7	138	15	250
10:05	59.3	150	9 1/2	200	11:06	78.11	138	15	250
10:06	60.02	150	9 1/2	200	11:07	78.45	138	15	250
10:07	60.65	148	9 1/2	200	11:08	78.76	138	15	250
10:08	61.22	148	9 1/2	200	11:09	79.12	138	15	250
10:09	61.79	148	9 1/2	200	11:10	79.4	138	15	250
10:10	62.3	148	9 1/2	200	11:15	80.58	132	15	250
10:15	64.26	148	9 1/2	200	11:20	81.8	132	15	250
10:20	66.23	148	9 1/2	200	11:25	82.77	132	15	250
10:25	67.56	148	9 1/2	200	11:30	83.6	132	15	250
10:30	68.7	145	9 1/2	200	11:35	84.44	132	15	250
10:35	69.88	145	9 1/2	200	11:40	85.03	132	15	250
10:40	70.8	145	9 1/2	200	11:45	85.74	132	15	250
10:45	71.41	145	9 1/2	200	11:50	86.34	130	15	250
10:50	72.2	145	9 1/2	200	11:55	86.94	130	15	250
10:55	72.91	145	9 1/2	200	12:00	87.42	130	15	250
11:00	73.6	145	9 1/2	200	12:01	89	118	21	300
Type/HP Turbine 50HP,230/460V,3PH 1800RPM					Orifice" 4" Pipe" 6"				
Pump IDP #10LC30					Airline 200ft M-scope 2-1" PVC 200ft each				
Stages 8 Stage (300GPM @ 368'TDH)					SWL 47.42ft				
Discharge 6"					Well Dia 18"x12" (28'2" of 18" / 55'3" of 12"casing)				
Setting 200ft 6"x 1 1/4" Col/Shaft					Depth 406ft				
Witness Max Dieber					RWD Adam F Rinbrand Jr.				

**Rinbrand Well Drilling Co.,Inc.**  
**14 Waldron Ave., Glen Rock, NJ 07452**  
**201-652-4274 / 201-445-4591fax Est.1919**

Page 2 of 3

**United Water New York - Step Test**  
**Well No. Eckerson Rd #71**

**Date 3-14-06**  
**Line Pressure= 74PSI**  
**Shut Off TDH= 424'TDH or 183PSI**

Time	PWL'	PSI	Orifice"	GPM	Time	PWL'	PSI	Orifice"	GPM
12:02	89.84	118	21	300	1:02	103.37	93	29	350
12:03	90.44	118	21	300	1:03	104.15	93	29	350
12:04	90.88	118	21	300	1:04	104.75	93	29	350
12:05	91.31	118	21	300	1:05	105.06	93	29	350
12:06	91.67	118	21	300	1:06	105.45	93	29	350
12:07	91.95	118	21	300	1:07	105.78	93	29	350
12:08	92.3	118	21	300	1:08	106.17	93	29	350
12:09	92.28	118	21	300	1:09	106.37	93	29	350
12:10	92.88	118	21	300	1:10	106.68	93	29	350
12:15	94.1	118	21	300	1:15	107.9	93	29	350
12:20	94.95	118	21	300	1:20	109	92	29	350
12:25	95.88	118	21	300	1:25	109.92	92	29	350
12:30	96.77	118	21	300	1:30	110.77	92	29	350
12:35	97.48	118	21	300	1:35	111.53	91	29	350
12:40	98.21	118	21	300	1:40	112.3	91	29	350
12:45	98.9	118	21	300	1:45	113	91	29	350
12:50	99.5	118	21	300	1:50	113.65	91	29	350
12:55	100.12	118	21	300	1:55	114.35	91	29	350
1:00	100.7	118	21	300	2:00	114.86	91	29	350
1:01	102.52	93	29	350					
Type/HP Turbine 50HP,230/460V,3PH 1800RPM					Orifice"	4"	Pipe"	6"	
Pump IDP #10LC30					Airline	200ft	M-scope	2-1"PVC 200ft each	
Stages 8Stage (300GPM @ 368'TDH)					SWL	47.42ft			
Discharge 6"					Well Dia	18"x12" (28'2" of 18"/ 55'3" of 12"casing)			
Setting 200ft 6"x 1 1/4"Col/Shaft					Depth	406ft			
Witness Max Dieber					RWD	Adam F. Rinbrand Jr.			

**Rinbrand Well Drilling Co.,Inc.**  
 14 Waldron Ave., Glen Rock, NJ 07452  
 201-652-4274 / 201-445-4591fax Est.1919

Page 3 of 3

United Water New York - Step Test  
 Well No. Eckerson Rd #71

Date 3-16-06  
 Line Pressure= 74PSI  
 Shut Off TDH= 424'TDH or 183PSI

Time	PWL'	PSI	Orifice"	GPM	Time	PWL'	PSI	Orifice	GPM
Recovery					Misc Info				
1 Minute					10:15	Airline 64%			
2 Minute					10:50	RPM=1789 Amps 37-37-38			
3 Minute					10:55	PH=7.0	Temp 53F		
4 Minute					11:00	408.55'TDH Drawdown 26.15' GPF=7.63'			
5 Minute					11:15	Airline 56%			
6 Minute					11:40	Airline 53%			
7 Minute					11:50	RPM=1786 Amps39-40-41			
8 Minute					11:55	PH=7.0	Temp 53F		
9 Minute					12:00	387.72'TDH Drawdown 40.00' GPF=6.25'			
10 Minute					12:30	Airline 48%			
15 Minute					12:45	RPM=1785 Amps 42-43-44			
20 Minute					12:50	PH=7.0	Temp 53F		
25 Minute					12:55	Airline 47%			
30 Minute					1:00	368.66'TDH Drawdown 53.28' GPF=5.63'			
					1:15	Airline 42%			
					1:45	PH=7.2	Temp 53F		
					1:50	RPM=1783 Amps 44-45-47			
					2:00	325.07'TDH Drawdown 67.44' GPF 5.18'			
Type/HP	Turbine 50HP,230/460V,3PH 1800RPM				Orifice"	4"	Pipe"	6"	
Pump	IDP #10LC30				Airline	200ft	M-scope	2- 1"PVC 200ft each	
Stages	8 Stage (300GPM @ 368'TDH)				SWL	47.42ft			
Discharge	6"				Well Dia	18"x12" (28'2"of 18"/ 55'3" of 12"casing)			
Setting	200ft 6" x 1 1/4"col/shaft				Depth	406ft			
Witness	Max Dieber				RWD	Adam F. Rinbrand Jr.			

**Lakeshore 73**




### **Lakeshore 73**

Lakeshore 73 is permitted by NYSDEC for 700 gpm and draws from the underlying bedrock aquifer. Recent production capacity indicates Lakeshore 73 has been utilized at rates between 400 gpm and 450 gpm, less than the original long-term operating capacity estimate of 500 gpm and not at the peaking estimate (and permitted rate) of 700 gpm. Lakeshore 73 was operating at approximately 370 gpm with an excess of 50 feet of submergence above the pump intake during the August 2001 3-day system peak demand period. Current pumping test data results indicate the specific capacity of Lakeshore 73 is similar to the results of the original testing, with no significant production-limiting decline noted. Based on the results of original testing, operational history, and results of current testing, Lakeshore 73 is capable of short-term (3-day) peaking at a rate of 700 gpm during a drought demand period similar to August 2001. This 3-day peak pumping rate represents an increase of 330 gpm over the 2001 peak system demand operating rate.

**UNITED WATER NEW YORK  
ROCKLAND COUNTY, NEW YORK**

**HISTORIC SPECIFIC CAPACITY  
LAKE SHORE 73**



OLD Pump

12-13-06

UWNY - Lakeshore Drive #73 150ft - 6" x 1 3/16" Col Shaft 10ft - 6" Tail.  
500GPM @ 310' TDH Layne #8TCH 13stage 60HP 1800RPM

DEC-04-06 03:48PM FROM-LBG RAMSEY NJ

2018180506

T-238 P.05/09 F-889

THESE CURVES SHOW THE GENERAL SHAPE OF THE PUMP BOWL CHARACTERISTICS UNDER SHUT TESTS AT THE CONSTANT SPEED INDICATED A TOLERANCE OF PLUS OR MINUS 3% MUST BE ALLOWED IN THE GUARANTEED CAPACITY HEAD AND EFFICIENCY AT THE RATED POINT WHEN PUMPING NON-ABRASIVE WATER 3000 PSI MAXIMUM AT ALTITUDE 5000 FT. OVER 86' FATH AND WITH THE BOWLS IMPELERS SUBMERGED

FOR HAKKERSIDE WATER CO.

ADDRESS: Lake Shore Dr. Wall (Lake)

TYPE OF PUMP: TFC RPM: 1765

SIZE IN INCHES: 15 IMPELLER: 512

FIELD PERFORMANCE

THE FIELD PERFORMANCE AS SHOWN BELOW MAKES ALLOWANCE FOR ALL THE HYDRAULIC AND MECHANICAL LOSSES IN THE COLUMN AND SHAFT OF THE INSTALLATION ACCORDING TO THE STANDARDS OF THE HYDRAULIC INSTITUTE. THE FIELD PUMPING HEAD IS THE LIFT FROM THE WELLS PLUS THE DISCHARGE HEAD MEASURED AT THE DISCHARGE CONNECTION AT THE SURFACE.


COLUMN: INS. LENGTH: FT. SHAFT DIA:

CAPACITY: U.S. GPM. FIELD PUMPING HEAD:

FIELD H.P. FIELD EFFICIENCY:

MOTOR EFF. WIRE TO WATER EFFICIENCY:

NOTES:



# ***Layne Christensen Company***

Route 30, P.O. Box 917 • Schoharie, New York 12157 • Phone: (518) 295-8288 • Fax: (518) 295- 8289

---

June 12, 2007

United Water New York  
360 West Nyack Road  
West Nyack, NY 10994

Attention: Mr. Robert Raczko, Engineer

***Reference: UWNY Lakeshore #73 Pump Replacement Report***

Dear Mr. Raczko:

Layne Christensen Company is pleased to submit this letter report with respect to the installation of a new pump complete with motor, discharge head, steel base plate, 6-inch column piping and shafting. The installation work was completed on May 16, 2007 and a final flow test run on June 11, 2007.

Layne Christensen pulled the existing pump setting installed a new Gould's 8RJHO, 5-stage vertical turbine pump cast iron bronze fitted with stainless steel collets and bolting. The design conditions for the new pump are 700 GPM @ 415' TDH with a secondary design point of 500 GPM @ 350' TDH. The new motor is a U.S. Electric 100 HP, 3600 RPM, standard efficient and compatible for use with a VFD. The installation also included those items listed in the first paragraph. A flow test was conducted as a final step to determine if the new pump was operating on its curve. The results of this test are summarized on Attachment 1. The pumping levels during the flow test were measured in the well with an electric water level meter.

## **Conclusions**

Based on the results of the flow test the new pump is operating on curve. A plot of the data points obtained during the flow test is provided in Attachment 2.

Please contact us should you have any questions or wish to discuss these results in further detail

We thank you for this continued opportunity to be of service.

Sincerely,

***LAYNE CHRISTENSEN COMPANY***

Stephen Crook, P.G.  
District Manager



## ATTACHMENT 1

## Pumping Test Record

6/11/2007

## UWNY LAKESHORE WELL

Time (Minutes)	Flow (Q) (GPM)	Pressure (PSI)	Pressure (FT)	Pumping Level (FT)	Static Level (FT)	Drawdown (FT)	Total Dynamic Head (FT)	Specific Capacity (GPM/FT)
31	699	150	346.50	85.20	10.30	27.17	431.70	NA
35	550	175	404.25	72.90	10.30	62.60	477.15	8.79
40	498	194	448.14	65.50	10.30	55.20	513.64	9.02
52	403	204	471.24	54.30	10.30	44.00	525.54	9.16

## ATTACHMENT 2


Company: CHRISTENSEN PUMPS    Customer: United Water, Lakeshore 73  
 Name: MEMPHIS, TENNESSEE  
 Date: 04/11/07    Order No:



**Pump:**  
 8RJHO (5 stages)  
 Lineshaft  
 Synch speed: 3600 rpm  
 Curve: 3005  
 Specific Speeds: Ns: 2825  
 Pump Notes for Standard Sizes:  
 Suction Size-5" Discharge Sizes-5",6"  
 Vertical Turbine:  
 Bowl size: 7.5 in  
 Max lateral: 0.63 in  
 Thrust K factor: 5.3 lb/ft  
**Pump Limits for Standard Construction:**  
 Temperature: 120 °F  
 Sphere size: 0.43 in  
 Pressure: 425 psi g

**Search Criteria:**  
 Flow: 700 US gpm    Head: 415 ft  
 Secondary Operating Point: 500 US gpm, 350 ft  
**Fluid:**  
 Water  
 SG: 1  
 Viscosity: 1.105 cP  
 NPSHa: --- ft  
 Temperature: 60 °F  
 Vapor pressure: 0.2563 psi a  
 Atm pressure: 14.7 psi a  
**Motor:**  
 Standard: NEMA    Size: 125 hp  
 Speed: 3600  
 Sizing criteria: Max Power on Design Curve

--- Data Point ---  
 Flow: 716 US gpm  
 Head: 406 ft  
 Eff: 78.9%  
 Power: 92.7 hp  
 NPSHr: 35.9 ft  
 --- Design Curve ---  
 Off Head: 551 ft  
 Shutoff dP: 238 psi  
 Min Flow: --- US gpm  
 BEP: 80.9% eff  
 @ 634 US gpm  
 NOL Pwr: 101 hp  
 @ 875 US gpm  
 --- Max Curve ---  
 Max Pwr: 112 hp  
 @ 908 US gpm



**Performance Evaluation:**

Flow US gpm	Speed rpm	Head ft	Pump %eff	Power hp	NPSHr ft
840	3530	324	68.8	99.7	42.2
700	3530	416	79.5	92.2	35
560	3530	486	79.4	86.3	27.9
420	3530	527	72.4	77	21.5
280	3530	545	56.3	68.3	19.7



## **Permits and Regulatory Correspondence**

**NEW YORK STATE DEPARTMENT OF HEALTH**  
Bureau of Water Supply Protection

**Application of Approval of Plans for  
Public Water Supply Improvement**

Applicant United Water New York	Location of works (C,V,I) Clarkstown (T) - Lakeshore 73, Wesel 32 Ramapo (T) - Eckerson 71	County Rockland	Water District (specific area served) United Water New York
Type of Ownership <input type="checkbox"/> Municipal <input type="checkbox"/> Commercial <input type="checkbox"/> Private - Other <input type="checkbox"/> Authority <input type="checkbox"/> Interstate <input type="checkbox"/> Industrial <input checked="" type="checkbox"/> Water Works Corp. <input type="checkbox"/> Private - Institutional <input type="checkbox"/> Federal <input type="checkbox"/> International <input type="checkbox"/> Board of Education <input type="checkbox"/> State <input type="checkbox"/> Native American Reservation			
<input checked="" type="checkbox"/> Modifications to existing system. If checked, provide PWS ID # NY <b>NY4303673</b> <input type="checkbox"/> New System. If checked, provide capacity development (viability) analysis*			
If this project involves a new system, new water district, or a district extension provide boundary description location details in digital format on CD or Floppy Disk. If digital boundary location details are not available provide a text description. <input type="checkbox"/> Digital GIS Data Provided <input type="checkbox"/> Digital CAD Data Provided <input type="checkbox"/> Other Digital Data Provided <input type="checkbox"/> Text Description Provided <input checked="" type="checkbox"/> N/A			
Funding Source <input checked="" type="checkbox"/> Private <input type="checkbox"/> DWSRF** <input type="checkbox"/> Federal <input type="checkbox"/> Other			
If DWSRF is checked, please provide DWSRF #			
Estimated Project Cost \$			
Source	Treatment	Storage	Distribution
Pumping	Engineering	Legal/Permitting	Total
\$200,000.00			
Type of Project <input type="checkbox"/> Source <input type="checkbox"/> Corrosion Control <input type="checkbox"/> U.V. Light Disinfection <input type="checkbox"/> Distribution <input type="checkbox"/> Transmission <input checked="" type="checkbox"/> Pumping Unit <input type="checkbox"/> Fluoridation <input type="checkbox"/> Storage <input type="checkbox"/> Chlorination <input type="checkbox"/> Other Treatment <input type="checkbox"/> Other			
Project Description: Replace pumps and motors at three well sites in UWN system (Lakeshore 73, Wesel 32 and Eckerson 71) to provide more flow for peak demand.			
Total Population of Service Area		298,000	
% population actually served		90	
% population affected by project		5	
Latest Total Consumption Data (in MGD)			
Average Day	Year	NYS Professional Licensed Engineer Stamp and Signature***	
31.5	2006		
Peak Hour	Year		
44.8	2006		
57.2	2006		
Name and Address of Design Engineer Robert F Raczko, P.E. UWN 360 West Nyack Road West Nyack, NY 10994 845-623-1500 x2267 email: bob.raczko@unitedwater.com			
		5/24/2007	
Signature of Applicant		Date	

NOTE: All applications must be accompanied by 3 sets of plans, 3 sets of specifications and an engineer's report describing the project in detail. The project must first be discussed with the appropriate city, county, district or regional public health engineer. Signature by a designated representative must be accompanied by a letter of authorization.

\*Additional information regarding capacity development may be found at:

<http://www.health.state.ny.us/nysdoh/water/main.htm>

\*\*Current DWSRF project listings may be found at:

<http://www.health.state.ny.us/nysdoh/water/main.htm>

\*\*\*By affixing the stamp and signature the Design Engineer agrees that the plans and specifications have been prepared in accordance with the most recent version of the recommended standards for water works and in accordance with the NYS Sanitary Code.

Bob Raczko, PE  
Operations Engineer

UNITED WATER  
360 West Nyack Road, West Nyack, NY 10994  
Tel: 845.623.1500 x2267 • Fax: 845.620.3318  
bob.raczko@unitedwater.com



May 25, 2007

Dan Miller, Ph.D  
Rockland County Department of Health  
Environmental Health Division  
Dr. Robert L. Yeager Health Center  
50 Sanatorium Rd  
Pomona, New York 10970

Subject: Pump Modifications at Three Well Sites

Dear Dr. Miller:

As requested, we have prepared a DOH Form 348 for three pump modification projects that we are undertaking to increase the peaking capacity of our water supply by June 15, 2007. These projects include:

- Wesel 32 - Provide new pump, larger motor and VFD to provide an additional 0.18 mgd
- Eckerson 71 - Provide new pump, larger motor and VFD to provide an additional 0.19 mgd
- Lakeshore 73 - Provide new pump, Larger motor and VFD to provide an additional 0.48 mgd

Please note that the increase in capacity will capture the full, permitted amount of capacity, above and beyond that which has historically been realized at these wellfields, but not exceed the permitted capacity. The pumps have been identified as candidates for replacement because they represent pumps which could not achieve the desired Total Dynamic Head (TDH) required to meet desired flow conditions, as well as there being sufficient hydrogeologic capacity available to capture. The former was determined by comparing field pumping data to manufacturer's data, and the latter being determined by reviewing years of SCADA and specific capacity data.

The required TDH was obtained by assuming worst case, peak pressure conditions in the system, then modeling the impact of the new capacity to the system in terms of pressure layered on top of those conditions. From there the pressure required to meet peaking conditions was obtained from the model, as represented by the TDH requirement below (this also assumes maximum drawdown in the wells). In all cases, the pressure design exceeds that which was seen in the system during August 2001 conditions, and also under maximum pressure conditions. Were August 2001 conditions to occur again, these new pumps would meet their full permitted capacities and exceed the 2001 flow by the amount noted above.

A summary is shown below:

Pump ID	Old Pump		Larger Capacity Pump		Aug 2001 Capacity	Increase (mgd)
	Flow (gpm)	TDH (ft)	Flow (gpm)	TDH (ft)		
Wesel 32	225	350	300	375	175	0.18
Eckerson 71	300	368	300	380	170	0.18
Lakeshore 73*	500	310	700	395	370	0.48

\*A copy of each of the permits has been attached for your reference. Note that a review of the permit for Lakeshore 73 indicates this well is permitted for 700 gpm, as opposed to 500 gpm.

If you have any questions or desire additional information, please contact me at 845.623.1500 X2267, or Michael McDonald, Program Manager, at 201.986.4740.

Yours Truly,



Robert F. Raczko, P.E.  
Operations Engineer

Att: Water Supply Permits

cc: Sam Rulli, P.E. - RCDOH  
Vito Spadavecchia - UWN  
Mike McDonald, P.E. - Black and Veatch  
Bill Prehoda, P.G. - LBG



**APPENDIX C**  
**CATAMOUNT WELLS 42 AND 54**

## **APPROACH**

Two existing wells comprise the Catamount Well Field, Wells 42 and 54 and the NYSDEC listed permitted rates are 510 gpm and 400 gpm, respectively. The Catamount wells tap the underlying unconsolidated sand and gravel aquifer. The historic capacity of the Catamount Well Field declines significantly with time due primarily to iron-related bacteria biofouling and iron hydroxide precipitates clogging the well screens. The declining specific capacity necessitated the rehabilitation of the wells on numerous occasions in order to regain capacity. Currently, both Catamount 42 and 54 exhibit the lowest recorded specific capacities to date.

To provide the ability to rehabilitate the Catamount Well Field wells on a more frequent basis to maintain production capacity, with minimal lost production time, a more efficient specific capacity maintenance program at the Catamount Well Field is being implemented. The capacity maintenance program being conducted includes a thorough rehabilitation of the Catamount wells utilizing carbon dioxide injection (AquaFreed®) with surge block and simultaneous discharge, followed by the installation of carbon dioxide injection pipes into each well. The injection pipes are part of the AquaGard™ system to periodically rehabilitate the well with carbon dioxide injection. The pumps remain in the well during the carbon dioxide injection and are utilized to purge the well after injection. The Aqua Gard™ process allows for more frequent carbon dioxide treatment while minimizing production down time.

The frequency of the Aqua Gard™ treatments will depend on the degree of specific capacity decline noted after the rehabilitation, however we anticipate that the first AquaGard™ injection will potentially occur at Catamount 42 as soon as three months after the current rehabilitation is completed. The frequency of the AquaGard™ rehabilitations will vary depending on the results, with the goal to maintain the maximum specific capacity with no additional permanent loss.

A complete AquaFreed® carbon dioxide injection and surge block rehabilitation were completed at each Catamount 42 and 54 prior to the installation of the Aqua Gard™ system at each well. The full rehabilitations insured the wells are operating at maximum capability prior to implementing the Aqua Gard™ system. The results of the pre-rehabilitation pumping tests conducted indicated the lowest specific capacities recorded to date. The pumping test results also indicated that the pump in Well 54 was operating off curve and inspection of the Well 42 pump showed shaft replacement and column replacement was necessary.

The rehabilitation results indicate that the maximum operating pumping rate at Catamount 42 was increased 25 gpm (from 175 gpm to 200 gpm) and Catamount 54 capacity increased from 135 gpm to 350 gpm. The rehabilitation results are similar to those obtained during the last major rehabilitation effort in 2004, but significantly less

than the original capacity. The results of the complete rehabilitations are summarized in the attached historic specific capacity graphs.

The existing pumps at both Catamount 42 and 54 were replaced with new submersible pumps, which were tested during the post-rehabilitation testing, and are operating on curve. The replacement pump curves are attached.





June 15, 2007

Mr. Vito Spadavecchia  
United Water New York  
360 W. Nyack Road  
West Nyack, NY 10994

RE: Catamount #42A & #54A

Dear Vito,

The new Grundfos 230S400-13 was installed in well #42A on 6/12/07 and a step test was done on 6/13/07. The pump is operating on curve.

A new Berkeley 7T60-350 was installed in well #54A on 6/14/07 and a step test was done on 6/15/07. This pump is operating on curve.

Sincerely,

*Steve Catania*

Steve Catania  
V.P. Operations  
Subsurface Technologies, Inc

Attachments

Cc: Bill Prehoda

SC/dc

40 Stone Castle Road, Rock Tavern, NY 12575 845.567.0187 Fax: 845.567.1035 <http://www.subsurfacetech.com>



Catamount 42  
Pump replacement test  
6/13/2007

Flow	Pressure	Pumping	TDH
GPM	PSI	Level	Feet
		Feet	Feet
0		8.56	
99	340	24.03	809.43
150	310	33.03	749.13
200	269	45.87	667.26
225	250	53	630.5


Catamount 54  
Pump replacement test  
6/15/2007

Flow	Pressure	Pumping	TDH
GPM	PSI	Level	Feet
		Feet	Feet
0		7.36	
100	340	23.78	809.18
200	290	42.42	712.32
350	190	71.09	509.99

## **SPECIFIC CAPACITY AND PUMP CURVES**

# UNITED WATER NEW YORK ROCKLAND COUNTY, NEW YORK

## HISTORIC SPECIFIC CAPACITY CATAMOUNT 42





# Goulds Vertical Turbine Pumps

## Performance Curve

### 5C32.1a


July 1985  
(New)

June 1st 2005

Catamount #42A


GOULDS PROPOSAL NO.	GOULDS S.O. NO.	INQUIRY NO.	CUSTOMER P.O. NO.	P.O. DATE	ITEM NO.	CUSTOMER
PROJECT: Catamount Well No. 42A						United Water New York
SERVICE #10ILC - 9 Stages		GPM CAPACITY: 300 GPM		FT. TDH: 428'	% EFFICIENCY	
REV. DATE		RPM 1770		CDS 3312		RPM

CENTRIFUGAL PUMP CHARACTERISTICS BASED ON GOULDS STANDARD CLEARANCES	
MODEL 10 ILC	SIZE 10"
IMP. DWG. B01143B	PATTERN 58831
EYE AREA 9.75	IMP. DIA. 7.61
K = 6.69 KG/M	





**GOULDS PUMPS, INC.**  
TEXAS DIVISION-STD. PRODUCTS GROUP

© 1985 Goulds Pumps, Inc.  
PRINTED IN U.S.A.


Position	Count	Description	Unit price
	1	<b>300S500-13</b>  <p>Product photo could vary from the actual product</p> <p><b>Product No.: 14B60013</b>  Multi-stage submersible pump for raw water supply, groundwater lowering and pressure boosting. The pump is suitable for pumping clean, thin, non-aggressive liquids without solid particles or fibers.</p> <p>The pump is made entirely of Stainless steel DIN W.-Nr. 1.4301 DIN W.-Nr. and suitable for horizontal and vertical installation.  The pump is fitted with a built-in non-return valve.</p> <p><b>Liquid:</b>  Maximum liquid temperature: 104 °F</p> <p><b>Technical:</b>  Speed for pump data: 3450 rpm  Rated flow: 299.4 US gpm  Rated head: 505 ft  Curve tolerance: ISO 9906 Annex A</p> <p><b>Materials:</b>  Pump: Stainless steel  1.4301 DIN W.-Nr.  304 AISI  Impeller: Stainless steel  1.4301 DIN W.-Nr.  304 AISI</p> <p><b>Installation:</b>  Pump outlet: 4" NPT  Motor diameter: 6 inch  Minimum borehole diameter: 6" in</p> <p><b>Electrical data:</b>  Power (P2) required by pump: 50 HP  Start. method: direct-on-line</p>	5463

14B60013 300S500-13




# Catamount 42 New

Description	Value
Product name::	300S500-13
Product Number::	14B60013
EAN number::	5700391740961
Technical:	
Speed for pump data:	3450 rpm
Rated flow:	299.4 US gpm
Flow range:	41.2 .. 412 US gpm
Rated head:	505 ft
Curve tolerance:	ISO 9906 Annex A
Stages:	13
Model:	A
Valve:	pump with built-in non-return valve
Materials:	
Pump:	Stainless steel 1.4301 DIN W.-Nr. 304 AISI
Impeller:	Stainless steel 1.4301 DIN W.-Nr. 304 AISI
Installation:	
Pump outlet:	4" NPT
Motor diameter:	6 inch
Minimum borehole diameter:	6" in
Liquid:	
Maximum liquid temperature:	104 °F
Electrical data:	
Applic. motor:	NEMA
Power (P2) required by pump:	50 HP
Start. method:	direct-on-line
Others:	
Sales region:	Namreg





14B60013 300S500-13



All units are [mm] unless otherwise presented.



## LEGGETTE, L. ASHEARS &amp; GRAHAM, INC.

6 ARROW ROAD, SUITE 103  
RAMSEY, NEW JERSEY 07446800-818-8524  
WWW.LBGWEB.COM

SHEET 1 OF 2

Job Code: CATAMOUNT Well Number: 42A ☒ Pumping ☐ Observation Pumping Test of Well: 42A Date: 6, 13, 07

Well Location: Street: RT202 Town: RAMAPO State: NY

Measurements Taken By: JH

Well Location:	Well Construction:	Well Depth:	Pump Setting / Type:	Pump Installation:	Power Source:
<input checked="" type="checkbox"/> Outdoors	<input checked="" type="checkbox"/> Overburden	<input checked="" type="checkbox"/> Measured <input type="checkbox"/> Reported	53' Feet Below TOC	<input type="checkbox"/> Temporary	<input type="checkbox"/> Portable Generator
<input type="checkbox"/> Well Pit	<input type="checkbox"/> Bedrock	Feet Below TOC	<input type="checkbox"/> Vertical Turbine	<input checked="" type="checkbox"/> Permanent	<input checked="" type="checkbox"/> Electric Utility
<input type="checkbox"/> Pump House	<input type="checkbox"/> Open Hole	Inner Casing Diameter: 12"	<input checked="" type="checkbox"/> Submersible	Pump Manufacturer:	<input type="checkbox"/> Other:
<input type="checkbox"/> Basement	<input type="checkbox"/> Screened	Screen Diameter: 12"	<input type="checkbox"/> Suction	Horsepower / Model:	
<input type="checkbox"/> Other:	<input type="checkbox"/> Gravel Packed	Screen Setting: 53' - 68'	<input type="checkbox"/> Jet		
	<input type="checkbox"/> Telescoping <input type="checkbox"/> Pipe Size	Drilled By: Date:	<input type="checkbox"/> Other:		
Type of Test:	Method of Water-Level Measurement:	Method of Flow Measurement:	Distance From Pumping Well (ft):	N/A	
<input type="checkbox"/> Constant-Rate	<input checked="" type="checkbox"/> Electric Tape	<input type="checkbox"/> Flow Meter	Water-Level Measuring Point:	M-SCOPE PORT	
<input checked="" type="checkbox"/> Step 100, 150, 200, 250	<input type="checkbox"/> Wetted Tape	<input type="checkbox"/> - Gallon Bucket/Drum	Static Water Level:		
<input type="checkbox"/> Slug	<input type="checkbox"/> Airline	<input checked="" type="checkbox"/> x Orifice Weir	Elevation of Monitoring Point:	0.1' ABOVE PUMP BASE	
<input type="checkbox"/> Recovery	<input type="checkbox"/> Transducer	Orifice Table:	Pump On (Date/Time):	6/13 17:55 Pump Off (Date/Time):	
<input type="checkbox"/> Other:	<input type="checkbox"/> Other:	<input type="checkbox"/> Other:			

Date	Time	Elapsed Time (min)	Depth to Water (ft)	Drawdown (ft)	Discharge Rate (gpm)	Notes (Observer, Water Quality, Weather, Discharge Quality, etc.)	Date	Time	Elapsed Time (min)	Depth to Water (ft)	Drawdown (ft)	Discharge Rate (gpm)	Notes (Observer, Water Quality, Weather, Discharge Quality, etc.)
6/13	1740	—	8.66	—		Shut off. press = 380 psi		1821	26	32.82	24.16	150	310 psi
								1822	27	32.73	24.07		
	1756	1	32.50	23.84	99			1823	28	32.75	24.09		
	1757	2	26.63	17.97	99	340 psi		1824	29	32.80	24.14		
	1758	3	24.95	16.29	99			1825	30	32.85	24.19	150	
	1759	4	24.30	15.64		57.5 - 54.0 = 62.1 AMP		1830	35	32.90	24.33		310 psi
	1800	5	24.06	15.42				1835	40	32.13	24.47		TDH = 749' S.C. = 6.13
	1801	6	23.99	15.33				1836	41	38.20	29.54	200	
	1802	7	23.98	15.32	99			1837	42	41.61	32.95		
	1803	8	23.99	15.33				1838	43	45.15	34.43		
	1804	9	24.00	15.34				1839	44	43.98	35.32		
	1805	10	24.02	15.36				1840	45	44.40	35.83	200	269 psi
	1810	15	24.03	15.43		340 psi		1841	46	44.84	36.18		
	1815	20	24.13	15.47	99	TDH = 810' S.C. = 6.40		1842	47	45.11	36.45	200	
	1816	21	29.70	21.04	150			1843	48	45.31	36.65		
	1817	22	32.74	24.08				1844	49	45.41	36.75	200	269 psi
	1818	23	32.54	23.88	150	302 psi		1845	50	45.50	36.84		
	1819	24	33.20	24.54	150			1850	55	45.80	37.14		269 psi
	1820	25	33.32	24.66				1855	60	45.94	37.31	200	TDH = 667' S.C. = 5.96



LEGGETT, BR. EARS & GRAHAM, INC.

6 ARROW ROAD, SUITE 103  
RAMSEY, NEW JERSEY 07446  
800-818-8524  
WWW.LBGWEB.COM

SHEET 2 OF 2

DATE 6/13/07

WELL NUMBER: CATARACT 42A State: NJ

☐ Observation

☒ Pumping


WELL LOCATION: Street: NJ 202

MEASUREMENTS TAKEN BY: JH

Date	Time	Elapsed Time (min)	Depth to Water (ft)	Drawdown (ft)	Discharge Rate (gpm)	Notes (Observer, Water Quality, Weather, Discharge Quality, etc.)
6/13	1856	61	48.75	40.09	225	
	1857	62	50.42	41.76		
	1858	63	51.13	42.42		250 psi
	1859	64	51.63	43.01	225	
	1900	65	52.04	43.38		
	1901	66	52.23	43.57		
	1902	67	52.38	43.72	225	
	1903	68	52.47	43.81		250 psi
	1904	69	52.54	43.88		
	1905	70	52.62	43.96	225	
	1910	75	52.90	44.24		250 psi
	1915	80	53.10	44.44	225	701 = 631 SC = 5.06 SAMPLED @ 1915 TWT: 56' PH: 6.2 TUB: 54' CO: 160m
	1916	1	32.10			
	1917	2	19.25			
	1918	3	14.02			
	1919	4	12.63			
	1920	5	11.00			
	1921	6	9.85			
	1922	7	9.42			
	1923	8	9.25			
	1924	9	9.18			
	1925	10	9.13			

**UNITED WATER NEW YORK  
ROCKLAND COUNTY, NEW YORK**

**HISTORIC SPECIFIC CAPACITY  
CATAMOUNT 54**



## HORSEPOWER

# Catamount 54 New

Berkeley Electronic Catalog

New Selection | Reports | Preferences | Feedback | Help |

Selection Criteria	Selection Results
<input checked="" type="checkbox"/> Conditions of Service	<input checked="" type="checkbox"/> Search Results
<input checked="" type="checkbox"/> Product Lines	<input checked="" type="checkbox"/> Performance Curve
<input checked="" type="checkbox"/> Pump Size List	<input checked="" type="checkbox"/> Performance Datasheet
	<input checked="" type="checkbox"/> Life Cycle Cost

Units | Curve Preferences | Print | Show Flow #2 | Multi-Speed Curves

## Performance Datasheet


## Additional Data

### Header Information

### Performance Details

Pump size	: 7T60-350	Based on curve number	: 7T60-350(9@5.39x4.75)
Stages	: 9		
<b>Operating Conditions</b>		<b>Liquid</b>	
Flow, rated	343.5 USgpm	Liquid type	: Water
Head, rated (requested)	526.3 ft	Additional liquid description	
Head, rated (actual)	526.3 ft	Solids diameter, max	0.00 in
Suction pressure, rated / max	0.00 / 0.00 psi.g	Temperature, max	68.00 deg F
NPSH available (system)	Ample ft	Fluid density, rated / max	0.998 / 0.998 SG
Frequency	60 Hz	Viscosity, rated	1.00 cP
		Vapor pressure, rated	0.00 psi.a
<b>Performance</b>		<b>Material</b>	
Speed criteria	<input checked="" type="radio"/> Synchronous <input type="radio"/> Variable	Material requested	: Auto
Pump speed, rated	<input checked="" type="checkbox"/> set @ 3,450 rpm	Material selected	: Not specified
Impeller diameter, rated	5.07 in	<b>Pressure Data</b>	
Impeller diameter, maximum	: 5.07 in	Maximum working pressure	: 382.8 psi.g
Impeller diameter, minimum	: 5.07 in	Maximum allowable working pressure	: 550.0 psi.g
Efficiency	: 74.73 %	Maximum allowable suction pressure	: N/A
NPSH required / margin required	: N/A / 0.00	Hydrostatic test pressure	: N/A
Specific speed / Suction specific speed	: N/A	<b>Driver &amp; Power Data</b>	
MCSF	: 130.0 USgpm	Driver sizing specification	Rated power
Head, maximum, rated diameter	: 884.6 ft	Margin over specification	0.00 %
Head rise to shutoff	: N/A %	Service factor	<input checked="" type="checkbox"/> Use service factor 1.15
Flow, best eff. point (BEP)	343.5 USgpm	Power, hydraulic	: 45.57 hp
Flow ratio (rated / BEP)	: 100.00 %	Power, rated	: 60.97 hp
Diameter ratio (rated / max)	: 100.00 %	Power, maximum, rated diameter	: 61.06 hp
Cutwater ratio (rated / cutwater)	: N/A	Power reserve (rated / max / sizing spec)	: 13.17 / 13.00 / 13.17 %
Head ratio (rated dia / max dia)	100.00 %	Minimum recommended motor rating	: 60.00 hp / 44.74 kW (Fixed)
Viscous coefficients (CQ / CH / CE)	: 1.00 / 1.00 / 1.00		
Selection status	: Acceptable		

### Performance Curve



# Catamount 54 New

New Selection | Reports | Preferences | Feedback | Help | Logout

Berkeley Electronic Catalog



Selection Criteria  
 Conditions of Service  
 Product Lines  
 Pump Size List

Selection Results  
 Search Results  
 Performance Curve  
 Performance Datasheet  
 Life Cycle Cost

Units | Curve Preferences | Print | Show Flow #2 | Multi-Speed Curves

## Performance Datasheet

## Additional Data

### Header Information

### Performance Details

Pump size : 7T80-350  
 Stages : 9  
 Operating Conditions ③  
 Flow, rated : 343.5 USgpm  
 Head, rated (requested) : 526.3 ft  
 Head, rated (actual) : 526.3 ft  
 Suction pressure, rated / max : 0.00 / 0.00 psi.g  
 NPSH available (system) : Ample ft  
 Frequency : 60 Hz  
 Performance  
 Speed criteria : ☒ Synchronous ☐ Variable  
 Pump speed, rated : ☒ set @ 3,450 rpm  
 Impeller diameter, rated : ☒ set @ 5.07 in  
 Impeller diameter, maximum : 5.07 in  
 Impeller diameter, minimum : 5.07 in  
 Efficiency : 74.73 %  
 NPSH required / margin required : N/A / 0.00  
 Specific speed / Suction specific speed : N/A  
 MCSF : 130.0 USgpm  
 Head, maximum, rated diameter : 884.8 ft  
 Head rise to shutoff : N/A %  
 Flow, best eff. point (BEP) : 343.5 USgpm  
 Flow ratio (rated / BEP) : 100.00 %  
 Diameter ratio (rated / max) : 100.00 %  
 Cutwater ratio (rated / cutwater) : N/A  
 Head ratio (rated dia / max dia) : 100.00 %  
 Viscous coefficients (CQ / CH / GE) : 1.00 / 1.00 / 1.00  
 Selection status : Acceptable

Based on curve number : 7T80-350(9@5.39x4.75)



Liquid ③ : -Water  
 Additional liquid description  
 Solids diameter, max : 0.00 in  
 Temperature, max : 66.00 deg F  
 Fluid density, rated / max : 0.998 / 0.998 SG  
 Viscosity, rated : 1.00 cP  
 Vapor pressure, rated : 0.00 psi.a

Material ③  
 Material requested : Auto  
 Material selected : Not specified

Pressure Data  
 Maximum working pressure : 382.8 psi.g  
 Maximum allowable working pressure : 550.0 psi.g  
 Maximum allowable suction pressure : N/A  
 Hydrostatic test pressure : N/A

Driver & Power Data  
 Driver sizing specification : Rated power  
 Margin over specification : 0.00 %  
 Service factor : ☒ Use service factor 1.15  
 Power, hydraulic : 45.57 hp  
 Power, rated : 60.97 hp  
 Power, maximum, rated diameter : 61.06 hp  
 Power reserve (rated / max / sizing spec) : 13.17 / 13.00 / 13.17 %  
 Minimum recommended motor rating : 60.00 hp / 44.74 kW (Fixed)

### Performance Curve





**REGULATORY CORRESPONDENCE**



# NEW YORK STATE DEPARTMENT OF HEALTH

Bureau of Water Supply Protection

## Application of Approval of Plans for Public Water Supply Improvement

Applicant United Water New York	Location of works (C,V,T) Ramapo (T)	County Rockland	Water District (specific area served) United Water New York
Type of Ownership <input type="checkbox"/> Municipal <input type="checkbox"/> Commercial <input type="checkbox"/> Private - Other <input type="checkbox"/> Authority <input type="checkbox"/> Interstate <input type="checkbox"/> Industrial <input checked="" type="checkbox"/> Water Works Corp. <input type="checkbox"/> Private - Institutional <input type="checkbox"/> Federal <input type="checkbox"/> International <input type="checkbox"/> Board of Education <input type="checkbox"/> State <input type="checkbox"/> Native American Reservation			
<input checked="" type="checkbox"/> Modifications to existing system. If checked, provide PWS ID # NY		NY4303673	
<input type="checkbox"/> New System. If checked, provide capacity development (viability) analysis*			
*If this project involves a new system, new water district, or a district extension provide boundary description location details in digital format on CD or Floppy Disk. If digital boundary location details are not available provide a text description.			
<input type="checkbox"/> Digital GIS Data Provided <input type="checkbox"/> Digital CAD Data Provided <input type="checkbox"/> Other Digital Data Provided <input type="checkbox"/> Text Description Provided <input checked="" type="checkbox"/> N/A			
Funding Source <input checked="" type="checkbox"/> Private <input type="checkbox"/> DWSRF** <input type="checkbox"/> Federal <input type="checkbox"/> Other			
If DWSRF is checked, please provide DWSRF #			
Estimated Project Cost \$			
Source	Treatment	Storage	Distribution
Pumping	Engineering	Legal/Permitting	Total
\$25,000.00			
Type of Project <input type="checkbox"/> Source <input checked="" type="checkbox"/> Corrosion Control <input type="checkbox"/> U.V. Light Disinfection <input type="checkbox"/> Distribution <input type="checkbox"/> Transmission <input type="checkbox"/> Pumping Unit <input type="checkbox"/> Fluoridation <input type="checkbox"/> Storage <input type="checkbox"/> Chlorination <input type="checkbox"/> Other Treatment <input type="checkbox"/> Other			
<b>Project Description</b> Replace pumps and motors at two wells at the UWNY catamount Wellfield (Catamount 42 and 54) to provide more flow for peak demand.			
Total Population of Service Area		298,000	
% population actually served		90	
% population affected by project		5	
<b>Latest Total Consumption Data (in MGD)</b>			
Average Day	Year	NYS Professional Licensed Engineer Stamp and Signature***	
31.5	2006		
Maximum Day	Year		
44.8	2006		
Peak Hour	Year		
57.2	2006		
<b>Name and Address of Design Engineer</b> Robert F Raczkowski, P.E. UWNY 360 West Nyack Road West Nyack, NY 10994 845-623-1500 x2267 email: bob.raczkowski@unitedwater.com			
		6/12/2007	
Signature of Applicant		Date	

NOTE: All applications must be accompanied by 3 sets of plans, 3 sets of specifications and an engineer's report describing the project in detail. The project must first be discussed with

an appropriate city, county, district or regional public health engineer. Signature by a designated representative must be accompanied by a letter of authorization.

Additional information regarding capacity development may be found at:

<http://www.health.state.ny.us/nysdoh/water/main.htm>

\*Current DWSRF project listings may be found at:

<http://www.health.state.ny.us/nysdoh/water/main.htm>

\*\*By affixing the stamp and signature the Design Engineer agrees that the plans and specifications have been prepared in accordance with the most recent revision of the recommended standards for water works and in accordance with the NYS Sanitary Code.

OH - 348 (02/05)



**APPENDIX D**  
**SYSTEM WELL CAPACITY MODIFICATIONS**

Donald F. Distanto, P.E.  
Director, Master Planning

UNITED WATER  
700 Kinderkamack Road, Oradell, NJ 07649  
Tel: 201.986.4749 • Fax: 201.225.5113  
donald.distanto@unitedwater.com



January 19, 2007

Rockland County Department of Health  
Environmental Health Division  
Dr. Robert L. Yeager Health Center  
50 Sanatorium Rd  
Pomona, New York 10970

Subject: System well capacity modification

Dear Dr. Miller:

Attached please find a report from Leggette, Brashears & Graham, Inc. (LBG) regarding the capacity of United Water New York's (UWNY) system wells. The existing reported capacity of the system wells is 20.5 mgd, which was based on the actual production amounts attained during the 3-day historical peak demand days in 2001. For several reasons, as explained in detail in LBG's report, we are requesting that the peak capacity be modified from 20.5 mgd to 21.5 mgd (an increase of 1.0 mgd, sustainable for two 3-day periods). Note that LBG's report/table refers to the 2001 capacity of 20.6 mgd. This was the actual system well production capacity in 2001 but it was reported as 20.5 mgd just for simplicity. The primary reasons for these modifications are as follows:

- The achieved capacity in 2001 were without the improvements made at Nanuet 13/14 and Viola 28/106
- One well (Germonds 21) was not in-service in 2001 and has since been placed into service
- Some wells were shutoff for periods of time during the August 2001 peak event (Spring Valley 3, Tappan 20 and New Hempstead 24). In reviewing the data it was determined that these wells had ample submergence to allow them to operate. In speaking to the operators about this, the issue of excessive pressure has been raised as one potential reason for shutting them down. To address this, we applied the hydraulic model using the capacities indicated in LBG's letter with an overall system demand of 47.9 mgd (i.e., the 2007 projection). The results indicate that 21.5 mgd can be produced. The model includes the recent distribution system improvements (i.e., East-to-West transmission main and the Eckerson Rd. Booster pump) as well as Letchworth WTP addition which have significantly helped transmit the water produced to the needed areas within acceptable pressures.

This requested modification is an important element of UWNY's ability to meet the June 15, 2007 volume commitment of 1.5 mgd. As you are aware, two other projects that are part of our short-term supply strategy (Sparkill Air Stripper and Blaisdell Pump Station) are still under review by RCDOH. Therefore, to assist UWNY with meeting this important water supply target,

we would greatly appreciate a determination on the attached package at your earliest convenience.

We look forward to working with you on this project. LBG and UWNYS would be pleased to meet with you to discuss this further, if necessary.

Yours Truly,

E-Signed by Donald  
VERIFY authenticity with ApproveIt

Donald Distant, PE  
Director, Master Planning

cc:

Michael Pointing, General Manager of UWNYS  
John Dillon, Corporate Attorney UW  
Michael McDonald, P.E., Program Manager, B&V  
Alan Weland, P.E., Director of Engineering UWNYS  
Gary Albertson, P.E. Vice President, UW

# **LEGGETTE, BRASHEARS & GRAHAM, INC.**

## **PROFESSIONAL GROUND-WATER AND ENVIRONMENTAL ENGINEERING SERVICES**

6 ARROW ROAD, SUITE 103  
RAMSEY, NJ 07446  
201-818-0700  
FAX 201-818-0505  
www.lbgweb.com

January 18, 2007

Mr. Don Distante, P.E.  
United Water New York  
700 Kinderkamack Road  
Oradell, NJ 07649

RE: Summary of Well Supply Contribution to 2001 System  
Drought Yield  
United Water New York  
Rockland County, New York

Dear Mr. Distante:

As per your request, Leggette, Brashears & Graham, Inc. (LBG) has completed a review of the United Water New York (UWNY) well-production data for 2001, relative to system capacity during droughts. The 2001 data were utilized since it corresponds to a historical peak demand during a period of very dry weather. The purpose of the review was to evaluate overall yield contribution of the wells to the UWNY system during peak demand periods (considered over the course of three successive days) under drought conditions such as those exhibited during 2001.

Based on the available SCADA-recorded information, the peak (3-day) UWNY system demand during the 2001 drought occurred on August 8, 9, and 10. A summary of the corresponding daily pumpage ("flow" rate) data, expressed in gallons per minute (gpm), is provided as Table 1. The "Adjusted Peak Capacity" column presented in Table 1, reflects the actual average rates for each well reported for the three day period in August 2001, rounded to the nearest 5 gpm. Totaling the average flow rate for each of the UWNY Wells that were in production during the August 2001 peak demand period, yields a well production total of 20.6 million gallons per day (mgd).

The well production total of 20.6 mgd represents well-pumpage corresponding to the maximum operational system demand at that time, and does not represent the maximum cumulative well yield that is currently available. Based on the currently existing pump, treatment and well conditions, and available aquifer yield, a greater amount of cumulative yield is available. The basis for this conclusion regarding available well capacity is presented by the following discussion regarding Spring Valley Well 3, Tappan 20,

B:\UWNY\A-None Wellfield Specific\Drought\UWNY2001DroughtDmndWUUCpctyLtr1\_2007.wpd

and New Hempstead 24, which were reportedly not pumped either at all or consistently during the targeted August 2001 peak period at the respective potential peak capacity.

The submergence data for Spring Valley Well 3 and Tappan 20 indicate that the utilized pumping rates over the three-day period were at some point decreased to a flow rate below the respective potential capacities, though no adverse conditions assumed as a basis for this decision were reported (see respective graphs presented in Attachment I). As such, the Adjusted Peak Capacity values indicated in Table 1 for Spring Valley Well 3 and Tappan 20, are based on the respective peak flow rate use during the corresponding three day period (145 gpm and 115 gpm, respectively).

As for New Hempstead 24, a peak flow rate of 418 gpm was noted for the August 2001 period. However, New Hempstead 18 (which with New Hempstead 24, comprise the local well field) was being pumped during this same time at 880 gpm and exhibited minimal submergence (see respective graphs presented as Attachment I). In consideration of the interference effects that have historically existed between these two wells, and the reported conditions that prevailed during the August 2001 period, the New Hempstead Well Field was capable of a cumulative yield of 1,200 gpm, which could have also been accomplished by pumping each well at approximately 600 gpm. As such, 600 gpm has been indicated for each of these wells in the Adjusted Peak Capacity column of Table 1. Further support of this capacity is that these two wells produced an average of 1,434 gpm during the 3-day peak demand event that occurred from August 3 through 5, 2005. This was also a dry period, albeit of shorter duration than that of 2001.

In addition to the three wells discussed above, three other UWNY Wells that reportedly were not utilized at the corresponding peak capacity over the three-day period in August 2001, by virtue of not being in service, are: Nanuet 14; Germonds 21 and Viola 106. Nanuet 14 was not in service during this time due to treatment system work which precluded the ability for it to be pumped. Germonds 21 was not in service as it is a relatively low-capacity well and at the time not considered crucial to have available. Viola 106 was not in service in early August 2001, due to clear-well construction activities for air removal. This well was returned to service in late August 2001.

In an effort to project the adjusted peak capacity during a drought, the flow and submergence data for Nanuet 13 and Nanuet 14 (comprising the local well field) collected in 2005 indicate average pumping rates of 390 gpm and 242 gpm, respectively, during the peak demand period in August 2005 (Attachment I). During this time frame, Nanuet 14 was not pumped consistently at 242 gpm, but at daily average rates ranging from 110 gpm to 312 gpm. The available submergence data and recorded interference effects with Nanuet 13, indicate that Nanuet 14 was capable of being pumped consistently at a rate of 312 gpm during that peak demand period. Thus, the Adjusted Peak Capacities for Nanuet 13 and 14 presented by Table 1 reflect the 2005 data, and are 390 gpm and 310 gpm, respectively, which equates to a 3-day peak demand period well-field yield of 700 gpm.

Germonds 21 was not in service in 2001, and flow data is absent for the peak demand period of August 2005. However, submergence data for this time period indicates that the well was in service. Recent well test results indicate that Germonds 21 is capable of being pumped at 150 gpm during peak

demand periods, and conservatively meeting current operating demands at 90 gpm. As such, the conservative operating demand (90 gpm) for Germonds 21 was assumed as the respective Adjusted Peak Capacity value provided in Table 1.


Submergence data for 2001 and 2005 indicate that if Viola 106 had been in service during the three-day demand period in August 2001, the well would have been capable of being pumped at 538 gpm, which is the average demand rate utilized in 2005 (see respective graphs presented as Attachment I). Thus, based on the flow rate and submergence data recorded for 2005, and the interference effects which occur between Viola 28 and Viola 106 (both comprise the local well field), the Adjusted Conservative Peak capacity of the Viola Well Field is 990 gpm (i.e., based on the 2005 data, which indicate Viola 28 at 450 gpm, and Viola 106 at 540 gpm).


Based on the available UWNY SCADA flow and submergence data, and the above discussion, the total Adjusted Peak Capacity for the active wells comprising the UWNY system during drought conditions (as exhibited in 2001 and 2005) is 21.5 mgd. This total does not include additional well capacities that may be available in the event that pump size and setting limitations relative to residual available submergence are compensated for at selected UWNY Wells.

If you have any questions or need additional information, please call.

Very truly yours,

LEGGETTE, BRASHEARS & GRAHAM, INC.

  
Bill Prehoda, PG  
Hydrogeologist/Sr. Associate

  
Frank Getchell, PG  
Hydrogeologist/Vice President

BP:pw  
Attachments

Distribution: M. McDonald; B&V



## TABLE

**TABLE 1**  
**United Water New York**  
**Rockland County, New York**  
**System Wells Peak Flow 2001**


Well	Pressure				Average	Adjusted Peak Capacity <sup>(1)</sup>
	District	8/8/2001	8/9/2001	8/10/2001		
		Values reported in gallons per minute				
Spring Valley 1A	10	559	545	546	550	550
Spring Valley 3	10	145	52	0	66	145
Spring Valley 4	10	107	272	245	208	210
Spring Valley 6	10	399	390	391	393	390
Spring Valley 17	10	408	400	404	404	400
<i>SVWF Total</i>					<i>1621</i>	<i>1695</i>
Nanuet 13	10	476	476	425	459	390
Nanuet 14	10	0	0	0		310
<i>Nanuet Total</i>					<i>459</i>	<i>700</i>
Blauvelt 15	10	333	332	331	332	330
Tappan 16	10	211	193	189	198	200
Tappan 20	10	53	115	101	90	115
<i>Tappan Total</i>					<i>287</i>	<i>315</i>
Bardonia 19	10	152	128	155	145	145
Germoids 21	10	0	0	0		90
Pearl River 22	10	93	94	89	92	90
New City 23	10	270	231	242	248	250
Wesel Road 32	10	178	179	171	176	175
Norge 64	10	363	365	319	349	350
Elmwood 66	10	241	241	240	241	240
Lake Shore 73	10	408	353	345	369	370
West Gate 79	10	126	126	125	126	125
Grotke 83	10	149	147	147	148	150
<i>Total PD 10:</i>	<i>20</i>				<i>4591</i>	<i>5025</i>
<i>Total PD 10 (mgd)</i>					<i>6.6</i>	<i>7.2</i>
Saddle River 53	95	437	436	413	429	430
Pascack 65	95	430	422	427	426	425
Pinebrook 69	95	447	449	425	440	440
Birchwood 70	95	165	165	163	164	165
Eckerson 71	95	165	169	155	163	165
Eckerson 82	95	254	251	248	251	250
<i>Total PD 95</i>	<i>6</i>				<i>1874</i>	<i>1875</i>
<i>Total PD 95 (mgd)</i>					<i>2.7</i>	<i>2.7</i>
New Hempstead 18	20	953	775	919	882	600
New Hempstead 24	20	0	418	24	147	600
<i>New Hempstead Total</i>					<i>1030</i>	<i>1200</i>
Tallman 26	20	439	440	436	438	440
Ramapo 27	20	925	928	916	923	925
Ramapo29A	20	716	712	709	712	710
<i>Ramapo Total</i>					<i>1635</i>	<i>1635</i>
Viola 28	20	825	957	1213	998	450
Viola 106	20	0	0	0	0	540
<i>Viola Total</i>					<i>998</i>	<i>990</i>
Monsey 30	20	230	231	229	230	230
Monsey 31A	20	200	201	199	200	200
<i>Monsey Total</i>					<i>430</i>	<i>430</i>
Pomona 37	20	181	179	149	170	170
Pomona 38	20	292	293	291	292	290
<i>Pomona Total</i>					<i>462</i>	<i>460</i>
Catamount 42A	20	173	174	172	173	175
Catamount 54A	20	218	218	216	217	215
<i>Catamount Total</i>					<i>390</i>	<i>390</i>
Nottingham 55	20	410	411	408	410	410
Willow Tree 56	20	661	655	650	655	655
Grandview 67	20	194	194	197	195	195
Grandview 78	20	194	193	160	182	180
<i>Grandview Total</i>					<i>378</i>	<i>375</i>
Cherry Lane 68	20	330	331	328	330	330
Rustic 72	20	448	449	447	448	450
<i>Total PD 20</i>	<i>19</i>				<i>7604</i>	<i>7765</i>
<i>Total PD 20 (mgd)</i>					<i>10.9</i>	<i>11.2</i>
Garnerville 46	40	0	0	0		
Thiells 50	40	37	38	38	38	40
Thiells 51	40	219	219	219	219	220
<i>Total PD 40</i>					<i>257</i>	<i>260</i>
<i>Total PD 40 (mgd)</i>					<i>0.4</i>	<i>0.4</i>
<i>Total System Wells (gpm)</i>					<i>14326</i>	<i>14925</i>
<i>Total System Wells (mgd)</i>					<i>20.6</i>	<i>21.5</i>

Note: (1) Values indicated for Spring Valley Well 3, Tappan 20, New Hempstead 18 and 24, Nanuet 13 and 14, Germoids 21, and Viola 28 and 106, are reflective of 2005 peak demand period data as discussed in the January 18, 2007 letter.

## **ATTACHMENT**


**UNITED WATER NEW YORK  
ROCKLAND COUNTY, NEW YORK**

**SPRING VALLEY WELL 3  
SCADA FLOW AND SUBMERGENCE DATA - 2001**




UNITED WATER NEW YORK  
ROCKLAND COUNTY, NEW YORK

SPRING VALLEY WELL 3  
SCADA FLOW AND SUBMERGENCE DATA 2005




UNITED WATER NEW YORK  
ROCKLAND COUNTY, NEW YORK

TAPPAN WELL 20  
SCADA FLOW AND SUBMERGENCE DATA - 2001




**UNITED WATER NEW YORK  
ROCKLAND COUNTY, NEW YORK**

**TAPPAN WELL 20  
SCADA FLOW AND SUBMERGENCE DATA, 1987 through 2005**



**UNITED WATER NEW YORK  
ROCKLAND COUNTY, NEW YORK**


**NEW HEMPSTEAD WELL 24  
SCADA FLOW AND SUBMERGENCE DATA - 2001**






**UNITED WATER NEW YORK  
ROCKLAND COUNTY, NEW YORK**

**GERMONDS WELL 21  
SCADA FLOW AND SUBMERGENCE DATA 2001**




**UNITED WATER NEW YORK  
ROCKLAND COUNTY, NEW YORK**

**NANUET WELL 14  
SCADA FLOW AND SUBMERGENCE DATA - 2001**




UNITED WATER NEW YORK  
ROCKLAND COUNTY, NEW YORK

NANUET WELL 14  
SCADA FLOW AND SUBMERGENCE DATA 2005




UNITED WATER NEW YORK  
ROCKLAND COUNTY, NEW YORK

GERMONDS WELL 21  
SCADA FLOW AND SUBMERGENCE DATA 2005




UNITED WATER NEW YORK  
ROCKLAND COUNTY, NEW YORK

VIOLA WELL 106  
SCADA FLOW AND SUBMERGENCE DATA 2001



UNITED WATER NEW YORK  
ROCKLAND COUNTY, NEW YORK

VIOLA WELL 106  
SCADA FLOW AND SUBMERGENCE DATA - 2005





**APPENDIX E**  
**TEST WELLS**



## **SCHEDULE AND MILESTONES**

### **July 2006**

- A Potential Well Development and Conceptual Cost Estimates Report was prepared evaluating eight (8) potential well sites for development into production wells.

### **December 2006**

- Meeting between United Water New York (UWNY), Rockland County Department of Health (RC-DOH) to discuss the conversion of test wells to production wells. At this meeting, properties that meet required standards to be constructed were discussed and a list of possible sites was developed.

### **January 2007**

- For the potential sites, a technical package was submitted to the RCDOH for the conversion of test wells to production wells.

### **February 2007**

- Discussed requirements for submittal of application packages with each town that the potential production wells are located.
- Discussed electrical requirements with Orange and Rockland (O&R) Utilities, Inc. for each site.
- PB Americas, Inc. visited all three (3) potential sites to identify wetlands, streambanks, and tree inventory for each site.

### **March 2007**

- Conference call with New York State Department of Environmental Conservation (NYSDEC), New York State Department of Health (NYSDOH), and RCDOH to discuss the permit requirements for the construction of the test wells.
- Electrical Application for Service was submitted to O&R Utilities, Inc.
- Partial Site Plans for Strawtown Road and Long Clove Well were submitted to the Rockland County Drainage Agency (RCDA) for Jurisdictional Determination (JD).
- Partial Site Plans for Strawtown Road and Long Clove Road are submitted for Jurisdictional Determination (JD) by the NYSDEC for the construction of the test wells.
- On March 19, 2007 a meeting with the Rockland County Legislature and public was held to discuss the two (2) projects being considered for development. A presentation for information purposes only was given by UWNY and questions regarding the work and potential impacts to the surrounding environment are discussed and will be monitored during the pump test.

- A licensed surveyor began preparing a survey for the three (3) sites.

#### **April 2007**

- The licensed surveyor retained for the work completed the survey for all three (3) sites.
- In a letter dated April 9, 2007, the RCDA confirmed that they do not have jurisdiction for the sites.

#### **May 2007**

- In a letter dated May 4, 2007, the RCDOC issued the test well drilling permit for Strawtown Road, Long Clove Well, and Lime Kiln Road Wells. A copy of the approved permit follows.
- In an email dated May 2, 2007, the NYSDEC confirmed that no other permits are required for the construction of the test wells.
- On May 14, 2007, letters are submitted to private well owners within a one-thousand five hundred (1,500') feet radius of the proposed wells. The letters are sent notifying all private well owners of the intention to construct new wells at the site and to offer monitoring of their wells during the pump test.
- On May 25, 2007, the Technical Advisory Committee (TAC) application was submitted to the Town of Clarkstown.
- Layne Christensen begins drilling the test wells at the Strawtown Road and Long Clove Road sites. Strawtown was air tested and the estimated capacity is between three hundred to four hundred (300 to 400) gpm. The air test at Long Clove Road results in an estimated capacity of sixty (60) gpm. The estimated capacity at Long Clove Road was approximately one hundred and fifty (150) gpm. A new test well location on the property is being considered that is closer to the existing test wells. However, this will require easement(s) from adjacent property owners. A new RC-DOH permit will be required for the new test well location.

#### **June 2007**

- A TAC hearing was held on June 13<sup>th</sup> for the Strawtown and Long Clove Test Wells with the Town of Clarkstown.
- A second Environmental Meeting of the Rockland County Legislature is currently scheduled for June 18, 2007.
- It is anticipated that the pump capacity test and monitoring of adjacent private wells will occur at the end of this month. In addition, a full water quality analysis shall be performed.
- Due to the reduced capacity encountered at the proposed Long Clove Road test well site, submit new test well location for approval for a new test well at the Long Clove Road site. Pending approval of the new location, drill new test well and air test shall be performed in June 2007.

**July/August 2007**

- Pending approval at the TAC hearing, it is anticipated that the design of the well house will be completed and an application for Preliminary and Final Planning Board hearings will be submitted to the Town of Clarkstown. It is anticipated that this will be scheduled to be heard in July and August 2007.
- Final applications for the NYSDOH and NYSDEC shall be applied for.
- The two (2) well projects shall be bid with pre-qualified contractors to construct the well and well house.

**September/October 2007**

- Pending approval at the Preliminary and Final Planning Board hearings, Construction Applications for the Town of Clarkstown shall be applied for.
- Pending approval of the Building, NYSDEC, and NYSDOH applications, the successful Contractor shall be given Notice to Proceed to begin construction of the production wells and above ground well houses.

**November/December 2007**

- Construction of the production wells shall continue and be completed by December 15, 2007.

## **PERMITS AND CORRESPONDENCE**

The following information is included for reference and follows:

### **Strawtown Road Well**

1. May 25, 2007 letter prepared by Buck, Seifert & Jost, Inc. (BS&J) addressed to the Town of Clarkstown Technical Advisory Committee (TAC), 3 pages
2. Strawtown PW-1 Geologic Log prepared by Leggette, Brashears & Graham, Inc. (LBG) dated May 18, 2007, 2 pages
3. Rockland County Department of Health Permit to Construct a Water Supply Well, Permit #07-004, dated May 4, 2007, 1 page
4. April 9, 2007 letter prepared by the County of Rockland Drainage Agency regarding Jurisdictional Determination (JD) for Proposed Production Well at Strawtown Site, 1 page
5. Construction of the Strawtown Test Well No. 2 - Site Plan, Well Diagram, and Notes drawing prepared by BS&J, 1 page – 11" x 17".
6. Construction of the Strawtown Well Cost Estimate dated March 14, 2007, 1 page.

### **Long Clove Well**

1. Long Clove TW-4 Geologic Log prepared by Leggette, Brashears & Graham, Inc. (LBG) dated May 29, 2007, 2 pages
2. May 25, 2007 letter prepared by Buck, Seifert & Jost, Inc. (BS&J) addressed to the Town of Clarkstown Technical Advisory Committee (TAC), 3 pages
3. Rockland County Department of Health Permit to Construct a Water Supply Well, Permit #07-004, dated May 4, 2007, 1 page
4. April 9, 2007 letter prepared by the County of Rockland Drainage Agency regarding Jurisdictional Determination (JD) for Proposed Production Well at Strawtown Site, 1 page
5. Construction of the Long Clove Test Well No. 3 - Site Plan, Well Diagram, and Notes drawing prepared by BS&J, 1 page – 11" x 17".
6. Construction of the Long Clove Well Cost Estimate dated March 14, 2007, 1 page.



**APPENDIX F**  
**SPARKILL**

**PERMITS AND CORRESPONDENCE**

## **PERMITS AND CORRESPONDENCE**

The following information is included for reference and follows:

1. UWNY receives final approval for the project on June 6, 2007 when the Zoning Board of Appeals (ZBA) for the Town of Orangetown denies an appeal of the Town Zoning Director's prior determination that the project does not require a use variance.
2. April 24, 2007 memorandum prepared by John Giardiello, P.E., Director of the Town of Orangetown Office of Building, Zoning, and Planning Administration and Enforcement addressed to the Zoning Board of Appeals, 2 pages.
3. Town of Orangetown Building Permit No. 36910 dated March 9, 2007 for the public water supply treatment system and building located at 59 Flitt Street, Tappan, NY, 2 pages.
4. November 1, 2006 memorandum prepared by John Giardiello, P.E., Director of the Town of Orangetown Office of Building, Zoning, and Planning Administration and Enforcement addressed to Cheryl Coopersmith, Chief Clerk and Debbie Arbolino, Administrative Aide, 1 page.
5. November 1, 2006 letter prepared by Rockland County Department of Health (RCDOH) regarding air emissions guidelines for the proposed UWNY Well Head Treatment at Well Nos. 8 and 11, Sparkill, NY, 1 page.
6. September 5, 2006 Denial of building permit application and referral to the ACABOR and ZBA for the proposed UWNY Well Head Treatment at Well Nos. 8 and 11, Sparkill, NY prepared by John Giardiello, P.E., Director of the Town of Orangetown Office of Building, Zoning, and Planning Administration and Enforcement, 2 pages.
7. Town of Orangetown Building Permit No. 36502 dated August 21, 2006 for the replacement of electrical service to the existing well house located at 59 Flitt Street, Tappan, NY, 2 pages.



**SITE AND ARCHITECTURAL PLANS**





**APPENDIX G**  
**BEDROCK WELL DE-AERATION**

**WILLOW TREE 56**

## **Willow Tree 56**

Willow Tree 56 is permitted by NYSDEC for 1,000 gpm and taps the underlying bedrock aquifer. Recent production capacity indicates Willow Tree 56 has been utilized at rates ranging between 400 gpm and 800 gpm. Willow Tree 56 was operating at an average of 655 gpm with an excess of 50 feet of submergence above the pump intake during the August 2001 3-day system peak demand period. Current pumping test data results indicate the specific capacity of Willow Tree 56 is similar to the results of the original testing, with no significant production-limiting decline noted.

Willow Tree 56 has exhibited air in the discharge, especially at higher pumping rates, limiting production capacity. UWNY proposes to install a de-aeration basin to eliminate air entrainment into the distribution system and allow for higher discharge capacity. Based on the results of original testing, operational history, and results of current testing, Willow Tree 56 is capable of sustaining the short-term (3-day) peaking at a rate of 1,000 gpm during a drought demand period similar to August 2001. This 3-day peak pumping rate represents an increase of 345 gpm over the 2001 peak system demand operating rate.









**NEW HEMPSTEAD 18 AND 24**

## **New Hempstead 18 and 24**

The New Hempstead Well Field is permitted by NYSDEC at a combined capacity of 1,700 gpm. Both New Hempstead 18 and 24 tap the underlying bedrock aquifer. Recent production capacity indicates that UWNY utilizes the wells in the New Hempstead Well Field primarily on an alternating basis and not 24 hours per day. Recent New Hempstead 18 production rates range between 800 gpm and 1,000 gpm (while New Hempstead 24 is off), and recent New Hempstead 24 production rates vary between 900 and 1,200 gpm (while New Hempstead 18 is off).

The New Hempstead Well Field is typically not operated at its maximum permitted production capacity of 1,700 gpm, in part due to air entrainment at higher production rates. UWNY proposes to install a deaeration basin to eliminate air entrainment into the distribution system. The New Hempstead combined operating discharge rate was 1,030 gpm (New Hempstead 18 – 882 gpm, New Hempstead 24 – 147 gpm) during the August 2001 3-day system peak demand period. The low discharge rate of New Hempstead 24 reflects primarily only one day of usage during this period. Current pumping test data results indicate the specific capacity of both New Hempstead 18 and 24 are similar to historic specific capacity data, with no significant production-limiting decline noted at the well field.

Based on the results of original testing, mutual interference, operational history, and results of current testing, the New Hempstead Well Field is capable of sustaining the short-term (3-day) peaking at a rate of 1,200 gpm during a drought demand period similar to August 2001. This well field peaking discharge can be obtained by operating Wells 18 and 24 at 600 gpm each, or potentially operating Well 24 at a higher rate and reducing the rate of Well 18 by an equivalent amount. This 3-day peak pumping rate represents an increase of 170 gpm over the 2001 peak system demand operating rate.

**PASCACK 65**

## **Pascack 65**

Pascack 65 is permitted by NYSDEC for 700 gpm and taps the underlying bedrock aquifer. Recent production capacity indicates Pascack 65 has been utilized at rates ranging between 350 gpm and 500 gpm. Pascack 65 was operating at an average of 426 gpm with an excess of 50 feet of submergence above the pump intake during the August 2001 3-day system peak demand period. Current pumping test data results indicate the specific capacity of Pascack 65 is similar to the results of the original testing, with no significant production-limiting decline noted.

Pascack 65 has historically exhibited air in the discharge, limiting production capacity especially at higher pumping rates. UWNY proposes to install a deaeration basin at Pascack 65 to eliminate air entrainment into the distribution system and allow for higher discharge capacity. Based on the results of original testing, operational history, and results of current testing, Pascack 65 is capable of sustaining the short-term (3-day) peaking at a rate of 600 gpm during a drought demand period similar to August 2001. This 3-day peak pumping rate represents an increase of 274 gpm over the 2001 peak system demand operating rate. .



## **APPENDIX H**

### **VIOLA AND ELMWOOD INFRASTRUCTURE IMPROVEMENTS**

## **Viola 28 and 106**


The Viola Well Field is permitted by NYSDEC at a combined capacity of 1,400 gpm. Both Viola 28 and 106 tap the underlying bedrock aquifer. Recent production capacity indicates that UWNYP utilizes the wells in the Viola Well Field primarily on an individual basis with the recent production rates range between 500 gpm and 700 gpm total. The Viola Well Field is typically not operated at its maximum permitted production capacity of 1,400 gpm due to air entrainment at higher production rates. UWNYP installed a deaeration basin in 2001 to eliminate air entrainment into the distribution system.

The Viola 28 average discharge rate was 998 gpm during the August 2001 3-day system peak demand period, without Viola 106 operating due to the deaeration basin not being put online until the end of August 2001. Current pumping test data results indicate the specific capacity of both Viola 28 and 106 are similar to historic specific capacity data, with no significant production-limiting decline noted at the well field. Based on the results of original testing, mutual interference, operational history, and results of current testing, the Viola Well Field is capable of sustaining the short-term (3-day) peaking at a rate of 1,400 gpm during a drought demand period similar to August 2001. This well field peaking discharge can be obtained by operating Wells 28 and 106 at 700 gpm each. This 3-day peak pumping rate represents an increase of 402 gpm over the 2001 peak system demand operating rate.



UNITED WATER NEW YORK  
ROCKLAND COUNTY, NEW YORK

HISTORIC SPECIFIC CAPACITY  
VIOLA 28




11-16-2006

GOULDS PROPOSAL NO.	GOULDS S.O. NO.	INQUIRY NO.	CUSTOMER P.O. NO.	P.O. DATE	ITEM NO.	CUSTOMER
---------------------	-----------------	-------------	-------------------	-----------	----------	----------

UNNY - Viola #28 Well Turbine Pump

PROJECT	Viola #28 Well Turbine Pump	SERVICE	150ft - 6" x 1 3/16" Col/Shaft	FL. TDH	127' TD	EFFICIENCY	RPM
			6" dia Impeller 4-stage	700GPM			1800RPM




MODEL  
**9THC**

DATE  
March 1996


REVISIONS  
N/A

**UNITED WATER NEW YORK  
ROCKLAND COUNTY, NEW YORK**

**HISTORIC SPECIFIC CAPACITY  
VIOLA 106**



GOULDS PRODUCT NO.	GOULDS S.O. NO.	INQUIRY NO.	CUSTOMER P.O. NO.	P.O. DATE	ITEM NO.	CUSTOMER
						WANNY #106 Subm
PROJECT	Viola #106		SERVICE		#9RCLC - 1stage Submersible	700GPM
Has Baker Fitness Adaptor		170ft - 8" Pipe / 190ft - #6-4 Subm. Wire		2- 3/4" PVC Poly Tubes		3450RPM
		E.T. TDH		134' TDH		3450RPM



MODEL  
**9RCLC**  
DATE  
October 1996  
SUPERCEDES  
August 1996

GOULDS PUMPS  
TURBINE DIVISION  
LITTLE ROCK, TEXAS


Characteristics based upon pumping clear, non-aerated water. Rating point only is guaranteed. Column losses not included.

12-14-06  
Somewhat off curve - But ok




# ITT - Goulds Pumps Turbine Operations

JF007  
Rev 0  
8/1999



# ITT - Goulds Pumps Turbine Operations

Rev 0  
3/1999



RINBRAND  
 Company, Inc.

Name:  
 Date: 04/05/07


*Same curve w/ Dictate Iron*



Pump:  
 Size: 11CHC (4 stages)  
 Type: Lineshaft  
 Synch speed: 1800 rpm  
 Curve: E3141-2  
 Specific Speeds: Ns: 2130  
 Pump Notes for Standard Sizes:  
 Suction Size-8" Discharge Sizes-6", 8"  
 Vertical Turbine:  
 Bowl size: 11 in  
 Max lateral: 0.75 in  
 Thrust K factor: 7 lb/ft

Search Criteria:  
 Flow: 780 US gpm  
 Head: 240 ft  
 Fluid:  
 Water  
 SG: 1  
 Viscosity: 1.106 cP  
 NPSHr: --- ft  
 Motor:  
 Standard: NEMA  
 Size: 75 hp  
 Speed: 1800  
 Temperature: 60 °F  
 Vapor pressure: 0.2563 psi a  
 Atm pressure: 14.7 psi a  
*Impellers*

Pump Limits for Standard Construction:  
 Temperature: 120 °F  
 Sphere size: 0.68 in  
 Pressure: 380 psi g  
 Sizing criteria: Max Power on Design Curve



— Data Point —  
 Flow: 780 US gpm  
 Head: 242 ft  
 Eff: 86%  
 Power: 55.3 hp  
 NPSHr: 8.74 ft  
 — Design Curve —  
 Shutoff Head: 261 ft  
 Shutoff dP: 122 psi  
 Min Flow: --- US gpm  
 BEP: 86% eff  
 @ 808 US gpm  
 NOL Pwr: 64 hp  
 @ 1299 US gpm  
 — Max Curve —  
 Max Pwr: 78.6 hp  
 1300 US gpm

Flow US gpm	Speed rpm	Head ft	Pump %eff	Power hp	NPSHr ft
938	1770	215	84.8	59.7	11.7
780	1770	242	86	55.3	8.74
624	1770	259	82.8	49.2	7.39
468	1770	266	74.5	42.2	7
312	1770	—	—	—	—

RINBRAND WELL DRILLING CO., INC.  
 14 Waldron Avenue  
 Glen Rock, NJ 07432-2831

is Pumps 2004d  
 780 gpm at 242' TDH  
 60Hp needed  
 Viola #28 pump 1 + 2 Booster Viola Booster 1 + 2  
 Selected from catalog: Goulds Lineshaft 8CHZ Vers: 3.06

## **Elmwood 66**


Elmwood 66 is permitted by NYSDEC at a capacity of 350 gpm and taps the underlying bedrock aquifer. Recent production capacity indicates that UWNY utilizes Elmwood 66 at a production rate up to 300 gpm, but not typically operated at its maximum permitted production capacity of 350 gpm. Elmwood 66 has a Lowery treatment system installed primarily for treatment of VOCs.

The Elmwood 66 average discharge rate was 241 gpm during the August 2001 3-day system peak demand period. Current pumping test data results indicate the specific capacity of Elmwood 66 is similar to historic specific capacity data, with no significant production-limiting decline noted at the well field. Based on the results of original testing, operational history, and results of current testing, Elmwood 66 is capable of sustaining the short-term (3-day) peaking at a rate of 350 during a drought demand period similar to August 2001. This 3-day peak pumping rate represents an increase of 109 gpm over the 2001 peak system demand operating rate.



UNITED WATER NEW YORK  
ROCKLAND COUNTY, NEW YORK

HISTORIC SPECIFIC CAPACITY  
ELMWOOD 66




3-23-07

GOULDS PROPOSAL NO.	GOULDS S.O. NO.	INQUIRY NO.	CUSTOMER P.O. NO.	P.O. DATE	ITEM NO.	CUSTOMER	UNITED WATER NEW YORK	7½HP
PROJECT	ELMWOOD WELL PUMP #66	SERVICE	#8RJHO - 3stage	(5" Impellers)	GPM CAPACITY	350GPM	FT. TDH	62' TDH
					% EFFICIENCY		RPM	1760RPM

3-23-07

85ft - 6"x1"Column & Shaft & 10ft - 6"Tail Pipe



MODEL  
**8RJHO**  
DATE  
May 2, 1988  
SUPERCEDES  
July 22, 1977


*Somewhat off curve*

C8RJHO

Well Pump 4-25-07 BU Pachoda

GOULDS PROPOSAL NO.	GOULDS S.O. NO.	INQUIRY NO.	CUSTOMER P.O. NO.	P.O. DATE	ITEM NO.	CUSTOMER	UNITED WATER NEW YORK	7 1/2 HP
PROJECT		ELMWOOD WELL PUMP #66		SERVICE		#8RJHO - 3stage		5 1/2" Impeller
				GPM CAPACITY		350GPM		62" TDH
				% EFFICIENCY				1760RPM


Original 1994 Drafted 85ft - 6"x1" Column & Shaft & 20ft - 5" Tail Pipe (Double Brown Impellers)  
 New Box 1st Nov 2006 Angeles 4-17-07



MODEL  
**8RJHO**  
 DATE  
 May 2, 1988  
 SUPERCEDES  
 July 22, 1977

*Distribution Booster Pump 4-25-07*

Goulds Proposal No.		Goulds S.O. No.	Industry No.	Customer P.O. No.	P.O. Date	Item No.	Customer
PROJECT		SERVICE			UNITED WATER NEW YORK		
Elmwood #66 Booster Pump		Model #8RJLO-5 Stage 4.68 Imp			GPM/CAPACITY 350 GPM		F.T. TDH 380' TDH
		Short setting 6" x 13/16" Column & Shaft 50HP 230/460V/3PH			50HP		3600 RPM
		Bronze Impellers 4.68" 5 stage					



MODEL  
**8RJLO**  
 DATE  
 March 1995  
 SUPERCEDES  
 May 2, 1988

KINDRAN WELL DRILLING CO., INC.  
 14 Walden Avenue  
 Glen Rock, NJ 07452-2831

DUCTILE IRON IMPELLERS would be same Curve.



## ► Acknowledgements

A great deal of resources and expertise have contributed to the assessment and implementation of means and methods for increasing supply to meet STWS goals. The effort has been a collaboration of UWNYS's engineering and operations staff, monitored by way of weekly progress meetings, and UWNYS's management, which has been meeting every two weeks to gage progress. A strong contingent of consulting expertise has been enlisted and working closely with UWNYS to support the program.

The following individuals and organizations have provided consistent support for the program and will continue to do so through 2008:

- Bob Raczko, P.E. – Senior Engineer; UWNYS
- Vito Spadavecchia – Production Manager; UWNYS Operations
- Michael Joosten – Senior Operations Staff; UWNYS Operations
- Bill Prehoda, P.G. – Hydrogeologist; Leggette, Brashers and Graham, Inc.
- Jonas Hollis, P.G. – Hydrogeologist; Leggette, Brashers and Graham, Inc.
- Michael Johnson, P.E. – Engineer; Buck, Seifert and Jost, Inc.
- Michael McDonald, P.E. – Program Manager; Black & Veatch, Inc.